

N. Meter Specifications

Metering Requirements

If the renewable energy resource generating facility is 6 kW or below, the output may be measured with either an inverter meter or a utility grade meter.

All facilities that are larger than 6 kW must measure the output of the facility with a utility grade meter. Facilities that are larger than 6 kW and that are not measuring output with a utility grade meter will not be certified. OAC 4901:1-40-04 (D)(1)

Please only report on the meter or the meters used to measure the output from the facility which will be reported to the attribute tracking system.

N.a The meter(s) that are measuring output from the facility are:

____ Inverter Meter(s)

X Utility Grade Meter(s)

N.1 *Please provide the following information for each meter used in your system.*

N.1.a Manufacturer: Accuenergy

N.1.b Serial Number: AT09105090

N.1.c Type: Acuvim IIR-M-60

N.1.d Date of Last Certification: 2010-09-25

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

11/11/2010 10:36:31 AM

in

Case No(s). 10-1433-EL-REN

Summary: Application Amendment to Section N: Meter Info electronically filed by Mr. Granger Souder on behalf of Ohio PV Solar Development One, LLC