

FILE

Ohio Power Siting Board

Staff Investigation Report and Recommendation

Case No.: 10-1452-EL-BNR

Project: Pleasant Valley – West Akron 138 Transmission Line
Loop to Cleveland Clinic Data Center

Applicants: American Transmission Systems, Incorporated
Cleveland Electric Illuminating Company

Report Date: 6 January 2011

Automatic Approval Date: 15 January 2011 (Construction Notice process)

Waiver Request: None

Inspection Date(s): 18 October 2010

Staff Assigned: J. O'Dell

Summary of Staff Recommendations (see report text for discussion):

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- None

Projected Docket Closure Date (if automatically approved): 31 May 2013

Investigation Report

Project Description: This project involves the installation of approximately 530 feet of 138 kV transmission line and three wood pole structures. The line is needed to provide electrical service to a new distribution substation for the Cleveland Clinic Data Center.

Site Description: No appreciable vegetative clearing is required. This project is located in the City of Brecksville, Cuyahoga County.

Discussion/Comments/Concerns: The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician _____ Date Processed _____

RECEIVED-DOCKETING DIV
2011 JAN -6 AM 11:43
PUCO