

FILE

Ohio Power Siting Board

Staff Investigation Report and Recommendation

Case No.: 11-2932-GA-BNR

Project: Harvard Avenue 16-inch High Pressure Line (PIR-732)

Applicant: Dominion East Ohio Gas Company

Report Date: 13 June 2011

Automatic Approval Date: 22 June 2011 (Construction Notice process)

Waiver Request: None

Inspection Date(s): 17 May 2011

Staff Assigned: J. O'Dell

RECEIVED-DOCKETING DIV
2011 JUN 13 PM 4:37
PUCO

Summary of Staff Recommendations (see report text for discussion):

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- None

Projected Docket Closure Date (if automatically approved): 1 October 2013

Project Description: This project replaces approximately 300 feet of existing 12-inch gas transmission line with a 16-inch line. When the old line is removed, the new line will be installed at the same location. The Applicant will utilize existing road r-o-w easements. This project is part of the Applicant's ongoing Pipeline Infrastructure Replacement program.

Site Description: Land use in proximity to the project consists of railroad and industrial uses. The project is located in the Village of Cuyahoga Heights, Cuyahoga County.

Discussion/Comments/Concerns: The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.

Technician Sus Date Processed

JUN 14 2011