



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

June 14, 2011

Via Electronic Filing

Ms. Betty McCauly
Administration/Docketing
Public Utilities Commission of Ohio
180 East Broad Street – 11th Floor
Columbus, OH 43215-3793

Re: Blue Creek Wind Farm, LLC
Case No. 11-1995-EL-BGA

Dear Ms. McCauly:

Attached please find Blue Creek Wind Farm's Response to Staff's Data Request 2 (A) issued on June 7, 2011 in the above-referenced proceeding. The attached response was provided to the Ohio Power Siting Board Staff by electronic mail yesterday, June 13, 2011.

If you have any questions, please give me a call.

Sincerely,

Sally W. Bloomfield

Attachment

Case No. 11-1995-EL-BGA
Blue Creek Wind Farm

Responses to Staff's Data Requests

Below are the responses to the Staff's Data Request 2 (A) issued on June 7, 2011 which were e-mailed to the Staff on June 13, 2011.

2(A) *Please model your aforementioned scenario (which would reduce shadow flicker to 30 hours/yr. or less for turbine 127 & residence 224) and provide modeling documentation.*

Attached is the Shadow Flicker Calendar demonstrating the reduction of Shadow Flicker at Residence 224 to 29 hours and 41 minutes through the use of curtailment.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/14/2011 3:04:55 PM

in

Case No(s). 11-1995-EL-BGA

Summary: Correspondence Submitting Response to OPSB Staff Data Request electronically filed by Teresa Orahod on behalf of Blue Creek Wind Farm, LLC