

Projected Docket Closure Date (if automatically approved): April 30, 2014

Investigation Report

Project Description: Columbia Gas of Ohio will be replacing a leaking 24" High Pressure steel pipeline under Ford Street in Maumee, OH to repair a Grade 1 leak at this location. This project will install approximately 140 feet of 24" and 60 feet of 6" high pressure gas main.

Site Description: The relocated pipeline will not require additional easements or rights-of-way. The majority of the pipe will be installed within public right-of-way while approximately 25% will be installed in a current easement.

Discussion/Comments/Concerns: This project will be installed under Ford Street in Maumee. Due to land constraints and the depth of the pipe, directional drilling is not an option. Columbia Gas will be closing Ford Street for approximately 1 week to open cut the street to install the new gas line. The remainder of the work can be accomplished while the street remains open.