

Case No. 12-0761-EL-REN

Hannah's Solar

Staff Interrogatories – Initial Set

Question 1: In section I.1 the projected gross annual generation (MWh) is listed as 0.01. However, PVWatts (http://mapserve3.nrel.gov/PVWatts_View/index.html) lists 9900 kWh or 9.9 MWh as the annual output for system. What is the correct projected gross annual generation (MWh)?

Answer 1: 9.9 MWh

Sincerely,

Mark Bellamy

Efficiency & Renewables Division

Energy & Environment Department

Public Utilities Commission of Ohio

180 E. Broad St.

Columbus, Ohio 43215

[614-644-8295](tel:6146448295)

www.PUCO.ohio.gov

This document was created only for the purpose stated within. It is for staff discussion only and does not reflect the view of the commission.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/14/2012 12:21:12 PM

in

Case No(s). 12-0761-EL-REN

Summary: Reply 12-0761 Answer 1 electronically filed by Hannah J Beck on behalf of BECK, HANNAH J