

**METERING SALES & SERVICE, INC.***Distributors of Metering Equipment & Systems*

1930 PIONEER ROAD
HUNTINGDON VALLEY, PA 19006
(215) 675-5117 • FAX (215) 675-4960

March 20, 2012

Ryan Marlborough
Photovoltaic Specialist
United Electric Supply Co.
10 Bellecor Drive
New Castle, DE 19720

Dear Mr. Marlborough:

The reconditioned Sangamo meter, S/N 42 906 487 that we shipped was fully tested and met the standards common to utilities. This meter was physically examined, cleaned and then tested utilizing a Watthour Engineering computerized test set with a Radian Research RM-11 Standard. When this meter left our facility, it measured +/- 1/2% full load and light load and +/- 1% power factor. These are the normally required test points.

If you have any further questions, please contact our office.

Very truly yours,

Steven J. Helzner

SJH:mms

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/26/2012 11:10:01 AM

in

Case No(s). 12-0498-EL-REN

Summary: Answer as requested, this is additional documentation that the Sangamo meter, model J4S, indicated in section 'N' is a utility-grade meter. electronically filed by Mr. Gary Lakritz on behalf of Charles Koch, Jr