

Case No. 12-1069-EL-REN
Dax Funderburk
Staff Interrogatories – Second Set

Question 1: In your response dated April 5, 2012, in response to the question as to whether you will use the utility grade meter or www.enphaseenergy.com? You answered, www.enphaseenergy.com. Since the facility has a nameplate capacity over 6 kW the meter or metering system that is used to report generation data to GATS must be “utility grade.” Please submit documentation that the hardware that is sending the data to www.enphaseenergy.com is “utility grade.” Hardware that is utility grade must have an accuracy of +/- 2%. Alternately you can use the utility grade meter included in the application to report generation data to GATS. If you are going to do this please indicate that in your response.

Answer 1: the meter will be reported to the Envoy and that reports everything to www.enphaseenergy.com. And then I will report the KWH and enter on GATS.

Question 2: The affidavit for the application must have the correct case number on it. You had probably reserved the case number towards the end of 2011 but finished the application in early 2012. Any 2011 case numbers that have not anything filed in them are voided as of Jan 1 and you must use 2012 case numbers. Please either sign, notarize, and file the affidavit I attached previously or cross out the 11-5941 and write in 12-1069 on the old affidavit and submit the affidavit with the change.

Answer 2: I wrote the new case number on the affidavit. Uploaded.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

4/12/2012 1:40:31 PM

in

Case No(s). 12-1069-EL-REN

Summary: Reply Staff interrogatories electronically filed by Mr. John D Smucker on behalf of Funderburk, Dax Mr.