

Question 1: In section N you list an Enphase system as your metering system. As your system is larger than 6 kW an utility grade meter is required. Please submit photos, meter specifications, and meter readings when you get the utility meters installed.

Answer 1: Two utility grade meters were installed (serial #45815979, #82588390). We installed two meters because we had two strings. Attached are picture of the installed meters.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/7/2012 8:34:59 AM

in

Case No(s). 12-1183-EL-REN

Summary: Reply Question 1: In section N you list an Enphase system as your metering system. As your system is larger than 6 kW an utility grade meter is required. Please submit photos, meter specifications, and meter readings when you get the utility meters installed.
Answer 1: Two utility grade meters were installed (serial #45815979, #82588390). We installed two meters because we had two strings. Attached are picture of the installed meters.
electronically filed by Mr. Richard N Kappel on behalf of Mr. Rick Kappel