Ohio Power Siting Board

Staff Investigation Report and Recommendation

Case No.: 12-1662-EL-BNR										
ject: Kirby-Tangy 138 kV Transmission Line Tap to Consolidated Electric's South Scioto Substation										
Applicants: American Transmission Systems, Inc. Ohio Edison Company	PUCO	2012 JUN 26	RECEIVED-DOCKETING DIV							
Report Date: 26 June 12	0	3	ÖKET.							
Automatic Approval Date: 5 July 2012 (Construction Notice process)		PM 4: 40	NG DIV							
Waiver Request: None										
Inspection Date(s): 31 May 2012 Staff Assigned: J. O'Dell										
Summary of Staff Recommendations (see report text for discussion):										
Application: [X] Approval [] Disapproval [] Approval with Conditi Waiver: [] Approval [] Disapproval [X] Not Applicable	ons									
Summary of Staff Recommended Conditions (see report text for discussion) None):									
Projected Docket Closure Date (if automatically approved): 1 October 2014	ļ									

Investigation Report

Project Description: This project involves the installation of approximately 350 feet of 138 kV transmission line. The line is needed to connect Consolidated Electric Cooperative's new distribution substation to the grid. Four new structures would be required. Three pole structures would be constructed within the r-o-w of the existing transmission line and one structure would be installed on the substation's property.

Site Description: Nearby land use consists of agricultural and rural residential uses. This project is located in Scioto Township, Delaware County.

Discussion/Comments/Concerns: No appreciable vegetative clearing is required. The construction of this project should pose only minimal negative social and ecological impacts.

						images				
accui	rate	e ar	id compi	Lete r	epro	duction	of a	a case	fil	e
docum	rent	: de	livered	in th	e re	gular co e Proces	urse	of bu	sine	38.
Techr	tot	aπ	4	2/	Date	e Proces	sed	HIN 9	6 20	12_
								DOLL A		