

**Case No. 12-0682-EL-REN**  
**Dennis Brooks**  
**Staff Interrogatories – Initial Set**

Question 1: In section K you stated that you are currently registered in an attribute tracking system. What is your GATS generation ID #?

Answer 1: 44092

Question 2: Since your facility is greater than 6 kW, the meter that will be used to report generation data must be “utility grade.” A utility grade meter is one that conforms to ANSI 12.1 which calls for an accuracy of +/- 2% or better. Please submit documentation that shows that the Schlumberger meter has an accuracy of +/- 2% or better. If your documentation includes a letter from the company that refurbished the meter, this letter must reference your meter’s serial number and the accuracy to which the meter was calibrated.

Answer 2.- see letter attached below



July 10, 2012

Hialeah Meter Company remanufactures kilowatt-hour meters according to ANSI C12 accuracy requirements, and acceptable performance percentages for watt-hour meters. We guarantee full load and light load accuracy within these standards for two years.

Hialeah Meter Company maintains traceability to NIST. We use RFL 5800 test boards considered by utilities to be one of the best recognized, automated test standards available.

Specializing in remanufacturing kilowatt-hour meters for over 55 years, Hialeah Meter Company has built an uncompromising commitment and reputation for providing utility grade, revenue rated, accurate meters. Our customers include utilities, government agencies (including military, housing authorities, universities), industrial, distributors, contractors, and exporters.

We have stood and will continue to stand behind the accuracy and dependability of our remanufactured meters to those with needs of accurately recovering electricity costs.

The following single phase FM 2S meters were produced at the Hialeah Meter facility:-

<u>Serial #</u>	<u>Date</u>
77403526	4.23.2010
60172279	4.23.2010

Lisa Senior  
General Manager  
Hialeah Meter Company  
450 W 28th St, Unit 4  
Hialeah, FL 33010  
p 305.887.8931  
F 305.887.6542  
[lisa@hialeahmeter.com](mailto:lisa@hialeahmeter.com)  
[www.hialeahmeter.com](http://www.hialeahmeter.com)

Veteran Owned Small Business - Corporation  
Dunns #063599187  
CAGE Code: 0Z9G1



**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**7/17/2012 12:14:33 PM**

**in**

**Case No(s). 12-0682-EL-REN**

Summary: Reply electronically filed by Mrs. Karla G Beiler on behalf of Brooks, Dennis