

GenOn Generation Deactivation Request – February 2012

Deactivation Study Results and Required Upgrades – May 29, 2012

General

PJM received a notice on February 29, 2012 from GenOn of its intent to deactivate through retirement the following generating units by not later than June 1, 2012:

Niles 1	109 MW
Niles 2	108 MW
Elrama 1	93 MW
Elrama 2	93 MW
Elrama 3	103 MW
Elrama 4	171 MW

Reliability Analysis:

PJM Interconnection Analysis (and affected Transmission Owners) performed a study of the Transmission System and found significant reliability concerns resulting from the deactivation of these generating units. In all, more than 46 reliability violations were identified in the deactivation analysis. A summary of the reliability impacts resulting from the proposed Deactivations include:

1. N-1 Common Mode Voltage Violations:

- Three low voltage violations on the 138 kV system

2. N-1 Thermal Violations:

- Two 138 kV thermal violations in AEP area

3. N-1-1 Thermal Violations:

- Five 138 kV thermal violations in ATSI area
- Five 138 kV thermal violations in AEP area

- One 345/138 kV thermal violation in ATSI area
- Two 138/345 kV thermal violations in DLCO area

4. N-1-1 Voltage Violations:

- Two 500 kV low voltage violations in APS area
- Two 138 kV low voltage violations in ATSI area
- One 500 kV voltage drop violation in APS area
- Three 138 kV voltage drop violations in ATSI area
- One 138 kV voltage drop violation in AEP area

5. Generation Deliverability Violations:

- One 765/500 kV thermal violation in AEP/APS area
- Three 345 kV thermal violations in AEP area
- One 345/138 kV thermal violation in DLCO area
- Two 230 kV violations in Penelec area
- Seven 138 kV thermal violation in AEP area
- Five 138 kV thermal violations in ATSI area

6. Load Deliverability Violations:

- None

Study Results and Required Upgrades:

The following generating units will be deactivated on June 1, 2012:

Niles 2	108 MW
Elrama 1	93 MW
Elrama 2	93 MW
Elrama 3	103 MW

PJM does need Niles 1 and Elrama 4 for reliability and thus those units are currently anticipated to continue to operate until October 1, 2012 pending analysis of outages required to implement required system upgrades.

Niles 1 109 MW

Elrama 4 171 MW

Required transmission upgrades and expected completion date:

ATSI zone:

- Sag Study on 7.2 miles SE Canton-Canton Central 138kV ckt. - 12/1/2012
- Existing RTEP project b1693: Replace the Star 345/138 kV #3 with a larger unit - 6/1/2013
- Reconductor Evergreen-Highland #1 138kV – 6/1/2013
- Reconductor Evergreen-Highland #2 138kV – 6/1/2013
- b1289: Reconductor Evergreen - Niles 138 kV (3 miles) and replace terminal equipment at Evergreen on Evergreen - Niles 138 kV – 6/1/2013
- Reconductor Highland-Salt Springs 138kV – 6/1/2013, possibly 6-1-2014
- Harmon 345-138-69kV Sub project – 6/1/2015
- W.Fremont-Groton-Hayes 138kV line – ISD 6-1-2018

AEP zone:

- Sag Study on 7.2 miles SE Canton-Canton Central 138kV ckt – 12/1/2012
- Advance Baseline project # B1457 (Tilton – Windsr). – 12/1/2012
- Perform a sag study of the conductor section Kammer - Ormet. – 12/1/2012
- Advance Baseline project # B1455. (Central - Wagenhals lines). – 12/1/2012
- Perform a sag study on Southeast Canton - Sunnyside ckt 1. – 12/1/2012
- Add (4) 765kV CBs at Kammer to redefine '4831' contingency. – 6/1/2015
- Advance Baseline project # B1879 – 12/1/2012
- Reconductor 13 miles of Kammer – W.BELLA 345kV circuit with 2156 ACSR. – 6/1/2014
- Advance Baseline project # B1452. - 12/1/2012
- Advance Baseline project # B1453. - 12/1/2012
- Sag Study on 7.2 miles SE Canton-Canton Central 138kV ckt. - 12/1/2012
- Advance Baseline project # B1457. - 12/1/2012
- Advance Baseline project # B1811. - 12/1/2013
- Build approximately 1 mile of Waterfront – Musking circuit comprising of 2-954 ACSR to get the rating higher - 12/1/2013
- Advance Baseline project # B1456. - 12/1/2012

- Sag Study on section 1 of WBella – Tilton. ~12 mi. - 12/1/2012

DLCO zone:

- Install a third 345-138 kV autotransformer at Collier Substation – 6/1/2013

APS zone:

- Existing Baseline RTEP Project b1804: "Build a 600 MVAR SVC at Meadow Brook 500 kV". – 06/2014

PenElec zone:

- Replace the 1200 Amp Line trap at Lewistown on the Raystown-Lewistown 230 kV line and replace substation conductor at Lewistown. – 12/2013
- Convert Moshannon substation to a 4 breaker 230 kV ring bus. The Milesburg and East Towanda line will be on opposite side of the ring to avoid sharing a common breaker – 6/1/2014.

EXECUTIVE SUMMARY

Since November, PJM has received notification from several generation owners of their intent to deactivate a number of generators totaling over 13,000 MW of generation. Generation owners are required to notify PJM of their intent to deactivate generation per Article V of the PJM tariff. Baseline reliability criteria violations have been identified as a result of the generation deactivations. Transmission reinforcements to address the reliability criteria violations are being developed.

The baseline upgrades related to the generation deactivation studies completed as of this time are summarized below. The requested generation deactivations range from May 2012 through the end of 2015. If the transmission upgrades that are required to maintain reliability cannot be implemented by the requested deactivation date, generation may need to be retained through Reliability Must Run (RMR) agreements. Based on the expected in-service date of some of the transmission upgrades included in this report, RMR agreements are being pursued.


The total increase to the RTEP to include these baseline project changes is \$1,881 million. With these changes, the RTEP will include over \$23.410 billion of transmission additions and upgrades since the first plan was approved by the Board in 2000.

SUMMARY OF RESULTS

Generation Deactivation Process

As noted above, generation deactivation is covered under Article V of the PJM tariff. The flowchart below details the generation deactivation process. After a generation owner notifies PJM of their intent to deactivate a unit, PJM conducts a series of studies to determine if deactivating the generator will have an adverse impact on the reliability of the bulk electric system. This baseline analysis determines the compliance of the system with reliability criteria and standards. If reliability criteria violations are identified, transmission upgrades are developed to resolve the identified issues. If the transmission upgrades can be put in place prior to the intended deactivation date, the unit can retire as requested. If the transmission upgrades cannot be put in place prior to the requested deactivation date then an RMR agreement may be pursued. The generation owner is not under any obligation to pursue the RMR agreement and may retire the unit at any time. PJM cannot compel a generator to remain in-service. Transmission upgrades required to maintain a reliable system are identified and reviewed with the Sub-regional RTEP Committees and the

Transmission Expansion Advisory Committee (TEAC). The cost of transmission upgrades to mitigate criteria violations caused by generation deactivation is allocated to load.



The upgrades included in this report are needed due to the deactivation of multiple units from several different generation owners. The table below summarizes the generation deactivations driving the need for the upgrades included in this report.

Unit Name	Capacity (MW)	Owner	Official Owner Request Date
Chesapeake 1	111	Dominion	11/15/2011
Chesapeake 2	111	Dominion	11/15/2011
Yorktown 1	159	Dominion	11/15/2011
Chesapeake 3	147	Dominion	11/15/2011
Chesapeake 4	207	Dominion	11/15/2011
Bergen 3	21	PS Power	12/1/2011
Burlington 8	21	PS Power	12/1/2011
National Park 1	21	PS Power	12/1/2011
Mercer 3	115	PS Power	12/1/2011
Sewaren 6	111	PS Power	12/1/2011
Armstrong 1	172	FE Solutions	1/26/2012
Armstrong 2	171	FE Solutions	1/26/2012

Unit Name	Capacity (MW)	Owner	Official Owner Request Date
Ashtabula 5	244	FE Solutions	1/26/2012
Bay Shore 2	138	FE Solutions	1/26/2012
Bay Shore 3	142	FE Solutions	1/26/2012
Bay Shore 4	215	FE Solutions	1/26/2012
Eastlake 1	132	FE Solutions	1/26/2012
Eastlake 2	132	FE Solutions	1/26/2012
Eastlake 3	132	FE Solutions	1/26/2012
Eastlake 4	240	FE Solutions	1/26/2012
Eastlake 5	597	FE Solutions	1/26/2012
Lake Shore 18	245	FE Solutions	1/26/2012
R Paul Smith 3	28	FE Solutions	1/26/2012
R Paul Smith 4	87	FE Solutions	1/26/2012
Walter C Beckjord 1	94	Duke Energy	2/1/2012
Walter C Beckjord 2	94	Duke Energy	2/1/2012
Walter C Beckjord 3	128	Duke Energy	2/1/2012
Walter C Beckjord 4	150	Duke Energy	2/1/2012
Walter C Beckjord 5	238	Duke Energy	2/1/2012
Walter C Beckjord 6	414	Duke Energy	2/1/2012
Albright 1	73	Monongahela Power	2/8/2012
Albright 2	73	Monongahela Power	2/8/2012
Albright 3	137	Monongahela Power	2/8/2012
Rivesville 5	35	Monongahela Power	2/8/2012
Rivesville 6	86	Monongahela Power	2/8/2012
Willow Island 1	51	Monongahela Power	2/8/2012
Willow Island 2	138	Monongahela Power	2/8/2012
New Castle 3	93	GenOn	2/29/2012
New Castle 4	92	GenOn	2/29/2012
New Castle 5	140	GenOn	2/29/2012
New Castle Diesels	5.5	GenOn	2/29/2012
Portland 1	158	GenOn	2/29/2012
Portland 2	243	GenOn	2/29/2012
Glen Gardner CTs	160	GenOn	2/29/2012
Shawville 1 - 4	597	GenOn	2/29/2012
Titus 1 - 3	243	GenOn	2/29/2012
Niles 1 & 2	217	GenOn	2/29/2012
Elrama 1 - 4	396	GenOn	2/29/2012
Fisk 19	326	Midwest Generation	3/8/2012
Crawford 7	213	Midwest Generation	3/8/2012
Crawford 8	319	Midwest Generation	3/8/2012

The baseline deactivation analysis, discussed herein, resulted in the need for transmission upgrades in several transmission zones. In total these analyses identified over 130 upgrades ranging from simple line terminal equipment upgrades, new substations and substation additions to reinforce underlying systems, rebuilding existing lines to higher capacity, and new transmission lines. A summary of the major baseline project additions that are \$5 million or greater are detailed below. A complete listing of all of the projects is included as an attachment to this document.

Mid-Atlantic Region System Upgrades

- PEPCO Transmission Zone
 - Reconductor 230 kV line 23032 and 23034 with high temperature conductor - \$16M
- PENELEC Transmission Zone
 - Construct a 115 kV ring bus at Claysburg Substation - \$5.25M
 - Construct Farmers Valley 345/230 kV and 230/115 kV substation by looping the Homer City to Stolle Road 345 kV line into Farmers Valley – \$29.5M
 - Relocate the Erie South 345 kV line bay - \$13M
 - Convert the Lewis Run – Farmers Valley 115 kV line to 230 kV - \$46.8M
- PPL Transmission Zone
 - Install a new North Lancaster 500/230 kV substation - \$42M
- JCPL Transmission Zone
 - Construct a new Whippany to Montville 230 kV line - \$37.5M

Western Region System Upgrades

- American Electric Power
 - Reconductor Kammer – West Bellaire 345 kV - \$20M
 - Install a new 765/345 substation at Mountaineer and build a ¾ mile 345 kV line to Sporn - \$65M
 - Terminate Transformer #2 at SW Lima in a new bay position - \$5M
 - Add four 765 kV breakers at Kammer - \$30M
- APS Transmission Zone
 - Loop the Homer City-Handsome Lake 345 kV line into the Armstrong substation and install a 345/138 kV transformer at Armstrong - \$27.8M
 - Install a new Buckhannon – Weston 138 kV line - \$17.5M
 - Convert Moshannon substation to a four breaker 230 kV ring - \$6.5M
- ATSI Transmission Zone
 - Install a 345/138 kV transformer at the Inland Q-11 station - \$7.2M

- Convert Eastlake units 1, 2, 3, 4 and 5 to synchronous condensers - \$100M
 - Convert Lakeshore 18 to synchronous condensers - \$20M
 - Re-conductor the Galion – GM Mansfield – Ontario - Cairns 138 kV line - \$9.8M
 - Install a 2nd 345/138 kV transformer at the Allen Junction station - \$7.2M
 - Install a 2nd 345/138 kV transformer at the Bay Shore station - \$7.2M
 - Create a new Northfield Area 345 kV switching station by looping in the Eastlake – Juniper 345 kV line and the Perry - Inland 345 kV line - \$37.5M
 - Build a new Mansfield - Northfield Area 345 kV line - \$184.5M
 - Create a new Harmon 345/138/69 kV substation by looping in the Star – South Canton 345 kV line - \$46M
 - Build a new Harmon – Brookside + Harmon - Longview 138 kV line - \$9.2M
 - Create a new Five Points Area 345/138 kV substation by looping in the Lemoyne – Midway 345 kV line - \$30M
 - Build a new 345-138kV Substation at Niles - \$32M
 - Build a new substation near the ATSI-AEP border and a new 138kV line from new substation to Longview - \$17.7M
 - Build new Allen Jct - Midway - Lemoyne 345kV line - \$86.3M
 - Build a new Leroy Center 345/138 kV substation by looping in the Perry – Harding 345 kV line - \$46M
 - Build a new Toronto to Harmon 345 kV line - \$218.3M
 - Build a new Toronto 345/138 kV substation - \$41.8M
 - Build a new West Fremont – Groton – Hayes 138 kV line - \$45M
 - Re-conductor the ATSI portion of South Canton – Harmon 345 kV line - \$6M
 - Add a new 150 MVAR SVC and 100 MVAR capacitor at New Castle - \$31.7M
- Duquesne Transmission Zone
 - Install a third 345/138 kV transformer at Collier - \$8M


Southern Region System Upgrades

- Dominion Virginia Power Transmission Zone
 - Build new Surry to Skiffes Creek 500 kV line - \$58.3M
 - Build new Skiffes Creek 500/230 substation - \$42.4M
 - Build new Skiffes Creek – Whealton 230 kV line - \$46.4M
 - Expand Yadkin 500/230 kV and 230/115 kV substation and Chesapeake 230/115 kV substation - \$45M
 - Add a third 500/230 kV transformer at Yadkin - \$16M
 - Add six 500 kV breakers at Yadkin - \$8M
 - Install a third 500/230 kV transformer at Clover - \$16M
 - Rebuild Lexington to Dooks 500 kV line - \$120M


- Upgrade Brema – Midlothian 230 kV line - \$10M
- Build a new Suffolk to Yadkin 230 kV line - \$40M
- Install a second Valley 500/230 kV transformer - \$16M
- Build a 500 MVAR SVC at Landstown 230 kV - \$60M

Western Region System Upgrades

The majority of the generator deactivations that PJM has received since November are for units in the western region of PJM. Generation owners including First Energy Solutions, Duke Energy, GenOn and Midwest Generation have notified PJM of their intent to deactivate units in the western region of PJM. As shown in the map below a number of these deactivations are clustered around Lake Erie in the American Transmission System Inc. (ATSI) transmission zone. Deactivation of the generation along Lake Erie will require significant transmission upgrades to resolve thermal and voltage violations in and around the City of Cleveland which has historically been constrained due to voltage limitations.



Several new 345 kV transmission lines, new 345/138 kV substations, and new reactive upgrades have been identified in addition to a large number of incremental upgrades to existing facilities. The map on the following page shows the new 345 kV lines and the new 345/138 kV stations.




As noted above, the ability to import power into the Cleveland area has historically been limited by voltage problems. Deactivation of the generation in and around Cleveland will exacerbate these voltage limitations. As a result, a significant number of upgrades have been identified to address voltage and voltage stability criteria. The Eastlake units 1 – 5 and the Lakeshore 18 unit were recommended to be converted to synchronous condensers. The estimated cost for this work is \$20M for each machine. The expected reactive capability for the Eastlake units 1 – 3 is 124 MVAR/machine, Eastlake unit 4 is 268 MVAR, Eastlake unit 5 is 485 MVAR and 260 MVAR for the Lakeshore 18 machine. In addition a new 345/138 kV substation at Leroy Center was recommended. The new station will be established by looping the existing Perry to Harding 345 kV line through the station. The estimated cost for the new Leroy Center substation is \$46M. A new Northfield area 345/138 kV substation was recommended to address voltage violations under load deliverability conditions. The new substation will be established by tapping the existing Eastlake to Juniper 345 kV line and the Perry to Inland 345 kV line. The estimated cost for that work is \$37.5M. A new 345 kV line from Mansfield to Northfield was also recommended to reinforce the 345 kV feed into the Northfield area. The estimated cost for this new line is \$184.5M. In addition, a new 345 kV line from Beaver Valley to Leroy Center and another new 345 kV line from Mansfield to Leroy Center are being considered to address ATSI voltage stability criteria violations. The estimated cost of the two new 345 kV lines is \$393M. The Beaver Valley to Leroy Center and Mansfield to Leroy Center 345 kV lines were not recommended to the PJM Board at this time. Additional analysis using the ATSI voltage stability is in progress.


A new Five Points 345/138 kV substation was recommended to address NERC category C3 (N-1-1) voltage violations. The new station will be created by looping the existing Lemoyne to Midway 345 kV line through the station. The estimated cost for this work is \$30M. A second Bayshore 345/138 kV transformer was also recommended to address NERC category C3 (N-1-1) voltage violations. The estimated cost for adding the second transformer at Bayshore is \$7.2M. In addition to these upgrades to address voltage problems in and around the City of Cleveland, a 150 MVAR SVC and 100 MVAR capacitor were

recommended at New Castle station in western Pennsylvania to address voltage problems primarily related to the deactivation of the New Castle generation.

There are also a number of projects that are required to address thermal violations. A new Harmon 345/138/69 kV station was recommended to address several NERC category C (breaker failure) contingency overloads. The new Harmon station will be established by looping the South Canton to Star 345 kV line through the station. The estimated cost for this project is \$46M. In addition, a new Toronto 345/138 kV substation was recommended to address a number of NERC category C3 (N-1-1) violations. The new substation will be established by looping the existing Sammis to Wylie Ridge 345 kV line through the station. The estimated cost for the new Toronto station is \$41.8M. In addition, a new Toronto to Harmon 345 kV line was recommended to reinforce the 345 kV system in the area. The estimated cost for the new Toronto to Harmon 345 kV line is \$218.3M.




A new 345 kV line from Allen Junction to Midway to Lemoyne was recommended to address a NERC category C3 (N-1-1) thermal violation on Lemoyne to BG Tap 138 kV line. The violation is being driven by the loss of the Allen Junction to Lulu 345 kV tie line to Michigan and the Lemoyne to Five Points 345 kV line. Approximately 48 miles (roughly 3/4 of the line) will utilize an open tower position on an existing double circuit tower structures. The estimate cost for Allen Junction to Midway to Lemoyne line is \$86.3M. A new 138 kV line between West Fremont and Hayes was recommended to address thermal violations on other 138 kV facilities for NERC category C5 (double circuit tower) contingency. Specifically the Ottawa to Lakeview 138 kV line and the Lakeview to Greenfield 138 kV line are both overloaded for a double circuit towerline contingency. The estimated cost of the new 138 kV line is \$45M.




A new 345 kV source into the Sporn station was recommended to address an overload on the Mountain to Belmont 765 kV line for a NERC category C breaker failure contingency at Marysville that trips the Marysville – Sorenson 765 kV line and the Marysville – Flatlick 765 kV line. The recommended project is to add a new 765/345 kV transformer at Mountaineer and build a new 345 kV line from Mountaineer to Sporn. The Sporn station is approximately 3/4 of a mile from Mountaineer. The estimated cost for this project is approximately \$65M.

Southern Region System Upgrades

Several new upgrades have been identified in the Dominion transmission zone. A number of the more significant upgrades are summarized below. These upgrades are being driven primarily by the deactivation of the Yorktown 1 unit (159 MW) and the Chesapeake 1 – 4 units (576 MW total). The map below shows the relative location of these units within the Dominion transmission zone.




Thermal and voltage violations were identified on the 230 kV facilities noted on the diagram at the right which serve the northern Hampton Roads area of Virginia. Several alternatives were evaluated to address these issues including a new 500 kV line from Chickahominy to a new station called Skiffes Creek, a new 500 kV line from Surry crossing the James River to the new Skiffes Creek station, and a new 230 kV line from Surry to Skiffes Creek. Each of these alternatives also included a new 230 kV line from Skiffes Creek to Wheelton with an estimated cost of \$46.4 million. PJM staff is recommending the new 500 kV line from Surry to Skiffes Creek which has an estimated cost of \$100.7 million including the new Skiffes Creek 500/230 kV substation. Each alternative resolved the reliability



criteria violations in 2015, however the 230 kV alternative was found to be less robust and would not be adequate under certain at-risk generation scenarios that were evaluated by PJM staff. In addition, the 230 kV alternative required a Phase Angle Regulator (PAR) to control the flow of power on the proposed Surry to Skiffes Creek 230 kV line which would add additional operational complexity. The 500 kV line from Chickohominy to Skiffes Creek was not chosen primarily due to it being the highest cost alternative.

A violation of Dominion planning criteria was identified on the Lexington to Dooks 500 kV line. One of the Dominion planning criteria establishes the critical system conditions by removing a single generator followed by the single contingency outage of any other line or generator. Under these conditions with either the Yorktown 3 unit or the Surry 2 unit off-line, the Lexington to Dooks 500 kV line overloads for the loss of the Bath to Valley 500 kV line. The recommended upgrade to address this violation is to rebuild the 40 mile Lexington to Dooks 500 kV line. The estimated cost for this work is \$120 million. The line is being recommended to be rebuilt to address the thermal overload and to address the aging infrastructure issues that are similar to problems that are driving the need for the rebuild of the Mt Storm – Dooks 500 kV line.



Other significant upgrades in the Dominion transmission zone include a third 500/230 kV transformer at Yadkin (estimated cost \$16 million) to address thermal overloads on the existing Yadkin 500/230 kV transformers for the loss of the other transformer, a third 500/230 kV transformer at Clover (estimated cost \$16 million) to address overloads on the existing Clover 500/230 kV transformers, a new Suffolk to Yadkin 230 kV line (estimated cost \$40 million) to address a NERC category C3 (N-1-1) overload, a second Valley 500/230 kV transformer to address overloads on the existing transformer to address NERC category C3(N-1-1) violations, and a new 500 MVAR Static VAR Compensator (SVC) on the 230 kV at Landstown to address NERC category C3 (N-1-1) voltage violations in the Southern Hampton Roads area.

Mid-Atlantic Region System Upgrades

There are a number of upgrades in the Mid-Atlantic region. Many of these upgrades are being driven by the deactivation of the GenOn units at Portland, Shawville, Titus and Glen Gardner.


In the PPL transmission zone a new 500/230 kV substation is being recommended to address several overloads on 230 kV facilities in the South Akron and South Manheim areas. The estimated cost for the project is \$42M. In the JCPL transmission zone a new 6.4 mile 230 kV line between Whippany and Montville is being recommended to address NERC Category C3 (N-1-1) violations due to the loss of the Montville to Roseland 230 kV line followed by the loss of the Kittatiny to Newton 230 kV line. The estimated cost for the project is \$37.5M.

There are several upgrades in the Pennelec transmission zone to address both thermal and voltage violations. A new 345/230/115 kV substation was recommended at the existing Farmers Valley 115 kV substation. The 345 kV source will be from the Homer City to Stolle Road 345 kV line that passes near the station. This project is needed to address NERC category B (single contingency) voltage drop violations, generator deliverability violations and NERC category C3 (N-1-1) thermal violations. The estimated cost for this work is \$29.5M. In addition to this upgrade, the existing 115 kV line from Farmers Valley to Lewis Run be converted to 230 kV. This upgrade is required to address generator deliverability violations. The estimated cost for this conversion work is \$46.8M.



Next Steps

PJM staff continues to work on a number of generator deactivation studies for units shown on the map below including twenty two units in the AEP transmission zone, two Avon Lake units in the ATSI transmission zone, several units at Sewaren in the PSEG zone and several units in the Atlantic Electric transmission zone. Although upgrades will be required to address reliability violations for these deactivations, based on initial analysis the number and scope of upgrades required for these deactivations is expected to be less than those described in this report.



Review by the Transmission Expansion Advisory Committee (TEAC)

The results of all of the deactivation analyses were reviewed with the TEAC at the February 16th, March 15th, April 12th meetings. Final upgrades included in this report were reviewed with the TEAC at the April 27, 2012 meeting.

Board Approval

The PJM Board met on May 17th and approved the elements of the 2012 RTEP documented herein.

Appendix: Retirement Baseline Upgrades

Upgrade ID	Project Description	Transmission Owner	Cost Estimate
b1879	Perform a sag study on the Hansonville - Meadowview 138 kV line (Improve the emergency rating to 245 MVA)	AEP	\$ 0.10
b1946	Perform a sag study on the Brues - West Bellaire 138 kV line	AEP	\$ 0.03
b1947	A sag study of the Dequine - Meadowlake 345 kV line #1 line may improve the emergency rating to 1400 MVA	AEP	\$ 0.01
b1948	Establish a new 765/345 interconnection at Sporn. Install a 765/345 kV transformer at Mountaineer and build ¾ mile of 345 kV to Sporn	AEP	\$ 65.00
b1949	Perform a sag study on the Grant Tap - Deer Creek 138 kV line and replace bus and risers at Deer Creek station	AEP	\$ 0.30
b1950	Perform a sag study on the Kammer - Ormet 138 kV line of the conductor section	AEP	\$ 0.10
b1951	Perform a sag study of the Maddox- Convoy 345 kV line to improve the emergency rating to 1400 MVA	AEP	\$ 0.03
b1952	Perform a sag study of the Maddox - T130 345 kV line to improve the emergency rating to 1400 MVA	AEP	\$ 0.03
b1953	Perform a sag study of the Meadowlake - Olive 345 kV line to improve the emergency rating to 1400 MVA	AEP	\$ 0.06
b1954	Perform a sag study on the Milan - Harper 138 kV line and replace bus and switches at Milan Switch station	AEP	\$ 0.35
b1955	Perform a sag study of the R-049 - Tillman 138 kV line may improve the emergency rating to 245 MVA	AEP	\$ 0.03
b1956	Perform a sag study of the Tillman - Dawkins 138 kV line may improve the emergency rating to 245 MVA	AEP	\$ 0.03
b1957	Terminate Transformer #2 at SW Lima in a new bay position	AEP	\$ 5.00
b1958	Perform a sag study on the Brookside - Howard 138 kV line and replace bus and risers at AEP Howard station	AEP	\$ 0.50
b1960	Sag Study on 7.2 miles SE Canton-Canton Central 138kV ckt	AEP	\$ 0.30
b1961	Sag study on the Southeast Canton - Sunnyside 138kV line	AEP	\$ 0.25
b1962	Add four 765 kV breakers at Kammer	AEP	\$ 30.00
b1963	Build approximately 1 mile of circuit comprising of 2-954 ACSR to get the rating of Waterford-Muskinum 345 kV higher	AEP	\$ 3.50
b1970	Reconductor 13 miles of the Kammer - West Bellaire 345kV circuit	AEP	\$ 20.00
b1971	Perform a sag study to improve the emergency rating on the Bridgville - Chandlersville 138 kV line	AEP	\$ 0.05
b1972	Replace disconnect switch on the South Canton 765/345 kV transformer	AEP	\$ 0.30
b1973	Perform a sag study to improve the emergency rating on the Carrollton - Sunnyside 138 kV line	AEP	\$ 0.05
b1974	Perform a sag study to improve the emergency rating on the Bethel Church - West Dover 138 kV line	AEP	\$ 0.03
b1975	Replace a switch at South Millersburg switch station	AEP	\$ 0.20
b1837	Replace breaker risers and wave traps at Marlowe 138 kV and wave traps at Bedington 138 kV	APS	\$ 0.60
b1840	Install a new Buckhannon - Weston 138 kV line	APS	\$ 17.50

Upgrade ID	Project Description	Transmission Owner	Cost Estimate
b1902	Replace line trap at Stonewall on the Stephenson 138 kV line terminal	APS	\$ 0.08
b1941	Loop the Homer City-Handsome Lake 345 kV line into the Armstrong substation and install a 345/138 kV transformer at Armstrong	APS	\$ 27.80
b1942	Change the CT ratio at Millville to improve the Millville – Old Chapel 138 kV line ratings	APS	\$ 0.05
b1964	Convert Moshannon substation to a 4 breaker 230 kV ring bus	APS	\$ 6.50
b1965	Install a 44 MVAR 138 kV capacitor at Luxor substation	APS	\$ 1.50
b1986	Upgrade the AP portion of the Elrama – Mitchell 138 kV line by replace breaker risers on the Mitchell 138 kV bus on the Elrama terminal	APS	\$ 0.05
b1987	Reconductor the Osage-Collins Ferry 138 kV line with 795 ACSS. Upgrade terminal equipment at Osage and Collins Ferry	APS	\$ 1.80
b1988	Raise structures between Lake Lynn and West Run to eliminate the clearance de-rates on the West Run – Lake Lynn 138 kV line	APS	\$ 0.32
b1989	Raise structures between Collins Ferry and West Run to eliminate the clearance de-rates on the Collins Ferry - West Run 138 kV line	APS	\$ 0.32
b1913	Convert Eastlake units 1, 2, 3, 4 and 5 to synchronous condensers	ATSI	\$ 100.00
b1914	Convert Lakeshore 18 to a synchronous condenser	ATSI	\$ 20.00
b1915	Install a 50 MVAR capacitor bank at the Maclean 138 kV station	ATSI	\$ 3.00
b1916	Install a 345/138 kV transformer at the Inland Q-11 station	ATSI	\$ 7.20
b1917	Install a 138 kV circuit breaker at the Inland Q-11 station	ATSI	\$ 0.90
b1918	Upgrade terminal equipment on the Avon – Crestwood 138 kV line	ATSI	\$ 0.30
b1919	Re-conductor the Galion – Leaside 138 kV line with 336 ACSS	ATSI	\$ 4.90
b1920	Re-conductor the Galion – GM Mansfield – Ontario - Cairns 138 kV line with 477 ACSS	ATSI	\$ 9.80
b1921	Install a 2nd 345/138 kV transformer at the Allen Junction station	ATSI	\$ 7.20
b1922	Install a 2nd 345/138 kV transformer at the Bayshore station	ATSI	\$ 7.20
b1923	Create a new Northfield Area 345 kV switching station by looping in the Eastlake – Juniper 345 kV line and the Perry - Inland 345 kV line	ATSI	\$ 37.50
b1924	Build a new Mansfield - Northfield Area 345 kV line	ATSI	\$ 184.50
b1925	Create a new Harmon 345/138/69 kV substation by looping in the Star – South Canton 345 kV line	ATSI	\$ 46.00
b1926	Build a new Harmon – Brookside + Harmon - Longview 138 kV line	ATSI	\$ 9.20
b1927	Create a new Five Points Area 345/138 kV substation by looping in the Lemoyne – Midway 345 kV line	ATSI	\$ 30.00
b1928	Install a 50 MVAR capacitor at Hayes 138 kV	ATSI	\$ 1.50
b1929	Install a 138/69 kV transformer at the Avery station	ATSI	\$ 3.20
b1930	Increase design temperature limitation on the Avery – Hayes 138 kV line by raising the existing structures	ATSI	\$ 0.13
b1931	Reconductor Cloverdale - Harmon #2 and #3 138 kV lines with 795 ACSS or greater conductor 6 miles total + Terminal upgrades	ATSI	\$ 3.60
b1932	Change the transformer tap settings on the Maclean 138/69 kV transformers	ATSI	\$ 0.05
b1933	Replace 336.4 ACSR SCCIR at Richland to upgrade the Richland – Naomi 138 kV line	ATSI	\$ 0.04

Upgrade ID	Project Description	Transmission Owner	Cost Estimate
b1934	Build a new 345/138 kV Substation at Niles	ATSI	\$ 32.00
b1934.1	Loop 1.2 miles of 345 kV into substation of the Highland – Shenango 345 kV line	ATSI	
b1934.2	New 345/138 kV transformer at Niles	ATSI	
b1935	ATSI-AEP 138 kV Substation on near territory border + 138 kV from new substation to Longview approx. 8 miles	ATSI	\$ 17.70
b1936	Build new Allen Jct - Midway - Lemonye 345 kV line (48 miles of open tower position)	ATSI	\$ 86.30
b1937	Build a new Leroy Center 345/138 kV substation by looping in the Perry – Harding 345 kV line	ATSI	\$ 46.00
b1938	Place a portion of the 138 kV Leroy Center 345/138 kV project into service by summer 2015	ATSI	\$ 3.30
b1939	Reconductor the Barberton – West Akron 138 kV line with 477 ACSS or greater (7.3 miles) + Terminal upgrades at Barberton	ATSI	\$ 4.23
b1959	Build a new West Fremont-Groton-Hayes 138kV line	ATSI	\$ 45.00
b1976	Reconductor ATSI portion of South Canton – Harmon 345 kV line	ATSI	\$ 6.00
b1977	Build new Toronto 345/138 kV substation by looping in the Sammis – Wylie Ridge 345 kV line and tie in four 138 kV lines	ATSI	\$ 41.80
b1977.1	Build a new Toronto-Harmon 345kV line	ATSI	\$ 218.30
b1978	Reconductor Inland – Clinic Health Q-11 138 kV line	ATSI	\$ 1.10
b1981	Replace relay on the Highland – G689 138 kV line	ATSI	\$ 0.05
b1982	Reconductor the Hoytdale – Newcastle 138 kV lines #1 and #2 with 795 ACSS	ATSI	\$ 4.80
b1983	Add 150 MVAR SVC and a 100 MVAR capacitor at New Castle	ATSI	\$ 31.70
b1984	Install a 50 MVAR capacitor at the Boardman 138 kV bus	ATSI	\$ 1.70
b1968	Establish operating procedure such that breaker 89, connecting Cheswick-Logans Ferry Z-53 to the No. 3 138 kV bus at Cheswick Substation is normally open	DL	\$ -
b1969	Install a third 345-138 kV autotransformer at Collier Substation. Currently s0321 and will be converted to baseline.	DL	\$ 8.00
b1985	Upgrade the Duquesne portion of the Elrama – Mitchell 138 kV line	DL	
b1905.1	Surry to Skiffes Creek 500 kV Line (7 miles overhead)	Dominion	\$ 58.30
b1905.2	Surry 500 kV Station Work	Dominion	\$ 1.50
b1905.3	Skiffes Creek 500-230 kV Tx and Switching Station	Dominion	\$ 42.40
b1905.4	New Skiffes Creek - Wheaton 230 kV line	Dominion	\$ 46.40
b1905.5	Wheaton 230 kV breakers	Dominion	\$ 2.10
b1905.6	Yorktown 230 kV work	Dominion	\$ 0.20
b1905.7	Lanexa 115 kV work	Dominion	\$ 0.13
b1905.8	Surry 230 kV work	Dominion	\$ 0.13
b1905.9	Kings Mill, Peninmen, Toano, Waller, Warwick	Dominion	\$ 0.03
b1906.1	At Yadkin 500 kV, install six 500 kV breakers	Dominion	\$ 9.00
b1906.2	Install a 2nd 230/115 kV TX at Yadkin	Dominion	\$ 5.00
b1906.3	Install a 2nd 230/115 kV TX at Chesapeake	Dominion	\$ 5.00
b1906.4	Uprate Yadkin – Chesapeake 115 kV	Dominion	\$ 10.00
b1906.5	Install a third 500/230 kV TX at Yadkin	Dominion	\$ 16.00
b1907	Install a 3rd 500/230 kV TX at Clover	Dominion	\$ 16.00

Upgrade ID	Project Description	Transmission Owner	Cost Estimate
b1908	Rebuild Lexington – Dooms 500 kV	Dominion	\$ 120.00
b1909	Upgrade Bremon – Midlothian 230 kV to its maximum operating temperature	Dominion	\$ 10.00
b1910	Build a Suffolk – Yadkin 230 kV line (14 miles) and install 4 breakers	Dominion	\$ 40.00
b1911	Add a second Valley 500/230 kV TX	Dominion	\$ 16.00
b1912	Install a 500 MVAR SVC at Landstown 230 kV	Dominion	\$ 60.00
b2003	Construct a Whippany to Montville 230 kV line (6.4 miles)	JCPL	\$ 37.50
b1999	Replace limiting wave trap, circuit breaker, substation conductor, relay and current transformer components at Northwood	ME	\$ 0.90
b2000	Replace limiting wave trap on the Glendon - Hosensack line	ME	\$ 0.05
b2001	Replace limiting circuit breaker and substation conductor transformer components at Portland 230kV	ME	\$ 0.40
b2002	Northwood 230/115 kV Transformer upgrade	ME	\$ 4.00
b1943	Construct a 115 kV ring bus at Claysburg Substation. Bedford North and Saxton lines will no longer share a common breaker	PENELEC	\$ 5.25
b1944	Reconductor Eclipse substation 115 kV bus with 1033 kcmil conductor.	PENELEC	\$ 0.15
b1945	Install second 230/115 kV autotransformer at Johnstown	PENELEC	\$ 4.50
b1966	Replace the 1200 Amp Line trap at Lewistown on the Raystown-Lewistown 230 kV line and replace substation conductor at Lewistown	PENELEC	\$ 0.15
b1967	Replace the Blairsville 138/115 kV transformer	PENELEC	\$ 4.20
b1990	Install a 25 MVAR 115 kV Capacitor at Grandview	PENELEC	\$ 0.90
b1991	Construct Farmers Valley 345/230 kV and 230/115 kV substation. Loop the Homer City-Stolle Road 345 kV line into Farmers Valley	PENELEC	\$ 29.50
b1992	Reconductor Cambria Slope-Summit 115kV with 795 ACSS Conductor	PENELEC	\$ 4.80
b1993	Relocate the Erie South 345 kV line terminal	PENELEC	\$ 13.00
b1994	Convert Lewis Run-Farmers Valley to 230 kV using 1033.5 ACSR conductor. Project to be completed in conjunction with new Farmers Valley 345/230 kV transformation	PENELEC	\$ 46.80
b1995	Change CT Ratio at Claysburg	PENELEC	\$ 0.00
b1996.1	Replace 600 Amp Disconnect Switches on Ridgeway-Whetstone 115 kV line with 1200 Amp Disconnects	PENELEC	\$ 0.50
b1996.2	Reconductor Ridgeway and Whetstone 115 kV Bus.	PENELEC	\$ 0.20
b1996.3	Replace Wave Trap at Ridgeway.	PENELEC	
b1996.4	Change CT Ratio at Ridgeway	PENELEC	
b1997	Replace 600 Amp Disconnect Switches on Dubois-Harvey Run-Whetstone 115 kV line with 1200 Amp Disconnects	PENELEC	\$ 0.20
b1998	Install a 75 MVAR 115 kV Capacitor at Shawville	PENELEC	\$ 1.50
b2008	Reconductor feeder 23032 and 23034 to high temp. conductor (10 miles)	PEPCO	\$ 16.00
b2004	Replace the CTs and switch in South Akron Bay 4 to increase the rating	PPL	\$ 0.53
b2005	Replace the CTs and switch in SAKR Bay 3 to increase the rating of the Millwood-South Akron 230 kV Line and of the rating in Bay 3	PPL	\$ 0.53
b2006	Install North Lancaster 500/230 kV substation	PPL	\$ 42.00
b2007	Install a 90 MVAR capacitor bank at the Frackville 230 kV Substation	PPL	\$ 3.00

Appendix: Baseline Cost Allocation

Upgrade ID	Description	Cost Estimate	Transmission Owner	Required IS Date
b1840	Install a new Buckhannon - Weston 138 kV line	\$ 17.50	APS	6/1/2016
b1906.2	Install a 2nd 230/115 kV TX at Yadkin	\$ 5.00	Dominion	6/1/2015
b1906.3	Install a 2nd 230/115 kV TX at Chesapeake	\$ 5.00	Dominion	6/1/2015
b1906.4	Upgrade Yadkin - Chesapeake 115 kV	\$ 10.00	Dominion	6/1/2015
b1906.5	Install a third 500/230 kV TX at Yadkin	\$ 16.00	Dominion	6/1/2016
b1910	Build a Suffolk - Yadkin 230 kV line (14 miles) and install 4 breakers	\$ 40.00	Dominion	6/1/2016
b1913	Convert Eastlake units 1, 2, 3, 4 and 5 to synchronous condensers	\$ 100.00	ATSI	6/1/2015
b1914	Convert Lakeshore 18 to a synchronous condenser	\$ 20.00	ATSI	6/1/2015
b1915	Install a 50 MVAR capacitor bank at the Maclean 138 kV station	\$ 3.00	ATSI	6/1/2013
b1916	Install a 345/138 kV transformer at the Inland Q-11 station	\$ 7.20	ATSI	6/1/2013
b1917	Install a 138 kV circuit breaker at the Inland Q-11 station	\$ 0.90	ATSI	6/1/2013
b1918	Upgrade terminal equipment on the Avon - Crestwood 138 kV line	\$ 0.30	ATSI	6/1/2013
b1919	Re-conductor the Gallion - Leaside 138 kV line with 336 ACSS	\$ 4.90	ATSI	6/1/2014
b1921	Install a 2nd 345/138 kV transformer at the Allen Junction station	\$ 7.20	ATSI	6/1/2014
b1922	Install a 2nd 345/138 kV transformer at the Bayshore station	\$ 7.20	ATSI	6/1/2014
b1923	Create a new Northfield Area 345 kV switching station by looping in	\$ 37.50	ATSI	6/1/2015
b1924	Build a new Mansfield - Northfield Area 345 kV line	\$ 184.50	ATSI	6/1/2015
b1925	Create a new Harmon 345/138/69 kV substation by looping in the Star	\$ 46.00	ATSI	6/1/2015
b1926	Build a new Harmon - Brookside + Harmon - Longview 138 kV line	\$ 9.20	ATSI	6/1/2015
b1927	Create a new Five Points Area 345/138 kV substation by looping in	\$ 30.00	ATSI	6/1/2015
b1928	Install a 50 MVAR capacitor at Hayes 138 kV	\$ 1.50	ATSI	6/1/2015
b1929	Install a 138/69 kV transformer at the Avery station	\$ 3.20	ATSI	6/1/2015
b1930	Increase design temperature limitation on the Avery - Hayes 138 kV	\$ 0.13	ATSI	6/1/2015
b1931	Reconductor Cloverdale - Harmon #2 and #3 138 kV lines with 795	\$ 3.60	ATSI	6/1/2015
b1932	Change the transformer tap settings on the Maclean 138/69 kV	\$ 0.05	ATSI	6/1/2015
b1933	Replace 336.4 ACSR SCCIR at Richland to upgrade the Richland -	\$ 0.04	ATSI	6/1/2015
b1934	Build a new 345/138 kV Substation at Niles	\$ 32.00	ATSI	6/1/2015
b1934.1	Loop 1.2 miles of 345 kV into substation of the Highland - Shenango		ATSI	6/1/2015
b1934.2	New 345/138 kV transformer at Niles		ATSI	6/1/2015
b1936	Build new Allen Jct - Midway - Lemoyne 345 kV line (48 miles of open	\$ 86.30	ATSI	6/1/2016
b1937	Build a new Leroy Center 345/138 kV substation by looping in the	\$ 46.00	ATSI	6/1/2016
b1938	Place a portion of the 138 kV Leroy Center 345/138 kV project into	\$ 3.30	ATSI	6/1/2015
b1939	Reconductor the Barberton - West Akron 138 kV line with 477 ACSS	\$ 4.23	ATSI	6/1/2016
b1942	Change the CT ratio at Millville to improve the Millville - Old Chapel 138	\$ 0.05	APS	6/1/2015
b1943	Construct a 115 kV ring bus at Claysburg Substation. Bedford North	\$ 5.25	PENELEC	6/1/2015
b1944	Reconductor Eclipse substation 115 kV bus with 1033 kcmil	\$ 0.15	PENELEC	6/1/2013
b1945	Install second 230/115 kV autotransformer at Johnstown	\$ 4.50	PENELEC	6/1/2015
b1946	Perform a sag study on the Brues - West Bellaire 138 kV line	\$ 0.03	AEP	12/1/2014
b1947	A sag study of the Dequine - Meadowlake 345 kV line #1 line may improve the emergency rating to 1400 MVA	\$ 0.01	AEP	12/1/2013
b1949	Perform a sag study on the Grant Tap - Deer Creek 138 kV line and replace bus and risers at Deer Creek station	\$ 0.30	AEP	12/1/2014

Upgrade ID	Description	Cost Estimate	Transmission Owner	Required IS Date
b1950	Perform a sag study on the Kammer – Ormet 138 kV line of the conductor section	\$ 0.10	AEP	12/1/2012
b1951	Perform a sag study of the Maddox- Convoy 345 kV line to improve the emergency rating to 1400 MVA	\$ 0.03	AEP	12/1/2013
b1952	Perform a sag study of the Maddox – T130 345 kV line to improve the emergency rating to 1400 MVA	\$ 0.03	AEP	12/1/2013
b1953	Perform a sag study of the Meadowlake - Olive 345 kV line to improve the emergency rating to 1400 MVA	\$ 0.06	AEP	12/1/2013
b1954	Perform a sag study on the Milan - Harper 138 kV line and replace bus and switches at Milan Switch station	\$ 0.35	AEP	12/1/2014
b1955	Perform a sag study of the R-049 - Tillman 138 kV line may improve the emergency rating to 245 MVA	\$ 0.25	AEP	12/1/2014
b1956	Perform a sag study of the Tillman - Dawkins 138 kV line may improve the emergency rating to 245 MVA	\$ 0.25	AEP	12/1/2013
b1958	Perform a sag study on the Brookside - Howard 138 kV line and replace bus and risers at AEP Howard station	\$ 0.50	AEP	12/1/2014
b1960	Sag Study on 7.2 miles SE Canton-Canton Central 138kV ckt	\$ 0.30	AEP	12/1/2012
b1961	Sag study on the Southeast Canton – Sunnyside 138kV line	\$ 0.25	AEP	12/1/2012
b1963	Build approximately 1 mile of circuit comprising of 2-954 ACSR to get the rating of Waterford-Muskinum 345 kV higher	\$ 3.50	AEP	12/1/2013
b1965	Install a 44 MVAR 138 kV capacitor at Luxor substation	\$ 1.50	APS	6/1/2014
b1966	Replace the 1200 Amp Line trap at Lewistown on the Raystown-	\$ 0.15	PENELEC	12/1/2013
b1967	Replace the Blairsville 138/115 kV transformer	\$ 4.20	PENELEC	6/1/2014
b1968	Establish operating procedure such that breaker 89, connecting	\$ -	DL	6/1/2012
b1971	Perform a sag study to improve the emergency rating on the Bridgville – Chandlersville 138 kV line	\$ 0.05	AEP	12/1/2014
b1972	Replace disconnect switch on the South Canton 765/345 kV transformer	\$ 0.30	AEP	12/1/2014
b1973	Perform a sag study to improve the emergency rating on the Carrollton – Sunnyside 138 kV line	\$ 0.05	AEP	12/1/2014
b1974	Perform a sag study to improve the emergency rating on the Bethel Church – West Dover 138 kV line	\$ 0.03	AEP	12/1/2014
b1975	Replace a switch at South Millersburg switch station	\$ 0.20	AEP	12/1/2014
b1978	Reconductor Inland – Clinic Health Q-11 138 kV line	\$ 1.10	ATSI	6/1/2015
b1981	Replace relay on the Highland – G689 138 kV line	\$ 0.05	ATSI	12/31/2012
b1982	Reconductor the Hoytdale – Newcastle 138 kV lines #1 and #2 with	\$ 4.80	ATSI	6/1/2015
b1983	Add 150 MVAR SVC and a 100 MVAR capacitor at New Castle	\$ 31.70	ATSI	6/1/2015
b1984	Install a 50 MVAR capacitor at the Boardman 138 kV bus	\$ 1.70	ATSI	6/1/2015
b1985	Upgrade the Duquesne portion of the Elrama – Mitchell 138 kV line	TBD	DL	4/16/2015
b1986	Upgrade the AP portion of the Elrama – Mitchell 138 kV line by replace	\$ 0.05	APS	6/1/2015
b1987	Reconductor the Osage-Collins Ferry 138 kV line with 795 ACSS.	\$ 1.80	APS	6/1/2015
b1988	Raise structures between Lake Lynn and West Run to eliminate the	\$ 0.32	APS	6/1/2015
b1989	Raise structures between Collins Ferry and West Run to eliminate the	\$ 0.32	APS	6/1/2015

Upgrade ID	Description	Cost Estimate	Transmission Owner	Required IS Date
b1990	Install a 25 MVAR 115 kV Capacitor at Grandview	\$ 0.90	PENELEC	6/1/2015
b1991	Construct Farmers Valley 345/230 kV and 230/115 kV substation.	\$ 29.50	PENELEC	6/1/2015
b1992	Reconductor Cambria Slope-Summit 115kV with 795 ACSS Conductor	\$ 4.80	PENELEC	6/1/2015
b1995	Change CT Ratio at Claysburg	\$ 0.00	PENELEC	6/1/2015
b1996.1	Replace 600 Amp Disconnect Switches on Ridgeway-Whetstone 115	\$ 0.50	PENELEC	6/1/2015
b1996.2	Reconductor Ridgeway and Whetstone 115 kV Bus.	\$ 0.20	PENELEC	6/1/2015
b1996.3	Replace Wave Trap at Ridgway.		PENELEC	6/1/2015
b1996.4	Change CT Ratio at Ridgway		PENELEC	6/1/2015
b1997	Replace 600 Amp Disconnect Switches on Dubois-Harvey Run-	\$ 0.20	PENELEC	6/1/2015
b1998	Install a 75 MVAR 115 kV Capacitor at Shawville	\$ 1.50	PENELEC	6/1/2015
b1999	Replace limiting wave trap, circuit breaker, substation conductor,	\$ 0.90	ME	6/1/2015
b2000	Replace limiting wave trap on the Glendon - Hosensack line	\$ 0.05	ME	6/1/2015
b2001	Replace limiting circuit breaker and substation conductor transformer	\$ 0.40	ME	6/1/2015
b2002	Northwood 230/115 kV Transformer upgrade	\$ 4.00	ME	6/1/2015
b2003	Construct a Whippany to Montville 230 kV line (6.4 miles)	\$ 37.50	JCPL	6/1/2015
b2004	Replace the CTs and switch in South Akron Bay 4 to increase the	\$ 0.53	PPL	6/1/2014
b2005	Replace the CTs and switch in SAKR Bay 3 to increase the rating of	\$ 0.53	PPL	6/1/2014
b2007	Install a 90 MVAR capacitor bank at the Frackville 230 kV Substation	\$ 3.00	PPL	6/1/2015

Upgrade ID	Description	Multi-Zone Cost Allocation	Required IS Date
b1905.1	Surry to Skiffes Creek 500 kV Line (7 miles overhead)	AEC - 1.83%, AEP - 15.12%, APS - 5.53%, ATSI - 8.65%, BGE - 4.46%, ComEd - 14.64%, ConEd - 0.55%, Dayton - 2.21%, DL - 1.85%, DPL - 2.61%, Dominion - 12.38%, ECP - 0.19%, JCPL - 4.07%, ME - 1.92%, Neptune - 0.41%, PECO - 5.54%, PENELEC - 1.93%, PEPCO - 4.33%, PPL - 4.77%, PSEG - 6.74%, RE - 0.27%,	6/1/2015
b1905.2	Surry 500 kV Station Work	AEC - 1.83%, AEP - 15.12%, APS - 5.53%, ATSI - 8.65%, BGE - 4.46%, ComEd - 14.64%, ConEd - 0.55%, Dayton - 2.21%, DL - 1.85%, DPL - 2.61%, Dominion - 12.38%, ECP - 0.19%, JCPL - 4.07%, ME - 1.92%, Neptune - 0.41%, PECO - 5.54%, PENELEC - 1.93%, PEPCO - 4.33%, PPL - 4.77%, PSEG - 6.74%, RE - 0.27%,	6/1/2015
b1905.3	Skiffes Creek 500-230 kV Tx and Switching Station	Dominion - 99.84%, PEPCO - 0.16%,	6/1/2015
b1905.4	New Skiffes Creek - Wheaton 230 kV line	Dominion - 99.84%, PEPCO - 0.16%,	6/1/2016
b1905.5	Wheaton 230 kV breakers	Dominion - 99.84%, PEPCO - 0.16%,	6/1/2016
b1905.6	Yorktown 230 kV work	Dominion - 99.84%, PEPCO - 0.16%,	6/1/2016
b1905.7	Lanexa 115 kV work	Dominion - 99.84%, PEPCO - 0.16%,	6/1/2016
b1905.8	Surry 230 kV work	Dominion - 99.84%, PEPCO - 0.16%,	6/1/2016
b1905.9	Kings Mill, Peninmen, Toano, Waller, Warwick	Dominion - 99.84%, PEPCO - 0.16%,	6/1/2016
b1906.1	At Yadkin 500 kV, install six 500 kV breakers	AEC - 1.83%, AEP - 15.12%, APS - 5.53%, ATSI - 8.65%, BGE - 4.46%, ComEd - 14.64%, ConEd - 0.55%, Dayton - 2.21%, DL - 1.85%, DPL - 2.61%, Dominion - 12.38%, ECP - 0.19%, JCPL - 4.07%, ME - 1.92%, Neptune - 0.41%, PECO - 5.54%, PENELEC - 1.93%, PEPCO - 4.33%, PPL - 4.77%, PSEG - 6.74%, RE - 0.27%,	6/1/2016
b1907	Install a 3rd 500/230 kV TX at Clover	APS - 5.83%, BGE - 4.74%, Dominion - 81.79%, PEPCO - 7.64%,	6/1/2016

Upgrade ID	Description	Multi-Zone Cost Allocation	Required IS Date
b1908	Rebuild Lexington – Doods 500 kV	AEC - 1.83%, AEP - 15.12%, APS - 5.53%, ATSI - 8.65%, BGE - 4.46%, ComEd - 14.64%, ConEd - 0.55%, Dayton - 2.21%, DL - 1.85%, DPL - 2.61%, Dominion - 12.38%, ECP - 0.19%, JCPL - 4.07%, ME - 1.92%, Neptune - 0.41%, PECO - 5.54%, PENELEC - 1.93%, PEPCO - 4.33%, PPL - 4.77%, PSEG - 6.74%, RE - 0.27%,	6/1/2016
b1909	Uprate Brems – Midlothian 230 kV to its maximum operating temperature	APS - 6.31%, BGE - 3.81%, Dominion - 81.9%, PEPCO - 7.98%,	6/1/2016
b1911	Add a second Valley 500/230 kV TX	APS - 14.85%, BGE - 3.1%, Dominion - 74.12%, PEPCO - 7.93%,	6/1/2016
b1912	Install a 500 MVAR SVC at Landstown 230 kV	DEOK - 0.46%, Dominion - 99.54%,	6/1/2016
b1920	Re-conductor the Galion – GM Mansfield – Ontario - Cairns 138 kV line with 477 ACSS	ATSI - 94.47%, DL - 2.9%, PENELEC - 2.63%,	6/1/2014
b1935	ATSI-AEP 138 kV Substation on near territory border + 138 kV from new substation to Longview approx. 8 miles	ATSI - 94.9%, DL - 2.97%, PENELEC - 2.13%,	
b1941	Loop the Homer City-Handsome Lake 345 kV line into the Armstrong substation and install a 345/138 kV transformer at Armstrong	APS - 67.86%, PENELEC - 32.14%,	6/1/2014
b1948	Establish a new 765/345 interconnection at Sporn. Install a 765/345 kV transformer at Mountaineer and build ¾ mile of 345 kV to Sporn	ATSI - 61.08%, DL - 21.87%, Dominion - 13.97%, PENELEC - 3.08%,	6/1/2015
b1957	Terminate Transformer #2 at SW Lima in a new bay position	AEP - 69.41%, ATSI - 23.11%, ECP - 0.17%, HTP - 0.19%, PENELEC - 2.42%, PSEG - 4.52%, RE - 0.18%,	12/1/2014
b1959	Build a new West Fremont-Groton-Hayes 138kV line	APS - 4.24%, ATSI - 87.76%, DL - 4.27%, PENELEC - 3.73%,	6/1/2018

Upgrade ID	Description	Multi-Zone Cost Allocation	Required IS Date
b1962	Add four 765 kV breakers at Kammer	AEC - 1.83%, AEP - 15.12%, APS - 5.53%, ATSI - 8.65%, BGE - 4.46%, ComEd - 14.64%, ConEd - 0.55%, Dayton - 2.21%, DL - 1.85%, DPL - 2.61%, Dominion - 12.38%, ECP - 0.19%, JCPL - 4.07%, ME - 1.92%, Neptune - 0.41%, PECO - 5.54%, PENELEC - 1.93%, PEPCO - 4.33%, PPL - 4.77%, PSEG - 6.74%, RE - 0.27%,	6/1/2015
b1964	Convert Moshannon substation to a 4 breaker 230 kV ring bus	APS - 41.06%, DPL - 6.68%, JCPL - 5.48%, ME - 10.7%, Neptune - 0.53%, PECO - 15.53%, PPL - 20.02%,	6/1/2014
b1969	Install a third 345-138 kV autotransformer at Collier Substation. Currently s0321 and will be converted to baseline.	APS - 18.69%, DL - 81.31%,	6/1/2013
b1970	Reconductor 13 miles of the Kammer – West Bellaire 345kV circuit	APS - 33.51%, ATSI - 32.21%, DL - 18.64%, Dominion - 6.01%, ECP - 0.1%, HTP - 0.11%, JCPL - 1.68%, Neptune - 0.18%, PENELEC - 4.58%, PSEG - 2.87%, RE - 0.11%,	6/1/2014
b1976	Reconductor ATSI portion of South Canton – Harmon 345 kV line	ATSI - 88.77%, ECP - 0.12%, HTP - 0.14%, JCPL - 1.24%, Neptune - 0.13%, PENELEC - 6.54%, PSEG - 2.94%, RE - 0.12%,	6/1/2015
b1977	Build new Toronto 345/138 kV substation by looping in the Sammis – Wylie Ridge 345 kV line and tie in four 138 kV lines	APS - 7%, ATSI - 88.14%, DL - 0.81%, PENELEC - 4.05%,	6/1/2017
b1977.1	Build a new Toronto-Harmon 345kV line	APS - 7%, ATSI - 88.14%, DL - 0.81%, PENELEC - 4.05%,	6/1/2017
b1993	Relocate the Erie South 345 kV line terminal	APS - 10.09%, ECP - 0.45%, HTP - 0.49%, JCPL - 5.14%, Neptune - 0.54%, PENELEC - 70.71%, PSEG - 12.1%, RE - 0.48%,	6/1/2015
b1994	Convert Lewis Run-Farmers Valley to 230 kV using 1033.5 ACSR conductor. Project to be completed in conjunction with new Farmers Valley 345/230 kV transformation	APS - 33.2%, ECP - 0.44%, HTP - 0.44%, JCPL - 8.64%, ME - 5.52%, Neptune - 0.86%, PENELEC - 36.81%, PSEG - 13.55%, RE - 0.54%,	6/1/2015
b2006	Install North Lancaster 500/230 kV substation	AEC - 1.1%, ECP - 0.37%, HTP - 0.37%, JCPL - 9.61%, ME - 19.42%, Neptune - 0.75%, PECO - 6.01%, PPL - 50.57%, PSEG - 11.35%, RE - 0.45%,	6/1/2017
b2008	Reconductor feeder 23032 and 23034 to high temp. conductor (10 miles)	BGE - 33.05%, DPL - 1.38%, PECO - 1.35%, PEPCO - 64.22%,	6/1/2015

Transmission Expansion Advisory Committee

May 10, 2012

Issues Tracking

- Open Issues
 - None
- New Issues

Interregional Planning Update

- March 30 IPSAC Webex
 - Market efficiency modeling / benchmarking
 - Environmental regulation impact review
 - Draft NCSP
 - PJM / NYISO short circuit study
 - Redlined Northeast Protocol posted for comment
 - PJM / NYISO initial discussions – PJM RTEP upgrades on border in PN area
 - Continued market efficiency model improvements

- Weekly communication developing a joint MISO/PJM market efficiency model
 - PJM/MISO protocol study 2nd half 2012
- PJM review of MISO 2011 cross-border work – results consistent with MISO
 - Wheatland - Breed 345kV (AEP - IPL)
 - Albers - Kenosha 138kV (WEC)
 - Burr Oak 345/138kV (NIPS)
 - Granville – Butler 138kV (WEC)
- PJM review of MISO MVP wind impacts

- Joint off-shore wind reliability analysis
 - 6 month timeline
 - 3 off shore injection scenarios into Dominion and NC POI
 - 3 GW, 5 GW, 10 GW
 - Dominion, Morehead City, Southport
 - 2027 60% load level
 - Thermal and voltage
 - Identify upgrades as necessary

Generation Deactivation Notification (Retirements) Update



Unit	Trans Zone	Requested Deactivation Date	PJM Reliability Status
Chesapeake 1 & 2, Yorktown 1	DOM	12/31/2014	Reliability Analysis complete. Impacts identified. Upgrades expected to be completed by June 2015.
Chesapeake 3 & 4	DOM	12/31/2015	Reliability Analysis complete. Impacts identified. Upgrades expected to be completed by June 2016.
Bergen 3; Burlington 8; National Park 1; Mercer 3; Sewaren 6	PSEG	6/1/2015	Reliability Analysis Complete. Impacts identified and expected to be resolved in three - four years. Working with affected TO to finalize upgrade schedule.
Armstrong 1 & 2; Ashtabula 5; Bayshore 2-4; Eastlake 1-5; Lake Shore 18; R Paul Smith 3 & 4;	AP	9/1/2012	Reliability analysis complete. Impacts identified and expected to be resolved by June 2016. Further refinement of the reliability analysis, required upgrades, and generator deactivation schedule continues. Unit will deactivate as scheduled. See posting - FE Generator Deactivation Study Results and Required Upgrades.
Walter C Beckjord 1	DEOK	5/1/2012	Reliability Analysis complete - no impacts identified.
Walter C Beckjord 2-6	DEOK	4/1/2015	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by June 2014
Albright 1-3; Rivesville 5 & 6; Willow Island 1 & 2	APS	9/1/2012	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by May 2013. Thus generator can be allowed to deactivate as scheduled on 9/1/2012 assuming all upgrades are still on track to be completed as scheduled.
New Castle 3-5; New Castle Diesels A & B	ATSI	4/16/2015	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by June 2015. Thus generator can be allowed to deactivate as scheduled.

Unit	Trans Zone	Requested Deactivation Date	PJM Reliability Status
Portland 1 & 2; Glen Gardner CT 1-8	MetEd	1/7/2015	Reliability Analysis complete - impacts identified - upgrades and operating procedures expected to be in place by May 2015 to allow generators to deactivate as scheduled.
Elrama 1-4	DUQ	6/1/2012	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by June 2014. Evaluating options.
Shawville 1-4; Titus 1-3	PenElec	4/16/2015	Reliability Analysis complete - impacts identified - upgrades and operating procedures expected to be in place by May 2015 to allow generators to deactivate as scheduled.
Niles 1 & 2	ATSI	6/1/2012	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by June 2014. Evaluating options.
Fisk Street 19, Crawford 7 & 8	ComEd	12/31/2012	Reliability Analysis Complete. No impacts identified.
Conesville 3	AEP	12/31/2012	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by June 2014. PJM continues to finalize details of required upgrades and completion dates.
Big Sandy 1; Clinch River 3; Glen Lyn 5 & 6; Kammer 1-3; Kanawha River 1 & 2; Muskingum River 1-4; Pickway 5; Sporn 1-4; Tanner Creek 1-3	AEP	6/1/2015	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by June 2015.

Unit	Trans Zone	Requested Deactivation Date	PJM Reliability Status
Avon Lake 7 & 9	ATSI	4/16/2015	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by May 2015
Sewaren 1-4	PSEG	6/1/2015	Reliability Analysis complete. No impacts expected with PSEG contemplating re-use of Capacity Rights for a new generation project
Cedar 1 & 2; Deepwater 1 & 6; Missouri Ave CT B, C & D	AE	5/31/2015	Reliability Analysis complete - impacts identified - upgrades scheduled to be completed by May 2015
Hutchings 1 & 2	Dayton	6/1/2015	Reliability Analysis underway

AEP Retirement Notifications

Conesville 3

Requested deactivation date: 12/31/2012

Big Sandy 1; Clinch River 3; Glen Lyn 5 & 6; Kammer 1-3;
Kanawha River 1 & 2; Muskingum River 1-4; Pickway 5;
Sporn 1-4; Tanner Creek 1-3

Requested deactivation date: 6/1/2015


AEP assumptions

Assumptions:

- Mountaineer 765/345 kV transformer in service (b1948)
- (4) 765 kV breakers installed at Kammer (b1962)

Both also identified for previous deactivation studies


AEP Transmission Zone




- Overload on Waterford – Muskingum River 345 kV line in generation deliverability and N-1-1 analysis involving a combination of outages including loss of Belmont – Kammer 765 kV and/or Marysville – Flatlick 765 kV line
- Proposed Solution: Reconductor or rebuild Sporn – Waterford – Muskingum River 345 kV line
- Estimated Project Cost: \$200M
- Expected in-service date: 6/1/2015

AEP Transmission Zone

- Overload on Don Marquis 345/138 kV #2 transformer for the loss of Don Marquis 345/138 kV #1 transformer and Don Marquis – North Fork 345 kV line.
- Proposed Solution: Loop Conesville – Bixby 345 kV Circuit into Ohio Central
- Estimated Project Cost: \$15M
- Expected in-service date: 6/1/2015




AEP Transmission Zone




- Address several overloads for various contingencies under generation deliverability and N-1-1 analysis including:
 - West Bellaire – Brues 138 kV line
 - Brues – Brues 2 138 kV line section
 - Bethlehem – County Line 138 kV line
 - Belpre – Degussa 138 kV line
 - Natirum – George Washington 138 kV line
 - Newcomerstown – South Coshocton
- Proposed Solution: Establish Burger 345/138 kV station
- Estimated Project Cost: \$35M
- Expected in-service date: 6/1/2015

AEP Transmission Zone



- Address several overloads for various contingencies under generation deliverability and N-1-1 analysis including:
 - Carbondale – Carbondale Tap 138 kV
 - Amos – Dalewood 138 kV
 - Chemical #1 – Orin 138 kV
 - Amos – Poca 138 kV
 - Chemical #1 – Orin 138 kV
 - Amos – Tackett Creek 138 kV
 - Cabin Creek – South Ridge 138 kV
 - Capitol – Chemical #2
 - Amos – Turner #2
- Proposed Solution: Rebuild Amos – Kanawha River 138 kV corridor
- Estimated Project Cost: \$150M
- Expected in-service date: 6/1/2015


AEP Transmission Zone



- Address overload on existing:
 - Muskingum River 345/138 kV transformers
 - Kanawha River 345/138 kV transformers
 - North Crown City – Thiven 138 kV
 - Addison – Thiven 138 kV
 - North Crown City – Windsor 138 kV
- Proposed Solution: Add 345/138 kV Transformer at Sporn, Kanawha River & Muskingum River stations
- Estimated Project Cost: \$30M
- Expected in-service date: 6/1/2015


AEP Transmission Zone

- Address overload on Tri State – Darrah 138 kV, and Tri State – Kenova 138 kV lines for N-1-1 analysis. Also, addresses overload on Tri State – Chadwick 138 kV for generation deliverability analysis.
- Proposed Solution: Terminate Tristate – Kyger Creek 345 kV line at Sporn
- Estimated Project Cost: \$10M
- Expected in-service date: 6/1/2015




AEP Transmission Zone

- Hillview - Newcomerstown 138 kV line loads to 101.1% of its rating of 191 MVA for the single contingency '05KAMMER-05SCANTO-05SCANTE-765-345' followed by 'BASE CASE'
- Proposed Solution: Advance existing baseline project B1737 (Sag study of Newcomerstown - Hillview 138 kV line and upgrade terminal equipment)
- Estimated Project Cost: \$0.2M
- Expected in-service date: 12/31/2012




AEP Transmission Zone

- Ohio Central - Prep Plant Tap 138 kV line loads to 101.7% of its rating of 446 MVA for the single contingency '05KAMMER-05SCANTO-05SCANTE-765-345' followed by '02GALION-05OHIOCT-05MUSKNG-05OH-345-1N2'
- Proposed Solution: Advance existing baseline project B1474 (Perform a sag study on the Ohio Central – Prep Plant tap 138 kV circuit)
- Estimated Project Cost: \$0.04
- Expected in-service date: 12/31/2012




AEP Transmission Zone



- Prep Plant Tap - Conesville East 138 kV line loads to 101.7% of its rating of 446 MVA for the single contingency of Kammer – South Canton 765 kV facility and associated equipment followed by '02GALION-05OHIOCT-05MUSKNG-05OH-345-1N2'
- Proposed Solution: Advance existing baseline project B1502 (Reconductor the Conesville East – Conesville Prep Plant Tap 138 kV section of the Conesville – Ohio Central)
- Estimated Project Cost: \$2M

AEP Transmission Zone

- Cross Street - Madison 138 kV line loads to 105.6% of its rating of 167 MVA for the single contingency of Rockport – Jefferson 765 kV followed by the Desoto 345/138 kV transformer
- Proposed Solution: Advance existing baseline project B1039 (Perform a sag study for the Madison – Cross Street 138 kV line)
- Estimated Project Cost: \$0.15
- Expected in service date:




Generation Deactivation Notification (Retirements) Update

Titus




- The Cartech – Riverview 69kV circuit # 1 overloads for the loss of North Temple – Rosedale 69 KV
- Proposed Solution: Construct a new North Temple - Riverview - Cartech 69 kV line (4.7 miles) with 795 ACSR
- Estimated cost: \$4.815M
- Expected in-service date: 6/1/2015





- North Temple – Rosedale 69 kV ck 1 overloads for the loss of North Temple – Riverview 69 KV
- Proposed Solution: Construct a new North Temple - Riverview - Cartech 69 kV line (4.7 miles) with 795 ACSR
- Estimated cost: \$4.815M
- Expected in-service date: 6/1/2015






MetEd Transmission Zone

Attachment N

- Middletown Jct - Swatra Hill 69kV ck 1 overloads for the loss of Wood Street Tap – Middletown 69 KV
- Proposed Solution:
Upgrade 4/0 and 350 Cu substation conductors at the Middletown Junction terminal of the Middletown Junction - Swatara Hill 69 kV line
- Estimated cost: TBD
- Expected in-service date: 6/1/2014






MetEd Transmission Zone


Attachment N

- Wood Street Tap – Middletown 69kV ck 1 overloads for the loss of Middletown Jct - Swatra Hill 69 KV
- Proposed Solution: Upgrade 4/0 Cu substation conductor at the Middletown terminal of the Middletown - Wood Street Tap 69 kV substation
- Estimated cost: \$0.0312M
- Expected in-service date: 6/1/2014






- Muhlenburg –
Rosedale 69kV ck 1
overloads for the loss
of North Temple -
Riverview 69 KV
- Proposed Solution:
Construct a new North
Temple - Riverview -
Cartech 69 kV line (4.7
miles) with 795 ACSR.
- Estimated cost: TBD
- Expected in-service
date: 6/1/2015



- Baldy - Lyons 69kV ckt 1 overloads for the loss of East Topton - Lyons 69 KV
- Proposed Solution: Upgrade an OC protection relay at the Baldy 69 kV substation.
- Estimated cost: \$0.0537M
- Expected in-service date: 6/1/2014




Generation Deactivation Notification (Retirements) Update

Avon

(All under review)

- Howard to Brookside 138 kV line overloaded for tower contingency 'C5-TWL-CR040'
- Proposed Solution: Perform a sag study and replace bus and risers at AEP Howard station.
- Expected cost is \$0.5M
- Projected in-service is 12/01/2014.






AEP Transmission Zone


Attachment N

- West Coshocton to Buckhorn (Holmes-Wayne Co-Op) 138 kV line overloads for breaker contingency '1913_C2'
- Proposed Solution: Loop Conesville – Bixby 345 kV circuit into Ohio Central station.
- Expected cost is \$15 M
- Projected in-service is 06/01/2015.



- Waterford to Muskingum River 345 kV line overloads for breaker contingency '2856_C2'
- Proposed Solution: Reconductor or rebuild Sporn – Waterford – Muskingum River 345 kV line
- Estimated Project Cost: \$200M
- In-service date: 06/01/2015

(Previously identified for Conesville 3; Big Sandy 1; Clinch River 3; Glen Lyn 5 & 6; Kammer 1-3; Kanawha River 1 & 2; Muskingum River 1-4; Pickway 5; Sporn 1-4; Tanner Creek 1-3







AEP Transmission Zone

Attachment N


- East Lima to North Woodcock 138 kV line overload for the line with stuck breaker contingency 3141_C2_05FOSTOR 345-B2
- Proposed Solution: Perform a sag study to improve the rating
- Expected cost is \$25k
- Projected in-service is 12/01/2014.




- Bluebell - Canton Central 138 kV line overloads for N-1-1: B_LINE_SY_48A (S.Canton-Harmon 345kV) + B_LINE_SY_043 (Canton Central-Hanna 345kV)
- Proposed Solution: Sag study to improve the rating of the line
- Expected AEP cost is \$25k
- Projected in-service is 12/01/2014.




- Kammer to W.Bellaire 138 kV line overloads for N-1-1: 05KAMMER_05SCANTO_116 + 53_B3
- Proposed Solution: Install 345 kV circuit breakers at West Bellaire
- Expected cost is \$5 million
- Projected in-service is 06/01/2015.





- Tilton to W. Bellaire 138 kV line overloads for N-1-1: 242946(05TIDD)-242948(05WBELLA)_1 + 05KAMMER_05SCANTO_116
- Proposed Solution: Sag Study on section 1 (795 ACSR) ~12 mi.
- Expected cost is \$50 k.
- Projected in-service is 12/01/2012.

- The Windsor to Tilton 138 kV line is normally overloaded for the loss of Tidd – West Bellaire 138 kV
- Proposed Solution: Advance Baseline project # B1457
- Expected cost is \$20 k
- Projected in-service is 12/01/2012.







AEP Transmission Zone

Attachment N


- Elliot Tap to Poston 138 kV line is normally overloaded for the loss of 37_B2_TOR12_WOM OP
- Proposed Solution: Rebuild 138 kV tap line
- Expected cost is \$8.7 million
- Projected in-service date: 12/31/2014



- Brues to W. Bellaire
138 kV line overloads
for N-1-1: 41_B3 +
242946(05TIDD)-
242948(05WBELLA)_
1
- Proposed Solution:
Perform a sag study
- Expected cost is \$20 k
- Projected in-service is
12/01/2012.




- Dale to W. Canton 138 kV line overloads for N-1-1:
B_LINE_SY_48A
(S.Canton-Harmon 345kV) + BASE CASE
- Proposed Solution:
Advance Baseline
project b1861
- Projected in-service is 06/01/2015.






- Dale to W. Canton 138 kV line overloads for N-1-1:
B_LINE_SY_48A (S.Canton-Harmon 345kV) + BASE CASE
- Proposed Solution: Build new Toronto 345/138 kV substation by looping in the Sammis – Wylie Ridge 345 kV line and tie in four 138 kV lines
- Estimated Project Cost: \$41.8M
- Projected in-service is 06/01/2015


(Previously identified for New Castle 3, 4, & 5; New Castle Diesels A & B)





- Tidd to Collier 345 kV line overloads for N-1-1: B_LINE_TIE_027 + B_LINE_TIE_013
- Proposed Solution: Perform sag study
- Estimated Project Cost: \$.05M
- Projected in-service is 06/01/2015.

- Johnson to Lorain 138 kV line overloads for breaker contingency
- Proposed Solution: Reconductor Johnson-Lorain 138kV with 954 ACSS + Replace wavetrapp
- Estimated cost: TBD
- Expected in-service date: 6/1/2015






ATSI Transmission Zone

Attachment N


- Lakeview to Greenfield 138 kV line overloads for tower contingency of Beaver-DB 345kV + DB-Hayes 345kV
- Proposed Solution: Build a new West Fremont-Groton-Hayes 138kV line
- Estimated Project Cost: \$45M
- Projected in-service date: 6/1/2018
- Short term: Existing Operating Procedure to open Lakeview-Greenfield from 6/1/2012 through 6/1/2018

(Previously identified for Niles 1 & 2;
Elrama 1, 2, 3 & 4)



- Howard to Brookside 138 kV line overloads for the tower contingency Beaver-Davies Bessie 345kV + Beaver-Davies Bessie -Hayes 345kV
- Proposed Solution: Existing ATSI-AEP 138kV Substation (Brubaker Sub) near territory border + 138kV from new substation to Longview approx. 8 miles + Requires AEP project to R/C Howard-Brubaker 138kV with 477 ACS
- Estimated Project Cost: \$17.7M
- Expected in-service date: 6/1/2016

(Previously identified for Armstrong 1 & 2; Ashtabula 5; Bayshore 2-4; Eastlake 1-5; Lake Shore 18; R Paul Smith 3 & 4; New Castle 3, 4, & 5; New Castle Diesels A & B)






ATSI Transmission Zone

Attachment N

- Barberton –W.Akron 138 kV line overloads for the tower contingency N.Medina-Star 345kV + Juniper-Star 345kV
- Proposed Solution: Reconductor Barberton-W.Akron 138kV (7.3mi 605 ACSR w/ 477 ACSS)
- Estimated Project Cost: \$4.23M
- Expected in-service date: 6/1/2016

(Previously identified for Armstrong 1 & 2; Ashtabula 5; Bayshore 2-4; Eastlake 1-5; Lake Shore 18; R Paul Smith 3 & 4)






ATSI Transmission Zone

Attachment N


- Pawnee Q-1 to Leroy Center overloads for the N-1-1 outage of Eastlake - Mayfield 138kV + Perry – Ashtabula - Erie West 345kV
- Proposed Solution: Existing project to accelerate a portion of already submitted Leroy Center 345-138kV Sub (2016) to (2015). Add (6) 138kV breakers + relaying at Leroy Center.
- Estimated Project Cost: \$3.3M
- Expected in-service date: 6/1/2015



(Previously identified for Armstrong 1 & 2; Ashtabula 5; Bayshore 2-4; Eastlake 1-5; Lake Shore 18; R Paul Smith 3 & 4)


- Kelsey-Hayes to Ottawa 138 kV line overloads for the breaker contingency Ottawa-W.Frem 138kV + Ottawa-Toussaint-Bayshore 138kV line
- Proposed Solution: Existing W.Fremont-Groton-Hayes 138kV + Operating Procedures until line is complete in 2018
- Estimated Project Cost: \$45M
- Projected in-service date: 6/1/2018
- Short term: Existing Operating Procedure to open Lakeview-Greenfield from 6/1/2012 through 6/1/2018

(Previously identified for Niles 1 & 2;
Elrama 1, 2, 3 & 4; Avon 7 & 9)



2012 RTEP Baseline Reliability Update

- Generator Deliverability thermal violation of either Chichester – Linwood 230 kV circuit for the loss of the parallel circuit
- Description: Add a 3rd 230kV transmission line between Chichester and Linwood substations and remove the Linwood SPS (B1900)
- Estimated Project Cost: \$27M
- Projected In-Service Date: 6/1/2018



2012 RTEP Scenario Analysis

- Renewable Portfolio Standards (RPS)
 - Update of capacity factors / input assumptions
 - Update of RPS nameplate
- At-Risk generation
- High load forecast

2012 RTEP Status Update

- Recent announcement
- EKPC included in the 2012 RTEP
- Expected integration: June 1, 2013

- **2013 Short Circuit Basecase**
 - TOs are currently reviewing the 2013 short circuit basecase and results
- **2017 Short Circuit Basecase**
 - The 2017 short circuit basecase will be available in mid-June
- **Resolution of 2016 basecase short issues is in progress**
 - Working w/ PSE&G regarding overdutied breakers that exceed 80kA

- 2016 Stability Cases Creation
 - 2016 Summer Peak and Summer Light Load stability cases will be available in mid-May
 - The 2016 Stability Cases are developed based on SDDWG 2010 series and 2016 RTEP case
- 2012 RTEP Baseline Stability Study
 - Study of 98 plants using 2016 stability cases
 - Analytical work begins mid-May and will end in September
- Sensitivity Stability Studies due to recent Generation Deactivation
 - Revisit several operating guidelines

Questions?

Email: RTEP@pjm.com

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

8/16/2012 1:48:41 PM

in

Case No(s). 12-0504-EL-FOR

Summary: Correspondence Supplement to the Ohio Edison Company, The Cleveland Electric Illuminating Company, The Toledo Edison Company and American Transmissions Systems, Inc. 2012 Electric Long-Term forecast report Part 10 of 11 - Attachments L-N electronically filed by Karen A Sweeney on behalf of Ohio Edison Company and The Cleveland Electric Illuminating Company and The Toledo Edison Company and American Transmissions Systems, Inc. and Eberts, Bradley D. Mr.