

## Alicia Liburdi

---

**To:** Bellamy, Mark  
**Subject:** RE: PUCO 12-2075-EL-REN ESS #1509 Sidney

Thanks,

Alicia Liburdi | Commercial Solar Incentives and Interconnections



[aliburdi@1stlightenergy.com](mailto:aliburdi@1stlightenergy.com)

3224 McHenry Ave, Suite F – Modesto, CA 95350

t. 209.824.5500, c. 209.482.0090, f. 209.824.5575 [www.1stlightenergy.com](http://www.1stlightenergy.com)

---

**From:** Bellamy, Mark [<mailto:Mark.Bellamy@puc.state.oh.us>]

**Sent:** Thursday, August 30, 2012 6:35 AM

**To:** Alicia Liburdi

**Subject:** PUCO 12-2075-EL-REN ESS #1509 Sidney

Dear Alicia Liburdi:

Hello. I am sending you questions related to the review of your Application for Certification as an Ohio Renewable Energy Resource Generating Facility. The responses to these questions will make it possible for Commission Staff to perform a comprehensive and timely review of your application. Please file your responses in the PUCO [Docketing Information System](#) under case number 12-2075-EL-REN. Feel free to copy and paste the questions into a word document, and save the file as a PDF, in order to provide your answers and/or photos for the purpose of e-filing the document.

Save the document as a PDF.

Then go to following website: <http://dis.puc.state.oh.us/>

Then

- Click on subscribe and e-file
- Log-in
- Click on E-File a document
- Choose your case number, add it, and click continue
- Choose the parties for the filing, and click continue
- Select type of document, Reply
- Complete the summary, click continue
- Choose your PDF document
- Add File, click continue
- Submit Filing

The application will be approved 60 days after the date the application and affidavit were submitted, unless it is suspended or denied by the commission, therefore please submit your responses within 5 business days to avoid the case being suspended. Make sure that you file/title your responses as 'reply to staff inquiries'. If you have any questions, please feel free to reply to this email or call (614)644-8295.

Thank you.

**Case No. 12-2075-EL-REN**  
**ESS #1509 Sidney**  
**Staff Interrogatories – Initial Set**

Question 1: In Section A of the application, the facility street address and the facility latitude and longitude are 28 miles apart. Please provide the correct facility street address and the facility latitude and longitude or explain why they are so far apart.

Answer 1: [40.30 / -84.17](#)

Question 2: In section I.1 the nameplate capacity is listed as 0.0495 MW. But in section G.4 you state the facility has 180 panels at 220 watts. Since  $180 \times 220W = 39600W$  or 0.0396 MW. Is the nameplate capacity 0.0396 MW?

Answer 2: [0.0396 MW](#)

Sincerely,

**Mark Bellamy**

Public Utilities Commission of Ohio  
Energy and Environment Department  
Environmental Specialist  
(614) 644-8295

[PUCO.ohio.gov](http://PUCO.ohio.gov)



This message and any response to it may constitute a public record and thus may be publicly available to anyone who requests it.

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**8/30/2012 12:01:56 PM**

**in**

**Case No(s). 12-2075-EL-REN**

Summary: Reply 12-2075 Reply to staff inquiry electronically filed by Mrs. Alicia M Liburdi on behalf of 1st Light Energy