



# Public Utilities Commission

Application to Commit  
Energy Efficiency/Peak Demand  
Reduction Programs  
(Mercantile Customers Only)

Case No.: 12-1828-EL-EEC

Mercantile Customer: Millcreek-West Unity Local Schools

Electric Utility: The Toledo Edison Company

Program Title or  
Description: New K-12

Rule 4901:1-39-05(F), Ohio Administrative Code (O.A.C.), permits a mercantile customer to file, either individually or jointly with an electric utility, an application to commit the customer's existing demand reduction, demand response, and energy efficiency programs for integration with the electric utility's programs. The following application form is to be used by mercantile customers, either individually or jointly with their electric utility, to apply for commitment of such programs in accordance with the Commission's pilot program established in Case No. [10-834-EL-POR](#)

Completed applications requesting the cash rebate reasonable arrangement option (Option 1) in lieu of an exemption from the electric utility's energy efficiency and demand reduction (EEDR) rider will be automatically approved on the sixty-first calendar day after filing, unless the Commission, or an attorney examiner, suspends or denies the application prior to that time. Completed applications requesting the exemption from the EEDR rider (Option 2) will also qualify for the 60-day automatic approval so long as the exemption period does not exceed 24 months. Rider exemptions for periods of more than 24 months will be reviewed by the Commission Staff and are only approved up the issuance of a Commission order.

Complete a separate application for each customer program. Projects undertaken by a customer as a single program at a single location or at various locations within the same service territory should be submitted together as a single program filing, when possible. Check all boxes that are applicable to your program. For each box checked, be sure to complete all subparts of the question, and provide all requested additional information. Submittal of incomplete applications may result in a suspension of the automatic approval process or denial of the application.

Any confidential or trade secret information may be submitted to Staff on disc or via email at [ee-pdr@puc.state.oh.us](mailto:ee-pdr@puc.state.oh.us).

## **Section 1: Mercantile Customer Information**

Name: Millcreek West Unity Local Schools

Principal address: 1401 W. Jackson West Unity OH 43570

Address of facility for which this energy efficiency program applies: 1401 W. Jackson West Unity OH 43570

Name and telephone number for responses to questions: Neil Wittberg 614 949 5616

Electricity use by the customer (check the box(es) that apply):

- The customer uses more than seven hundred thousand kilowatt hours per year at the above facility. (Please attach documentation.)
- The customer is part of a national account involving multiple facilities in one or more states. (Please attach documentation.)

## **Section 2: Application Information**

A) The customer is filing this application (choose which applies):

- Individually, without electric utility participation.
- Jointly with the electric utility.

B) The electric utility is: The Toledo Edison Company

C) The customer is offering to commit (check any that apply):

- Energy savings from the customer's energy efficiency program. (Complete Sections 3, 5, 6, and 7.)
- Capacity savings from the customer's demand response/demand reduction program. (Complete Sections 4, 5, 6, and 7.)
- Both the energy savings and the capacity savings from the customer's energy efficiency program. (Complete all sections of the Application.)

## Section 3: Energy Efficiency Programs

A) The customer's energy efficiency program involves (check those that apply):

- Early replacement of fully functioning equipment with new equipment. (Provide the date on which the customer replaced fully functioning equipment, and the date on which the customer would have replaced such equipment if it had not been replaced early. Please include a brief explanation for how the customer determined this future replacement date (or, if not known, please explain why this is not known)). **If Checked, Please see Exhibit 1 and Exhibit 2**
- Installation of new equipment to replace equipment that needed to be replaced. The customer installed new equipment on the following date(s):  
\_\_\_\_\_.
- Installation of new equipment for new construction or facility expansion. The customer installed new equipment on the following date(s):  
SEE EXHIBIT 2.
- Behavioral or operational improvement.

B) Energy savings achieved/to be achieved by the energy efficiency program:

- 1) If you checked the box indicating that the project involves the early replacement of fully functioning equipment replaced with new equipment, then calculate the annual savings [(kWh used by the original equipment) - (kWh used by new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: \_\_\_\_\_ kWh

- 2) If you checked the box indicating that the customer installed new equipment to replace equipment that needed to be replaced, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh used by the higher efficiency new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: \_\_\_\_\_ kWh

Please describe any less efficient new equipment that was rejected in favor of the more efficient new equipment. **Please see Exhibit 1 if applicable**

- 3) If you checked the box indicating that the project involves equipment for new construction or facility expansion, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh used by higher efficiency new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: 620,657 kWh

Please describe the less efficient new equipment that was rejected in favor of the more efficient new equipment. **Please see Exhibit 1 if applicable**

- 4) If you checked the box indicating that the project involves behavioral or operational improvements, provide a description of how the annual savings were determined.

## **Section 4: Demand Reduction/Demand Response Programs**

- A) The customer's program involves (check the one that applies):
- Coincident peak-demand savings from the customer's energy efficiency program.
  - Actual peak-demand reduction. (Attach a description and documentation of the peak-demand reduction.)
  - Potential peak-demand reduction (check the one that applies):
    - The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a tariff of a regional transmission organization (RTO) approved by the Federal Energy Regulatory Commission.
    - The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a program that is equivalent to an RTO program, which has been approved by the Public Utilities Commission of Ohio.
- B) On what date did the customer initiate its demand reduction program?
- \_\_\_\_\_
- C) What is the peak demand reduction achieved or capable of being achieved (show calculations through which this was determined):
- \_\_\_\_\_ kW

## **Section 5: Request for Cash Rebate Reasonable Arrangement (Option 1) or Exemption from Rider (Option 2)**

Under this section, check the box that applies and fill in all blanks relating to that choice.

Note: If Option 2 is selected, the application will not qualify for the 60-day automatic approval. All applications, however, will be considered on a timely basis by the Commission.

A) The customer is applying for:

Option 1: A cash rebate reasonable arrangement.

OR

Option 2: An exemption from the energy efficiency cost recovery mechanism implemented by the electric utility.

OR

Commitment payment

B) The value of the option that the customer is seeking is:

Option 1: A cash rebate reasonable arrangement, which is the lesser of (show both amounts):

A cash rebate of \$29,674 (Rebate shall not exceed 50% project cost. Attach documentation showing the methodology used to determine the cash rebate value and calculations showing how this payment amount was determined.)

Option 2: An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider.

An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for \_\_\_\_\_ months (not to exceed 24 months). (Attach calculations showing how this time period was determined.)

OR

A commitment payment valued at no more than \$\_\_\_\_\_. (Attach documentation and calculations showing how this payment amount was determined.)

OR

- Ongoing exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for an initial period of 24 months because this program is part of the customer's ongoing efficiency program. (Attach documentation that establishes the ongoing nature of the program.) In order to continue the exemption beyond the initial 24 month period, the customer will need to provide a future application establishing additional energy savings and the continuance of the organization's energy efficiency program.)

## Section 6: Cost Effectiveness

The program is cost effective because it has a benefit/cost ratio greater than 1 using the (choose which applies):

- Total Resource Cost (TRC) Test. The calculated TRC value is: \_\_\_\_\_ (Continue to Subsection 1, then skip Subsection 2)
- Utility Cost Test (UCT) . The calculated UCT value is: **See Exhibit 3** (Skip to Subsection 2.)

### Subsection 1: TRC Test Used (please fill in all blanks).

The TRC value of the program is calculated by dividing the value of our avoided supply costs (generation capacity, energy, and any transmission or distribution) by the sum of our program overhead and installation costs and any incremental measure costs paid by either the customer or the electric utility.

The electric utility's avoided supply costs were \_\_\_\_\_.

Our program costs were \_\_\_\_\_.

The incremental measure costs were \_\_\_\_\_.

## Subsection 2: UCT Used (please fill in all blanks).

We calculated the UCT value of our program by dividing the value of our avoided supply costs (capacity and energy) by the costs to our electric utility (including administrative costs and incentives paid or rider exemption costs) to obtain our commitment.

Our avoided supply costs were **See Exhibit 3**

The utility's program costs were **See Exhibit 3**

The utility's incentive costs/ rebate costs were **See Exhibit 3**

## **Section 7: Additional Information**

Please attach the following supporting documentation to this application:

- Narrative description of the program including, but not limited to, make, model, and year of any installed and replaced equipment.
- A copy of the formal declaration or agreement that commits the program or measure to the electric utility, including:
  - 1) any confidentiality requirements associated with the agreement;
  - 2) a description of any consequences of noncompliance with the terms of the commitment;
  - 3) a description of coordination requirements between the customer and the electric utility with regard to peak demand reduction;
  - 4) permission by the customer to the electric utility and Commission staff and consultants to measure and verify energy savings and/or peak-demand reductions resulting from your program; and,
  - 5) a commitment by the customer to provide an annual report on your energy savings and electric utility peak-demand reductions achieved.
- A description of all methodologies, protocols, and practices used or proposed to be used in measuring and verifying program results. Additionally, identify and explain all deviations from any program measurement and verification guidelines that may be published by the Commission.

**Ohio****Public Utilities  
Commission****Application to Commit  
Energy Efficiency/Peak Demand  
Reduction Programs  
(Mercantile Customers Only)****Case No.: 12-1828-EL-EEC**

State of Ohio :


Traci Thompson, Affiant, being duly sworn according to law, deposes and says that:

1. I am the duly authorized representative of:



Millcreek-West Unity Local Schools

[insert customer or EDU company name and any applicable name(s) doing business as]

2. I have personally examined all the information contained in the foregoing application, including any exhibits and attachments. Based upon my examination and inquiry of those persons immediately responsible for obtaining the information contained in the application, I believe that the information is true, accurate and complete.



Signature of Affiant &amp; Title

Sworn and subscribed before me this 30<sup>th</sup> day of May, 2012 Month/Year  
Signature of official administering oath  
JANA R. GRIFFIN, Notary  
Print Name and TitleMy commission expires on \_\_\_\_\_  
Jana R. Griffin  
Notary Public, State of Ohio

Williams County

My Commission Expires: June 23, 2012



## Exhibit 1

Customer Legal Entity Name: Millcreek-West Unity Local School District

Site Address: Millcreek-West Unity K-12

Principal Address: 1401 W. Jackson Street

Project No.	Project Name	Narrative description of your program including, but not limited to, make, model and year of any installed and replaced equipment:	Description of methodologies, protocols and practices used in measuring and verifying project results	What date would you have replaced your equipment if you had not replaced it early? Also, please explain briefly how you determined this future replacement date.	Please describe the less efficient new equipment that you rejected in favor of the more efficient new equipment.
1	Millcreek-West Unity K-12 High Efficient Envelope	A new K-12 was built for Millcreek SD in West Unity Ohio. They installed an energy efficient envelope that far exceeds ASHRAE's minimum requirements. The rebate was calculated by creating a building energy model in quest and comparing the energy use against an ASHRAE minimum envelope per 90.1 appendix G.	Data was gathered from the plans (Attachment D) and input to Equest to create an as built model. This building was compared to an identical model with code minimum envelope (walls, roof and windows) insulation values and savings was calculated (see Attachment A for a summary of model results detailed model outputs can be provided upon request). This was input to the custom rebate calculator to determine the rebate amount.	N/A	ASHRAE baseline code compliant envelope per 90.1 standard
2	High Efficient Lighting and Occupancy Sensors	Highly efficient lighting and occ sensors were installed throughout the new K-12 facility	Data was gathered from the electrical plans (Attachment D) and the electrical odm's (Attachment G) this was input to our lighting count sheet (Attachment B) and then input to the lighting rebate calculator to determine savings and rebate amount.	N/A	code minimum lighting
3	Heat Recovery Units	Heat recovery units, by renewable, were installed on all of the dedicated outdoor air units (9) throughout the new facility. These are static plate energy recovery units.	Data was gathered from the mechanical plans (Attachment D) and input into Attachment F. Savings was calculated using binned weather data and calculating the amount of energy recovered by these units based on their effectiveness, occupied hours, flow rates and indoor setpoints. Rebate was calculated using custom rebate calculator.	N/A	N/A
4	Ground Source Heat Pumps	Highly efficient climate master ground source heat pumps were installed at the new K-12	Specifications were gathered from Attachment D and input to Attachment C. The total rebate amount was calculated based on the \$250 per heat pump prescriptive amount. kWh savings were calculated in Equest comparing the as built building to an ASHRAE baseline building (per 90.1 appendix G) Calculation - Baseline HVAC kWh usage - Proposed HVAC kWh usage = (52861.5 - 62024 + 669 + 1176.9) - (38345+35912+113935+206739) = 315,056 kWh	N/A	code minimum efficient heat pumps
5	VFDs	VFDs were installed on the ground source heat pump loop at the new K-12	Data was gathered from Attachment D and input into the motors and drives calculator to determine the rebate amount. kWh savings were calculated based on a 25% reduction in energy use over a motor with no such control in place. $2.30 \text{ hp} * .746 \text{ kw/hp} / .520 \text{ hr} * .1LF * .25 = 49.415 \text{ kWh}$ An analysis was done in yaskawa's software tool on one of the 2 identical motors to check savings. A value of 33,037 kWh savings per motor was determined. The estimate for both motors of 49.415 kWh is being applied for because it is more conservative.	N/A	no motor controls
6	Energy Efficient Split Systems	Split systems were installed to cool the computer rooms throughout the facility. These systems have a SEER of 16	Data was gathered from Attachment D as well as split system specs / efficiencies from Attachment L & M. The kWh savings was calculated in Attachment K. The rebate amount was determined from the prescriptive business incentive of \$150 for split systems under 65,000 btuh and efficiencies over 14.3 seer	N/A	ASHRAE minimum efficient split systems

Docket No. 12-1828  
Site: 1401 W. Jackson Street

Rev (2/1/2012)

Mercantile Customer Program

Page 1 of 4

**Exhibit 2**

**Customer Legal Entity Name:** Millcreek-West Unity Local School District  
**Site Address:** Millcreek-West Unity K-12  
**Principal Address:** 1401 W. Jackson Street

Project Number	Project Name	In-Service Date	Project Cost \$	50% of Project Cost \$	KWh Saved/Year (D) counting towards utility compliance	KWh Saved/Year (E) eligible for incentive	Utility Peak Demand Reduction Contribution, KW (F)	Prescriptive Rebate Amount (\$)	Eligible Rebate Amount (\$)	Note 2
1	Millcreek West Unity K-12 High Efficient Envelope	09/28/2009	\$9,591,919	\$4,795,960	45,464	45,464	-	\$3,637	\$2,728	
2	High Efficient Lighting and Occupancy Sensors	09/28/2009	\$123,463	\$61,732	141,241	141,241	-	\$6,660	\$4,995	
3	Heat Recovery Units	09/28/2009	\$22,500	\$11,250	65,223	65,223	-	\$5,218	\$3,914	
4	Ground Source Heat Pumps	09/28/2009	\$516,000	\$258,000	315,056	315,056	-	\$21,500	\$16,125	
5	VFDs	09/28/2009	\$7,524	\$3,762	49,415	49,415	-	\$2,100	\$1,575	
6	Energy Efficient Split Systems	09/28/2009	\$5,481	\$2,741	4,258	4,258	-	\$450	\$338	
<b>Total</b>			<b>\$10,266,887</b>		<b>620,657</b>	<b>620,657</b>	<b>0</b>	<b>\$39,565</b>	<b>\$29,674</b>	

**Docket No.** 12-1828  
**Site:** 1401 W. Jackson Street

**Notes**

- (1) Customer's usage is adjusted to account for the effects of the energy efficiency programs included in this application. When applicable, such adjustments are prorated to the in-service date to account for partial year savings.  
(2) The eligible rebate amount is based upon 75% of the rebates offered by the FirstEnergy Commercial and Industrial Energy Efficiency programs or 75% of \$0.08/kWh for custom programs for all energy savings eligible for a cash rebate as defined in the PUCCO order in Case NO.10-834-EL-EEC dated 9/15/2010, not to exceed the lesser of 50% of the project cost or \$250,000 per project. The rebate also cannot exceed \$500,000 per customer per year, per utility service territory.

Commitment  
Payment

\$



\$0

### Exhibit 3 Utility Cost Test

UCT = Utility Avoided Costs / Utility Costs

Project	Total Annual Savings, MWh (A)	Utility Avoided Cost \$/MWh (B)	Utility Avoided Cost \$ (C)	Utility Cost \$ (D)	Cash Rebate \$ (E)	Administrator Variable Fee \$ (F)	Total Utility Cost \$ (G)	UCT (H)
1	45	\$ 308	\$ 14,016	\$ 675	\$2,728	\$455	\$ 3,857	<b>3.6</b>
2	141	\$ 308	\$ 43,542	\$ 675	\$4,995	\$1,412	\$ 7,082	<b>6.15</b>
3	65	\$ 308	\$ 20,107	\$ 675	\$3,914	\$652	\$ 5,241	<b>3.84</b>
4	315	\$ 308	\$ 97,125	\$ 675	\$16,125	\$3,151	\$ 19,951	<b>4.87</b>
5	49	\$ 308	\$ 15,234	\$ 675	\$1,575	\$494	\$ 2,744	<b>5.55</b>
6	4	\$ 308	\$ 1,313	\$ 675	\$338	\$43	\$ 1,055	<b>1.24</b>
<b>Total</b>	<b>621</b>	<b>\$ 308</b>	<b>\$ 191,336</b>	<b>\$ 4,050</b>	<b>\$29,674</b>	<b>\$ 6,207</b>	<b>\$ 39,930</b>	<b>4.8</b>

#### Notes

(A) From Exhibit 2, = kWh saved / 1000

(B) This value represents avoided energy costs (wholesale energy prices) from the Department of Energy, Energy Information Administration's 2009 Annual Energy Outlook (AEO) low oil prices case. The AEO represents a national average energy price, so for a better representation of the energy price that Ohio customers would see, a Cinergy Hub equivalent price was derived by applying a ratio based on three years of historic national average and Cinergy Hub prices. This value is consistent with avoided cost assumptions used in EE&PDR Program Portfolio and Initial Benchmark Report, filed Dec 15, 2009 (See Section 8.1, paragraph a).

(C) = (A) \* (B)

(D) Represents the utility's costs incurred for self-directed mercantile applications for applications filed and applications in progress. Includes incremental costs of legal fees, fixed administrative expenses, etc.

(E) This is the amount of the cash rebate paid to the customer for this project.

(F) Based on approximate Administrator's variable compensation for purposes of calculating the UCT, actual compensation may be less.

(G) = (D) + (E) + (F)

(H) = (C) / (G)

Milicreek-West Unity Local School District ~ Milicreek-West Unity K-12  
Docket No. 12-1828

Site: 1401 W. Jackson Street



Line Number	Address Information		Product Information		Customer Information		Project Information		Financial Information		Other Information	
	Address Line 1	Address Line 2	Product Name	Product Model	Customer Name	Customer Address	Project Name	Project Number	Financial Type	Financial Amount	Other Description	Other Notes
	City	State	Manufacturer	Model	Phone Number	Address Line 1	Address Line 2	Address City	Address State	Address Zip	Comments	Comments
1												
2												
3												
4												
5												
6												
7												
8												
9												
10												
11												
12												
13												
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												
25												
26												
27												
28												
29												
30												
31												
32												
33												
34												
35												
36												
37												
38												
39												
40												
41												
42												
43												
44												
45												
46												
47												
48												
49												
50												
51												
52												
53												
54												
55												
56												
57												
58												
59												
60												
61												
62												
63												
64												
65												
66												
67												
68												
69												
70												
71												
72												
73												
74												
75												
76												
77												
78												
79												
80												
81												
82												
83												
84												
85												
86												
87												
88												
89												
90												
91												
92												
93												
94												
95												
96												
97												
98												
99												
100												
101												
102												
103												
104												
105												
106												
107												
108												
109												
110												
111												
112												
113												
114												
115												
116												
117												
118												
119												
120												
121												
122												
123												
124												
125												
126												
127												
128												
129												
130												
131												
132												
133												
134												
135												
136												
137												
138												
139												
140												
141												
142												
143												
144												
145												
146												
147												
148												
149												
150												
151												
152												
153												
154												
155												
156												
157												
158												
159												
160												
161												
162												
163												
164												
165												
166												
167												
168												
169												
170												
171												
172												
173												
174												
175												
176												
177												
178												
179												
180												
181												
182												
183												
184												
185												
186												
187												
188												
189												
190												
191												
192												
193												
194												
195												
196												
197												
198												
199												
200												

## Project Estimated Annual Savings Summary

Estimated Annual kWh Savings	141,241
Total Change in Connected Load	23.48

Annual Estimated Cost Savings	\$14,124.10
Annual Operating Hours	2,080

Interior Lighting Incentive @ \$0.05/kWh (excluding retrofit CFLs, sensors, or LED exit signs)	\$2,735.30
Exterior Lighting Incentive @ \$0.05/kWh (excluding retrofit CFLs, sensors, or LED exit signs)	\$0.00
Total retrofit CFL Incentive @ \$1/screw-in CFL lamp; \$15/hard-wired CFL lamp (includes all retrofit CFLs, both interior and exterior)	\$0.00
Total retrofit LED Exit Incentive @ \$10/exit sign	\$0.00
Total Lighting Controls Incentive @ \$25/sensor (includes all Lighting Controls, both interior and exterior)	\$3,925.00

Total Calculated Incentive	\$6,660.30
----------------------------	------------

Total Fixture Quantity excluding retrofit CFLs and LED Exit Sign	1
Total Lamp Quantity for retrofit Screw-In CFLs	0
Total Lamp Quantity for retrofit Hard-Wired CFLs	0
Total Fixture Quantity for retrofit LED Exit Signs	0
Total Quantity for Occupancy Sensors	157
Total Quantity for Daylight Sensors	0

Please briefly describe how you estimated your coincidence factor (CF) and applicant equivalent full-load hours (EFLH) for facility type "Other" indicated on the Lighting Form tab



Ohio Edison • The Illuminating Company • Toledo Edison

## Mercantile Customer Program - Custom Project Rebate Calculator

Project Name and Number:	P-1, P-3
Site Name:	Millcreek West Unity K-12
Completed by (Name):	Neil Wittberg
Date completed:	5/21/2012

Energy Conservation Measure	Annual Energy Savings kWh	Eligible Prescriptive Rebate Amount kWh * \$0.08
Whole Building Envelope Performance	45,464	3637.12
Heat Recovery Units	65,223	5217.84
<b>Total Project Energy Savings kWh</b>	<b>110,687</b>	
<b>Total Custom Prescriptive Rebate Amount \$</b>	\$	<b>8,854.96</b>

### Notes about this rebate calculation:

A new K-12 was built for Millcreek SD in West Unity Ohio. They installed a closed loop ground source heat pump system, energy recovery ventilators, efficient lighting and envelope as well as vfd's on their pumps. The rebate was calculated by creating a building energy model in equest and comparing the energy use against an ASHRAE baseline building per 90.1 appendix G.



Ohio Edison • The Illuminating Company • Toledo Edison

## Variable Frequency Drive Rebate Form

Project Name:	VFDs
Site Name:	Milicreek West Unity K-12
Completed by (Name):	Neil
Date completed:	5/29/2012

VFD and Controlled Motor Nameplate DATA							
Motor Application	VFD Manufacturer	VFD Model Number	Unique Motor ID(s)	Motor Location	Enclosure type: TEFC or ODP	Annual Hours of Operation <sup>2</sup>	Load Factor (LF) <sup>3</sup>
Heat Pump Circulation Direct	DuraPulse	P-1	Mechanical 126	TEFC	5520	0.8	M4104T.9
Heat Pump Circulation Direct	DuraPulse	P-2	Mechanical 126	TEFC	5520	0.8	M4104T.9
							30
							92.4
							<b>1,050</b>
							<b>0</b>
							<b>0</b>
							<b>0</b>
							<b>0</b>
							<b>0</b>
							<b>Incentive through 10/11/2011 @ \$35/hp</b>
							<b>2,100</b>

(1) VFD incentives (through 10/11/2011) are calculated at a flat rate of \$35 per horsepower controlled, up to a maximum of 500 hp controlled per VFD. When a single VFD is used to control two motors in a lead/lag (standby, redundant) configuration, use only the horsepower rating of one motor to figure controlled horsepower. For instance, if a single VFD controls two 30hp motors with only one operating at a time, the incentive calculation should be based on 30 hp:  $30\text{hp} \times \$35/\text{hp} = \$900$ .

(2) For VAV fan motors, enter 2790 annual hours of operation. For HVAC pump motors, enter 5520 annual hours of operation. For all other motor usage, please estimate your annual hours of operation and attach an explanation of how you determined this value.

(3) For all motor and VFD applications, use the Load Factor (LF) default value of 0.80, unless data is available to support the use of a motor-specific LF other than 0.80. Please attach an explanation, including your analysis and/or data used, to support motor-specific LF value.



millcreek west unity p-1

Neil Wittberg

to:

vmnofziger@firstenergycorp.com

09/24/2012 05:15 PM

Hide Details

From: Neil Wittberg <neil.wittberg@plugsquare.com>

To: "vmnofziger@firstenergycorp.com" <vmnofziger@firstenergycorp.com>

## 2 Attachments



Millcreek West Unity - As Built.pdf Millcreek West Unity\_BaseEnvelope.pdf



Vicky,

I've attached the model reports for this. The kWh savings was determined by taking the difference of the total electricity uses between the two. This model only captures savings attributable to the roof, wall and window R-values.

Let me know if this clears everything up.

**Neil M. Wittberg**

Energy Engineer

**Plug Smart**

P: 614.949.5616

F: 1.800.518.5576

[www.plugsquare.com](http://www.plugsquare.com)

Confidential-

This e-mail and any files transmitted with it are the property of Juice Technologies, LLC. and/or its affiliates, are confidential, and are intended solely for the use of the individual or entity to whom this e-mail is addressed. If you are not one of the named recipients or otherwise have a reason to believe that you have received this email in error, please notify the sender and delete this message immediately from your computer. Any other use, retention, dissemination, forwarding, printing or copying of this e-mail is strictly prohibited.

## Orientation and Energy Use Comparison

### Attachment A

Baseline	Azimuth (degrees)	Energy Use (kWh)	Azimuth (Degrees)	Energy Use (kWh)
	0	988,007.00		0
				942,543.00

Savings (kWh)	
	45,464.00

Millcreek West Unity

## REPORT- BEPU Building Utility Performance

DOE-2.2-47h2 9/24/2012 17:03:32 BDL RUN 1

WEATHER FILE- Toledo OH TMW2																									
		TASK		MISC EQUIP		SPACE HEATING		SPACE COOLING		HEAT REJECT		PUMPS & AUX		VENT FANS		REFRIG DISPLAY		HT PUMP SUPPLEM		DOMEST HOT WTR		EXT USAGE		TOTAL	
		LIGHTS	LIGHTS																						
EM1	ELECTRICITY	KWH	268788.	0.	272097.	38345.	35912.	0.	113935.	206739.	0.	6728.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	942543.	
FM1	NATURAL-GAS	THERM	0.	0.	0.	618.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	3740.	

TOTAL ELECTRICITY	942543.	KWH	8.430	KWH	/SOFT-YR GROSS-AREA	8.430	KWH	/SOFT-YR NET-AREA
TOTAL NATURAL-GAS	3740.	THERM	0.033	THERM	/SOFT-YR GROSS-AREA	0.033	THERM	/SOFT-YR NET-AREA

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.14  
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00  
 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 2  
 HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 1.0

NOTE : ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES .

## Millcreek West Unity

## REPORT- BEPU Building Utility Performance

DOE-2.2-47h2 9/24/2012 16:55:44 BDL RUN 1

WEATHER FILE- Toledo OH TMW2																									
		TASK		MISC EQUIP		SPACE HEATING		SPACE COOLING		HEAT REJECT		PUMPS & AUX		VENT FANS		REFRIG DISPLAY		HT PUMP SUPPLEM		DOMEST HOT WTR		EXT USAGE		TOTAL	
		LIGHTS	LIGHTS																						
		-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
EM1	ELECTRICITY	268788.	0.	272097.	59710.	33118.	0.	125454.	221871.	0.	6970.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	988007.	
FM1	NATURAL-GAS	0.	0.	0.	848.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	0.	3.973.	
TOTAL	ELECTRICITY	988007.	KWH	8.837	KWH	/SOFT-YR GROSS-AREA	8.837	KWH	/SOFT-YR GROSS-AREA	0.036	THERM	0.036	THERM	0.036	THERM	0.036	THERM	0.036	THERM	0.036	THERM	0.036	THERM	/SOFT-YR NET-AREA /SQFT-YR NET-AREA	
TOTAL	NATURAL-GAS	3973.	TERM	0.036	TERM	/SOFT-YR GROSS-AREA	0.036	TERM	0.036	TERM	0.036	TERM	0.036	TERM	0.036	TERM	0.036	TERM	0.036	TERM	0.036	TERM	0.036	TERM	

PERCENT OF HOURS ANY SYSTEM ZONE OUTSIDE OF THROTTLING RANGE = 0.15  
 PERCENT OF HOURS ANY PLANT LOAD NOT SATISFIED = 0.00  
 HOURS ANY ZONE ABOVE COOLING THROTTLING RANGE = 0  
 HOURS ANY ZONE BELOW HEATING THROTTLING RANGE = 13


NOTE : ENERGY IS APPORTIONED HOURLY TO ALL END-USE CATEGORIES .


ATTACHMENT B

Project Title: Millcreek West Unity k-12  
Prepared By:Neil  
Date:4/25/2012

61	Classroom	227	1	3	8	8	2
	Laboratory	1393	2	4	8	8	003A
	Stairs	323		4	8	8	58
	003A			4	8	8	53
	Hall	1787		8	2	2	54
53	Classroom	954	1	4	4	4	55
	Classroom	905	1	4	4	4	55
55	Classroom	894	1	4	4	4	55
	Classroom	883	1	4	4	4	56
56	Classroom	914	1	4	4	4	57
	Gym	6407	18	6	4	4	86
86	Gym	10298	22	8	4	4	87
124	Office	352	1	5	1	1	124
	Office	125	1	5	1	1	125
123	Lobby	94	1	14	1	1	123
	Lobby	1293		4	6	1	121
89	Hall	360		6	1	1	121
88	Hall	536		5	1	1	89
109	Dining	4414	43	2	3	3	109
91	Lobby	232		2	3	3	91
96	Laboratory	1877	4	1	1	1	110
102	Storage	136		1	1	1	110
103	Mech/Elec	644	2	1	1	1	115
98	Office	120	1	1	1	1	115
126	Mech/Elec	362		1	1	1	127
147	Mech/Elec	147		1	1	1	126
1480	Mech/Elec	1480		6	5	5	104
90	Lobby	1294		6	1	1	90
91	Hall	232		5	1	1	88
92	Lobby	232		5	1	1	91
93	Restroom	99	1	1	1	1	96
99	Office	99	1	1	1	1	96
97	Hall	129	2	1	1	1	97
100	Restroom	63	1	1	1	1	100
101	Office	136	1	1	1	1	101
106	Storage	136		1	1	1	102
107	Hall	60		1	1	1	102
108	Locker	141	1	1	1	1	103
114	Food Prep	1034	2	1	1	1	103
118	Mech/Elec	84	1	1	1	1	103
119	Locker	67	1	1	1	1	103
120	Restroom	65	1	1	1	1	103
113	Office	100	1	1	1	1	103
004A	Stairs	250	1	1	1	1	103
128	Mech/Elec	114	1	1	1	1	103
122	Mech/Elec	42		1	1	1	103
131	Food Prep	586	2	1	1	1	103
215	Classroom	931	1	5	5	5	111
216	Classroom	897	1	4	4	4	215
217	Classroom	900	1	4	4	4	216
211	Classroom	880	1	4	4	4	217
212	Classroom	880	1	4	4	4	211
213	Classroom	912	1	4	4	4	212
214	Classroom	912	1	4	4	4	213
224	Classroom	880	1	4	4	4	223
225	Classroom	909	1	4	4	4	224
221	Mech/Elec	119		4	4	4	224
218	Hall	205		225	225	225	225
220	Restroom	244	2	1	1	1	226
219	Restroom	210	2	1	1	1	227
220B	Stairs	328		2	2	2	227
208	Stacks	147	1	1	1	1	227
215	Mech/Elec	215		8	2	2	227
209	Office	130	1	1	1	1	227
210	Office	408	1	2	2	2	227
205	Reading	2430	7	6	12	4	205
228	Office	209	1	2	2	2	206
230	Office	155	1	1	1	1	206
002B	Stairs	273	1	1	1	1	205
203	Restroom	298	1	2	2	2	204
202	Restroom	298	1	2	2	2	204
202B	Stairs	286	1	1	1	1	203
200	Lobby	752		2	2	2	202
214	Hall	2724		6	1	1	202
232	Classroom	908	1	4	4	4	214
233	Classroom	883	1	4	4	4	233
234	Classroom	886	1	4	4	4	233
235	Classroom	921	1	4	4	4	234









Occupancy Controls		Watts Controlled OS500W			
122	0	182	0		
244	0	122	0		
364	0	244	0		
422	0	364	0		
409	0	422	0		
305	0	409	0		
61	0	305	0		
103	0	61	0		
546	1	103	0		
0	0	546	1		
0	0	0	0		
366	0	0	0		
364	0	366	0		
0	0	364	0		
0	0	0	0		
182	0	0	0		
182	0	182	0		
182	0	182	0		
182	0	182	0		
182	0	182	0		
364	0	182	0		
273	0	364	0		
182	0	273	0		
182	0	182	0		
273	0	182	0		
364	0	273	0		
183	0	364	0		
0	0	183	0		
0	0	0	0		
182	0	0	0		
122	0	182	0		
61	0	122	0		
224	0	61	0		
1092	1	1092	1		
1092	1	1092	1		
1092	1	1092	1		
1092	1	1092	1		
1092	1	1092	1		
0	0	1092	1		
306	0	0	0		
277	0	306	0		
0	0	277	0		
0	0	0	0		
1365	0	0	0		
61	0	1365	0		
61	0	61	0		
1365	2	61	0		
2440	2	1365	2		
1952	2	2440	2		
0	0	1952	2		
305	0	0	0		
91	0	0	0		
93	0	91	0		
183	0	93	0		
93	0	183	0		
91	0	93	0		
0	0	91	0		
364	0	0	0		
321	0	364	0		
732	2	321	0		
732	0	732	2		
1092	2	732	2		
1456	2	1092	2		
1456	2	1456	2		

Room Type	Area	COMcheck Rating	Allowed Wattsage	Proposed Wattsage	Proposed Watts/SF
Audience	0	0.9	0	0	HDV/0
Classroom	3525	1.4	49735	43316	1.23310345
Conference Room	277	1.3	360.1	546	1.371119134
Dining	4414	0.9	3972.6	7636	1.729950159
Dorm Room	0	1.1	0	0	HDV/0
Exam/Treatment	0	1.5	0	0	HDV/0
Exercise Area	1360	0.9	1224	1820	1.33825294
Food Prep	1870	1.2	2244	2609	1.395187166
Gym	16705	2.3	38421.5	23404	1.03017659
Hall	14757	0.5	7373.5	9161	0.625790333
Laboratory	7855	1.4	10597	5901	0.751241248
Laundry	182	0.6	109.2	122	0.67033967
Lobby	4231	1.3	5503.3	3879	0.91804538
Locker	1858	0.6	1114.8	2701	1.453713671
Lounge	0	1.2	0	0	HDV/0
Mail Sorting	0	1.2	0	0	HDV/0
Mech/Elec	6920	1.5	10380	5092	0.73583835
Nurse	0	1.	0	0	HDV/0
Office	5288	1.1	5816.8	6384	1.207261725
Operating Room	0	2.2	0	0	HDV/0
Parking Garage	0	0.2	0	0	HDV/0
Patient Room	0	0.7	0	0	HDV/0
Pharmacy	0	1.2	0	0	HDV/0
Reading	2430	1.2	2916	3968	1.632921811
Restroom	3783	0.9	3404.7	4577	1.209886334
Sales Area	0	1.7	0	0	HDV/0
Stacks	1692	1.7	249.9	322	1.236065238
Stairs	3079	0.6	1013.2	877	0.518331513
Storage	0	0.8	2463.2	164.5	0.534284372
Workshop	0	1.9	0	0	HDV/0
<b>Totals</b>	<b>112373</b>	<b>1.2</b>	<b>147302.8</b>	<b>123320</b>	<b>15.94%</b>
					23482.8
Hours of Operation	Electric Rate	KWh Saved	\$ Saved		
		0	0		

If Doing COMcheck with whole building Area, fill in Area below (Default building type is School):

Building Type	Area	COMcheck Rating	Allowed Wattsage	Proposed Wattsage	% Above/Below Code	Watts Saved
School	112373	1.2	124915.6	123320	9.03%	11027.6

Building Type	Area	COMcheck Rating	Allowed Wattsage	Proposed Wattsage	% Above/Below Code	Watts Saved
School	112373	1.2	124915.6	123320	9.03%	11027.6
Hours of Operation	Electric Rate	KWh Saved	\$ Saved			
		0	0			

Occupancy Sensor Summation:

Watts Controlled	OS500W	OS Total
81509	73	78



[REDACTED]

.....

.....

.....

.....

.....

.....

.....	79	73
.....	81609	





0	0	885
0	0	891
0	0	0
0	0	0
0	0	947
0	0	1247
0	0	1880
0	0	318
0	0	395
0	0	433
0	0	77
0	0	180
0	0	1906
0	0	1495
0	0	173
0	0	192

Proposed With	
A	B

		Fixture Wattage																									
		F1	F2	F3	F4	F5	F6	F7	F8	Fixture Type																	
A	B	C	D	E	F	G	H	I	F1M	F1S	F2M	F2S	F3A	F4A	F5	F6	F7	F8	F1I	F12	F13	F14	F15	AA	BB	CC	0
Audience	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Classroom	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Conference Room	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Dining	0	0	0	43	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Dorm Room	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Exam/Treatment	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Exercise Area	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Food Prep	0	0	0	0	0	0	0	0	2	13	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Gym	40	-14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Hall	0	0	0	2	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Laboratory	0	0	0	0	0	0	0	0	8	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Lobby	0	0	0	13	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Locker	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	0	40	5	0	0	0	0	0	0		
Lounge	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Main Sorting	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Mech/Elec	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Nurse	0	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Office	0	0	1	0	0	0	0	0	19	21	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0		
Operating Room	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Parking Garage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Patient Room	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Pharmacy	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Reading	0	0	6	0	12	0	0	0	0	0	0	0	0	0	0	0	0	0	28	4	0	0	0	0	0		
Restroom	0	0	0	16	0	10	0	0	0	0	1	1	0	0	0	0	0	36	0	0	0	0	0	0	0		
Sales Area	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		
Stacks	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0		
Stairs	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	12	0	0	0	0	0	0	0		
Storage	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0	0	9	10	0	0		
Workshop	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0		

Total fixtures | 1333

## ATTACHMENT C

Millcreek SD  
Heat Pumps

Tag	CFM	OA	Cooling	Heating	EER	COP	Qualifying Efficiencies			Number Qualifying			Incentive @ \$250/heat pump	\$	Accepted Measure Cost
							14.7	cop	2064	3.4	86	86			
1-1	550	195	15.5	14.1	19	3.7	0.004367	0.004265	0	8.802371	15.5	22.9023713	0.179578947	0.262102383	
1-2	1510	510	43.5	40.9	19.4	3.8	0.012255	0.012371	0	25.53312	43.5	66.4331196	0.175876289	0.257940129	
1-3	550	195	15.5	14.1	19	3.7	0.004367	0.004265	0	8.802371	15.5	22.9023713	0.179578947	0.262102383	
1-4	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.253908005	
1-5	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.257940129	
1-6	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.253908005	
1-7	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.257940129	
1-8	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.253908005	
1-9	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.257940129	
1-10	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.253908005	
1-11	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.257940129	
2-1	640	175	22.5	20.1	19.1	3.7	0.006339	0.006079	0	12.54806	22.5	32.6480612	0.178638743	0.262102383	
2-2	580	200	15.5	14.1	19	3.7	0.004367	0.004265	0	8.802371	15.5	22.9023713	0.179578947	0.233955876	
2-3	1230	285	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
2-4	1230	285	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
2-5	640	195	22.5	20.1	19.1	3.7	0.006339	0.006079	0	12.54806	22.5	32.6480612	0.178638743	0.233955876	
2-6	640	195	22.5	20.1	19.1	3.7	0.006339	0.006079	0	12.54806	22.5	32.6480612	0.178638743	0.233955876	
2-7	1230	270	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
2-8	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
2-9	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
2-10	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.229294065	
2-11	460	30	15	13.9	19	3.7	0.004226	0.004204	0	8.677515	15	22.577515	0.179578947	0.233955876	
2-12	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.229294065	
2-13	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
2-14	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.229294065	
2-15	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
2-16	1060	390	31.6	32.1	19.2	3.9	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.177708333	0.229294065	
2-17	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
3-1	1230	420	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
3-2	1230	420	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.232577726	
3-3	550	180	15.5	14.1	19	3.7	0.004367	0.004265	0	8.802371	15.5	22.9023713	0.179578947	0.233955876	
3-4	460	155	15	13.9	19	3.7	0.004226	0.004204	0	8.677515	15	22.577515	0.179578947	0.233955876	
3-5	730	250	23.2	20.4	19.1	3.7	0.006536	0.00617	0	12.75355	23.2	33.1352457	0.178638743	0.233955876	
3-6	640	235	22.5	20.1	19.1	3.7	0.006339	0.006079	0	12.54806	22.5	32.6480612	0.178638743	0.233955876	
3-7	640	105	22.5	20.1	19.1	3.7	0.006339	0.006079	0	12.54806	22.5	32.6480612	0.178638743	0.233955876	
3-8	460	85	15	13.9	19	3.7	0.004226	0.004204	0	8.677515	15	22.577515	0.179578947	0.233955876	
3-9	640	320	22.8	20.2	19.1	3.7	0.006423	0.00611	0	12.61049	22.8	32.8104894	0.178638743	0.233955876	
4-1	880	330	26.1	23.9	19.1	3.7	0.004226	0.004204	0	8.677515	15	22.577515	0.178638743	0.233955876	
4-2	550	195	15.5	14.1	19	3.7	0.004367	0.004265	0	14.92033	26.1	38.8203315	0.300840594	0.233955876	
4-3	550	195	15.5	14.1	19	3.7	0.004367	0.004265	0	8.802371	15.5	22.9023713	0.179578947	0.233955876	
4-4	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.231752441	
4-5	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.231752441	
4-6	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.231752441	
4-7	640	100	22.5	20.1	19.1	3.7	0.006339	0.006079	0	12.54806	22.5	32.6480612	0.179578947	0.231752441	
4-8	1060	375	31.6	32.1	17.6	3.8	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.145512848	0.228492313	
4-9	1230	465	40	15	13.9	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.228492313	
4-10	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.228492313	
4-11	1060	375	31.6	32.1	17.6	3.8	0.008903	0.009709	0	20.0944	31.6	52.1394411	#REF!	0.228492313	
4-12	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289	0.228492313	
5-1	1060	316	32.1	22.8	19.1	3.8	0.008903	0.009709	0	20.0944	31.6	52.1394411	0.193863636	0.228492313	

5-2	550	195	15.5	14.1	19	3.7	0.004367	0.004265	0	8.802371	15.5	22.9023713	0.179578947
5-3	550	195	15.5	14.1	19	3.7	0.004367	0.004265	0	8.802371	15.5	22.9023713	0.179578947
5-4	1790	375	55.7	48.5	18.2	3.7	0.015692	0.014669	0	30.27766	55.7	78.7776602	0.187472527
5-5	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289
5-6	1230	570	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289
5-7	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289
5-8	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289
5-9	1510	500	43.5	40.9	19.4	3.8	0.012255	0.012371	0	25.53312	43.5	66.4331196	0.175876289
5-10	1230	465	42.1	40.1	19.4	3.8	0.011861	0.012129	0	25.03369	42.1	65.1336943	0.175876289
6-1	5600	1360	127	115.3	16.2	3.6	0.03578	0.034874	0	71.97967	127	187.279675	0.210617284
6-2	5600	1360	127	115.3	16.2	3.6	0.03578	0.034874	0	71.97967	127	187.279675	0.210617284
7-1	9200	3465	241.8	215.6	16.2	3.6	0.068122	0.065211	0	134.5951	241.8	350.195124	0.210617284
7-2	9200	3465	241.8	215.6	16.2	3.6	0.068122	0.065211	0	134.5951	241.8	350.195124	0.210617284
8-1	3950	1840	130	116.8	16.2	3.6	0.036625	0.035328	0	72.9161	130	189.716097	0.210617284
8-2	1800	880	56.7	48.8	18.2	3.7	0.015974	0.01476	0	30.46494	56.7	79.2649446	0.187472527
8-3	955	120	28.1	25.9	19.1	3.7	0.007917	0.007834	0	16.16889	28.1	42.0688948	0.178638743
8-4	1510	100	43.5	40.9	19.4	3.8	0.012255	0.012371	0	25.53312	43.5	66.4331196	0.175876289
8-5	1510	100	43.5	40.9	19.4	3.8	0.012255	0.012371	0	25.53312	43.5	66.4331196	0.175876289
8-6	1060	45	31.6	32.1	17.6	3.8	0.008903	0.009709	0	20.05944	31.6	52.1394411	0.193863636
8-7	640	60	22.5	20.1	19.1	3.7	0.006339	0.006079	0	12.54806	22.5	32.6480612	0.178638743
8-8	790	190	25.6	23.6	19.1	3.7	0.007212	0.007138	0	14.73305	25.6	38.333047	0.178638743
8-9	1790	760	56.2	48.6	18.2	3.7	0.015833	0.0147	0	30.34009	56.2	78.940083	0.187472527
8-10	460	75	15	13.9	19	3.7	0.004226	0.004204	0	8.677515	15	22.577515	0.179578947
8-11	880	255	26.1	23.9	19.1	3.7	0.007353	0.007229	0	14.92033	26.1	38.8203315	0.178638743
8-12	1510	290	43.5	40.9	19.4	3.8	0.012255	0.012371	0	25.53312	43.5	66.4331196	0.175876289
8-13	1060	460	32	32.2	17.6	3.8	0.009015	0.009739	0	20.10187	32	52.3018692	0.193863636
8-14	1060	460	32	32.2	17.6	3.8	0.009015	0.009739	0	20.10187	32	52.3018692	0.193863636
9-1	560	515	16.3	14.3	19	3.7	0.004592	0.004325	0	8.927228	16.3	23.2272276	0.179578947
9-2	550	510	16.3	14.3	19	3.7	0.004592	0.004325	0	8.927228	16.3	23.2272276	0.179578947
9-3	640	640	23.9	20.8	19.1	3.7	0.006733	0.006291	0	12.95506	23.9	33.7850584	0.178638743
9-4	1230	1230	44.7	41.5	17.6	3.7	0.012593	0.012552	0	25.90769	44.7	67.4076886	0.193863636
9-5	1230	1230	44.7	41.5	17.6	3.7	0.012593	0.012552	0	25.90769	44.7	67.4076886	0.193863636
9-6	1060	975	33.4	32.5	19.2	3.9	0.00941	0.00983	0	20.28915	33.4	52.7891537	0.177708333
10-1	1790	535	55.9	49.5	18.2	3.7	0.015749	0.014972	0	30.90194	55.9	80.4019418	0.187472527
10-2	1920	535	56.5	49.8	18.2	3.7	0.015918	0.015063	0	31.08923	56.5	80.8892263	0.187472527

Add Heat

-224,776	0.068119	140.5966
-216,438	0.065592	135.3812
-144,743	0.043864	90.53623
-16,120	0.004885	10.083
-43,420	0.013158	27.15906
-10,006	0.003032	6.258717
-9,470	0.00287	5.923451
-36,265	0.01099	22.68363
-34,742	0.010529	21.731
-34,159	0.010352	21.36633
-31,328	0.009494	19.59555
-51,129	0.015495	31.98101
-25,541	0.00774	15.9758
-23,248	0.007045	14.54154
-56,283	0.017057	35.20482
-44,367	0.013445	27.7514
-44,180	0.013389	27.63443
-43,908	0.013306	27.4643
-43,275	0.013115	27.06836
-41,041	0.012437	25.671
-19,866	0.00602	12.42611
-8,010	0.002427	5.010226
-15,150	0.004591	9.476271
-25,603	0.007759	16.01459
-20,336	0.006163	12.7201
-42,002	0.012729	26.2721
-50,724	0.015372	31.72768
-17,701	0.005364	11.07191
-9,644	0.002923	6.032288
-25,500	0.007728	15.95016
-16,316	0.004945	10.2056
-33,731	0.010222	21.09862
-2,215	0.000671	1.385475
-56,670	0.017174	35.44688
-49,260	0.014928	30.81195
-42,343	0.012832	26.4854
-51,727	0.015676	32.35505
-42,137	0.01277	26.35654
-50,906	0.015427	31.84152
-17,505	0.005305	10.94932
-17,085	0.005178	10.68661
-45,233	0.013708	28.29308
-30,916	0.009369	19.33785
-18,806	0.005699	11.76309
-70,231	0.021284	43.92924
-65,366	0.019809	40.8862

-8,790	0.002664	5.498114
-22,288	0.006754	13.94106
-36,119	0.010946	22.59231
-6,661	0.002019	4.166432
-41,600	0.012607	26.02065
-27,693	0.008392	17.32187
-47,678	0.014449	29.82242
-26,036	0.00789	16.28543
-2,557	0.000775	1.599394
-32,514	0.009853	20.33739
-31,393	0.009514	19.63621
-31,393	0.009514	19.63621
-31,205	0.009457	19.51862
-34,759	0.010534	21.74163
-32,658	0.009897	20.42746
-31,628	0.009585	19.7832
-31,095	0.009423	19.44981
-34,450	0.01044	21.54835
-30,631	0.009283	19.15958
-46,528	0.0141	29.1031
-41,996	0.012727	26.26835
-9,477	0.002872	5.92783
-17,657	0.005351	11.04439
-16,695	0.005059	10.44266
-58,850	0.017835	36.81047
-42,204	0.01279	26.39845
-42,092	0.012756	26.3284
-44,585	0.013512	27.88776
-23,633	0.007162	14.78236
-58,355	0.017685	36.50084
-41,871	0.012689	26.19016
-43,245	0.013105	27.04959
-40,419	0.012249	25.28194
-48,844	0.014802	30.55175
-50,594	0.015333	31.64637
-67,142	0.020347	41.99708
-13,914	0.004217	8.703157
-4,763	0.001443	2.97924
-26,345	0.007984	16.4787
-3,299,779		2064

	HEAT RECOVERY UNIT SAVINGS SUMMARY									
	AHU-1	AHU-2	AHU-3	AHU-4	AHU-5	AHU-6	AHU-7	AHU-8	AHU-9	TOTAL
kWh:	15,055.4	3,206.2	7,701.9	15,194.8	14,584.9	9,479.3	4,019.4	11,187.3	2,962.3	65,222.5
Dollars:	\$ 1,204.43	\$ 256.50	\$ 616.16	\$ 1,215.58	\$ 1,166.79	\$ 758.34	\$ 321.55	\$ 894.98	\$ 236.98	\$ 6,671.32
75%	\$ 903.32	\$ 192.37	\$ 462.12	\$ 911.69	\$ 875.09	\$ 568.76	\$ 241.16	\$ 671.24	\$ 177.74	\$ 5,003.49

USA\_OH\_Toledo.725360\_TMY3.bin

## HEAT RECOVERY UNIT SAVINGS

AHU-1

## INPUTS

Minimum Fraction Outdoor Air:	100%	
Heat Recover Effectiveness:	60.0%	
Summer Set Point Temperature:	72 F	Winter Set Point
Set Point Enthalpy:	26.39 Btu/lba	Set Point Enthalpy:
Supply Air Temperature:	53 F	70
Supply Air Enthalpy:	21.86 Btu/lba	22.72
Supply Air Volume:	4320 cfm	
Supply Air Density:	0.075 lb/ft^3	

Rate:	\$0.08	
75% Load EER:	18.31	COP
		SAVINGS
Cooling kWh:	2,979.72	Heating kWh: 12,075.65
Dollars:	\$238.38	Dollars: \$966.05
75%	\$178.78	75% \$724.54

HRU on 50% of weekend  
Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q (mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	1.53
85	89	87.7	36.2	57	100%	87.7	36.20	6.52
80	84	82.1	33.3	229	100%	82.1	33.30	18.45
75	79	76.7	31.2	289	100%	76.7	31.20	16.20
70	74	72.5	29.6	246	100%	72.5	29.60	9.20
65	69	67.9	28.2	260	100%	67.9	28.20	5.48
60	64	62.6	24.9	243	100%	62.6	24.90	4.23
55	59	57.2	21.7	172	100%	57.2	21.70	2.05
50	54	52.1	19.1	192	100%	52.1	19.10	8.11
45	49	47.4	16.8	133	100%	47.4	16.80	9.18
40	44	43.0	14.8	199	100%	43.0	14.80	18.38
35	39	37.4	12.7	248	100%	37.4	12.70	28.98
30	34	32.1	10.6	182	100%	32.1	10.60	25.73
25	29	27.6	9	146	100%	27.6	9.00	23.36
20	24	23.1	7.4	100	100%	23.1	7.40	17.87
15	19	17.4	5.6	110	100%	17.4	5.60	21.97
10	14	12.0	4	58	100%	12.0	4.00	12.66
5	9	7.4	2.7	20	100%	7.4	2.70	4.67
0	4	2.6	1.3	19	100%	2.6	1.30	4.75
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	1.58
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00
								240.90

USA\_OH\_Toledo.725360\_TMY3.bin

## HEAT RECOVERY UNIT SAVINGS

AHU-2

## INPUTS

Minimum Fraction Outdoor Air:	100%	
Heat Recover Effectiveness:	10.0%	
Summer Set Point Temperature:	72 F	Winter Set Point
Set Point Enthalpy:	26.39 Btu/lba	70
Supply Air Temperature:	53 F	Set Point Enthalpy:
Supply Air Enthalpy:	21.86 Btu/lba	22.72
Supply Air Volume:	5520 cfm	
Supply Air Density:	0.075 lb/ft^3	

Rate:	\$0.08	
75% Load EER:	18.31 COP	3.73
SAVINGS		
Cooling kWh:	634.57	Heating kWh: 2,571.67
Dollars:	\$50.77	Dollars: \$205.73
75%	\$38.07	75% \$154.30

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q (mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	0.33
85	89	87.7	36.2	57	100%	87.7	36.20	1.39
80	84	82.1	33.3	229	100%	82.1	33.30	3.93
75	79	76.7	31.2	289	100%	76.7	31.20	3.45
70	74	72.5	29.6	246	100%	72.5	29.60	1.96
65	69	67.9	28.2	260	100%	67.9	28.20	1.17
60	64	62.6	24.9	243	100%	62.6	24.90	0.90
55	59	57.2	21.7	172	100%	57.2	21.70	0.44
50	54	52.1	19.1	192	100%	52.1	19.10	1.73
45	49	47.4	16.8	133	100%	47.4	16.80	1.96
40	44	43.0	14.8	199	100%	43.0	14.80	3.91
35	39	37.4	12.7	248	100%	37.4	12.70	6.17
30	34	32.1	10.6	182	100%	32.1	10.60	5.48
25	29	27.6	9	146	100%	27.6	9.00	4.98
20	24	23.1	7.4	100	100%	23.1	7.40	3.81
15	19	17.4	5.6	110	100%	17.4	5.60	4.68
10	14	12.0	4	58	100%	12.0	4.00	2.70
5	9	7.4	2.7	20	100%	7.4	2.70	0.99
0	4	2.6	1.3	19	100%	2.6	1.30	1.01
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	0.34
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00
							<b>51.30</b>	

USA\_OH\_Toledo.725360\_TMY3.bin

## HEAT RECOVERY UNIT SAVINGS

AHU-3

## INPUTS

AHU 015	
Minimum Fraction Outdoor Air:	100%
Heat Recover Effectiveness:	60.0%
Summer Set Point Temperature:	72 F
Set Point Enthalpy:	26.39 Btu/lba
Supply Air Temperature:	53 F
Supply Air Enthalpy:	21.86 Btu/lba
Supply Air Volume:	2210 cfm
Supply Air Density:	0.075 lb/ft^3
Winter Set Point	70
Set Point Enthalpy:	22.72

Rate:	\$0.08		
75% Load EER:	18.31	COP	3.73
SAVINGS			
Cooling kWh:	1,524.35	Heating kWh:	6,177.59
Dollars:	\$121.95	Dollars:	\$494.21
75%	\$91.46	75%	\$370.66

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q(mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	0.78
85	89	87.7	36.2	57	100%	87.7	36.20	3.34
80	84	82.1	33.3	229	100%	82.1	33.30	9.44
75	79	76.7	31.2	289	100%	76.7	31.20	8.29
70	74	72.5	29.6	246	100%	72.5	29.60	4.71
65	69	67.9	28.2	260	100%	67.9	28.20	2.80
60	64	62.6	24.9	243	100%	62.6	24.90	2.17
55	59	57.2	21.7	172	100%	57.2	21.70	1.05
50	54	52.1	19.1	192	100%	52.1	19.10	4.15
45	49	47.4	16.8	133	100%	47.4	16.80	4.70
40	44	43.0	14.8	199	100%	43.0	14.80	9.40
35	39	37.4	12.7	248	100%	37.4	12.70	14.83
30	34	32.1	10.6	182	100%	32.1	10.60	13.16
25	29	27.6	9	146	100%	27.6	9.00	11.95
20	24	23.1	7.4	100	100%	23.1	7.40	9.14
15	19	17.4	5.6	110	100%	17.4	5.60	11.24
10	14	12.0	4	58	100%	12.0	4.00	6.48
5	9	7.4	2.7	20	100%	7.4	2.70	2.39
0	4	2.6	1.3	19	100%	2.6	1.30	2.43
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	0.81
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00

USA\_OH\_Toledo.725360\_TMY3.bin

## HEAT RECOVERY UNIT SAVINGS

AHU-4

## INPUTS

HVAC	
Minimum Fraction Outdoor Air:	100%
Heat Recover Effectiveness:	60.0%
Summer Set Point Temperature:	72 F
Set Point Enthalpy:	26.39 Btu/lba
Supply Air Temperature:	53 F
Supply Air Enthalpy:	21.86 Btu/lba
Supply Air Volume:	4360 cfm
Supply Air Density:	0.075 lb/ft^3
Winter Set Point	70
Set Point Enthalpy:	22.72

Rate:	\$0.08		
75% Load EER:	18.31	COP	
SAVINGS			
Cooling kWh:	3,007.31	Heating kWh:	12,187.46
Dollars:	\$240.59	Dollars:	\$975.00
75%	\$180.44	75%	\$731.25

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q(mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	1.54
85	89	87.7	36.2	57	100%	87.7	36.20	6.58
80	84	82.1	33.3	229	100%	82.1	33.30	18.62
75	79	76.7	31.2	289	100%	76.7	31.20	16.35
70	74	72.5	29.6	246	100%	72.5	29.60	9.28
65	69	67.9	28.2	260	100%	67.9	28.20	5.53
60	64	62.6	24.9	243	100%	62.6	24.90	4.27
55	59	57.2	21.7	172	100%	57.2	21.70	2.07
50	54	52.1	19.1	192	100%	52.1	19.10	8.18
45	49	47.4	16.8	133	100%	47.4	16.80	9.27
40	44	43.0	14.8	199	100%	43.0	14.80	18.55
35	39	37.4	12.7	248	100%	37.4	12.70	29.25
30	34	32.1	10.6	182	100%	32.1	10.60	25.97
25	29	27.6	9	146	100%	27.6	9.00	23.58
20	24	23.1	7.4	100	100%	23.1	7.40	18.03
15	19	17.4	5.6	110	100%	17.4	5.60	22.17
10	14	12.0	4	58	100%	12.0	4.00	12.78
5	9	7.4	2.7	20	100%	7.4	2.70	4.71
0	4	2.6	1.3	19	100%	2.6	1.30	4.79
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	1.60
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00

USA\_OH\_Toledo.725360\_TMY3.bin

## HEAT RECOVERY UNIT SAVINGS

AHU-5

## INPUTS

Minimum Fraction Outdoor Air:	100%	
Heat Recover Effectiveness:	60.0%	
Summer Set Point Temperature:	72 F	Winter Set Point
Set Point Enthalpy:	26.39 Btu/lba	Set Point Enthalpy:
Supply Air Temperature:	53 F	70
Supply Air Enthalpy:	21.86 Btu/lba	
Supply Air Volume:	4185 cfm	
Supply Air Density:	0.075 lb/ft^3	

Rate:	\$0.08	
75% Load EER:	18.31 COP	3.73
SAVINGS		
Cooling kWh:	2,886.61	Heating kWh: 11,698.29
Dollars:	\$230.93	Dollars: \$935.86
75%	\$173.20	75% \$701.90

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q (mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	1.48
85	89	87.7	36.2	57	100%	87.7	36.20	6.32
80	84	82.1	33.3	229	100%	82.1	33.30	17.87
75	79	76.7	31.2	289	100%	76.7	31.20	15.69
70	74	72.5	29.6	246	100%	72.5	29.60	8.91
65	69	67.9	28.2	260	100%	67.9	28.20	5.31
60	64	62.6	24.9	243	100%	62.6	24.90	4.10
55	59	57.2	21.7	172	100%	57.2	21.70	1.98
50	54	52.1	19.1	192	100%	52.1	19.10	7.85
45	49	47.4	16.8	133	100%	47.4	16.80	8.90
40	44	43.0	14.8	199	100%	43.0	14.80	17.81
35	39	37.4	12.7	248	100%	37.4	12.70	28.08
30	34	32.1	10.6	182	100%	32.1	10.60	24.92
25	29	27.6	9	146	100%	27.6	9.00	22.63
20	24	23.1	7.4	100	100%	23.1	7.40	17.31
15	19	17.4	5.6	110	100%	17.4	5.60	21.28
10	14	12.0	4	58	100%	12.0	4.00	12.27
5	9	7.4	2.7	20	100%	7.4	2.70	4.52
0	4	2.6	1.3	19	100%	2.6	1.30	4.60
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	1.53
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00

USA\_OH\_Toledo.725360\_TMY3.bin

## HEAT RECOVERY UNIT SAVINGS

AHU-6

## INPUTS

INPUTS			
Minimum Fraction Outdoor Air:	100%		
Heat Recover Effectiveness:	60.0%		
Summer Set Point Temperature:	72 F	Winter Set Point	70
Set Point Enthalpy:	26.39 Btu/lba	Set Point Enthalpy:	22.72
Supply Air Temperature:	53 F		
Supply Air Enthalpy:	21.86 Btu/lba		
Supply Air Volume:	2720 cfm		
Supply Air Density:	0.075 lb/ft^3		

Rate:	\$0.08		
75% Load EER:	18.31	COP	
SAVINGS			
Cooling kWh:	1,876.12	Heating kWh:	7,603.19
Dollars:	\$150.09	Dollars:	\$608.25
75%	\$112.57	75%	\$456.19

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q.(mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	0.96
85	89	87.7	36.2	57	100%	87.7	36.20	4.10
80	84	82.1	33.3	229	100%	82.1	33.30	11.61
75	79	76.7	31.2	289	100%	76.7	31.20	10.20
70	74	72.5	29.6	246	100%	72.5	29.60	5.79
65	69	67.9	28.2	260	100%	67.9	28.20	3.45
60	64	62.6	24.9	243	100%	62.6	24.90	2.67
55	59	57.2	21.7	172	100%	57.2	21.70	1.29
50	54	52.1	19.1	192	100%	52.1	19.10	5.10
45	49	47.4	16.8	133	100%	47.4	16.80	5.78
40	44	43.0	14.8	199	100%	43.0	14.80	11.57
35	39	37.4	12.7	248	100%	37.4	12.70	18.25
30	34	32.1	10.6	182	100%	32.1	10.60	16.20
25	29	27.6	9	146	100%	27.6	9.00	14.71
20	24	23.1	7.4	100	100%	23.1	7.40	11.25
15	19	17.4	5.6	110	100%	17.4	5.60	13.83
10	14	12.0	4	58	100%	12.0	4.00	7.97
5	9	7.4	2.7	20	100%	7.4	2.70	2.94
0	4	2.6	1.3	19	100%	2.6	1.30	2.99
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	1.00
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00

USA\_OH\_Toledo.725360\_TMY3.bin

**HEAT RECOVERY UNIT SAVINGS****AHU-7****INPUTS**

Minimum Fraction Outdoor Air:	100%		
Heat Recover Effectiveness:	10.0%		
Summer Set Point Temperature:	72 F	Winter Set Point	70
Set Point Enthalpy:	26.39 Btu/lba	Set Point Enthalpy:	22.72
Supply Air Temperature:	53 F		
Supply Air Enthalpy:	21.86 Btu/lba		
Supply Air Volume:	6920 cfm		
Supply Air Density:	0.075 lb/ft^3		

Rate:	\$0.08		
75% Load EER:	18.31 COP		3.73
<b>SAVINGS</b>			
Cooling kWh:	795.51	Heating kWh:	3,223.90
Dollars:	\$63.64	Dollars:	\$257.91
75%	\$47.73	75%	\$193.43

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q (mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	0.41
85	89	87.7	36.2	57	100%	87.7	36.20	1.74
80	84	82.1	33.3	229	100%	82.1	33.30	4.92
75	79	76.7	31.2	289	100%	76.7	31.20	4.33
70	74	72.5	29.6	246	100%	72.5	29.60	2.46
65	69	67.9	28.2	260	100%	67.9	28.20	1.46
60	64	62.6	24.9	243	100%	62.6	24.90	1.13
55	59	57.2	21.7	172	100%	57.2	21.70	0.55
50	54	52.1	19.1	192	100%	52.1	19.10	2.16
45	49	47.4	16.8	133	100%	47.4	16.80	2.45
40	44	43.0	14.8	199	100%	43.0	14.80	4.91
35	39	37.4	12.7	248	100%	37.4	12.70	7.74
30	34	32.1	10.6	182	100%	32.1	10.60	6.87
25	29	27.6	9	146	100%	27.6	9.00	6.24
20	24	23.1	7.4	100	100%	23.1	7.40	4.77
15	19	17.4	5.6	110	100%	17.4	5.60	5.86
10	14	12.0	4	58	100%	12.0	4.00	3.38
5	9	7.4	2.7	20	100%	7.4	2.70	1.25
0	4	2.6	1.3	19	100%	2.6	1.30	1.27
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	0.42
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00
							<b>64.32</b>	

USA\_OH\_Toledo.725360\_TMY3.bin

## HEAT RECOVERY UNIT SAVINGS

AHU-8

## INPUTS

AHU 015	
Minimum Fraction Outdoor Air:	50%
Heat Recover Effectiveness:	60.0%
Summer Set Point Temperature:	72 F
Set Point Enthalpy:	26.39 Btu/lba
Supply Air Temperature:	53 F
Supply Air Enthalpy:	21.86 Btu/lba
Supply Air Volume:	5635 cfm
Supply Air Density:	0.075 lb/ft^3
Winter Set Point	70
Set Point Enthalpy:	22.72

Rate:	\$0.08	
75% Load EER:	18.31	COP
SAVINGS		
Cooling kWh:	2,302.35	Heating kWh: 8,884.95
Dollars:	\$184.19	Dollars: \$710.80
75%	\$138.14	75% \$533.10

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q (mmBTU)
105	109	107.0	0	0	50%	89.5	13.20	0.00
100	104	102.0	0	0	50%	87.0	13.20	0.00
95	99	97.0	0	0	50%	84.5	13.20	0.00
90	94	91.3	38.3	11	50%	81.7	32.35	1.00
85	89	87.7	36.2	57	50%	79.9	31.30	4.25
80	84	82.1	33.3	229	50%	77.1	29.85	12.03
75	79	76.7	31.2	289	50%	74.4	28.80	10.57
70	74	72.5	29.6	246	50%	72.3	28.00	6.00
65	69	67.9	28.2	260	100%	67.9	28.20	7.14
60	64	62.6	24.9	243	100%	62.6	24.90	5.52
55	59	57.2	21.7	172	100%	57.2	21.70	2.67
50	54	52.1	19.1	192	95%	53.0	19.43	10.10
45	49	47.4	16.8	133	77%	53.0	18.98	9.25
40	44	43.0	14.8	199	66%	53.0	18.80	15.71
35	39	37.4	12.7	248	55%	53.0	18.87	20.76
30	34	32.1	10.6	182	50%	52.1	18.50	16.78
25	29	27.6	9	146	50%	49.8	17.70	15.24
20	24	23.1	7.4	100	50%	47.6	16.90	11.65
15	19	17.4	5.6	110	50%	44.7	16.00	14.33
10	14	12.0	4	58	50%	42.0	15.20	8.26
5	9	7.4	2.7	20	50%	39.7	14.55	3.05
0	4	2.6	1.3	19	50%	37.3	13.85	3.10
-5	-1	-1.7	0.1	6	50%	35.2	13.25	1.03
-10	-6	-7.1	-1.3	0	50%	32.5	12.55	0.00
<b>178.44</b>					<b>50%</b>	<b>32.5</b>	<b>12.55</b>	<b>0.00</b>

USA\_OH\_Toledo.725360\_TMY3.bin

**HEAT RECOVERY UNIT SAVINGS**

AHU-9

**INPUTS**

Minimum Fraction Outdoor Air:	100%		
Heat Recover Effectiveness:	10.0%		
Summer Set Point Temperature:	72 F	Winter Set Point	70
Set Point Enthalpy:	26.39 Btu/lba	Set Point Enthalpy:	22.72
Supply Air Temperature:	53 F		
Supply Air Enthalpy:	21.86 Btu/lba		
Supply Air Volume:	5100 cfm		
Supply Air Density:	0.075 lb/ft^3		

Rate:	\$0.08		
75% Load EER:	18.31 COP		3.73
SAVINGS			
Cooling kWh:	586.29	Heating kWh:	2,376.00
Dollars:	\$46.90	Dollars:	\$190.08
75%	\$35.18	75%	\$142.56

Weekend Factor  
0.142857

StrTemp	EndTemp	Toa(F)	hoa(Btu/lba)	hrs	foa	Tma(F)	hma(Btu/lba)	Q (mmBTU)
105	109	107.0	0	0	100%	107.0	0.00	0.00
100	104	102.0	0	0	100%	102.0	0.00	0.00
95	99	97.0	0	0	100%	97.0	0.00	0.00
90	94	91.3	38.3	11	100%	91.3	38.30	0.30
85	89	87.7	36.2	57	100%	87.7	36.20	1.28
80	84	82.1	33.3	229	100%	82.1	33.30	3.63
75	79	76.7	31.2	289	100%	76.7	31.20	3.19
70	74	72.5	29.6	246	100%	72.5	29.60	1.81
65	69	67.9	28.2	260	100%	67.9	28.20	1.08
60	64	62.6	24.9	243	100%	62.6	24.90	0.83
55	59	57.2	21.7	172	100%	57.2	21.70	0.40
50	54	52.1	19.1	192	100%	52.1	19.10	1.60
45	49	47.4	16.8	133	100%	47.4	16.80	1.81
40	44	43.0	14.8	199	100%	43.0	14.80	3.62
35	39	37.4	12.7	248	100%	37.4	12.70	5.70
30	34	32.1	10.6	182	100%	32.1	10.60	5.06
25	29	27.6	9	146	100%	27.6	9.00	4.60
20	24	23.1	7.4	100	100%	23.1	7.40	3.52
15	19	17.4	5.6	110	100%	17.4	5.60	4.32
10	14	12.0	4	58	100%	12.0	4.00	2.49
5	9	7.4	2.7	20	100%	7.4	2.70	0.92
0	4	2.6	1.3	19	100%	2.6	1.30	0.93
-5	-1	-1.7	0.1	6	100%	-1.7	0.10	0.31
-10	-6	-7.1	-1.3	0	100%	-7.1	-1.30	0.00
							<b>47.40</b>	

## 725360TY.bin

StrTemp	EndTemp	T(F)	Twb(F)	h(Btu/lba)	w(lbw/lba)	hrs1-8	hrs9-16	hrs17-24
=====	=====	=====	=====	=====	=====	=====	=====	=====
105	109	107	-99	-99	-99	0	0	0
100	104	102	-99	-99	-99	0	0	0
95	99	97	-99	-99	-99	0	0	0
90	94	91.3	74.8	38.3	0.0148	0	11	5
85	89	87.7	72.4	36.2	0.0138	0	57	23
80	84	82.1	68.8	33.3	0.0124	0	229	93
75	79	76.7	66	31.2	0.0117	23	289	178
70	74	72.5	63.8	29.6	0.0112	80	246	211
65	69	67.9	61.9	28.2	0.0109	268	260	273
60	64	62.6	57	24.9	0.0091	336	243	293
55	59	57.2	51.9	21.7	0.0073	264	172	246
50	54	52.1	47.5	19.1	0.0061	260	192	206
45	49	47.4	43.5	16.8	0.005	225	133	167
40	44	43	39.6	14.8	0.0041	199	199	197
35	39	37.4	35.8	12.7	0.0035	329	248	311
30	34	32.1	31.6	10.6	0.0027	269	182	180
25	29	27.6	28.2	9	0.0022	203	146	167
20	24	23.1	24.9	7.4	0.0017	150	100	147
15	19	17.4	20.9	5.6	0.0013	117	110	78
10	14	12	17.4	4	0.001	70	58	76
5	9	7.4	14.4	2.7	0.0008	56	20	42
0	4	2.6	11.3	1.3	0.0006	35	19	14
-5	-1	-1.7	8.5	0.1	0.0005	25	6	13
-10	-6	-7.1	5.1	-1.3	0.0004	11	0	0
-15	-11	-13	-99	-99	-99	0	0	0
-20	-16	-18	-99	-99	-99	0	0	0
-25	-21	-23	-99	-99	-99	0	0	0
-30	-26	-28	-99	-99	-99	0	0	0

hrs1-24

=====

0  
0  
0  
16  
80  
322  
490  
537  
801  
872  
682  
658  
525  
595  
888  
631  
516  
397  
305  
204  
118  
68  
44  
11  
0  
0  
0  
0



Product Quick Search

M4104T-9

Go

WHERE TO BUY | CONTACT US | SITE MAP

HOME

PRODUCTS

SUPPORT

NEWS/EVENTS

ABOUT BALDOR

**General Information****■ Overview****[Specifications](#)****■ Performance Data****■ Parts List****■ Drawings****More Information****■ Where To Buy****■ Baldor Sales Offices****◀ Return to List****[AC Motors](#) | [Severe Duty](#) |  
Specifications: M4104T-9**

SPEC. NUMBER:	10C151Y734H2
CATALOG NUMBER:	M4104T-9
FL AMPS:	76-70/35
208V AMPS:	--
BEARING-DRIVE-END:	6311
BEARING-OPP-DRIVE-END:	6309
DESIGN CODE:	C
DOE-CODE:	010A
FL EFFICIENCY:	92.4
ENCLOSURE:	TEFC
FRAME:	286T
HERTZ:	60
INSULATION-CLASS:	F
KVA-CODE:	G
SPEED [rpm]:	1770
OUTPUT [hp]:	30
PHASE:	3
POWER-FACTOR:	86
RATING:	40C AMB-CONT
SERIAL-NUMBER:	--
SERVICE FACTOR:	1.15
VOLTAGE:	208-230/460

ATTACHMENT H

\* For certified information, contact your local [Baldor office](#).
[Home](#) | [Products](#) | [Support](#) | [News/Events](#) | [About Baldor](#) | [RSS](#) | [YouTube](#)
[California Transparency in Supply Chains Act of 2010 Disclosures](#) | [Terms of Use](#) | [Privacy Policy](#)

Copyright © 2001-2012 Baldor Electric Company. All rights reserved.

P-6

## Millcreek West Unity

minimum ASHRAE efficiency                    10.9 seer

Operating Hours                                2800

total capacity                                52000 btu/hr

seer    16

Current Use                                 Minimum Eff Use

9100                                        13357.8

Savings                                        4257.798



HVAC Advanced Products Division

## Attachment L



## SUBMITTAL DATA: MSY-A24NA &amp; MSY-A24NA

24,000 BTU/H WALL-MOUNTED AIR-CONDITIONING SYSTEMS

Job Name:	Location:	Date:
Purchaser:	Engineer:	
Submitted to:	For <input type="checkbox"/> Reference <input type="checkbox"/> Approval <input type="checkbox"/> Construction	
Unit Designation:	Schedule No.:	

**GENERAL FEATURES**

- Wall-mounted indoor unit for residential applications
- Compact side discharge outdoor unit
- Zone control
- Quiet operation for both indoor and outdoor units
- "Powerful Mode" function permits system to temporarily run at a lower/higher temperature with an increased fan speed, which quickly brings the room to the optimum comfort level
- Wireless remote controller is included
- Indoor unit powered from outdoor unit using A-Control
- Automatic restart following a power outage
- Self-check function — onboard diagnostics
- Dry Mode function is standard
- Limited warranty: one year on parts and defects and six years on the compressor

**OPTIONAL ACCESSORIES****Indoor Unit**

- M-NET Control Adapter (MAC-399IF)
- MA Contact Terminal Interface (MAC-397IF)
- Wired Remote Controller (PAR-21MAA; requires MAC-397IF)
- Condensate Pump (230V; SI3100-230)
- Anti-allergy Enzyme Filter (MAC-2300FT)
- Three-pole Disconnect Switch (TAZ-MS303)

**Cooling\***

Rated Capacity .....	22,000 Btu/h
Minimum Capacity .....	4,400 Btu/h
SEER .....	16.0
Total Input .....	2,880 W

\* Rating Conditions (Cooling) - Indoor: 80°F (27°C) DB, 67°F (19°C) WB; Outdoor: 95°F (35°C) DB, 75°F (24°C) WB.

Power Supply .....	208 / 230V, 1-Phase, 60 Hz
Breaker Size .....	20 A

**Voltage**

Indoor - Outdoor S1-S2 .....	AC 208 / 230V
Indoor - Outdoor S2-S3 .....	DC 12-24V
Indoor - Remote Controller .....	Wireless

**OPERATING RANGE**

		Indoor Intake Air Temp.	Outdoor Intake Air Temp.
Cooling	Maximum	90°F (32°C) DB, 73°F (23°C) WB	115°F (46°C) DB
	Minimum	67°F (19°C) DB, 57°F (14°C) WB	14°F (-10°C) DB

<b>Indoor Unit</b>	
MCA .....	1.0 A
Fan Motor .....	0.76 F.L.A.
Airflow (Lo - Med - Hi - Powerful)	
Cooling .....	296 - 431 - 568 - 624 Dry CFM 265 - 385 - 508 - 558 Wet CFM
Sound Pressure Level (Lo - Med - Hi - Powerful)	
Cooling .....	34 - 40 - 49 - 51 dB(A)

DIMENSIONS	UNIT INCHES / MM
W	43-5/16 / 1,100
D	10-1/4 / 260
H	12-13/16 / 325

Weight .....	.37 lbs. / 17 kg
External Finish .....	Munsell No. 3Y 7.8 / 1.1
Field Drainpipe Size O.D. ....	.5/8" / 15.88 mm
Remote Controller .....	Wireless

<b>Outdoor Unit</b>	
Compressor .....	DC-driven Inverter Twin Rotary
MCA .....	17 A
Fan Motor .....	0.93 F.L.A.
Sound Pressure Level	
Cooling .....	55 dB(A)

DIMENSIONS	INCHES / MM
W	33-1/16 / 840
D	13 / 330
H	33-7/16 / 849



Weight .....	128 lbs. / 58 kg
External Finish .....	Munsell 3Y 7.8 / 1.1

Refrigerant Type .....	R410A
Refrigerant Pipe Size O.D. ....	
Gas Side .....	.5/8" / 15.88 mm
Liquid Side .....	.1/4" / 6.35 mm
Max. Refrigerant Pipe Length .....	100 ft. / 30 m
Max. Refrigerant Pipe Height Difference .....	50 ft. / 15 m
Connection Method .....	Flared




# DIMENSIONS: MSY-A24NA & MUY-A24NA


**MSY-A24NA**



**MUY-A24NA**



**REQUIRED SPACE**



**HVAC Advanced Products Division**  
3400 Lawrenceville Suwanee Rd  
Suwanee, GA 30024  
Tele: 678-376-2900 • Fax: 800-889-9904  
Toll Free: 800-433-4822 (#3)  
www.mehvac.com  
Specifications are subject to change without notice.



HVAC Advanced Products Division

## Attachment M



## SUBMITTAL DATA: MSY-A15NA &amp; MSY-A15NA

15,000 BTU/H WALL-MOUNTED AIR-CONDITIONING SYSTEMS

Job Name:	Location:	Date:
Purchaser:	Engineer:	
Submitted to:	For <input type="checkbox"/> Reference <input type="checkbox"/> Approval <input type="checkbox"/> Construction	
Unit Designation:	Schedule No.:	

**GENERAL FEATURES**

- Wall-mounted indoor unit for residential applications
- Compact side discharge outdoor unit
- Zone control
- Quiet operation for both indoor and outdoor units
- "Powerful Mode" function permits system to temporarily run at a lower/higher temperature with an increased fan speed, which quickly brings the room to the optimum comfort level
- Wireless remote controller is included
- Indoor unit powered from outdoor unit using A-Control
- Automatic restart following a power outage
- Self-check function — onboard diagnostics
- Dry Mode function is standard
- Limited warranty: one year on parts and defects and six years on the compressor

**OPTIONAL ACCESSORIES****Indoor Unit**

- M-NET Control Adapter (MAC-399IF)
- MA Contact Terminal Interface (MAC-397IF)
- Wired Remote Controller (PAR-21MAA; requires MAC-397IF)
- Condensate Pump (230V; SI3100-230)
- Anti-allergy Enzyme Filter (MAC-415FT)
- Three-pole Disconnect Switch (TAZ-MS303)

**Cooling\***

Rated Capacity .....	15,000 Btu/h
Minimum Capacity .....	3,100 Btu/h
SEER .....	16.0
Total Input .....	1,690 W

\* Rating Conditions (Cooling) - Indoor: 80°F (27°C) DB, 67°F (19°C) WB; Outdoor: 95°F (35°C) DB, 75°F (24°C) WB.

Power Supply .....	208 / 230V, 1-Phase, 60 Hz
Breaker Size .....	15 A

**Voltage**

Indoor - Outdoor S1-S2 .....	AC 208 / 230V
Indoor - Outdoor S2-S3 .....	DC 12-24V
Indoor - Remote Controller .....	Wireless

**OPERATING RANGE**

		Indoor Intake Air Temp.	Outdoor Intake Air Temp.
Cooling	Maximum	90°F (32°C) DB, 73°F (23°C) WB	115°F (46°C) DB
	Minimum	67°F (19°C) DB, 57°F (14°C) WB	14°F (-10°C) DB

**Indoor Unit**

MCA .....	1.0 A
Fan Motor .....	0.76 F.L.A.
Airflow (Lo - Med - Hi - Powerful) Cooling .....	.268 - 328 - 381 - 419 Dry CFM 240 - 293 - 342 - 376 Wet CFM
Sound Pressure Level (Lo - Med - Hi - Powerful) Cooling .....	34 - 40 - 45 - 47 dB(A)

DIMENSIONS	UNIT INCHES / MM
W	30-11/16 / 780
D	8-1/4 / 210
H	11-3/4 / 299

Weight .....	.23 lbs. / 10 kg
External Finish .....	Munsell No. 3Y 7.8 / 1.1
Field Drainpipe Size O.D. ....	.5/8" / 15.88 mm
Remote Controller .....	Wireless

**Outdoor Unit**

Compressor .....	DC-driven Inverter Twin Rotary
MCA .....	14 A
Fan Motor .....	0.52 F.L.A.
Sound Pressure Level Cooling .....	50 dB(A)



DIMENSIONS	INCHES / MM
W	31-1/2 / 800
D	11-1/4 / 286
H	21-5/8 / 549

Weight .....	.88 lbs. / 40 kg
External Finish .....	Munsell 3Y 7.8 / 1.1

Refrigerant Type .....	R410A
Refrigerant Pipe Size O.D.	
Gas Side .....	.1/2" / 12.7 mm
Liquid Side .....	.1/4" / 6.35 mm
Max. Refrigerant Pipe Length .....	65 ft. / 19 m
Max. Refrigerant Pipe Height Difference .....	40 ft. / 12 m
Connection Method .....	Flared



# DIMENSIONS: MSY-A15NA & MUY-A15NA



**HVAC Advanced Products Division**  
 3400 Lawrenceville Suwanee Rd  
 Suwanee, GA 30024  
 Tel: 678-376-2900 • Fax: 800-889-9904  
 Toll Free: 800-433-4822 (#3)  
[www.mehvac.com](http://www.mehvac.com)  
 Specifications are subject to change without notice.



**Mercantile Customer Project Commitment Agreement**  
**Cash Rebate Option**

**THIS MERCANTILE CUSTOMER PROJECT COMMITMENT AGREEMENT** ("Agreement") is made and entered into by and between Toledo Edison, its successors and assigns (hereinafter called the "Company") and Millcreek West Unity Local Schools, Taxpayer ID No.34-6407273its permitted successors and assigns (hereinafter called the "Customer") (collectively the "Parties" or individually the "Party") and is effective on the date last executed by the Parties as indicated below.

**WITNESSETH**

**WHEREAS**, the Company is an electric distribution utility and electric light company, as both of these terms are defined in R.C. § 4928.01(A); and

**WHEREAS**, Customer believes that it is a mercantile customer, as that term is defined in R.C. § 4928.01(A)(19), doing business within the Company's certified service territory; and

**WHEREAS**, R.C. § 4928.66 (the "Statute") requires the Company to meet certain energy efficiency and peak demand reduction ("EE&PDR") benchmarks; and

**WHEREAS**, when complying with certain EE&PDR benchmarks the Company may include the effects of mercantile customer-sited EE&PDR projects; and

**WHEREAS**, Customer has certain customer-sited demand reduction, demand response, or energy efficiency project(s) as set forth in attached Exhibit A (the "Customer Energy Project(s)") that it desires to commit to the Company for integration into the Company's Energy Efficiency & Peak Demand Reduction Program Portfolio Plan ("Company Plan") that the Company will implement in order to comply with the Statute; and

**WHEREAS**, the Customer, pursuant to the Public Utilities Commission of Ohio's ("Commission") September 15, 2010 Order in Case No. 10-834-EL-EEC, desires to pursue a cash rebate of some of the costs pertaining to its Customer Energy Project(s) ("Cash Rebate").

**WHEREAS**, Customer's decision to commit its Customer Energy Project(s) to the Company for inclusion in the Company Plan has been reasonably encouraged by the possibility of a Cash Rebate.

**WHEREAS**, in consideration of, and upon receipt of, said cash rebate, Customer will commit the Customer Energy Project(s) to the Company and will comply with all other terms and conditions set forth herein.

**NOW THEREFORE**, in consideration of the mutual promises set forth herein, and for other good and valuable consideration, the receipt and sufficiency of which is hereby acknowledged, the parties, intending to be legally bound, do hereby agree as follows:

1. **Customer Energy Projects.** Customer hereby commits to the Company and Company accepts for integration into the Company Plan the Customer Energy Project(s) set forth on attached Exhibit 1. Said commitment shall be for the life of the Customer Energy Project(s). Company will incorporate said project(s) into the Company Plan to the extent that such projects qualify. In so committing, Customer acknowledges that the information provided to the Company about the Customer Energy Project(s) is true and accurate to the best of its knowledge.
  - a. By committing the Customer Energy Project(s) to the Company, Customer acknowledges and agrees that the Company shall control the use of the kWh and/or kW reductions

resulting from said projects for purposes of complying with the Statute. It is expressly agreed that Customer may use any and all energy related and other attributes created from the Customer Energy Project(s) to the extent permitted by state or federal laws or regulations, provided, and to the extent, that such uses by Customer do not conflict with said compliance by the Company.

- b. The Company acknowledges that some of Customer's Energy Projects contemplated in this paragraph may have been performed under certain other federal and/or state programs in which certain parameters are required to be maintained in order to retain preferential financing or other government benefits (individually and collectively, as appropriate, "Benefits"). In the event that the use of any such project by the Company in any way affects such Benefits, and upon written request from the Customer, Company will release said Customer's Energy Project(s) to the extent necessary for Customer to meet the prerequisites for such Benefits. Customer acknowledges that such release (i) may affect Customer's cash rebate discussed in Article 3 below; and (ii) will not affect any of Customer's other requirements or obligations.
  - c. Any future Customer Energy Project(s) committed by Customer shall be subject to a separate application and, upon approval by the Commission, said projects shall become part of this Agreement.
  - d. Customer will provide Company or Company's agent(s) with reasonable assistance in the preparation of the Commission's standard joint application for approval of this Agreement ("Joint Application") that will be filed with the Commission, with such Joint Application being consistent with then current Commission requirements.
2. **Joint Application to the Commission.** The Parties will submit the Joint Application using the Commission's standard "Application to Commit Energy Efficiency/Peak Demand Reduction Programs" ("Joint Application") in which they will seek the Commission's approval of (i) this Agreement; (ii) the commitment of the Customer Energy Project(s) for inclusion in the Company Plan; and (iii) the Customer's Cash Rebate.

The Joint Application shall include all information as set forth in the Commission's standard form which, includes without limitation:

- i. A narrative description of the Customer Energy Project(s), including but not limited to, make, model and year of any installed and/or replaced equipment;
  - ii. A copy of this Agreement; and
  - iii. A description of all methodologies, protocols, and practices used or proposed to be used in measuring and verifying program results.
3. **Customer Cash Rebate and Annual Report.** Upon Commission approval of the Joint Application, Customer shall provide Company with a W-9 tax form, which shall at a minimum include Customer's tax identification number. Within the greater of 90 days of the Commission's approval of the Joint Application or the completion of the Customer Energy Project, the Company

will issue to the Customer the Cash Rebate in the amount set forth in the Commission's Finding and Order approving the Joint Application.

- a. Customer acknowledges: i) that the Company will cap the Cash Rebate at the lesser of 50% of Customer Energy Project(s) costs or \$250,000; ii) the maximum rebate that the Customer may receive per year is \$500,000 per Taxpayer Identification Number per utility service territory; and iii) if the Customer Energy Project qualifies for a rebate program approved by the Commission and offered by the Company, Customer may still elect to file such project under the Company's mercantile customer self direct program, however the Case Rebate that will be paid shall be discounted by 25%; and
- b. Customer acknowledges that breaches of this Agreement, include, but are not limited to:
  - i. Customer's failure to comply with the terms and conditions set forth in the Agreement, or its equivalent, within a reasonable period of time after receipt of written notice of such non-compliance;
  - ii. Customer knowingly falsifying any documents provided to the Company or the Commission in connection with this Agreement or the Joint Application.
- c. In the event of a breach of this Agreement by the Customer, Customer agrees and acknowledges that it will repay to the Company, within 90 days of receipt of written notice of said breach, the full amount of the Cash Rebate paid under this Agreement. This remedy is in addition to any and all other remedies available to the Company by law or equity.

**4. Termination of Agreement.** This Agreement shall automatically terminate:

- a. If the Commission fails to approve the Joint Agreement;
- b. Upon order of the Commission; or
- c. At the end of the life of the last Customer Energy Project subject to this Agreement.

Customer shall also have an option to terminate this Agreement should the Commission not approve the Customer's Cash Rebate, provided that Customer provides the Company with written notice of such termination within ten days of either the Commission issuing a final appealable order or the Ohio Supreme Court issuing its opinion should the matter be appealed.

- 5. Confidentiality.** Each Party shall hold in confidence and not release or disclose to any person any document or information furnished by the other Party in connection with this Agreement that is designated as confidential and proprietary ("Confidential Information"), unless: (i) compelled to disclose such document or information by judicial, regulatory or administrative process or other provisions of law; (ii) such document or information is generally available to the public; or (iii) such document or information was available to the receiving Party on a non-confidential basis at the time of disclosure.
- a. Notwithstanding the above, a Party may disclose to its employees, directors, attorneys, consultants and agents all documents and information furnished by the other Party in connection with this Agreement, provided that such employees, directors, attorneys, consultants and agents have been advised of the confidential nature of this information and through such disclosure are deemed to be bound by the terms set forth herein.

- b. A Party receiving such Confidential Information shall protect it with the same standard of care as its own confidential or proprietary information.
  - c. A Party receiving notice or otherwise concluding that Confidential Information furnished by the other Party in connection with this Agreement is being sought under any provision of law, to the extent it is permitted to do so under any applicable law, shall endeavor to: (i) promptly notify the other Party; and (ii) use reasonable efforts in cooperation with the other Party to seek confidential treatment of such Confidential Information, including without limitation, the filing of such information under a valid protective order.
  - d. By executing this Agreement, Customer hereby acknowledges and agrees that Company may disclose to the Commission or its Staff any and all Customer information, including Confidential Information, related to a Customer Energy Project, provided that Company uses reasonable efforts to seek confidential treatment of the same.
6. **Taxes.** Customer shall be responsible for all tax consequences (if any) arising from the payment of the Cash Rebate.
7. **Notices.** Unless otherwise stated herein, all notices, demands or requests required or permitted under this Agreement must be in writing and must be delivered or sent by overnight express mail, courier service, electronic mail or facsimile transmission addressed as follows:

**If to the Company:**

FirstEnergy Service Company  
76 South Main Street  
Akron, OH 44308  
Attn: Victoria Nofziger  
Telephone: 330-384-4684  
Fax: 330-761-4281  
Email: [vnnofziger@firstenergycorp.com](mailto:vnnofziger@firstenergycorp.com)

**If to the Customer:**

Millcreek West Unity Local Schools  
1401 W. Jackson St.  
West Unity OH 43570  
Attn: Traci Thompson  
419.924.2366  
email: [TThompson@hilltopcadets.org](mailto:TThompson@hilltopcadets.org)

or to such other person at such other address as a Party may designate by like notice to the other Party. Notice received after the close of the business day will be deemed received on the next business day; provided that notice by facsimile transmission will be deemed to have been received by the recipient if the recipient confirms receipt telephonically or in writing.

- 8. **Authority to Act.** The Parties represent and warrant that they are represented by counsel in connection with this Agreement, have been fully advised in connection with the execution thereof, have taken all legal and corporate steps necessary to enter into this Agreement, and that the undersigned has the authority to enter into this Agreement, to bind the Parties to all provisions herein and to take the actions required to be performed in fulfillment of the undertakings contained herein.
- 9. **Non-Waiver.** The delay or failure of either party to assert or enforce in any instance strict performance of any of the terms of this Agreement or to exercise any rights hereunder conferred, shall not be construed as a waiver or relinquishment to any extent of its rights to assert or rely upon such terms or rights at any later time or on any future occasion.
- 10. **Entire Agreement.** This Agreement, along with related exhibits, and the Company's Rider DSE, or its equivalent, as amended from time to time by the Commission, contains the Parties' entire understanding with respect to the matters addressed herein and there are no verbal or collateral representations, undertakings, or agreements not expressly set forth herein. No change in, addition to, or waiver of the terms of this Agreement shall be binding upon any of the Parties unless the same is set forth in writing and signed by an authorized representative of each of the Parties. In

the event of any conflict between Rider DSE or its equivalent and this document, the latter shall prevail.

11. **Assignment.** Customer may not assign any of its rights or obligations under this Agreement without obtaining the prior written consent of the Company, which consent will not be unreasonably withheld. No assignment of this Agreement will relieve the assigning Party of any of its obligations under this Agreement until such obligations have been assumed by the assignee and all necessary consents have been obtained.
12. **Severability.** If any portion of this Agreement is held invalid, the Parties agree that such invalidity shall not affect the validity of the remaining portions of this Agreement, and the Parties further agree to substitute for the invalid portion a valid provision that most closely approximates the economic effect and intent of the invalid provision.
13. **Governing Law.** This Agreement shall be governed by the laws and regulations of the State of Ohio, without regard to its conflict of law provisions.
14. **Execution and Counterparts.** This Agreement may be executed in multiple counterparts, which taken together shall constitute an original without the necessity of all parties signing the same page or the same documents, and may be executed by signatures to electronically or telephonically transmitted counterparts in lieu of original printed or photocopied documents. Signatures transmitted by facsimile shall be considered original signatures.

IN WITNESS WHEREOF, the Parties hereto have caused this Agreement to be executed by their duly authorized officers or representatives as of the day and year set forth below.

Millcreek West Utility Local  
(Customer)

By: Traci Thompson  
Title: Treasurer  
Date: 5/30/12

Toledo Edison  
(Company)

By: John C. Parvin  
Title: VP, Energy Efficiency  
Date: 5-7-12



## Energy Savings Predictor Report Industrial Edition

To:

Date: 10/2/2012

Prepared by:

Project: Millcreek West Unity

<b>Utility:</b>	First Energy: Toledo Edison	Base Rate:	\$ 0.10
Demand Charge:	\$ 0.10	Alternate Rate:	\$ 0.10

### Estimated Energy Savings


System	Energy Usage
Present System:	119,160 kWh
Drive System:	86,123 kWh
<b>Energy Saved:</b>	<b>33,037 kWh</b>
Predicted Savings:	Total
Energy Saved/Year:	\$ 3,304
<b>Yearly Savings:</b>	<b>\$ 3,308</b>

### **Carbon Dioxide Emissions**

System	Carbon Footprint
Present System:	43.67 Ton(s)
Drive System:	31.56 Ton(s)
<b>Carbon Dioxide Savings:</b>	<b>12.11 Ton(s)</b>



**Simple Project Payback/ROI: 1.330 Years**



Carbon Dioxide (CO2) savings estimation based on electricity produced from Coal at 0.733 of CO2/Lbs

Weight Units: English

Calculations are based on available data. Yaskawa America, Inc. assumes no responsibility for the accuracy of the supplied data or of this report.

## GLHP

### System Data

System Identification:	GLHP	Pump System
Type:	Pump System	
Flow Control:	Discharge Valve	Minimum Head: 10 ft.wg.

Motor Data		Drive and Installation Data		Duty Cycle						
Efficiency:	92.4 %	Drive Cost:	\$ 4,400	Rate	Flow (%)	Time (%)	Time (Hours)			
Power:	30 HP	Install Cost:	\$ 0	B	100 %	20 %	1,100			
Voltage:	208 V	Dem. Rebate:	\$ 0.10	B	90 %	30 %	1,650			
FLA:	88 A	# Systems:	1	B	80 %	20 %	1,100			
<b>Incentive</b>		<b>Drive Selection</b>		B	70 %	10 %	550			
Utility Rebate:	\$ 0 per system; One-time	Catalog #:	P7U20221A	B	60 %	10 %	550			
				B	50 %	5 %	275			
				B	40 %	5 %	275			
				B	30 %	0 %	0			
				B	20 %	0 %	0			
				B	10 %	0 %	0			
				<b>B</b>	<b>= Base Rate</b>					
				<b>A</b>	<b>= Alternate Rate</b>					
<b>Hours of Operation</b>										
Hours per Day:	22 Hours									
Days per Week:	5 Days									
Weeks per Year:	50 Weeks									
<b>Total Hours:</b>	5,500 Hours/Year									



### Carbon Dioxide Emissions

System	Carbon Footprint Single	Carbon Footprint Total
Present System:	43.67 Ton(s)	43.67 Ton(s)
Drive System:	31.56 Ton(s)	31.56 Ton(s)
<b>Savings:</b>	<b>12.11 Ton(s)</b>	<b>12.11 Ton(s)</b>

<b>Payback Analysis</b>	<b>Year 1</b>	<b>Year 2</b>	<b>Year 3</b>	<b>Year 4</b>	<b>Year 5</b>	<b>Total</b>
Equipment Cost:	\$ 4,400					\$ 4,400
Installation Cost:	\$ 0					\$ 0
Utility Rebate:	\$ 0					\$ 0
Demand Savings:	\$ 5	\$ 5	\$ 5	\$ 5	\$ 5	\$ 23
Energy Saved:	\$ 3,304	\$ 3,304	\$ 3,304	\$ 3,304	\$ 3,304	\$ 16,519
<b>Total:</b>	<b>\$ -1,091</b>	<b>\$ 2,217</b>	<b>\$ 5,525</b>	<b>\$ 8,834</b>	<b>\$ 12,142</b>	<b>\$ 12,142</b>



### Estimated Energy Savings

<b>Operating Info:</b>	<b>Single</b>	<b>Total</b>	<b>Predicted Savings:</b>	<b>Single</b>	<b>Total</b>
Operating Hours:	5,500 Hours	5,500 Hours	Energy Saved/Year:	\$ 3,304	\$ 3,304
Present System:	119,160 kWh	119,160 kWh	Demand Savings/Year:	\$ 5	\$ 5
Drive System:	86,123 kWh	86,123 kWh	<b>Yearly Savings:</b>	<b>\$ 3,308</b>	<b>\$ 3,308</b>
<b>Energy Saved:</b>	<b>33,037 kWh</b>	<b>33,037 kWh</b>	<b>Simple Payback Time:</b>	1.330 Years	



Carbon Dioxide (CO2) savings estimation based on electricity produced from Coal at 0.733 of CO2/Lbs

Weight Units: English



Calculations are based on available data. Yaskawa America, Inc. assumes no responsibility for the accuracy of the supplied data or of this report.

Chart(s)

Calculations are based on available data. Yaskawa America, Inc. assumes no responsibility for the accuracy of the supplied data or of this report.

Chart(s)

Calculations are based on available data. Yaskawa America, Inc. assumes no responsibility for the accuracy of the supplied data or of this report.

Chart(s)

Calculations are based on available data. Yaskawa America, Inc. assumes no responsibility for the accuracy of the supplied data or of this report.

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**10/15/2012 2:08:54 PM**

**in**

**Case No(s). 12-1828-EL-EEC**

Summary: Application to Commit Energy Efficiency/Peak Demand Reduction Programs of The Toledo Edison Company and Millcreek-West Unity Local Schools electronically filed by Ms. Jennifer M. Sybyl on behalf of The Toledo Edison Company and Millcreek-West Unity Local Schools