

Case No. 12-2504-EL-REN

Willow Brook Farms

Staff Interrogatories – Initial Set

Question 1: The AcquiSuite EMB A8810 described in section N of the application is a data acquisition service that receives data from the meter, not the actual meter itself. Please provide the manufacturer, serial number, type, date of last certification, and photograph of the meter you will be using to measure output from the generating facility.

Answer 1: The meter is a WattsOn meter, Model MSCT3, Type 800A. It's serial number is 58715. The picture of the meter is below.



This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/16/2012 1:14:13 PM

in

Case No(s). 12-2504-EL-REN

Summary: Response in the matter of the incorrect meter information on the application for a renewable energy facility for Willow Brook Farms electronically filed by Mr. Gary Lakritz on behalf of Willow Brook Farms