



**Application to Commit
Energy Efficiency/Peak Demand
Reduction Programs
(Mercantile Customers Only)**

Case No.: 12-2927-EL-EEC

Mercantile Customer: Air Liquide Industrial US LP

Electric Utility: The Toledo Edison Company

**Program Title or
Description:** Energy Efficiency Lighting Retrofit Project for 2011

Rule 4901:1-39-05(F), Ohio Administrative Code (O.A.C.), permits a mercantile customer to file, either individually or jointly with an electric utility, an application to commit the customer's existing demand reduction, demand response, and energy efficiency programs for integration with the electric utility's programs. The following application form is to be used by mercantile customers, either individually or jointly with their electric utility, to apply for commitment of such programs in accordance with the Commission's pilot program established in Case No. 10-834-EL-POR

Completed applications requesting the cash rebate reasonable arrangement option (Option 1) in lieu of an exemption from the electric utility's energy efficiency and demand reduction (BEDR) rider will be automatically approved on the sixty-first calendar day after filing, unless the Commission, or an attorney examiner, suspends or denies the application prior to that time. Completed applications requesting the exemption from the BEDR rider (Option 2) will also qualify for the 60-day automatic approval so long as the exemption period does not exceed 24 months. Rider exemptions for periods of more than 24 months will be reviewed by the Commission Staff and are only approved up the issuance of a Commission order.

Complete a separate application for each customer program. Projects undertaken by a customer as a single program at a single location or at various locations within the same service territory should be submitted together as a single program filing, when possible. Check all boxes that are applicable to your program. For each box checked, be sure to complete all subparts of the question, and provide all requested additional information. Submittal of incomplete applications may result in a suspension of the automatic approval process or denial of the application.

Any confidential or trade secret information may be submitted to Staff on disc or via email at ee-pdr@puc.state.oh.us.

Section 1: Mercantile Customer Information

Name: Air Liquide Industrial US LP

Principal address: 3535 W. 12th Street, Houston, TX 77008

Address of facility for which this energy efficiency program applies:

1720 Trade Road, Holland, OH 43528

Name and telephone number for responses to questions:

Brad Engle - Energy Optimization Manager (713-438-6358)

Electricity use by the customer (check the box(es) that apply):

- ☒ The customer uses more than seven hundred thousand kilowatt hours per year at the above facility. (Please attach documentation.)
- ☐ The customer is part of a national account involving multiple facilities in one or more states. (Please attach documentation.)

Section 2: Application Information

A) The customer is filing this application (choose which applies):

- ☐ Individually, without electric utility participation.
- ☒ Jointly with the electric utility.

B) The electric utility is: The Toledo Edison Company

C) The customer is offering to commit (check any that apply):

- ☐ Energy savings from the customer's energy efficiency program. (Complete Sections 3, 5, 6, and 7.)
- ☐ Capacity savings from the customer's demand response/demand reduction program. (Complete Sections 4, 5, 6, and 7.)
- ☒ Both the energy savings and the capacity savings from the customer's energy efficiency program. (Complete all sections of the Application.)

Section 3: Energy Efficiency Programs

A) The customer's energy efficiency program involves (check those that apply):

- ☒ Early replacement of fully functioning equipment with new equipment. (Provide the date on which the customer replaced fully functioning equipment, and the date on which the customer would have replaced such equipment if it had not been replaced early. Please include a brief explanation for how the customer determined this future replacement date (or, if not known, please explain why this is not known)). **If Checked, Please see Exhibit 1 and Exhibit 2**
- ☐ Installation of new equipment to replace equipment that needed to be replaced. The customer installed new equipment on the following date(s): ____.
- ☐ Installation of new equipment for new construction or facility expansion. The customer installed new equipment on the following date(s): ____.
- ☐ Behavioral or operational improvement.

B) Energy savings achieved/to be achieved by the energy efficiency program:

- 1) If you checked the box indicating that the project involves the early replacement of fully functioning equipment replaced with new equipment, then calculate the annual savings [(kWh used by the original equipment) - (kWh used by new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: 286,349 kWh

- 2) If you checked the box indicating that the customer installed new equipment to replace equipment that needed to be replaced, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh used by the higher efficiency new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: _____ kWh

Please describe any less efficient new equipment that was rejected in favor of the more efficient new equipment. **Please see Exhibit 1 if applicable**

- 3) If you checked the box indicating that the project involves equipment for new construction or facility expansion, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh used by higher efficiency new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: _____ kWh

Please describe the less efficient new equipment that was rejected in favor of the more efficient new equipment. **Please see Exhibit 1 if applicable**

- 4) If you checked the box indicating that the project involves behavioral or operational improvements, provide a description of how the annual savings were determined.

Section 4: Demand Reduction/Demand Response Programs

A) The customer's program involves (check the one that applies):

- ☒ Coincident peak-demand savings from the customer's energy efficiency program.
- ☐ Actual peak-demand reduction. (Attach a description and documentation of the peak-demand reduction.)
- ☐ Potential peak-demand reduction (check the one that applies):
 - ☐ The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a tariff of a regional transmission organization (RTO) approved by the Federal Energy Regulatory Commission.
 - ☐ The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a program that is equivalent to an RTO program, which has been approved by the Public Utilities Commission of Ohio.

B) On what date did the customer initiate its demand reduction program?

See Exhibit 2

C) What is the peak demand reduction achieved or capable of being achieved (show calculations through which this was determined):

28 kW

Section 5: Request for Cash Rebate Reasonable Arrangement (Option 1) or Exemption from Rider (Option 2)

Under this section, check the box that applies and fill in all blanks relating to that choice.

Note: If Option 2 is selected, the application will not qualify for the 60-day automatic approval. All applications, however, will be considered on a timely basis by the Commission.

A) The customer is applying for:

☒ Option 1: A cash rebate reasonable arrangement.

OR

☐ Option 2: An exemption from the energy efficiency cost recovery mechanism implemented by the electric utility.

OR

☐ Commitment payment

B) The value of the option that the customer is seeking is:

Option 1: A cash rebate reasonable arrangement, which is the lesser of (show both amounts):

☒ A cash rebate of \$10,322. (Rebate shall not exceed 50% project cost. Attach documentation showing the methodology used to determine the cash rebate value and calculations showing how this payment amount was determined.)

Option 2: An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider.

☐ An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for _____ months (not to exceed 24 months). (Attach calculations showing how this time period was determined.)

OR

☐ A commitment payment valued at no more than \$_____. (Attach documentation and calculations showing how this payment amount was determined.)

OR

- ☐ Ongoing exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for an initial period of 24 months because this program is part of the customer's ongoing efficiency program. (Attach documentation that establishes the ongoing nature of the program.) In order to continue the exemption beyond the initial 24 month period, the customer will need to provide a future application establishing additional energy savings and the continuance of the organization's energy efficiency program.)

Section 6: Cost Effectiveness

The program is cost effective because it has a benefit/cost ratio greater than 1 using the (choose which applies):

- ☐ Total Resource Cost (TRC) Test. The calculated TRC value is: _____(Continue to Subsection 1, then skip Subsection 2)
- ☒ Utility Cost Test (UCT) . The calculated UCT value is: **See Exhibit 3** (Skip to Subsection 2.)

Subsection 1: TRC Test Used (please fill in all blanks).

The TRC value of the program is calculated by dividing the value of our avoided supply costs (generation capacity, energy, and any transmission or distribution) by the sum of our program overhead and installation costs and any incremental measure costs paid by either the customer or the electric utility.

The electric utility's avoided supply costs were _____.

Our program costs were _____.

The incremental measure costs were _____.

Subsection 2: UCT Used (please fill in all blanks).

We calculated the UCT value of our program by dividing the value of our avoided supply costs (capacity and energy) by the costs to our electric utility (including administrative costs and incentives paid or rider exemption costs) to obtain our commitment.

Our avoided supply costs were **See Exhibit 3**

The utility's program costs were **See Exhibit 3**

The utility's incentive costs/rebate costs were **See Exhibit 3**

Section 7: Additional Information

Please attach the following supporting documentation to this application:

- Narrative description of the program including, but not limited to, make, model, and year of any installed and replaced equipment.
- A copy of the formal declaration or agreement that commits the program or measure to the electric utility, including:
 - 1) any confidentiality requirements associated with the agreement;
 - 2) a description of any consequences of noncompliance with the terms of the commitment;
 - 3) a description of coordination requirements between the customer and the electric utility with regard to peak demand reduction;
 - 4) permission by the customer to the electric utility and Commission staff and consultants to measure and verify energy savings and/or peak-demand reductions resulting from your program; and,
 - 5) a commitment by the customer to provide an annual report on your energy savings and electric utility peak-demand reductions achieved.
- A description of all methodologies, protocols, and practices used or proposed to be used in measuring and verifying program results. Additionally, identify and explain all deviations from any program measurement and verification guidelines that may be published by the Commission.

Ohio | Public Utilities Commission

Application to Commit
Energy Efficiency/Peak Demand
Reduction Programs
(Mercantile Customers Only)

Case No.: 12-2927-EL-EEC

State of Ohio :

, Affiant, being duly sworn according to law, deposes and says that:

1. I am the duly authorized representative of:

Air Liquide Industrial US LP

[insert customer or BDU company name and any applicable name(s) doing business as]

2. I have personally examined all the information contained in the foregoing application, including any exhibits and attachments. Based upon my examination and inquiry of those persons immediately responsible for obtaining the information contained in the application, I believe that the information is true, accurate and complete.

Terrence A. B...


Signature of Affiant & Title

Sworn and subscribed before me this 15 day of NOVEMBER, 2012 Month/Year

C. Casey
Signature of official administering oath

Christopher Casey Notary Public
Print Name and Title

My commission expires on 03/17/2015



Customer Legal Entity Name: Air Liquide Industrial US LP

Site Address: Air Liquide Industrial US LP

Principal Address: 1720 Trade Road

Project No.	Project Name	Narrative description of your program including, but not limited to, make, model, and year of any installed and replaced equipment:	Description of methodologies, protocols and practices used in measuring and verifying project results	What date would you have replaced your equipment if you had not replaced it early? Also, please explain briefly how you determined this future replacement date.	Please describe the less efficient new equipment that you rejected in favor of the more efficient new equipment.
1	Toledo Plant - Lighting Retrofit	Pre-Retrofit Equipment: (1.) Halogen Lamps (22) Total each lamp at 1500-Watts, LITHONIA Mini Floodlight Fixture Model #H1500. (2.) Halogen Lamps (5) Total each lamp at 175-Watts, LITHONIA Model #H175. (3.) Halogen Lamps (2) Total each lamp at 150-Watts, model number #H150. (4.) Fluorescent T-12 Lamps (25) Fixtures each fixture at 273-Watts, Sylvania model number #F83SS. Post-Retrofit Equipment "Replacement Equipment": (1.) Metal Halide (22) Total each lamp at 150-Watts, RAB Lighting Fixture Model #MH150 - also installed with Photocell, INTERMATIC model number #6P008, (2.) Halogen Lamps (5) Total each at 175-Watts - Photocell installed, INTERMATIC model number #6P008, (3.) Halogen Lamps (2) Total each at 150-Watts - Photocell installed INTERMATIC model number #6P008. (4.) Fluorescent T-5 Lamps (12) Fixtures with each Fixture having (6) lamps, each lamp at	Practices used to verify light retrofit performance include: (1.) Verification of installed lighting fixtures & lamps with reduced "Watts Per Fixture". (2.) Verification of Photocell performance installed on various replacement fixtures. Additionally daily verification of Photocell performance observed by Plant Personnel/Team.	If this lighting equipment was not replaced early it most likely would have been replaced in a 8-16 year timeframe. Due to the high life cycle cost of operating this energy inefficient lighting system the decision was made for replacement. This retrofit was a large savings to the annual life cycle cost of the operating the lighting system.	N/A

Exhibit 2

Customer Legal Entity Name: Air Liquide Industrial US LP

Site Address: Air Liquide Industrial US LP

Principal Address: 1720 Trade Road

	Unadjusted Usage, kwh (A)	Weather Adjusted Usage, kwh (B)	Weather Adjusted Usage with Energy Efficiency Addbacks, kwh (C) <i>Note 1</i>
2011	60,476,082	60,476,082	60,692,609
Average	60,476,082	60,476,082	60,692,609

Project Number	Project Name	In-Service Date	Project Cost \$	50% of Project Cost \$	KWh Saved/Year (D) counting towards utility compliance	KWh Saved/Year (E) eligible for incentive	Utility Peak Demand Reduction Contribution, KW (F)	Prescriptive Rebate Amount (G) \$	Eligible Rebate Amount (H) \$ <i>Note 2</i>
1	Toledo Plant - Lighting Retrofit	03/31/2011	\$37,214	\$18,607	286,349	286,349	28	\$13,762	\$10,322
					-	-	-		
					-	-	-		
					-	-	-		
					-	-	-		
					-	-	-		
					-	-	-		
					-	-	-		
		Total	\$37,214		286,349	286,349	28	\$13,762	\$10,322

Docket No. 12-2927

Site: 1720 Trade Road

Notes

(1) Customer's usage is adjusted to account for the effects of the energy efficiency programs included in this application. When applicable, such adjustments are prorated to the in-service date to account for partial year savings.

(2) The eligible rebate amount is based upon 75% of the rebates offered by the FirstEnergy Commercial and Industrial Energy Efficiency programs or 75% of \$0.08/kWh for custom programs for all energy savings eligible for a cash rebate as defined in the PUCO order in Case NO.10-834-EL-EEC dated 9/15/2010, not to exceed the lesser of 50% of the project cost or \$250,000 per project. The rebate also cannot exceed \$500,000 per customer per year, per utility service territory.

**Commitment
Payment
\$**

\$0

Exhibit 3 Utility Cost Test

UCT = Utility Avoided Costs / Utility Costs

Project	Total Annual Savings, MWh (A)	Utility Avoided Cost \$/MWh (B)	Utility Avoided Cost \$ (C)	Utility Cost \$ (D)	Cash Rebate \$ (E)	Administrator Variable Fee \$ (F)	Total Utility Cost \$ (G)	UCT (H)
1	286	\$ 308	\$ 88,276	\$ 4,050	\$10,322		\$ 14,372	6.1
Total	286	\$ 308	88,276	4,050	\$10,322	\$0	14,372	6.1

Notes

- (A) From Exhibit 2, = kWh saved / 1000
- (B) This value represents avoided energy costs (wholesale energy prices) from the Department of Energy, Energy Information Administration's 2009 Annual Energy Outlook (AEO) low oil prices case. The AEO represents a national average energy price, so for a better representation of the energy price that Ohio customers would see, a Cinergy Hub equivalent price was derived by applying a ratio based on three years of historic national average and Cinergy Hub prices. This value is consistent with avoided cost assumptions used in EE&PDR Program Portfolio and Initial Benchmark Report, filed Dec 15, 2009 (See Section 8.1, paragraph a).
- (C) = (A) * (B)
- (D) Represents the utility's costs incurred for self-directed mercantile applications for applications filed and applications in progress. Includes incremental costs of legal fees, fixed administrative expenses, etc.
- (E) This is the amount of the cash rebate paid to the customer for this project.
- (F) Based on approximate Administrator's variable compensation for purposes of calculating the UCT, actual compensation may be less.
- (G) = (D) + (E) + (F)
- (H) = (C) / (G)

Air Liquide Industrial US LP ~ Air Liquide Industrial US LP
Docket No. 12-2927

Site: 1720 Trade Road



Annual kWh 356,280





Pre-Retrofit Annual Usage -kWh	356,280
Post-Retrofit Annual Usage-kWh	34,261
Total Change In Connect Load - KW	36.76
Annual Savings - kWh	322,019
Annual Project Savings - \$	\$13,782
First Energy - Energy Efficiency Rebate	\$16,101

[Lighting](#) > [Outdoor Area Fixtures](#) > [Floodlights](#)

LITHONIA Mini Floodlight Fixture, 1500W

☆☆☆☆☆ | [Write a Review](#) | [Read all Reviews](#) | [Read all Ask & Answer](#)

Floodlight, Micro Fixture Type, Quartz Halogen Lamp Type, 1500 Fixture Wattage, Suggested Lamp Item No. 2V617, 8, 9, 208-277 Voltage, RSC Socket Base Socket Type, Wide Light Distribution, Description/Special Features Wet Location, Die Cast Aluminum Housing Material, Bronze Housing Finish, No Lamp Included, 8-1/4 In. Height, 13 In. Width, 6 In. Depth, Standards UL Listed For Wet Location, F1500

Granger Item #	4EA48
Price (ea.)	\$48.35
Brand	LITHONIA
Mfr. Model #	F1500QD
UNSPSC #	39111704
Ship Qty. 	1
Sell Qty. (Will-Call) 	1
Ship Weight (lbs.)	6.4
Availability	Ready to Ship 
Catalog Page No.	646 
Country of Origin (Country of Origin is subject to change.)	China

[Enlarge Image](#)

[home](#) > [Lighting Fixtures](#) > [Flood Light Fixtures](#) > [Metal Halide / Pulse Start Flood Lights](#) > [150 Watt Metal Halide / Pulse Start Flood Lights](#)



RAB EZHH150PSQ - Metal Halide Flood Light Fixture

150 Watt - Pulse Start - 120/208/240/277 Volt

[Write the first review](#)

[Follow this product](#)



The RAB EZHH150PSQ pulse start metal halide area flood light fixture operates at 150 watts and has a 4 tap input. It is UL listed for wet locations, includes (1) 150 watt pulse start metal halide ED17 lamp (medium base), and features a HX-HPF ballast with a high power factor.

Stock Code: RAB-EZHH150PSQ

Additional images



 +1 0

Instructions: Please use one line for each fixture type in a room or area.

For existing or proposed control, choose OCC for Occupancy Sensor, DAY for photosensor, Hi-Lo for hi-lo-level sensors or NONE for none. Controls in spaces where existing controls exist do not qualify.

The total of Column S, the quantities of CFLs and exit signs in Column M, and the quantities of sensors in Column R, will be used to calculate your incentive on the NonStandard Lighting form.

PRODUCT BASIC INFORMATION						BASELINE NEW CONSTRUCTION																																																																																																																																																																																																																																																																																																																																																																																																																																																																							
New Construction or Renovation	Building Address	Floor	Area Description	Space Description	Measurement Space Type	PRE-INSTALLATION INFORMATION				BASELINE NEW CONSTRUCTION				POST-INSTALLATION																																																																																																																																																																																																																																																																																																																																																																																																																																																															
						Manufacturer or Supplier	Product Name	Pre-Fixture Qty	Pre-Fixture Code	Pre-Fixture / Space Qty	Pre-Fixture / Space Qty	Existing Fixture Quantity	Lighting Fixture Quantity (Watts)	Baseline Wt (Watts)	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty	Post-Fixture Code	Post-Fixture Qty

Project Estimated Annual Savings Summary

Lighting

Estimated Annual kWh Savings	286,349
Total Change in Connected Load	31.42

Annual Estimated Cost Savings	\$28,634.90
Annual Operating Hours	8,760

Interior Lighting Incentive @ \$0.05/kWh (excluding retrofit CFLs, sensors, or LED exit signs)	\$1,139.25
Exterior Lighting Incentive @ \$0.05/kWh (excluding retrofit CFLs, sensors, or LED exit signs)	\$12,623.15
Total retrofit CFL Incentive @ \$1/screw-in CFL lamp; \$15/hard-wired CFL lamp (includes all retrofit CFLs, both interior and exterior)	\$0.00
Total retrofit LED Exit Incentive @ \$10/exit sign	\$0.00
Total Lighting Controls Incentive @ \$25/occupancy sensor and \$25/daylight sensor (includes all Lighting Controls, both interior and exterior)	\$0.00

Total Calculated Incentive	\$13,762.40
----------------------------	-------------

Total Fixture Quantity excluding retrofit CFLs and LED Exit Signs	39
Total Lamp Quantity for retrofit Screw-In CFLs	0
Total Lamp Quantity for retrofit Hard-Wired CFLs	0
Total Fixture Quantity for retrofit LED Exit Signs	0
Total Quantity for Occupancy Sensors	0
Total Quantity for Daylight Sensors	0

Please briefly describe how you estimated your coincidence factor (CF) and applicant equivalent full-load hours (EFLH) for facility type "Other" indicated on the Lighting Form tab

Demand Savings (For Internal Use Only)	27.54
--	-------

Non-Standard Lighting Incentives Program applicants must attach a completed copy of FirstEnergy NonStandard Lighting Calculator to the application form. FirstEnergy NonStandard Lighting Calculator can be found on the program Web site - www.energysaveohio.com

Rev. 1009

Please use the Calculator tab to define the lighting project. For both the Pre Fixture Code and Post Fixture Code (for Retrofit, post fixture code only for New Construction), please refer to the "Wattage Table" tab of FirstEnergy NonStandard Lighting Calculator for appropriate Fixture Code. "Pre Watts/Fixture" and "Post Watts/Fixture" will be assigned based on the fixture code entered in their respective columns. The "Fixture Code Generator" can also be used to assign the fixture code based on technology specifications.

In cases where Pre Watts/Fixture or Post Watts/Fixture for the make/model/configuration of lighting equipment is available and differs from the value shown in the Wattage Table, or if the fixture configuration/technology is not represented in the Wattage Table, please enter the appropriate description and fixture wattage in the Wattage Table under the section for Cut Sheet Fixtures. *Please note that manufacturer's specification (cut) sheets showing the actual input wattage are required for all pre-installation fixtures that do not use the Wattage Table values. Please clearly indicate the relevant data on the provided specification (cut) sheets by circling or highlighting the information.*

When you have completed the Calculator and adjusted for Change in Connected Load (when necessary), use the Project Estimated Summary tab to fill in page 3 of the Non-Standard Lighting Application - Project Estimated Annual Savings Summary.

If you have questions about the program or need assistance completing the form, please call the program at 1-866-578-5220 or email your inquiry to energysaveohio@saic.com.

The table below explains and/or provides examples of input in each of the spreadsheet columns.

Project Basic Information	Column Name	Column Description	Example/Explanation	
	Applicant Information Block	Lighting Zone (exterior only)	Please select the appropriate lighting zone for your location, as defined in the table below.	
			Lighting Zone	Description
			0	Undeveloped areas within national parks, state parks, forest land, rural areas, and other undeveloped areas as defined by the authority having jurisdiction
			1	Developed areas of national parks, state parks, forest land, and rural areas
			2	Areas predominantly consisting of residential zoning, neighborhood business districts, light industrial with limited nighttime use and residential mixed use areas
			3	All other areas
			4	High activity commercial districts in major metropolitan areas as designated by the local jurisdiction
	Line Item	Integer line number	Used only for program reference	
	Building Address	Building address	The address of the facility in which the fixtures will be replaced/installed.	
	Floor	Floor number where fixture(s) are located	Please use B for basements and corresponding numerals for all other floors.	
	Area Description	Description of location that matches site map	Examples include: director's office, room 325, copy room.	
	Space Description (New Construction only)	Determines whether or not occupancy sensors are required by code. If required, any occupancy sensors installed in this space will not be incented.	Area Description	
			University Classroom (excluding Shop or Labs)	
			Conference, Meeting or Training Room	
Employee Lunch or Break Room				
Other				
Copy or Printing Room				
Dressing, Locker or Fitting Room				
Private Office less than 250 ft^2				
Restrooms				
Storage or Supply Room Between 50 ft^2 and 1,000 ft^2				
Predominant Space Type	Description of predominant space type for the area	Some examples include: Education - Primary School, Grocery, All Hospitals, Office - Large, Warehouse, and Other (see below for the complete list under Coincidence Factor). <i>Note: This choice determines the values used for Coincidence Factor, and Equivalent Full Load Hours, and must be one of the choices in the drop-down list on the worksheet. This field will account for energy savings related to the percentage of the connected load that is on during the electric system's peak window. If the choice is Other, please contact a program representative for determination of an appropriate Coincidence Factor. For interior New Construction fixtures, this also determines the baseline lighting power density (LPD) in ft².</i>		

	Area Cooling	Description of cooling available in area.	<p>Choices are: Cooled space, Freezer Space, Medium-temperature refrigerated space, High-temperature refrigerated space, Uncooled space and Exterior Space.</p> <p><i>Note: This choice determines the values used for Interactive Factor (demand) and Interactive Factor (energy) and must be one of the choices listed above. This field will account for energy savings related to interactive effects of reduced lighting space heat gains on the cooling system.</i></p>
Pre-Installation (Retrofit only)	Pre Fixt. No.	# of existing fixtures	Quantity of existing fixtures accounted for on a line item
	Pre Fixt Code	Code from Wattage Table	<p>This value can be entered manually or selected from the drop-down list and must match one of the fixture codes in the Wattage Table. If using default fixture codes and their associated Wattages, see the Fixture Code Legend worksheet for instructions on determining fixture codes found in the Wattage Table worksheet. If using custom fixture codes (e.g. for project specific fixture wattages, or if the desired fixture is not available in the Wattage Table), use the Cut Sheet Fixtures portion of the Wattage Table to add a fixture description (column C) and Watt/Fixt (column G). These values will need to be verified by manufacturers' cut sheets.</p>
	Pre Watts / Fixt	Watts/Fixt for the existing fixture type on a given line	This value is assigned based on the pre-fixture code entered.
	Pre kW / Space	(Pre Watts/Fixt) * (Pre Fixt No.)	This item is calculated.
	Existing Control	Pre-installation control device	<p>Please enter OCC for occupancy sensor, DAYLTG for daylighting photosensor, or NONE for none.</p> <p><i>Note: This choice determines the value used for controls factor, and must be one of the three choices listed above. This field will account for energy savings related to lighting control as per the state-mandated TRM calculation methodology.</i></p>
Baseline (New Construction only)	Units	Area, linear feet or quantity	For interior lighting this is the area (ft ²) associated with the space type. For exterior lighting this is the quantity, linear feet (ft) or area (ft ²) associated with the exterior lighting description.
	Lighting Power Density	Watts per unit	For interior lighting, this value is determined by the space type. For exterior lighting, this value is determined by the exterior lighting description.
Post-Installation	Post Fixt. No.	# of new fixtures	Quantity of new fixtures accounted for on a line item
	Post Fixt Code	Code from Wattage Table	<p>This value can be entered manually or selected from the drop-down list and must match one of the fixture codes in the Wattage Table. If using default fixture codes and their associated Wattages, see the Fixture Code Legend worksheet for instructions on determining fixture codes found in the Wattage Table worksheet. If using custom fixture codes (e.g. for project specific fixture wattages, or if the desired fixture is not available in the Wattage Table), use the Cut Sheet Fixtures portion of the Wattage Table to add a fixture description (column C) and Watt/Fixt (column G). These values will need to be verified by manufacturers' cut sheets.</p>
	Post Watts / Fixt	Watts/Fixt for the new fixture type on a given line	<p>This value is assigned based on the post-fixture code entered. If this value is known and differs from the value shown in the Wattage Table, enter this value in the Cut Sheet Fixtures portion of the Wattage Table, as described above.</p>
	Post kW / Space	(Post Watts/Fixt) * (Post Fixt No.)	This item is calculated.

	Proposed Control	Post-installation control device	<p>Please enter OCC for occupancy sensor, DAYLTG for daylighting photosensor, or NONE for none.</p> <p><i>Note: This choice determines the value used for controls factor, and must be one of the three choices listed above. This field will account for energy savings related to lighting control as per the state-mandated TRM calculation methodology.</i></p>
--	------------------	----------------------------------	---


Energy Calculations

Change in Connected Load	Pre kW/Space - Post kW/Space	This item is calculated.			
Coincidence Factor	CF = Demand Coincidence Factor. The percentage of the connected load that is on during electric system's peak window (noon - 8 PM, Monday - Friday).	Predominant Space Type	Coincidence Factor		
		Education - Primary School	0.57		
		Education - Secondary School	0.57		
		Education - Community College	0.64		
		Education - University	0.64		
		Grocery	0.94		
		All Hospitals	0.84		
		Medical - Clinic	0.86		
		Lodging - Hotel Guest Rooms	0.84		
		Lodging - Motel Common Spaces	1.00		
		Manufacturing - Light Industrial	0.63		
		Office - Large	0.84		
		Office - Small	0.84		
		Restaurant - Sit-Down	0.88		
		Restaurant - Fast Food	0.88		
		Retail - 3-Story Large	0.89		
		Retail - Single-Story Large	0.89		
		Retail - Small	0.89		
		Storage - Conditioned	0.85		
		Storage - Unconditioned	0.85		
		Warehouse	0.85		
		Dusk-to-Dawn Lighting	0.00		
		Exit Signs	1.00		
		Multifamily-Common Areas	0.84		
		Other - Please estimate CF and EFLH	As measured		
		Interactive factor (demand)	Interactive HVAC Demand Factor – applies to C&I interior lighting in space that has air conditioning or refrigeration only. This represents the secondary demand savings in cooling required which results from decreased indoor lighting wattage.	Cooled Space = 0.34 Freezer Space = 0.50 Medium-Temp Refrig Space = 0.29 High-Temp Refrig Space = 0.18 Uncooled Space = 0 Exterior Space = 0	
		Interactive factor (energy)	Interactive HVAC Energy Factor – applies to C&I interior lighting in space that has air conditioning or refrigeration only. This represents the secondary energy savings in cooling required which results from decreased indoor lighting wattage.	Cooled Space = 0.12 Freezer Space = 0.50 Medium-Temp Refrig Space = 0.29 High-Temp Refrig Space = 0.18 Uncooled Space = 0 Exterior Space = 0	
Controls Factor	Controls Factor is referred to as SVG in the Technical Resource Manual and is defined as SVG = The percent of time that lights are off due to lighting controls relative to the baseline controls system (typically manual switch).	Occupancy Sensor, Controlled Hi-Low Fluorescent Control and controlled HID = 30% Daylight Dimmer System = 50%			
Demand Savings	Demand Savings = ΔkW X CF X (1+IFdemand)	This item is calculated.			
Applicant Equivalent Full Load Hours Estimate	The average annual operating hours of the baseline lighting equipment as defined by the applicant, which if applied to full connected load will yield annual energy use. Prescribed EFLH at right will be automatically applied in the spreadsheet based on selected Predominant Space Type. If selected Predominant Space Type=Other, the applicant's estimate will be applied in the spreadsheet. These applicants will be asked to verify their EFLH estimates. If the applicant does not provide an estimate of EFLH, 3760 will be used.	Facility Type	EFLH		
		Education - Primary School	2080		
		Education - Secondary School	2080		
		Education - Community College	5010		
		Education - University	5010		
		Grocery	4612		
		Medical - Hospital	4532		
		Medical - Clinic	3392		
		Lodging Hotel (Guest Rooms)	2697		
		Lodging Motel	2697		
		Manufacturing - Light Industrial	5913		
		Multifamily - Common Areas	2697		
		Office - Large	3435		
		Office - Small	3435		
		Restaurant - Sit-Down	4156		
		Restaurant - Fast-Food	4156		
		Retail - 3-Story large	3068		
		Retail - Single Story Large	3068		
		Retail - Small	3068		
		Storage - Conditioned	2388		
		Storage - Unconditioned	2388		
		Warehouse	2388		
		Dusk-to-Dawn	3833		
		Other	3760 unless otherwise specified		


	Annual kWh Saved (excluding CFLS or LED exits)	Energy Savings = [kWbase X (1+IFenergy) X EFLH] – [kWinst X (1+IFenergy) X EFLH]	This item is calculated for lighting fixture changes only. CFL lamps, LED exit signs, and savings from sensors are not included here.
	Annual kWh Saved (CFL or LED exit sign)	Energy Savings = [kWbase X (1+IFenergy) X EFLH] – [kWinst X (1+IFenergy) X EFLH]	This item is calculated for CFL and LED exit sign installations only.
	Annual kWh Saved Sensors	Energy Savings are based on the impact of the new sensor on an existing or retrofitted fixture, relative to the same fixture or retrofit with no sensor.	This item is calculated for savings from installed lighting occupancy sensors or photosensors. Replacing the same sensor technology (i.e. occupancy sensors with occupancy sensors) does not result in energy savings.

Fixture Code Legend and Notes

Sample Linear Fluorescent Fixture Code



Sample of Other Fixture Code:



Code Explanations

Fixture Type

CF	Compact Fluorescent
CFD	Compact Fluorescent, double-D shape
CFS	Compact Fluorescent, Spiral
CFT	Compact Fluorescent, Twin tube (including "Biaxial" fixtures)
CFQ	Compact Fluorescent, Quad tube
ECF	Exit sign, Compact Fluorescent
EI	Exit sign, Incandescent
ELED	Exit sign, LED
F	Fluorescent, linear
FC	Fluorescent, Circline
FU	Fluorescent, U-tube
H	Halogen
HLV	Halogen, Low Voltage
HPS	High Pressure Sodium
I	Incandescent
LED	Light Emitting Diode (LED) traffic signal
MH	Metal Halide
MHPS	Metal Halide, Pulse Start
MV	Mercury Vapor
QL	Induction

Lamp Type

for fluorescent fixtures

A	"F25T12" - 25 watt, 4ft, T12 lamp
IL	T8, Instant start
SIL	T8, Instant start, Super 30 watt
SSIL	T8, Instant start, Super 28 watt
L	T8, rapid start
G	T5, standard
GH	T5, standard, High output lamp
E	T12, Energy efficient
EH	T12, Energy efficient, High output lamp
EI	T12, Energy efficient, Instant start
EV	T12, Energy efficient, Very high output
S	T12, Standard

Ballast Type

for fluorescent fixtures

L	Electronic
S	Standard magnetic
E	Energy efficient magnetic

Configuration (letter)

T	Tandem wired fixture
D	Delamped fixture, i.e. some lamps permanently removed but ballasts remain

Configuration (number)

for delamped fixtures

Number signifies the total number of ballasts in the fixture: e.g. An "F42EEID2" is an "F44EE" with two lamps removed so that there is one extraneous ballast

for tandem wired ballasts

Number signifies the total number of lamps being run by the ballast: e.g. An "F42LLIT4" would indicate that a four-lamp ballast is wired to run two-lamp fixtures.

with no preceding letter

Number indicates the number of ballasts in an ambiguous multiple ballast fixture: e.g. An "F43ILU2" indicates a three-lamp fixture with two ballasts (as is often the case if there is A/B switching).

Ballast Light Output

R	Reduced light output
H	High light output
V	Very high light output

SI	T12, Standard, Instant start
SH	T12, Standard, High output lamp
SV	T12, Standard, Very high output lamp
T	T10, Standard

Notes:

- 1) The column labeled Watts/Fixtures in the data table includes ballast loads.
- 2) The fixture wattage values represent an average value, rounded to the nearest whole watt.

Lighting Audit and Design Tool

Lighting Fixture Code Generator

Fill In White Fields

Linear, Circuline and U-tube Fluorescent Fixtures	
Fixture Type:	Fluorescent
Fixture Subtype:	Linear
Lamp Length:	4 Feet (48 Inches)
Number of Lamps:	6 Lamps
Lamp Type:	T5, Standard
Ballast Type:	Standard Magnetic
Delamped/Tandem/Multiple Ballasts - Optional:	
Ballast Light Output (Ballast Factor) - Optional:	
Fixture Code:	Use Cut Sheet Fixture

Compact Fluorescent and Exit Sign Fixtures	
Fixture Type:	Compact Fluorescent
Fixture Subtype:	Standard
Nominal Lamp Wattage:	11
Number of Lamps:	1 Lamp
Lamp Length - Optional:	Standard
Fixture Code:	CF11/1

TABLE OF STANDARD WATTAGES

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
CF10/2D	CFD10W	Compact Fluorescent, 2D, (1) 10W lamp	Mag-STD	1	10	16
CF10/2D-L	CFD10W	Compact Fluorescent, 2D, (1) 10W lamp	Electronic	1	10	12
CF11/1	CF11W	Compact Fluorescent, (1) 11W lamp	Mag-STD	1	11	13
CF11/2	CF11W	Compact Fluorescent, (2) 11W lamp	Mag-STD	2	11	26
CF16/2D	CFD16W	Compact Fluorescent, 2D, (1) 16W lamp	Mag-STD	1	16	26
CF16/2D-L	CFD16W	Compact Fluorescent, 2D, (1) 16W lamp	Electronic	1	16	18
CF18/3-L	CF18W	Compact Fluorescent, (3) 18W lamp	Electronic	3	18	60
CF21/2D	CFD21W	Compact Fluorescent, 2D, (1) 21W lamp	Mag-STD	1	21	26
CF21/2D-L	CFD21W	Compact Fluorescent, 2D, (1) 21W lamp	Electronic	1	21	22
CF23/1	CF23W	Compact Fluorescent, (1) 23W lamp	Mag-STD	1	23	29
CF23/1-L	CF23W	Compact Fluorescent, (1) 23W lamp	Electronic	1	23	25
CF26/3-L	CF26W	Compact Fluorescent, (3) 26W lamp	Electronic	3	26	82
CF26/4-L	CF26W	Compact Fluorescent, (4) 26W lamp	Electronic	4	26	108
CF26/6-L	CF26W	Compact Fluorescent, (6) 26W lamp	Electronic	6	26	162
CF26/8-L	CF26W	Compact Fluorescent, (8) 26W lamp	Electronic	8	26	216
CF28/2D	CFD28W	Compact Fluorescent, 2D, (1) 28W lamp	Mag-STD	1	28	35
CF28/2D-L	CFD28W	Compact Fluorescent, 2D, (1) 28W lamp	Electronic	1	28	28
CF32/3-L	CF32W	Compact Fluorescent, (3) 32W lamp	Electronic	3	32	114
CF32/4-L	CF32W	Compact Fluorescent, (4) 32W lamp	Electronic	4	32	152
CF32/6-L	CF32W	Compact Fluorescent, (6) 32W lamp	Electronic	6	32	228
CF32/8-L	CF32W	Compact Fluorescent, (8) 32W lamp	Electronic	8	32	304
CF38/2D	CFD38W	Compact Fluorescent, 2D, (1) 38W lamp	Mag-STD	1	38	46
CF38/2D-L	CFD38W	Compact Fluorescent, 2D, (1) 38W lamp	Electronic	1	38	36
CF42/1-L	CF42W	Compact Fluorescent, (1) 42W lamp	Electronic	1	42	48
CF42/2-L	CF42W	Compact Fluorescent, (2) 42W lamp	Electronic	2	42	100
CF42/3-L	CF42W	Compact Fluorescent, (3) 42W lamp	Electronic	3	42	141
CF42/4-L	CF42W	Compact Fluorescent, (4) 42W lamp	Electronic	4	42	188
CF42/6-L	CF42W	Compact Fluorescent, (6) 42W lamp	Electronic	6	42	282
CF42/8-L	CF42W	Compact Fluorescent, (8) 42W lamp	Electronic	8	42	376
CFQ10/1	CFQ10W	Compact Fluorescent, quad, (1) 10W lamp	Mag-STD	1	10	15
CFQ13/1	CFQ13W	Compact Fluorescent, quad, (1) 13W lamp	Mag-STD	1	13	17
CFQ13/1-L	CFQ13W	Compact Fluorescent, quad, (1) 13W lamp, BF=1.05	Electronic	1	13	15
CFQ13/2	CFQ13W	Compact Fluorescent, quad, (2) 13W lamp	Mag-STD	2	13	31
CFQ13/2-L	CFQ13W	Compact Fluorescent, quad, (2) 13W lamp, BF=1.0	Electronic	2	13	28

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
CFQ13/3	CFQ13W	Compact Fluorescent, quad, (3) 13W lamp	Mag-STD	3	13	48
CFQ15/1	CFQ15W	Compact Fluorescent, quad, (1) 15W lamp	Mag-STD	1	15	20
CFQ17/1	CFQ17W	Compact Fluorescent, quad, (1) 17W lamp	Mag-STD	1	17	24
CFQ17/2	CFQ17W	Compact Fluorescent, quad, (2) 17W lamp	Mag-STD	2	17	48
CFQ18/1	CFQ18W	Compact Fluorescent, quad, (1) 18W lamp	Mag-STD	1	18	26
CFQ18/1-L	CFQ18W	Compact Fluorescent, quad, (1) 18W lamp, BF=1.0	Electronic	1	18	20
CFQ18/2	CFQ18W	Compact Fluorescent, quad, (2) 18W lamp	Mag-STD	2	18	45
CFQ18/2-L	CFQ18W	Compact Fluorescent, quad, (2) 18W lamp, BF=1.0	Electronic	2	18	38
CFQ18/4	CFQ18W	Compact Fluorescent, quad, (4) 18W lamp	Mag-STD	2	18	90
CFQ20/1	CFQ20W	Compact Fluorescent, quad, (1) 20W lamp	Mag-STD	1	20	23
CFQ20/2	CFQ20W	Compact Fluorescent, quad, (2) 20W lamp	Mag-STD	2	20	46
CFQ22/1	CFQ22W	Compact Fluorescent, quad, (1) 22W lamp	Mag-STD	1	22	24
CFQ22/2	CFQ22W	Compact Fluorescent, quad, (2) 22W lamp	Mag-STD	2	22	48
CFQ22/3	CFQ22W	Compact Fluorescent, quad, (3) 22W lamp	Mag-STD	3	22	72
CFQ25/1	CFQ25W	Compact Fluorescent, quad, (1) 25W lamp	Mag-STD	1	25	33
CFQ25/2	CFQ25W	Compact Fluorescent, quad, (2) 25W lamp	Mag-STD	2	25	66
CFQ26/1	CFQ26W	Compact Fluorescent, quad, (1) 26W lamp	Mag-STD	1	26	33
CFQ26/1-L	CFQ26W	Compact Fluorescent, quad, (1) 26W lamp, BF=0.95	Electronic	1	26	27
CFQ26/2	CFQ26W	Compact Fluorescent, quad, (2) 26W lamp	Mag-STD	2	26	66
CFQ26/2-L	CFQ26W	Compact Fluorescent, quad, (2) 26W lamp, BF=0.95	Electronic	2	26	50
CFQ26/3	CFQ26W	Compact Fluorescent, quad, (3) 26W lamp	Mag-STD	3	26	99
CFQ26/6-L	CFQ26W	Compact Fluorescent, quad, (6) 26W lamp, BF=0.95	Electronic	6	26	150
CFQ28/1	CFQ28W	Compact Fluorescent, quad, (1) 28W lamp	Mag-STD	1	28	33
CFQ9/1	CFQ9W	Compact Fluorescent, quad, (1) 9W lamp	Mag-STD	1	9	14
CFQ9/2	CFQ9W	Compact Fluorescent, quad, (2) 9W lamp	Mag-STD	2	9	23
CFS7/1	CFS7W	Compact Fluorescent, spiral, (1) 7W lamp	Electronic	1	7	7
CFS9/1	CFS9W	Compact Fluorescent, spiral, (1) 9W lamp	Electronic	1	9	9
CFS11/1	CFS11W	Compact Fluorescent, spiral, (1) 11W lamp	Electronic	1	11	11
CFS15/1	CFS15W	Compact Fluorescent, spiral, (1) 15W lamp	Electronic	1	15	15
CFS20/1	CFS20W	Compact Fluorescent, spiral, (1) 20W lamp	Electronic	1	20	20
CFS23/1	CFS23W	Compact Fluorescent, spiral, (1) 23W lamp	Electronic	1	23	23
CFS27/1	CFS27W	Compact Fluorescent, spiral, (1) 27W lamp	Electronic	1	27	27
CFT13/1	CFT13W	Compact Fluorescent, twin, (1) 13W lamp	Mag-STD	1	13	17
CFT13/2	CFT13W	Compact Fluorescent, twin, (2) 13W lamp	Mag-STD	2	13	31
CFT13/3	CFT13W	Compact Fluorescent, twin, (3) 13 W lamp	Mag-STD	3	13	48
CFT18/1	CFT18W	Compact Fluorescent, long twin., (1) 18W lamp	Mag-STD	1	18	24

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
CFT22/1	CFT22W	Compact Fluorescent, twin, (1) 22W lamp	Mag-STD	1	22	27
CFT22/2	CFT22W	Compact Fluorescent, twin, (2) 22W lamp	Mag-STD	2	22	54
CFT22/4	CFT22W	Compact Fluorescent, twin, (4) 22W lamp	Mag-STD	4	22	108
CFT24/1	CFT24W	Compact Fluorescent, long twin, (1) 24W lamp	Mag-STD	1	24	32
CFT28/1	CFT28W	Compact Fluorescent, twin, (1) 28W lamp	Mag-STD	1	28	33
CFT28/2	CFT28W	Compact Fluorescent, twin, (2) 28W lamp	Mag-STD	2	28	66
CFT32/1-L	CFM32W	Compact Fluorescent, twin or multi, (1) 32W lamp	Electronic	1	32	34
CFT32/2-L	CFM32W	Compact Fluorescent, twin or multi, (2) 32W lamp	Electronic	2	32	62
CFT32/6-L	CFM32W	Compact Fluorescent, twin or multi, (2) 32W lamp	Electronic	6	32	186
CFT36/1	CFT36W	Compact Fluorescent, long twin, (1) 36W lamp	Mag-STD	1	36	51
CFT36/4-BX	CFT36W	Compact Fluorescent, Biax, (4) 36W lamp	Electronic	4	36	148
CFT36/6-BX	CFT36W	Compact Fluorescent, Biax, (6) 36W lamp	Electronic	6	36	212
CFT36/6-L	CFT36W	Compact Fluorescent, long Twin, (6) 36W lamp	Electronic	6	36	198
CFT36/6-L-H	CFT36W	Compact Fluorescent, long Twin, (6) 36W lamp/ High Ballast Factor	Electronic	6	36	210
CFT36/8-BX	CFT36W	Compact Fluorescent, Biax, (8) 36W lamp	Electronic	8	36	296
CFT36/8-L	CFT36W	Compact Fluorescent, long Twin, (8) 36W lamp	Electronic	8	36	270
CFT36/8-L-H	CFT36W	Compact Fluorescent, long Twin, (8) 36W lamp/ High Ballast Factor	Electronic	8	36	286
CFT36/9-BX	CFT36W	Compact Fluorescent, Biax, (9) 36W lamp	Electronic	9	36	318
CFT40/1	CFT40W	Compact Fluorescent, twin, (1) 40W lamp	Mag-STD	1	40	46
CFT40/12-BX	CFT40W	Compact Fluorescent, Biax, (12) 40W lamp	Electronic	12	40	408
CFT40/1-BX	CFT40W	Compact Fluorescent, Biax, (1) 40W lamp	Electronic	1	40	46
CFT40/1-L	CFT40W	Compact Fluorescent, long twin, (1) 40W lamp	Electronic	1	40	43
CFT40/2	CFT40W	Compact Fluorescent, twin, (2) 40W lamp	Mag-STD	2	40	85
CFT40/2-BX	CFT40W	Compact Fluorescent, Biax, (2) 40W lamp	Electronic	2	40	72
CFT40/2-L	CFT40W	Compact Fluorescent, long twin, (2) 40W lamp	Electronic	2	40	72
CFT40/3	CFT40W	Compact Fluorescent, twin, (3) 40 W lamp	Mag-STD	3	40	133
CFT40/3-BX	CFT40W	Compact Fluorescent, Biax, (3) 40W lamp	Electronic	3	40	102
CFT40/3-L	CFT40W	Compact Fluorescent, long twin, (3) 40W lamp	Electronic	3	40	105
CFT40/4-BX	CFT40W	Compact Fluorescent, Biax, (4) 40W lamp	Electronic	4	40	144
CFT40/5-BX	CFT40W	Compact Fluorescent, Biax, (5) 40W lamp	Electronic	5	40	190
CFT40/6-BX	CFT40W	Compact Fluorescent, Biax, (6) 40W lamp	Electronic	6	40	204
CFT40/6-L	CFT40W	Compact Fluorescent, long Twin, (6) 40W lamp	Electronic	6	40	220
CFT40/6-L-H	CFT40W	Compact Fluorescent, long Twin, (6) 40W lamp/ High Ballast Factor	Electronic	6	40	233
CFT40/8-BX	CFT40W	Compact Fluorescent, Biax, (8) 40W lamp	Electronic	8	40	288
CFT40/8-L	CFT40W	Compact Fluorescent, long Twin, (8) 40W lamp	Electronic	8	40	300
CFT40/8-L-H	CFT40W	Compact Fluorescent, long Twin, (8) 40W lamp/ High Ballast Factor	Electronic	8	40	340

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
CFT40/9-BX	CFT40W	Compact Fluorescent, Biax, (9) 40W lamp	Electronic	9	40	306
CFT5/1	CFT5W	Compact Fluorescent, twin, (1) 5W lamp	Mag-STD	1	5	9
CFT5/2	CFT5W	Compact Fluorescent, twin, (2) 5W lamp	Mag-STD	2	5	18
CFT50/12-BX	CFT50W	Compact Fluorescent, Biax, (12) 50W lamp	Electronic	12	50	648
CFT50/1-BX	CFT50W	Compact Fluorescent, Biax, (1) 50W lamp	Electronic	1	50	54
CFT50/2-BX	CFT50W	Compact Fluorescent, Biax, (2) 50W lamp	Electronic	2	50	108
CFT50/3-BX	CFT50W	Compact Fluorescent, Biax, (3) 50W lamp	Electronic	3	50	162
CFT50/4-BX	CFT50W	Compact Fluorescent, Biax, (4) 50W lamp	Electronic	4	50	216
CFT50/5-BX	CFT50W	Compact Fluorescent, Biax, (5) 50W lamp	Electronic	5	50	270
CFT50/6-BX	CFT50W	Compact Fluorescent, Biax, (6) 50W lamp	Electronic	6	50	324
CFT50/8-BX	CFT50W	Compact Fluorescent, Biax, (8) 50W lamp	Electronic	8	50	432
CFT50/9-BX	CFT50W	Compact Fluorescent, Biax, (9) 50W lamp	Electronic	9	50	486
CFT55/12-BX	CFT55W	Compact Fluorescent, Biax, (12) 55W lamp	Electronic	12	55	672
CFT55/1-BX	CFT55W	Compact Fluorescent, Biax, (1) 55W lamp	Electronic	1	55	56
CFT55/2-BX	CFT55W	Compact Fluorescent, Biax, (2) 55W lamp	Electronic	2	55	112
CFT55/3-BX	CFT55W	Compact Fluorescent, Biax, (3) 55W lamp	Electronic	3	55	168
CFT55/4-BX	CFT55W	Compact Fluorescent, Biax, (4) 55W lamp	Electronic	4	55	224
CFT55/5-BX	CFT55W	Compact Fluorescent, Biax, (5) 55W lamp	Electronic	5	55	280
CFT55/6-BX	CFT55W	Compact Fluorescent, Biax, (6) 55W lamp	Electronic	6	55	336
CFT55/6-L	CFT55W	Compact Fluorescent, long Twin, (6) 55W lamp	Electronic	6	55	352
CFT55/6-L-H	CFT55W	Compact Fluorescent, long Twin, (6) 55W lamp/ High Ballast Factor	Electronic	6	55	373
CFT55/8-BX	CFT55W	Compact Fluorescent, Biax, (8) 55W lamp	Electronic	8	55	448
CFT55/8-L	CFT55W	Compact Fluorescent, long Twin, (8) 55W lamp	Electronic	8	55	468
CFT55/8-L-H	CFT55W	Compact Fluorescent, long Twin, (8) 55W lamp/ High Ballast Factor	Electronic	8	55	496
CFT55/9-BX	CFT55W	Compact Fluorescent, Biax, (9) 55W lamp	Electronic	9	55	504
CFT7/1	CFT7W	Compact Fluorescent, twin, (1) 7W lamp	Mag-STD	1	7	10
CFT7/2	CFT7W	Compact Fluorescent, twin, (2) 7W lamp	Mag-STD	2	7	21
CFT9/1	CFT9W	Compact Fluorescent, twin, (1) 9W lamp	Mag-STD	1	9	11
CFT9/2	CFT9W	Compact Fluorescent, twin, (2) 9W lamp	Mag-STD	2	9	23
CFT9/3	CFT9W	Compact Fluorescent, twin, (3) 9W lamp	Mag-STD	3	9	34
		EXIT Sign Fixtures				
ECF5/1	CFT5W	EXIT Compact Fluorescent, (1) 5W lamp	Mag-STD	1	5	9
ECF5/2	CFT5W	EXIT Compact Fluorescent, (2) 5W lamp	Mag-STD	2	5	20
ECF7/1	CFT7W	EXIT Compact Fluorescent, (1) 7W lamp	Mag-STD	1	7	10
ECF7/2	CFT7W	EXIT Compact Fluorescent, (2) 7W lamp	Mag-STD	2	7	21
ECF8/1	F8T5	EXIT T5 Fluorescent, (1) 8W lamp	Mag-STD	1	8	12

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
ECF8/2	F8T5	EXIT T5 Fluorescent, (2) 8W lamp	Mag-STD	2	8	24
ECF9/1	CFT9W	EXIT Compact Fluorescent, (1) 9W lamp	Mag-STD	1	9	12
ECF9/2	CFT9W	EXIT Compact Fluorescent, (2) 9W lamp	Mag-STD	2	9	20
EI10/2	I10	EXIT Incandescent, (2) 10W lamp		2	10	20
EI15/1	I15	EXIT Incandescent, (1) 15W lamp		1	15	15
EI15/2	I15	EXIT Incandescent, (2) 15W lamp		2	15	30
EI20/1	I20	EXIT Incandescent, (1) 20W lamp		1	20	20
EI20/2	I20	EXIT Incandescent, (2) 20W lamp		2	20	40
EI25/1	I25	EXIT Incandescent, (1) 25W lamp		1	25	25
EI25/2	I25	EXIT Incandescent, (2) 25W lamp		2	25	50
EI34/1	I34	EXIT Incandescent, (1) 34W lamp		1	34	34
EI34/2	I34	EXIT Incandescent, (2) 34W lamp		2	34	68
EI40/1	I40	EXIT Incandescent, (1) 40W lamp		1	40	40
EI40/2	I40	EXIT Incandescent, (2) 40W lamp		2	40	80
EI5/1	I5	EXIT Incandescent, (1) 5W lamp		1	5	5
EI5/2	I5	EXIT Incandescent, (2) 5W lamp		2	5	10
EI50/2	I50	EXIT Incandescent, (2) 50W lamp		2	50	100
EI7.5/1	I7.5	EXIT Tungsten, (1) 7.5 W lamp		1	7.5	8
EI7.5/2	I7.5	EXIT Tungsten, (2) 7.5 W lamp		2	7.5	15
ELED0.5/1	LED0.5W	EXIT Light Emitting Diode, (1) 0.5W lamp, Single Sided		1	0.5	0.5
ELED0.5/2	LED0.5W	EXIT Light Emitting Diode, (2) 0.5W lamp, Dual Sided		2	0.5	1
ELED1.5/1	LED1.5W	EXIT Light Emitting Diode, (1) 1.5W lamp, Single Sided		1	1.5	1.5
ELED1.5/2	LED1.5W	EXIT Light Emitting Diode, (2) 1.5W lamp, Dual Sided		2	1.5	3
ELED10.5/1	LED10.5W	EXIT Light Emitting Diode, (1) 10.5W lamp, Single Sided		1	10.5	10.5
ELED10.5/2	LED10.5W	EXIT Light Emitting Diode, (2) 10.5W lamp, Dual Sided		2	10.5	21
ELED2/1	LED2W	EXIT Light Emitting Diode, (1) 2W lamp, Single Sided		1	2	2
ELED2/2	LED2W	EXIT Light Emitting Diode, (2) 2W lamp, Dual Sided		2	2	4
ELED3/1	LED3W	EXIT Light Emitting Diode, (1) 3W lamp, Single Sided		1	3	3
ELED3/2	LED3W	EXIT Light Emitting Diode, (2) 3W lamp, Dual Sided		2	3	6
ELED5/1	LED5W	EXIT Light Emitting Diode, (1) 5W lamp, Single Sided		1	5	5
ELED5/2	LED5W	EXIT Light Emitting Diode, (2) 5W lamp, Dual Sided		2	5	10
ELED8/1	LED8W	EXIT Light Emitting Diode, (1) 8W lamp, Single Sided		1	8	8
ELED8/2	LED8W	EXIT Light Emitting Diode, (2) 8W lamp, Dual Sided		2	8	16
		Linear Fluorescent Fixtures				
F1.51LS	F15T8	Fluorescent, (1) 18" T8 lamp	Mag-STD	1	15	19
F1.51SS	F15T12	Fluorescent, (1) 18" T12 lamp	Mag-STD	1	15	19

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F1.52LS	F15T8	Fluorescent, (2) 18" T8 lamp	Mag-STD	2	15	36
F1.52SS	F15T12	Fluorescent, (2) 18", T12 lamp	Mag-STD	2	15	36
F21SHS	F24T12/HO	Fluorescent, (1) 24", HO lamp	Mag-STD	1	35	62
F21ILL	F17T8	Fluorescent, (1) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	17	20
F21ILL/T2	F17T8	Fluorescent, (1) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	17	17
F21ILL/T2-R	F17T8	Fluorescent, (1) 24", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 2 Lamp Ballast	Electronic	1	17	15
F21ILL/T3	F17T8	Fluorescent, (1) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	17	16
F21ILL/T3-R	F17T8	Fluorescent, (1) 24", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 3 Lamp Ballast	Electronic	1	17	14
F21ILL/T4	F17T8	Fluorescent, (1) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	17	15
F21ILL/T4-R	F17T8	Fluorescent, (1) 24", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 4 Lamp Ballast	Electronic	1	17	14
F21LL	F17T8	Fluorescent, (1) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	1	17	16
F21LL/T2	F17T8	Fluorescent, (1) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	17	16
F21LL/T3	F17T8	Fluorescent, (1) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	17	17
F21LL/T4	F17T8	Fluorescent, (1) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	17	17
F21LL-R	F17T8	Fluorescent, (1) 24", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	1	17	15
F21LS	F17T8	Fluorescent, (1) 24", T8 lamp, Standard Ballast	Mag-STD	1	17	24
F21GL	F24T5	Fluorescent, (1) 24", STD T5 lamp	Electronic	1	14	18
F21SE	F20T12	Fluorescent, (1) 24", STD lamp	Mag-ES	1	20	26
F21SS	F20T12	Fluorescent, (1) 24", STD lamp	Mag-STD	1	20	28
F21GHL	F24T5/HO	Fluorescent, (1) 24", STD HO T5 lamp	Electronic	1	24	29
F22SHS	F24T12/HO	Fluorescent, (2) 24", HO lamp	Mag-STD	2	35	90
F22GHL	F24T5/HO	Fluorescent, (2) 24", STD HO T5 lamp	Electronic	2	24	55
F22ILE	F17T8	Fluorescent, (2) 24", T-8 Instant Start lamp, Energy Saving Magnetic Ballast	Mag-ES	2	17	45
F22ILL	F17T8	Fluorescent, (2) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	17	33
F22ILL/T4	F17T8	Fluorescent, (2) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	17	31

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F22ILL/T4-R	F17T8	Fluorescent, (2) 24", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 4 Lamp Ballast	Electronic	2	17	28
F22ILL-R	F17T8	Fluorescent, (2) 24", T-8 lamp, Instant Start Ballast, RLO (BF<.85)	Electronic	2	17	29
F22LL	F17T8	Fluorescent, (2) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	2	17	31
F22LL/T4	F17T8	Fluorescent, (2) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	17	34
F22LL-R	F17T8	Fluorescent, (2) 24", T-8 lamp, Rapid Start Ballast, RLO (BF<.85)	Electronic	2	17	28
F22GL	F24T5	Fluorescent, (2) 24", STD T5 lamp	Electronic	2	14	35
F22SE	F20T12	Fluorescent, (2) 24", STD lamp	Mag-ES	2	20	51
F22SS	F20T12	Fluorescent, (2) 24", STD lamp	Mag-STD	2	20	56
F23ILL	F17T8	Fluorescent, (3) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	3	17	47
F23ILL-H	F17T8	Fluorescent, (3) 24", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	3	17	49
F23ILL-R	F17T8	Fluorescent, (3) 24", T-8 lamp, Instant Start Ballast, RLO (BF<.85)	Electronic	3	17	43
F23LL	F17T8	Fluorescent, (3) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	3	17	52
F23LL-R	F17T8	Fluorescent, (3) 24", T-8 lamp, Rapid Start Ballast, RLO (BF<.85)	Electronic	3	17	41
F23SE	F20T12	Fluorescent, (3) 24", STD lamp	Mag-ES	3	20	77
F23SS	F20T12	Fluorescent, (3) 24", STD lamp	Mag-STD	3	20	84
F24ILL	F17T8	Fluorescent, (4) 24", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	17	61
F24ILL-R	F17T8	Fluorescent, (4) 24", T-8 lamp, Instant Start Ballast, RLO (BF<.85)	Electronic	4	17	55
F24LL	F17T8	Fluorescent, (4) 24", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	4	17	68
F24LL-R	F17T8	Fluorescent, (4) 24", T-8 lamp, Rapid Start Ballast, RLO (BF<.85)	Electronic	4	17	57
F24SE	F20T12	Fluorescent, (4) 24", STD lamp	Mag-ES	4	20	102
F24SS	F20T12	Fluorescent, (4) 24", STD lamp	Mag-STD	4	20	112
F26SE	F20T12	Fluorescent, (6) 24", STD lamp	Mag-ES	6	20	153
F26SS	F20T12	Fluorescent, (6) 24", STD lamp	Mag-STD	6	20	168
F31EE	F30T12/ES	Fluorescent, (1) 36", ES lamp	Mag-ES	1	25	38
F31EE/T2	F30T12/ES	Fluorescent, (1) 36", ES lamp, Tandem wired	Mag-ES	1	25	33
F31EL	F30T12/ES	Fluorescent, (1) 36", ES lamp	Electronic	1	25	26
F31ES	F30T12/ES	Fluorescent, (1) 36", ES lamp	Mag-STD	1	25	42
F31ES/T2	F30T12/ES	Fluorescent, (1) 36", ES lamp, Tandem wired	Mag-STD	1	25	37
F31ILL	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	25	26
F31ILL/T2	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	25	23
F31ILL/T2-H	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, HLO (BF: .96-1.1), Tandem 2 Lamp Ballast	Electronic	1	25	24

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F31ILL/T2-R	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, RLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	25	23
F31ILL/T3	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	25	22
F31ILL/T3-R	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 3 Lamp Ballast	Electronic	1	25	22
F31ILL/T4	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	25	22
F31ILL/T4-R	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 4 Lamp Ballast	Electronic	1	25	22
F31ILL-H	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	1	25	28
F31ILL-R	F25T8	Fluorescent, (1) 36", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	1	25	27
F31LL	F25T8	Fluorescent, (1) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	1	25	24
F31LL/T2	F25T8	Fluorescent, (1) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	25	23
F31LL/T3	F25T8	Fluorescent, (1) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	25	24
F31LL/T4	F25T8	Fluorescent, (1) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	25	22
F31LL-H	F25T8	Fluorescent, (1) 36", T-8 lamp, Rapid Start Ballast, HLO (BF:.96-1.1)	Electronic	1	25	26
F31LL-R	F25T8	Fluorescent, (1) 36", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	1	25	23
F31SE/T2	F30T12	Fluorescent, (1) 36", STD lamp, Tandem wired	Mag-ES	1	30	37
F31GHL	F36T5/HO	Fluorescent, (1) 36", STD HO T5 lamp	Electronic	1	39	43
F31SHS	F36T12/HO	Fluorescent, (1) 36", HO lamp	Mag-STD	1	50	70
F31SL	F30T12	Fluorescent, (1) 36", STD lamp	Electronic	1	30	31
F31GL	F36T5	Fluorescent, (1) 36", STD T5 lamp	Electronic	1	21	27
F31SS	F30T12	Fluorescent, (1) 36", STD lamp	Mag-STD	1	30	46
F31SS/T2	F30T12	Fluorescent, (1) 36", STD lamp, Tandem wired	Mag-STD	1	30	41
F32EE	F30T12/ES	Fluorescent, (2) 36", ES lamp	Mag-ES	2	25	66
F32EL	F30T12/ES	Fluorescent, (2) 36", ES lamp	Electronic	2	25	50
F32ES	F30T12/ES	Fluorescent, (2) 36", ES lamp	Mag-STD	2	25	73
F32ILL	F25T8	Fluorescent, (2) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	25	46
F32ILL/T4	F25T8	Fluorescent, (2) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	25	44
F32ILL/T4-R	F25T8	Fluorescent, (2) 36", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 4 Lamp Ballast	Electronic	2	25	43

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F32ILL-H	F25T8	Fluorescent, (2) 36", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	2	25	48
F32ILL-R	F25T8	Fluorescent, (2) 36", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	2	25	46
F32LE	F25T8	Fluorescent, (2) 36", T-8 lamp	Mag-ES	2	25	65
F32LL	F25T8	Fluorescent, (2) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	2	25	46
F32LL/T4	F25T8	Fluorescent, (2) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	25	45
F32LL-H	F25T8	Fluorescent, (2) 36", T-8 lamp, Rapid Start Ballast, HLO (BF:.96-1.1)	Electronic	2	25	50
F32LL-R	F25T8	Fluorescent, (2) 36", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	2	25	42
F32LL-V	F25T8	Fluorescent, (2) 36", T-8 lamp, Rapid Start Ballast, VHLO (BF>1.1)	Electronic	2	25	70
F32SE	F30T12	Fluorescent, (2) 36", STD lamp	Mag-ES	2	30	74
F32GHL	F36T5/HO	Fluorescent, (1) 36", STD HO T5 lamp	Electronic	2	39	85
F32SHS	F36T12/HO	Fluorescent, (2) 36", HO, lamp	Mag-STD	2	50	114
F32SL	F30T12	Fluorescent, (2) 36", STD lamp	Electronic	2	30	58
F32GL	F36T5	Fluorescent, (1) 36", STD T5 lamp	Electronic	2	21	52
F32SS	F30T12	Fluorescent, (2) 36", STD lamp	Mag-STD	2	30	81
F33ES	F30T12/ES	Fluorescent, (3) 36", ES lamp	Mag-STD	3	25	115
F33ILL	F25T8	Fluorescent, (3) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	3	25	67
F33ILL-R	F25T8	Fluorescent, (3) 36", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	3	25	66
F33LL	F25T8	Fluorescent, (3) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	3	25	72
F33LL-R	F25T8	Fluorescent, (3) 36", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	3	25	62
F33SE	F30T12	Fluorescent, (3) 36", STD lamp, (1) STD ballast and (1) ES ballast	Mag-ES	3	30	120
F33SS	F30T12	Fluorescent, (3) 36", STD lamp	Mag-STD	3	30	127
F34ILL	F25T8	Fluorescent, (4) 36", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	25	87
F34ILL-R	F25T8	Fluorescent, (4) 36", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	4	25	86
F34LL	F25T8	Fluorescent, (4) 36", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	4	25	89
F34LL-R	F25T8	Fluorescent, (4) 36", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	4	25	84
F34SE	F30T12	Fluorescent, (4) 36", STD lamp	Mag-ES	4	30	148
F34SL	F30T12	Fluorescent, (4) 36", STD lamp	Electronic	4	30	116
F34SS	F30T12	Fluorescent, (4) 36", STD lamp	Mag-STD	4	30	162
F36EE	F30T12/ES	Fluorescent, (6) 36", ES lamp	Mag-ES	6	25	198
F36ILL-R	F25T8	Fluorescent, (6) 36", T-8 lamp, Instant Start Ballast, RLO (BF<.85)	Electronic	6	25	134
F36SE	F30T12	Fluorescent, (6) 36", STD lamp	Mag-ES	6	30	238
F40EE/D1	None	Fluorescent, (0) 48" lamp, Completely delamped fixture with (1) hot ballast	Mag-ES	0	0	4
F40EE/D2	None	Fluorescent, (0) 48" lamp, Completely delamped fixture with (2) hot ballast	Mag-ES	0	0	8
F41EE	F40T12/ES	Fluorescent, (1) 48", ES lamp	Mag-ES	1	34	43
F41EE/D2	F40T12/ES	Fluorescent, (1) 48", ES lamp, 2 ballast	Mag-ES	1	34	43

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F41EE/T2	F40T12/ES	Fluorescent, (1) 48", ES lamp, tandem wired, 2-lamp ballast	Mag-ES	1	34	36
F41EHS	F48T12/HO/ES	Fluorescent, (1) 48", ES HO lamp	Mag-STD	1	55	80
F41EIS	F48T12/ES	Fluorescent, (1) 48" ES Instant Start lamp. Magnetic ballast	Mag-STD	1	30	51
F41EL	F40T12/ES	Fluorescent, (1) 48", T12 ES lamp, Electronic Ballast	Electronic	1	34	32
F41EL/T2	F40T12/ES	Fluorescent, (1) 48", T-12 ES lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	34	32
F41ES	F40T12/ES	Fluorescent, (1) 48", ES lamp	Mag-STD	1	34	50
F41EVS	F48T12/VHO/ES	Fluorescent, (1) 48", VHO ES lamp	Mag-STD	1		123
F41IAL	F25T12	Fluorescent, (1) 48", F25T12 lamp, Instant Start Ballast	Electronic	1	25	25
F41IAL/T2-R	F25T12	Fluorescent, (1) 48", F25T12 lamp, Instant Start, Tandem 2-Lamp Ballast, RLO (BF<0.85)	Electronic	1	25	19
F41IAL/T3-R	F25T12	Fluorescent, (1) 48", F25T12 lamp, Instant Start, Tandem 3-Lamp Ballast, RLO (BF<0.85)	Electronic	1	25	20
F41ILL	F32T8	Fluorescent, (1) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	32	31
F41SILL	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	30	28
F41SILL/T2	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	30	27
F41SILL/T3	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	30	27
F41SILL/T4	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	30	26
F41SILL-R	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	1	30	25
F41SILL/T2-R	F30T8	Fluorescent, (1) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 2 Lamp Ballast	Electronic	1	30	24
F41SILL/T3-R	F30T8	Fluorescent, (1) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 3 Lamp Ballast	Electronic	1	30	24
F41SILL/T4-R	F30T8	Fluorescent, (1) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	1	30	23
F41SILL-H	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	1	30	37
F41SILL/T2-H	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1), Tandem 2 Lamp Ballast	Electronic	1	30	36
F41SILL/T3-H	F30T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1), Tandem 3 Lamp Ballast	Electronic	1	30	36
F41SSILL	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	28	26
F41SSILL/T2	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	28	25
F41SSILL/T3	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	28	25
F41SSILL/T4	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	28	24
F41SSILL-R	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	1	28	23

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F41SSILL/T2-R	F28T8	Fluorescent, (1) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 2 Lamp Ballast	Electronic	1	28	22
F41SSILL/T3-R	F28T8	Fluorescent, (1) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 3 Lamp Ballast	Electronic	1	28	22
F41SSILL/T4-R	F28T8	Fluorescent, (1) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	1	28	21
F41SSILL-H	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	1	28	33
F41SSILL/T2-H	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1), Tandem 2 Lamp Ballast	Electronic	1	28	32
F41SSILL/T3-H	F28T8	Fluorescent, (1) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1), Tandem 3 Lamp Ballast	Electronic	1	28	32
F41ILL/T2	F32T8	Fluorescent, (1) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	32	30
F41ILL/T2-H	F32T8	Fluorescent, (1) 48", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1), Tandem 2 Lamp Ballast	Electronic	1	32	33
F41ILL/T2-R	F32T8	Fluorescent, (1) 48", T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 2 Lamp Ballast	Electronic	1	32	26
F41ILL/T3	F32T8	Fluorescent, (1) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	32	30
F41ILL/T3-H	F32T8	Fluorescent, (1) 48", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1), Tandem 3 Lamp Ballast	Electronic	1	32	31
F41ILL/T3-R	F32T8	Fluorescent, (1) 48", T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 3 Lamp Ballast	Electronic	1	32	26
F41ILL/T4	F32T8	Fluorescent, (1) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	32	28
F41ILL/T4-R	F32T8	Fluorescent, (1) 48", T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	1	32	26
F41ILL-H	F32T8	Fluorescent, (1) 48", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	1	32	36
F41LE	F32T8	Fluorescent, (1) 48", T-8 lamp	Mag-ES	1	32	35
F41LL	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	1	32	32
F41LL/T2	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	32	30
F41LL/T2-H	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, HLO (BF:.96-1.1), Tandem 2 Lamp Ballast	Electronic	1	32	39
F41LL/T2-R	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85), Tandem 2 Lamp Ballast	Electronic	1	32	27
F41LL/T3	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	32	31
F41LL/T3-H	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, HLO (BF:.96-1.1), Tandem 3 Lamp Ballast	Electronic	1	32	33
F41LL/T3-R	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85), Tandem 3 Lamp Ballast	Electronic	1	32	25

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F41LL/T4	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	32	30
F41LL/T4-R	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	1	32	26
F41LL-H	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, HLO (BF:.96-1.1)	Electronic	1	32	39
F41LL-R	F32T8	Fluorescent, (1) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	1	32	27
F41SE	F40T12	Fluorescent, (1) 48", STD lamp	Mag-ES	1	40	50
F41GHL	F48T5/HO	Fluorescent, (1) 48", STD HO T5 lamp	Electronic	1	54	59
F41SHS	F48T12/HO	Fluorescent, (1) 48", STD HO lamp	Mag-STD	1	60	85
F41SIL	F48T12	Fluorescent, (1) 48", STD IS lamp, Electronic ballast	Electronic	1	39	46
F41SIL/T2	F48T12	Fluorescent, (1) 48", STD IS lamp, Electronic ballast, tandem wired	Electronic	1	39	37
F41SIS	F48T12	Fluorescent, (1) 48", STD IS lamp	Mag-STD	1	39	60
F41SIS/T2	F48T12	Fluorescent, (1) 48", STD IS lamp, tandem to 2-lamp ballast	Mag-STD	1	39	52
F41GL	F48T5	Fluorescent, (1) 48", STD T5 lamp	Electronic	1	28	32
F41SL/T2	F40T12	Fluorescent, (1) 48", T-12 STD lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	40	36
F41SS	F40T12	Fluorescent, (1) 48", STD lamp	Mag-STD	1	40	57
F41SVS	F48T12/VHO	Fluorescent, (1) 48", STD VHO lamp	Mag-STD	1	110	135
F41TS	F40T10	Fluorescent, (1) 48", T-10 lamp	Mag-STD	1	40	51
F42EE	F40T12/ES	Fluorescent, (2) 48", ES lamp	Mag-ES	2	34	72
F42EE/D2	F40T12/ES	Fluorescent, (2) 48", ES lamp, 2 Ballasts (delamped)	Mag-ES	2	34	76
F42EHS	F48T12/HO/ES	Fluorescent, (2) 42", HO lamp (3.5' lamp)	Mag-STD	2	55	135
F42EIS	F48T12/ES	Fluorescent, (2) 48" ES Instant Start lamp. Magnetic ballast	Mag-STD	2	30	82
F42EL	F40T12/ES	Fluorescent, (2) 48", T12 ES lamps, Electronic Ballast	Electronic	2	34	60
F42ES	F40T12/ES	Fluorescent, (2) 48", ES lamp	Mag-STD	2	34	80
F42EVS	F48T12/VHO/ES	Fluorescent, (2) 48", VHO ES lamp	Mag-STD	2		210
F42IAL/T4-R	F25T12	Fluorescent, (2) 48", F25T12 lamp, Instant Start, Tandem 4-Lamp Ballast, RLO (BF<0.85)	Electronic	2	25	40
F42IAL-R	F25T12	Fluorescent, (2) 48", F25T12 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	2	25	39
F42ILL	F32T8	Fluorescent, (2) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	32	59
F42SILL	F30T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	30	53
F42SILL/T4	F30T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	30	52
F42SILL-R	F30T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	2	30	47
F42SILL/T4-R	F30T8	Fluorescent, (2) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	2	30	46
F42SILL-H	F30T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-2.2)	Electronic	2	30	72
F42SSILL	F28T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	28	48

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F42SSILL/T4	F28T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	28	47
F42SSILL-R	F28T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	2	28	45
F42SSILL/T4-R	F28T8	Fluorescent, (2) 48", Super T-8 lamp, IS Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	2	28	44
F42SSILL-H	F28T8	Fluorescent, (2) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-2.2)	Electronic	2	28	67
F42ILL/T4	F32T8	Fluorescent, (2) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	32	56
F42ILL/T4-R	F32T8	Fluorescent, (2) 48", T-8 lamp, Instant Start Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	2	32	51
F42ILL-H	F32T8	Fluorescent, (2) 48", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	2	32	65
F42ILL-R	F32T8	Fluorescent, (2) 48", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	2	32	52
F42ILL-V	F32T8	Fluorescent, (2) 48", T-8 lamp, Instant Start Ballast, VHLO (BF>1.1)	Electronic	2	32	79
F42LE	F32T8	Fluorescent, (2) 48", T-8 lamp	Mag-ES	2	32	71
F42LL	F32T8	Fluorescent, (2) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	2	32	60
F42LL/T4	F32T8	Fluorescent, (2) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	2	32	59
F42LL/T4-R	F32T8	Fluorescent, (2) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85), Tandem 4 Lamp Ballast	Electronic	2	32	53
F42LL-H	F32T8	Fluorescent, (2) 48", T-8 lamp, Rapid Start Ballast, HLO (BF:.96-1.1)	Electronic	2	32	70
F42LL-R	F32T8	Fluorescent, (2) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	2	32	54
F42LL-V	F32T8	Fluorescent, (2) 48", T-8 lamp, Rapid Start Ballast, VHLO (BF>1.1)	Electronic	2	32	85
F42SE	F40T12	Fluorescent, (2) 48", STD lamp	Mag-ES	2	40	86
F42GHL	F48T5/HO	Fluorescent, (2) 48", STD HO T5 lamp	Electronic	2	54	117
F42SHS	F48T12/HO	Fluorescent, (2) 48", STD HO lamp	Mag-STD	2	60	145
F42SIL	F48T12	Fluorescent, (2) 48", STD IS lamp, Electronic ballast	Electronic	2	39	74
F42SIS	F48T12	Fluorescent, (2) 48", STD IS lamp	Mag-STD	2	39	103
F42GL	F48T5	Fluorescent, (2) 48", STD T5 lamp	Electronic	2	28	63
F42SS	F40T12	Fluorescent, (2) 48", STD lamp	Mag-STD	2	40	94
F42SVS	F48T12/VHO	Fluorescent, (2) 48", STD VHO lamp	Mag-STD	2	110	242
F43EE	F40T12/ES	Fluorescent, (3) 48", ES lamp	Mag-ES	3	34	115
F43EHS	F48T12/HO/ES	Fluorescent, (3) 48", ES HO lamp (3.5' lamp)	Mag-STD	3	55	215
F43EIS	F48T12/ES	Fluorescent, (3) 48" ES Instant Start lamp. Magnetic ballast	Mag-STD	3	30	133
F43EL	F40T12/ES	Fluorescent, (3) 48", T12 ES lamps, Electronic Ballast	Electronic	3	34	92
F43ES	F40T12/ES	Fluorescent, (3) 48", ES lamp	Mag-STD	3	34	130
F43EVS	F48T12/VHO/ES	Fluorescent, (3) 48", VHO ES lamp	Mag-STD	3		333
F43IAL-R	F25T12	Fluorescent, (3) 48", F25T12 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	3	25	60

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F43ILL	F32T8	Fluorescent, (3) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	3	32	89
F43SILL	F30T8	Fluorescent, (3) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	3	30	78
F43SILL-R	F30T8	Fluorescent, (3) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	3	30	70
F43SILL-H	F30T8	Fluorescent, (3) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-3.3)	Electronic	3	30	105
F43SSILL	F28T8	Fluorescent, (3) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	3	28	72
F43SSILL-R	F28T8	Fluorescent, (3) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	3	28	66
F43SSILL-H	F28T8	Fluorescent, (3) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-3.3)	Electronic	3	28	98
F43ILL/2	F32T8	Fluorescent, (3) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), (2) ballast	Electronic	3	32	90
F43ILL-H	F32T8	Fluorescent, (3) 48", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	3	32	93
F43ILL-R	F32T8	Fluorescent, (3) 48", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	3	32	78
F43ILL-V	F32T8	Fluorescent, (3) 48", T-8 lamp, Instant Start Ballast, VHLO (BF>1.1)	Electronic	3	32	112
F43LE	F32T8	Fluorescent, (3) 48", T-8 lamp	Mag-ES	3	32	110
F43LL	F32T8	Fluorescent, (3) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	3	32	93
F43LL/2	F32T8	Fluorescent, (3) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), (2) ballast	Electronic	3	32	92
F43LL-H	F32T8	Fluorescent, (3) 48", T-8 lamp, Rapid Start Ballast, HLO (BF:.96-1.1)	Electronic	3	32	98
F43LL-R	F32T8	Fluorescent, (3) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	3	32	76
F43SE	F40T12	Fluorescent, (3) 48", STD lamp	Mag-ES	3	40	136
F43GHL	F48T5/HO	Fluorescent, (3) 48", STD HO T5 lamp	Electronic	3	54	177
F43SHS	F48T12/HO	Fluorescent, (3) 48", STD HO lamp	Mag-STD	3	60	230
F43SIL	F48T12	Fluorescent, (3) 48", STD IS lamp, Electronic ballast	Electronic	3	39	120
F43SIS	F48T12	Fluorescent, (3) 48", STD IS lamp	Mag-STD	3	39	162
F43SS	F40T12	Fluorescent, (3) 48", STD lamp	Mag-STD	3	40	151
F43SVS	F48T12/VHO	Fluorescent, (3) 48", STD VHO lamp	Mag-STD	3	110	377
F44EE	F40T12/ES	Fluorescent, (4) 48", ES lamp	Mag-ES	4	34	144
F44EE/D4	F40T12/ES	Fluorescent, (4) 48", ES lamp, 4 Ballasts (delamped)	Mag-ES	4	34	152
F44EHS	F48T12/HO/ES	Fluorescent, (4) 48", ES HO lamp	Mag-STD	4	55	270
F44EIS	F48T12/ES	Fluorescent, (4) 48" ES Instant Start lamp, Magnetic ballast	Mag-STD	4	30	164
F44EL	F40T12/ES	Fluorescent, (4) 48", T12 ES lamp, Electronic Ballast	Electronic	4	34	120
F44ES	F40T12/ES	Fluorescent, (4) 48", ES lamp	Mag-STD	4	34	160
F44EVS	F48T12/VHO/ES	Fluorescent, (4) 48", VHO ES lamp	Mag-STD	4		420
F44IAL-R	F25T12	Fluorescent, (4) 48", F25T12 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	4	25	80
F44ILL	F32T8	Fluorescent, (4) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	32	112
F44SILL	F30T8	Fluorescent, (4) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	30	105
F44SILL-R	F30T8	Fluorescent, (4) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	4	30	91
F44SILL-H	F30T8	Fluorescent, (4) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-4.4)	Electronic	4	30	140
F44SSILL	F28T8	Fluorescent, (4) 48", Super T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	28	96

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F44SSILL-R	F28T8	Fluorescent, (4) 48", Super T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	4	28	86
F44SSILL-H	F28T8	Fluorescent, (4) 48", Super T-8 lamp, Instant Start Ballast, HLO (BF:.96-4.4)	Electronic	4	28	131
F44ILL/2	F32T8	Fluorescent, (4) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), (2) ballast	Electronic	4	32	118
F44ILL-R	F32T8	Fluorescent, (4) 48", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	4	32	102
F44LE	F32T8	Fluorescent, (4) 48", T-8 lamp	Mag-ES	4	32	142
F44LL	F32T8	Fluorescent, (4) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95)	Electronic	4	32	118
F44LL/2	F32T8	Fluorescent, (4) 48", T-8 lamp, Rapid Start Ballast, NLO (BF: .85-.95), (2) ballast	Electronic	4	32	120
F44LL-R	F32T8	Fluorescent, (4) 48", T-8 lamp, Rapid Start Ballast, RLO (BF<0.85)	Electronic	4	32	105
F44SE	F40T12	Fluorescent, (4) 48", STD lamp	Mag-ES	4	40	172
F44GHL	F48T5/HO	Fluorescent, (4) 48", STD HO T5 lamp	Electronic	4	54	234
F44SHS	F48T12/HO	Fluorescent, (4) 48", STD HO lamp	Mag-STD	4	60	290
F44SIL	F48T12	Fluorescent, (4) 48", STD IS lamp, Electronic ballast	Electronic	4	39	148
F44SIS	F48T12	Fluorescent, (4) 48", STD IS lamp	Mag-STD	4	39	204
F44SS	F40T12	Fluorescent, (4) 48", STD lamp	Mag-STD	4	40	188
F44SVS	F48T12/VHO	Fluorescent, (4) 48", STD VHO lamp	Mag-STD	4	110	484
F45ILL	F32T8	Fluorescent, (5) 48", T-8 lamp, (1) 3-lamp IS ballast and (1) 2-lamp IS ballast, NLO (BF: .85-.95)	Electronic	5	32	148
F45GHL	F48T5/HO	Fluorescent, (5) 48", STD HO T5 lamp	Electronic	5	54	294
F46EE	F40T12/ES	Fluorescent, (6) 48", ES lamp	Mag-ES	6	34	216
F46EL	F40T12/ES	Fluorescent, (6) 48", ES lamp	Electronic	6	34	186
F46ES	F40T12/ES	Fluorescent, (6) 48", ES lamp	Mag-STD	6	34	236
F46ILL	F32T8	Fluorescent, (6) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	6	32	175
F46ILL-R	F32T8	Fluorescent, (6) 48", T-8 lamp, Instant Start Ballast, RLO (BF< .85)	Electronic	6	32	156
F46LL	F32T8	Fluorescent, (6) 48", T-8 lamp, NLO (BF: .85-.95)	Electronic	6	32	182
F46GHL	F48T5/HO	Fluorescent, (6) 48", STD HO T5 lamp	Electronic	6	54	351
F46SE	F40T12	Fluorescent, (6) 48", STD lamp	Mag-ES	6	40	258
F46SS	F40T12	Fluorescent, (6) 48", STD lamp	Mag-STD	6	40	282
F48EE	F40T12/ES	Fluorescent, (8) 48", ES lamp	Mag-ES	8	34	288
F48ILL	F32T8	Fluorescent, (8) 48", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	8	32	224
F48ILL-R	F32T8	Fluorescent, (8) 48", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	8	32	204
F48GHL	F48T5/HO	Fluorescent, (8) 48", STD HO T5 lamp	Electronic	8	54	468
F51LHL	F60T8/HO	Fluorescent, (1) 60", T-8 HO lamp, Instant Start Ballast	Electronic	1	55	59
F51ILL	F40T8	Fluorescent, (1) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	40	36
F51ILL/T2	F40T8	Fluorescent, (1) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	40	36

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F51ILL/T3	F40T8	Fluorescent, (1) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 3 Lamp Ballast	Electronic	1	40	35
F51ILL/T4	F40T8	Fluorescent, (1) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 4 Lamp Ballast	Electronic	1	40	34
F51ILL-R	F40T8	Fluorescent, (1) 60", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	1	40	43
F51SHE	F60T12/HO	Fluorescent, (1) 60", STD HO lamp	Mag-ES	1	75	88
F51SHL	F60T12/HO	Fluorescent, (1) 60", STD HO lamp	Electronic	1	75	69
F51GHL	F60T5/HO	Fluorescent, (1) 60", STD HO T5 lamp	Electronic	1	49	54
F51GHL	F60T5/HO	Fluorescent, (1) 60", STD HO T5 lamp	Electronic	1	80	89
F51SHS	F60T12/HO	Fluorescent, (1) 60", STD HO lamp	Mag-STD	1	75	92
F51SL	F60T12	Fluorescent, (1) 60", STD lamp	Electronic	1	50	44
F51GL	F60T5	Fluorescent, (1) 60", STD T5 lamp	Electronic	1	35	39
F51SS	F60T12	Fluorescent, (1) 60", STD lamp	Mag-STD	1	50	63
F51SVS	F60T12/VHO	Fluorescent, (1) 60", VHO ES lamp	Mag-STD	1	135	165
F52ILHL	F60T8/HO	Fluorescent, (2) 60", T-8 HO lamp, Instant Start Ballast	Electronic	2	55	123
F52ILL	F40T8	Fluorescent, (2) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	40	72
F52ILL/T4	F40T8	Fluorescent, (2) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	2	40	67
F52ILL-H	F40T8	Fluorescent, (2) 60", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	2	40	80
F52ILL-R	F40T8	Fluorescent, (2) 60", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	2	40	73
F52SHE	F60T12/HO	Fluorescent, (2) 60", STD HO lamp	Mag-ES	2	75	176
F52SHL	F60T12/HO	Fluorescent, (2) 60", STD HO lamp	Electronic	2	75	138
F52GHL	F60T5/HO	Fluorescent, (2) 60", STD HO T5 lamp	Electronic	2	49	106
F52SHS	F60T12/HO	Fluorescent, (2) 60", STD HO lamp	Mag-STD	2	75	168
F52SL	F60T12	Fluorescent, (2) 60", STD lamp	Electronic	2	50	88
F52GL	F60T5	Fluorescent, (2) 60", STD T5 lamp	Electronic	2	35	76
F52SS	F60T12	Fluorescent, (2) 60", STD lamp	Mag-STD	2	50	128
F52SVS	F60T12/VHO	Fluorescent, (2) 60", VHO ES lamp	Mag-STD	2	135	310
F53ILL	F40T8	Fluorescent, (3) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	3	40	106
F53ILL-H	F40T8	Fluorescent, (3) 60", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	3	40	108
F54ILL	F40T8	Fluorescent, (4) 60", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	40	134
F54ILL-H	F40T8	Fluorescent, (4) 60", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	4	40	126
F61SIL	F72T12	Fluorescent, (1) 72", STD lamp, IS electronic ballast	Electronic	1	55	68
F61SE	F72T12	Fluorescent, (1) 72", STD lamp	Mag-ES	1	55	76
F61SHS	F72T12/HO	Fluorescent, (1) 72", STD HO lamp	Mag-STD	1	85	120
F61SS	F72T12	Fluorescent, (1) 72", STD lamp	Mag-STD	1	55	90

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F61SVS	F72T12/VHO	Fluorescent, (1) 72", VHO lamp	Mag-STD	1	160	180
F62ILHL	F72T8	Fluorescent, (2) 72", T-8 HO lamp, Instant Start Ballast	Electronic	2	65	147
F62SIL	F72T12	Fluorescent, (2) 72", STD lamp, IS electronic ballast	Electronic	2	55	108
F62SE	F72T12	Fluorescent, (2) 72", STD lamp	Mag-ES	2	55	122
F62SHE	F72T12/HO	Fluorescent, (2) 72", STD HO lamp	Mag-ES	2	85	194
F62SHS	F72T12/HO	Fluorescent, (2) 72", STD HO lamp	Mag-STD	2	85	220
F62SL	F72T12	Fluorescent, (2) 72", STD lamp	Electronic	2	55	108
F62SS	F72T12	Fluorescent, (2) 72", STD lamp	Mag-STD	2	55	145
F62SVS	F72T12/VHO	Fluorescent, (2) 72", VHO lamp	Mag-STD	2	160	330
F63SIL	F72T12	Fluorescent, (3) 72", STD lamp, IS electronic ballast	Electronic	3	55	176
F63SS	F72T12	Fluorescent, (3) 72", STD lamp	Mag-STD	3	55	202
F64SIL	F72T12	Fluorescent, (4) 72", STD lamp, IS electronic ballast	Electronic	4	55	216
F64SE	F72T12	Fluorescent, (4) 72", STD lamp	Mag-ES	4	55	230
F64SHE	F72T12/HO	Fluorescent, (4) 72", STD HO lamp	Mag-ES	4	85	388
F64SS	F72T12	Fluorescent, (4) 72", STD lamp	Mag-STD	4	55	244
F81EE/T2	F96T12/ES	Fluorescent, (1) 96", ES lamp, tandem to 2-lamp ballast	Mag-ES	1	60	62
F81EHL	F96T12/HO/ES	Fluorescent, (1) 96", ES HO lamp	Electronic	1	95	80
F81EHL/T2	F96T12/HO/ES	Fluorescent, (1) 96", ES HO lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	95	85
F81EHS	F96T12/HO/ES	Fluorescent, (1) 96", ES HO lamp	Mag-STD	1	95	125
F81EL	F96T12/ES	Fluorescent, (1) 96", ES lamp	Electronic	1	60	60
F81EL/T2	F96T12/ES	Fluorescent, (1) 96", ES lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	60	55
F81ES	F96T12/ES	Fluorescent, (1) 96", ES lamp	Mag-STD	1	60	83
F81ES/T2	F96T12/ES	Fluorescent, (1) 96", ES lamp, tandem to 2-lamp ballast	Mag-STD	1	60	64
F81EVS	F96T12/VHO/ES	Fluorescent, (1) 96", ES VHO lamp	Mag-STD	1	185	200
F81ILL	F96T8	Fluorescent, (1) 96", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	59	58
F81ILL/T2	F96T8	Fluorescent, (1) 96", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	59	55
F81ILL/T2-R	F96T8	Fluorescent, (1) 96", T-8 lamp, Instant Start Ballast, RLO (BF<.85), Tandem 2 Lamp Ballast	Electronic	1	59	49
F81ILL-H	F96T8	Fluorescent, (1) 96", T-8 lamp, Instant Start Ballast, HLO (BF:.96-1.1)	Electronic	1	59	68
F81ILL-R	F96T8	Fluorescent, (1) 96", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	1	59	57
F81ILL-V	F96T8	Fluorescent, (1) 96", T-8 lamp, Instant Start Ballast, VHLO (BF>1.1)	Electronic	1	59	71
F81LHL	F96T8/HO	Fluorescent, (1) 96", T8 HO lamp	Electronic	1	86	85
F81LHL/T2	F96T8/HO	Fluorescent, (1) 96", T8 HO lamp, tandem wired to 2-lamp ballast	Electronic	1	86	80

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F81SE	F96T12	Fluorescent, (1) 96", STD lamp	Mag-ES	1	75	91
F81EHS	F96T12/HO	Fluorescent, (1) 96", ES HO lamp	Mag-STD	1	95	125
F81SHE	F96T12/HO	Fluorescent, (1) 96", STD HO lamp	Mag-ES	1	110	132
F81SHL/T2	F96T12/HO	Fluorescent, (1) 96", STD HO lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	110	98
F81SHS	F96T12/HO	Fluorescent, (1) 96", STD HO lamp	Mag-STD	1	110	145
F81SL	F96T12	Fluorescent, (1) 96", STD lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	1	75	70
F81SL/T2	F96T12	Fluorescent, (1) 96", STD lamp, Rapid Start Ballast, NLO (BF: .85-.95), Tandem 2 Lamp Ballast	Electronic	1	75	67
F81SS	F96T12	Fluorescent, (1) 96", STD lamp	Mag-STD	1	75	100
F81SVS	F96T12/VHO	Fluorescent, (1) 96", STD VHO lamp	Mag-STD	1	215	230
F82EE	F96T12/ES	Fluorescent, (2) 96", ES lamp	Mag-ES	2	60	123
F82EHE	F96T12/HO/ES	Fluorescent, (2) 96", ES HO lamp	Mag-ES	2	95	207
F82EHL	F96T12/HO/ES	Fluorescent, (2) 96", ES HO lamp	Electronic	2	95	170
F82EHS	F96T12/HO/ES	Fluorescent, (2) 96", ES HO lamp	Mag-STD	2	95	227
F82EL	F96T12/ES	Fluorescent, (2) 96", ES lamp	Electronic	2	60	110
F82ES	F96T12/ES	Fluorescent, (2) 96", ES lamp	Mag-STD	2	60	138
F82EVS	F96T12/VHO/ES	Fluorescent, (2) 96", ES VHO lamp	Mag-STD	2	185	390
F82ILL	F96T8	Fluorescent, (2) 96", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	59	109
F82ILL-R	F96T8	Fluorescent, (2) 96", T-8 lamp, Instant Start Ballast, RLO (BF<0.85)	Electronic	2	59	98
F82LHL	F96T8/HO	Fluorescent, (2) 96", T8 HO lamp	Electronic	2	86	160
F82SE	F96T12	Fluorescent, (2) 96", STD lamp	Mag-ES	2	75	158
F82SHE	F96T12/HO	Fluorescent, (2) 96", STD HO lamp	Mag-ES	2	110	237
F82SHL	F96T12/HO	Fluorescent, (2) 96", STD HO lamp	Electronic	2	110	195
F82SHS	F96T12/HO	Fluorescent, (2) 96", STD HO lamp	Mag-STD	2	110	257
F82SL	F96T12	Fluorescent, (2) 96", STD lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	2	75	134
F82SS	F96T12	Fluorescent, (2) 96", STD lamp	Mag-STD	2	75	173
F82SVS	F96T12/VHO	Fluorescent, (2) 96", STD VHO lamp	Mag-STD	2	215	450
F83EE	F96T12/ES	Fluorescent, (3) 96", ES lamp	Mag-ES	3	60	210
F83EHE	F96T12/HO/ES	Fluorescent, (3) 96", ES HO lamp, (1) 2-lamp ES Ballast, (1) 1-lamp STD Ballast	Mag-ES/STD	3	95	319
F83EHS	F96T12/HO/ES	Fluorescent, (3) 96", ES HO lamp	Mag-STD	3	95	352
F83EL	F96T12/ES	Fluorescent, (3) 96", ES lamp	Electronic	3	60	179
F83ES	F96T12/ES	Fluorescent, (3) 96", ES lamp	Mag-STD	3	60	221
F83EVS	F96T12/VHO/ES	Fluorescent, (3) 96", ES VHO lamp	Mag-STD	3	185	590
F83ILL	F96T8	Fluorescent, (3) 96", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	3	59	167
F83SHS	F96T12/HO	Fluorescent, (3) 96", STD HO lamp	Mag-STD	3	110	392

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
F83SS	F96T12	Fluorescent, (3) 96", STD lamp	Mag-STD	3	75	273
F83SVS	F96T12/VHO	Fluorescent, (3) 96", STD VHO lamp	Mag-STD	3	215	680
F84EE	F96T12/ES	Fluorescent, (4) 96", ES lamp	Mag-ES	4	60	246
F84EHE	F96T12/HO/ES	Fluorescent, (4) 96", ES HO lamp	Mag-ES	4	95	414
F84EHL	F96T12/HO/ES	Fluorescent, (4) 96", ES HO lamp	Electronic	4	95	340
F84EHS	F96T12/HO/ES	Fluorescent, (4) 96", ES HO lamp	Mag-STD	4	95	454
F84EL	F96T12/ES	Fluorescent, (4) 96", ES lamp	Electronic	4	60	220
F84ES	F96T12/ES	Fluorescent, (4) 96", ES lamp	Mag-STD	4	60	276
F84EVS	F96T12/VHO/ES	Fluorescent, (4) 96", ES VHO lamp	Mag-STD	4	185	780
F84ILL	F96T8	Fluorescent, (4) 96", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	59	219
F84LHL	F96T8/HO	Fluorescent, (4) 96", T8 HO lamp	Electronic	4	86	320
F84SE	F96T12	Fluorescent, (4) 96", STD lamp	Mag-ES	4	75	316
F84SHE	F96T12/HO	Fluorescent, (4) 96", STD HO lamp	Mag-ES	4	110	474
F84SHL	F96T12/HO	Fluorescent, (3) 96", STD HO lamp	Electronic	4	110	390
F84SHS	F96T12/HO	Fluorescent, (4) 96", STD HO lamp	Mag-STD	4	110	514
F84SL	F96T12	Fluorescent, (4) 96", STD lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	4	75	268
F84SS	F96T12	Fluorescent, (4) 96", STD lamp	Mag-STD	4	75	346
F84SVS	F96T12/VHO	Fluorescent, (4) 96", STD VHO lamp	Mag-STD	4	215	900
F86EHS	F96T12/HO/ES	Fluorescent, (6) 96", ES HO lamp	Mag-STD	6	95	721
F86ILL	F96T8	Fluorescent, (6) 96", T-8 lamp, Instant Start Ballast, NLO (BF: .85-.95)	Electronic	6	59	328
		Circline Fluorescent Fixtures				
FC12/1	FC12T9	Fluorescent, (1) 12" circular lamp, RS ballast	Mag-STD	1	32	31
FC12/2	FC12T9	Fluorescent, (2) 12" circular lamp, RS ballast	Mag-STD	2	32	62
FC16/1	FC16T9	Fluorescent, (1) 16" circular lamp	Mag-STD	1	40	35
FC20/1	FC6T9	Fluorescent, Circlite, (1) 20W lamp, Preheat ballast	Mag-STD	1	20	20
FC22/1	FC8T9	Fluorescent, Circlite, (1) 22W lamp, preheat ballast	Mag-STD	1	22	20
FC22/32/1	FC22/32T9	Fluorescent, Circlite, (1) 22W/32W lamp, preheat ballast	Mag-STD	1	22/32	58
FC32/1	FC12T9	Fluorescent, Circline, (1) 32W lamp, preheat ballast	Mag-STD	1	32	40
FC32/40/1	FC32/40T9	Fluorescent, Circlite, (1) 32W/40W lamp, preheat ballast	Mag-STD	1	32/40	80
FC40/1	FC16T9	Fluorescent, Circline, (1) 32W lamp, preheat ballast	Mag-STD	1	32	42
FC44/1	FC44T9	Fluorescent, Circlite, (1) 44W lamp, preheat ballast	Mag-STD	1	44	46
FC6/1	FC6T9	Fluorescent, (1) 6" circular lamp, RS ballast	Mag-STD	1	20	25
FC8/1	FC8T9	Fluorescent, (1) 8" circular lamp, RS ballast	Mag-STD	1	22	26
FC8/2	FC8T9	Fluorescent, (2) 8" circular lamp, RS ballast	Mag-STD	2	22	52
		U-Tube Fluorescent Fixtures				
FU1EE	FU40T12/ES	Fluorescent, (1) U-Tube, ES lamp	Mag-ES	1	34	43

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
FU1ILL	FU31T8/6	Fluorescent, (1) U-Tube, T-8 lamp, Instant Start ballast	Electronic	1	32	31
FU1LL	FU31T8/6	Fluorescent, (1) U-Tube, T-8 lamp	Electronic	1	32	32
FU1LL-R	FU31T8/6	Fluorescent, (1) U-Tube, T-8 lamp, RLO (BF<0.85)	Electronic	1	31	27
FU2SS	FU40T12	Fluorescent, (2) U-Tube, STD lamp	Mag-STD	2	40	96
FU2SE	FU40T12	Fluorescent, (2) U-Tube, STD lamp	Mag-ES	2	40	85
FU2EE	FU40T12/ES	Fluorescent, (2) U-Tube, ES lamp	Mag-ES	2	34	72
FU2ES	FU40T12/ES	Fluorescent, (2) U-Tube, ES lamp	Mag-STD	2	34	82
FU2ILL	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp, Instant Start Ballast	Electronic	2	32	59
FU2ILL/T4	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp, Instant Start Ballast, tandem wired	Electronic	2	32	56
FU2ILL/T4-R	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp, Instant Start Ballast, RLO, tandem wired	Electronic	2	32	51
FU2ILL-H	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp, Instant Start HLO Ballast	Electronic	2	32	65
FU2ILL-R	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp, Instant Start RLO Ballast	Electronic	2	32	52
FU2LL	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp	Electronic	2	32	60
FU2LL/T2	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp, Tandem 4 lamp ballast	Electronic	2	32	59
FU2LL-R	FU31T8/6	Fluorescent, (2) U-Tube, T-8 lamp, RLO (BF<0.85)	Electronic	2	31	54
FU3EE	FU40T12/ES	Fluorescent, (3) U-Tube, ES lamp	Mag-ES	3	35	115
FU3ILL	FU31T8/6	Fluorescent, (3) U-Tube, T-8 lamp, Instant Start Ballast	Electronic	3	32	89
FU3ILL-R	FU31T8/6	Fluorescent, (3) U-Tube, T-8 lamp, Instant Start RLO Ballast	Electronic	3	32	78
		Standard Incandescent Fixtures				
I100/1	I100	Incandescent, (1) 100W lamp		1	100	100
I100/2	I100	Incandescent, (2) 100W lamp		2	100	200
I100/3	I100	Incandescent, (3) 100W lamp		3	100	300
I100/4	I100	Incandescent, (4) 100W lamp		4	100	400
I100/5	I100	Incandescent, (5) 100W lamp		5	100	500
I1000/1	I1000	Incandescent, (1) 1000W lamp		1	1000	1000
I100E/1	I100/ES	Incandescent, (1) 100W ES lamp		1	90	90
I100EL/1	I100/ES/LL	Incandescent, (1) 100W ES/LL lamp		1	90	90
I120/1	I120	Incandescent, (1) 120W lamp		1	120	120
I120/2	I120	Incandescent, (2) 120W lamp		2	120	240
I125/1	I125	Incandescent, (1) 125W lamp		1	125	125
I135/1	I135	Incandescent, (1) 135W lamp		1	135	135
I135/2	I135	Incandescent, (2) 135W lamp		2	135	270
I15/1	I15	Incandescent, (1) 15W lamp		1	15	15
I15/2	I15	Incandescent, (2) 15W lamp		2	15	30
I150/1	I150	Incandescent, (1) 150W lamp		1	150	150
I150/2	I150	Incandescent, (2) 150W lamp		2	150	300

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
I1500/1	I1500	Incandescent, (1) 1500W lamp		1	1500	1500
I150E/1	I150/ES	Incandescent, (1) 150W ES lamp		1	135	135
I150EL/1	I150/ES/LL	Incandescent, (1) 150W ES/LL lamp		1	135	135
I170/1	I170	Incandescent, (1) 170W lamp		1	170	170
I20/1	I20	Incandescent, (1) 20W lamp		1	20	20
I20/2	I20	Incandescent, (2) 20W lamp		2	20	40
I200/1	I200	Incandescent, (1) 200W lamp		1	200	200
I200/2	I200	Incandescent, (2) 200W lamp		2	200	400
I2000/1	I2000	Incandescent, (1) 2000W lamp		1	2000	2000
I200L/1	I200/LL	Incandescent, (1) 200W LL lamp		1	200	200
I25/1	I25	Incandescent, (1) 25W lamp		1	25	25
I25/2	I25	Incandescent, (2) 25W lamp		2	25	50
I25/4	I25	Incandescent, (4) 25W lamp		4	25	100
I250/1	I250	Incandescent, (1) 250W lamp		1	250	250
I300/1	I300	Incandescent, (1) 300W lamp		1	300	300
I34/1	I34	Incandescent, (1) 34W lamp		1	34	34
I34/2	I34	Incandescent, (2) 34W lamp		2	34	68
I36/1	I36	Incandescent, (1) 36W lamp		1	36	36
I40/1	I40	Incandescent, (1) 40W lamp		1	40	40
I40/2	I40	Incandescent, (2) 40W lamp		2	40	80
I400/1	I400	Incandescent, (1) 400W lamp		1	400	400
I40E/1	I40/ES	Incandescent, (1) 40W ES lamp		1	34	34
I40EL/1	I40/ES/LL	Incandescent, (1) 40W ES/LL lamp		1	34	34
I42/1	I42	Incandescent, (1) 42W lamp		1	42	42
I448/1	I448	Incandescent, (1) 448W lamp		1	448	448
I45/1	I45	Incandescent, (1) 45W lamp		1	45	45
I50/1	I50	Incandescent, (1) 50W lamp		1	50	50
I50/2	I50	Incandescent, (2) 50W lamp		2	50	100
I500/1	I500	Incandescent, (1) 500W lamp		1	500	500
I52/1	I52	Incandescent, (1) 52W lamp		1	52	52
I52/2	I52	Incandescent, (2) 52W lamp		2	52	104
I54/1	I54	Incandescent, (1) 54W lamp		1	54	54
I54/2	I54	Incandescent, (2) 54W lamp		2	54	108
I55/1	I55	Incandescent, (1) 55W lamp		1	55	55
I55/2	I55	Incandescent, (2) 55W lamp		2	55	110
I60/1	I60	Incandescent, (1) 60W lamp		1	60	60

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
I60/2	I60	Incandescent, (2) 60W lamp		2	60	120
I60/3	I60	Incandescent, (3) 60W lamp		3	60	180
I60/4	I60	Incandescent, (4) 60W lamp		4	60	240
I60/5	I60	Incandescent, (5) 60W lamp		5	60	300
I60E/1	I60/ES	Incandescent, (1) 60W ES lamp		1	52	52
I60EL/1	I60/ES/LL	Incandescent, (1) 60W ES/LL lamp		1	52	52
I65/1	I65	Incandescent, (1) 65W lamp		1	65	65
I65/2	I65	Incandescent, (2) 65W lamp		2	65	130
I67/1	I67	Incandescent, (1) 67W lamp		1	67	67
I67/2	I67	Incandescent, (2) 67W lamp		2	67	134
I67/3	I67	Incandescent, (3) 67W lamp		3	67	201
I69/1	I69	Incandescent, (1) 69W lamp		1	69	69
I7.5/1	I7.5	Tungsten exit light, (1) 7.5 W lamp, used in night light application		1	7.5	8
I7.5/2	I7.5	Tungsten exit light, (2) 7.5 W lamp, used in night light application		2	7.5	15
I72/1	I72	Incandescent, (1) 72W lamp		1	72	72
I75/1	I75	Incandescent, (1) 75W lamp		1	75	75
I75/2	I75	Incandescent, (2) 75W lamp		2	75	150
I75/3	I75	Incandescent, (3) 75W lamp		3	75	225
I75/4	I75	Incandescent, (4) 75W lamp		4	75	300
I750/1	I750	Incandescent, (1) 750W lamp		1	750	750
I75E/1	I75/ES	Incandescent, (1) 75W ES lamp		1	67	67
I75EL/1	I75/ES/LL	Incandescent, (1) 75W ES/LL lamp		1	67	67
I80/1	I80	Incandescent, (1) 80W lamp		1	80	80
I85/1	I85	Incandescent, (1) 85W lamp		1	85	85
I90/1	I90	Incandescent, (1) 90W lamp		1	90	90
I90/2	I90	Incandescent, (2) 90W lamp		2	90	180
I90/3	I90	Incandescent, (3) 90W lamp		3	90	270
I93/1	I93	Incandescent, (1) 93W lamp		1	93	93
I95/1	I95	Incandescent, (1) 95W lamp		1	95	95
I95/2	I95	Incandescent, (2) 95W lamp		2	95	190
		Halogen Incandescent Fixtures				
H100/1	H100	Halogen Incandescent, (1) 100W lamp		1	100	100
H1000/1	H1000	Halogen Incandescent, (1) 1000W lamp		1	1000	1000
H1200/1	H1200	Halogen Incandescent, (1) 1200W lamp		1	1200	1200
H150/1	H150	Halogen Incandescent, (1) 150W lamp		1	150	150
H150/2	H150	Halogen Incandescent, (2) 150W lamp		2	150	300

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
H1500/1	H1500	Halogen Incandescent, (1) 1500W lamp		1	1500	1500
H200/1	H200	Halogen Incandescent, (1) 200W lamp		1	200	200
H250/1	H250	Halogen Incandescent, (1) 250W lamp		1	250	250
H300/1	H300	Halogen Incandescent, (1) 300W lamp		1	300	300
H35/1	H35	Halogen Incandescent, (1) 35W lamp		1	35	35
H350/1	H350	Halogen Incandescent, (1) 350W lamp		1	350	350
H40/1	H40	Halogen Incandescent, (1) 40W lamp		1	40	40
H400/1	H400	Halogen Incandescent, (1) 400W lamp		1	400	400
H42/1	H42	Halogen Incandescent, (1) 42W lamp		1	42	42
H425/1	H425	Halogen Incandescent, (1) 425W lamp		1	425	425
H45/1	H45	Halogen Incandescent, (1) 45W lamp		1	45	45
H45/2	H45	Halogen Incandescent, (2) 45W lamp		2	45	90
H50/1	H50	Halogen Incandescent, (1) 50W lamp		1	50	50
H50/2	H50	Halogen Incandescent, (2) 50W lamp		2	50	100
H500/1	H500	Halogen Incandescent, (1) 500W lamp		1	500	500
H52/1	H52	Halogen Incandescent, (1) 52W lamp		1	52	52
H55/1	H55	Halogen Incandescent, (1) 55W lamp		1	55	55
H55/2	H55	Halogen Incandescent, (2) 55W lamp		2	55	110
H60/1	H60	Halogen Incandescent, (1) 60W lamp		1	60	60
H72/1	H72	Halogen Incandescent, (1) 72W lamp		1	72	72
H75/1	H75	Halogen Incandescent, (1) 75W lamp		1	75	75
H75/2	H75	Halogen Incandescent, (2) 75W lamp		2	75	150
H750/1	H750	Halogen Incandescent, (1) 750W lamp		1	750	750
H90/1	H90	Halogen Incandescent, (1) 90W lamp		1	90	90
H90/2	H90	Halogen Incandescent, (2) 90W lamp		2	90	180
H900/1	H900	Halogen Incandescent, (1) 900W lamp		1	900	900
HLV20/1	H20/LV	Halogen Low Voltage Incandescent, (1) 20W lamp		1	20	30
HLV25/1	H25/LV	Halogen Low Voltage Incandescent, (1) 25W lamp		1	25	35
HLV35/1	H35/LV	Halogen Low Voltage Incandescent, (1) 35W lamp		1	35	45
HLV42/1	H42/LV	Halogen Low Voltage Incandescent, (1) 42W lamp		1	42	52
HLV50/1	H50/LV	Halogen Low Voltage Incandescent, (1) 50W lamp		1	50	60
HLV65/1	H65/LV	Halogen Low Voltage Incandescent, (1) 65W lamp		1	65	75
HLV75/1	H75/LV	Halogen Low Voltage Incandescent, (1) 75W lamp		1	75	85
QL Induction Fixtures						
QL55/1	QL55	QL Induction, (1) 55W lamp	Generator	1	55	55
QL85/1	QL85	QL Induction, (1) 85W lamp	Generator	1	85	85

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
QL165/1	QL165	QL Induction, (1) 165W lamp	Generator	1	165	165
		High Pressure Sodium Fixtures				
HPS100/1	HPS100	High Pressure Sodium, (1) 100W lamp	CWA	1	100	138
HPS1000/1	HPS1000	High Pressure Sodium, (1) 1000W lamp	CWA	1	1000	1100
HPS150/1	HPS150	High Pressure Sodium, (1) 150W lamp	CWA	1	150	188
HPS200/1	HPS200	High Pressure Sodium, (1) 200W lamp	CWA	1	200	250
HPS225/1	HPS225	High Pressure Sodium, (1) 225W lamp	CWA	1	225	275
HPS250/1	HPS250	High Pressure Sodium, (1) 250W lamp	CWA	1	250	295
HPS310/1	HPS310	High Pressure Sodium, (1) 310W lamp	CWA	1	310	365
HPS35/1	HPS35	High Pressure Sodium, (1) 35W lamp	CWA	1	35	46
HPS360/1	HPS360	High Pressure Sodium, (1) 360W lamp	CWA	1	360	414
HPS400/1	HPS400	High Pressure Sodium, (1) 400W lamp	CWA	1	400	465
HPS50/1	HPS50	High Pressure Sodium, (1) 50W lamp	CWA	1	50	66
HPS600/1	HPS600	High Pressure Sodium, (1) 600W lamp	CWA	1	600	675
HPS70/1	HPS70	High Pressure Sodium, (1) 70W lamp	CWA	1	70	95
HPS750/1	HPS750	High Pressure Sodium, (1) 750W lamp	CWA	1	750	835
		Metal Halide Fixtures				
MH100/1	MH100	Metal Halide, (1) 100W lamp	CWA	1	100	128
MH1000/1	MH1000	Metal Halide, (1) 1000W lamp	CWA	1	1000	1080
MH150/1	MH150	Metal Halide, (1) 150W lamp	CWA	1	150	190
MH1500/1	MH1500	Metal Halide, (1) 1500W lamp	CWA	1	1500	1610
MH175/1	MH175	Metal Halide, (1) 175W lamp	CWA	1	175	215
MH1800/1	MH1800	Metal Halide, (1) 1800W lamp	CWA	1	1800	1875
MH200/1	MH200	Metal Halide, (1) 200W lamp	CWA	1	200	232
MH250/1	MH250	Metal Halide, (1) 250W lamp	CWA	1	250	295
MH32/1	MH32	Metal Halide, (1) 32W lamp	CWA	1	32	43
MH300/1	MH300	Metal Halide, (1) 300W lamp	CWA	1	300	342
MH320/1	MH320	Metal Halide, (1) 320W lamp	CWA	1	320	365
MH350/1	MH350	Metal Halide, (1) 350W lamp	CWA	1	350	400
MH360/1	MH360	Metal Halide, (1) 360W lamp	CWA	1	360	430
MH400/1	MH400	Metal Halide, (1) 400W lamp	CWA	1	400	458
MH400/2	MH400	Metal Halide, (2) 400W lamp	CWA	2	400	916
MH450/1	MH450	Metal Halide, (1) 450W lamp	CWA	1	450	508
MH35/1	MH35	Metal Halide, (1) 35W lamp	CWA	1	35	44
MH50/1	MH50	Metal Halide, (1) 50W lamp	CWA	1	50	72
MH70/1	MH70	Metal Halide, (1) 70W lamp	CWA	1	70	95

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
MH750/1	MH750	Metal Halide, (1) 750W lamp	CWA	1	750	850
MHPS/LR/100/1	MHPS100	Metal Halide Pulse Start, (1) 100W lamp w/ Linear Reactor Ballast	LR	1	100	118
MHPS/LR/150/1	MHPS150	Metal Halide Pulse Start, (1) 150W lamp w/ Linear Reactor Ballast	LR	1	150	170
MHPS/LR/175/1	MHPS175	Metal Halide Pulse Start, (1) 175W lamp w/ Linear Reactor Ballast	LR	1	175	194
MHPS/LR/200/1	MHPS200	Metal Halide Pulse Start, (1) 200W lamp w/ Linear Reactor Ballast	LR	1	200	219
MHPS/LR/250/1	MHPS250	Metal Halide Pulse Start, (1) 250W lamp w/ Linear Reactor Ballast	LR	1	250	275
MHPS/LR/300/1	MHPS300	Metal Halide Pulse Start, (1) 300W lamp w/ Linear Reactor Ballast	LR	1	300	324
MHPS/LR/320/1	MHPS320	Metal Halide Pulse Start, (1) 320W lamp w/ Linear Reactor Ballast	LR	1	320	349
MHPS/LR/350/1	MHPS350	Metal Halide Pulse Start, (1) 350W lamp w/ Linear Reactor Ballast	LR	1	350	380
MHPS/LR/400/1	MHPS400	Metal Halide Pulse Start, (1) 400W lamp w/ Linear Reactor Ballast	LR	1	400	435
MHPS/LR/450/1	MHPS450	Metal Halide Pulse Start, (1) 450W lamp w/ Linear Reactor Ballast	LR	1	450	485
MHPS/LR/750/1	MHPS750	Metal Halide Pulse Start, (1) 750W lamp w/ Linear Reactor Ballast	LR	1	750	805
MHPS/SCWA/100/1	MHPS100	Metal Halide Pulse Start, (1) 100W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	100	128
MHPS/SCWA/1000/1	MHPS1000	Metal Halide Pulse Start, (1) 1000W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	1000	1080
MHPS/SCWA/150/1	MHPS150	Metal Halide Pulse Start, (1) 150W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	150	190
MHPS/SCWA/175/1	MHPS175	Metal Halide Pulse Start, (1) 175W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	175	208
MHPS/SCWA/200/1	MHPS200	Metal Halide Pulse Start, (1) 200W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	200	232
MHPS/SCWA/250/1	MHPS250	Metal Halide Pulse Start, (1) 250W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	250	288
MHPS/SCWA/300/1	MHPS300	Metal Halide Pulse Start, (1) 300W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	300	342
MHPS/SCWA/320/1	MHPS320	Metal Halide Pulse Start, (1) 320W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	320	368
MHPS/SCWA/350/1	MHPS350	Metal Halide Pulse Start, (1) 350W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	350	400
MHPS/SCWA/400/1	MHPS400	Metal Halide Pulse Start, (1) 400W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	400	450
MHPS/SCWA/450/1	MHPS450	Metal Halide Pulse Start, (1) 450W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	450	506
MHPS/SCWA/750/1	MHPS750	Metal Halide Pulse Start, (1) 750W lamp w/ Super Constant Wattage Autotransformer Ballast	SCWA	1	750	815

Appendix C of the PA TRM						
FIXTURE CODE	LAMP CODE	DESCRIPTION	BALLAST	LAMP/ FIXT	WATT/ LAMP	WATT/ FIXT
		<i>Mercury Vapor Fixtures</i>				
MV100/1	MV100	Mercury Vapor, (1) 100W lamp	CWA	1	100	125
MV1000/1	MV1000	Mercury Vapor, (1) 1000W lamp	CWA	1	1000	1075
MV175/1	MV175	Mercury Vapor, (1) 175W lamp	CWA	1	175	205
MV250/1	MV250	Mercury Vapor, (1) 250W lamp	CWA	1	250	290
MV40/1	MV40	Mercury Vapor, (1) 40W lamp	CWA	1	40	50
MV400/1	MV400	Mercury Vapor, (1) 400W lamp	CWA	1	400	455
MV400/2	MV400	Mercury Vapor, (2) 400W lamp	CWA	2	400	910
MV50/1	MV50	Mercury Vapor, (1) 50W lamp	CWA	1	50	74
MV700/1	MV700	Mercury Vapor, (1) 700W lamp	CWA	1	700	780
MV75/1	MV75	Mercury Vapor, (1) 75W lamp	CWA	1	75	93

Lighting Form

Lighting Inventory Form

Applicant Name: _____
Facility Name: _____
Date: _____
Lighting Zone: _____

Instructions: Please use one line for each fixture type in a room or area.
For existing or proposed controls, choose ODC for Occupancy Sensor, DAY for photocell, H/L for hi/low sensors or NONE for none. Controls in spaces where existing controls exist do not qualify.
The total of Column 5, the quantities of CFLs and exit signs in Column M, and the quantities of sensors in Column R, will be used to calculate your inventory on the Nonstandard Lighting form.

Line Item	Room Construction or Renovation	Building Address	Floor	Area Description	Space Description	PROJECT BASIS INFORMATION		Interior Lighting Description (Exterior Lighting Only)	Area Coding	PRE-INSTALLATION INFORMATION			Proposed Control	Existing Sensor/Control	BASELINE NEW CONSTRUCTIONS										Proposed Control	Proposed Sensor/Control	Change in Connected Load (W)	Applicant Conformance Factor (ECF) Estimate	Conformance Factor	Inconformity Factor	Savings Factor	Pre Controls	Post Controls	Savings (W)	Applicant Payback Period (Months)	Prescribed Payback Period (Months)	Annual kWh Saved																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
						Interior or Exterior Feature	Photometric Space Type			Pre Fixture Qty	Pre Fixture Code	Pre Fixture Watts			Control Type	Control Code	Area	Square Feet (SF)	Lighting Fixture Quantity (Watts)	Baseline 1a (W)	Baseline 1b (W)	Post Fixture Code	Post Fixture Qty	Post Fixture Watts														Control Type	Control Code																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																														
1	Renov	400 North Street	2	Office	Other	Interior	Office - Small	Recessed Troffer 1200 x 600	Unrated space	1	PS001	100	100	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None	None

Lighting Form

[illegible]

Project Estimated Annual Savings Summary

Lighting

Estimated Annual kWh Savings	286,349
Total Change in Connected Load	31.42

Annual Estimated Cost Savings	\$28,634.90
Annual Operating Hours	8,760

Interior Lighting Incentive @ \$0.05/kWh (excluding retrofit CFLs, sensors, or LED exit signs)	\$1,139.25
Exterior Lighting Incentive @ \$0.05/kWh (excluding retrofit CFLs, sensors, or LED exit signs)	\$12,623.15
Total retrofit CFL Incentive @ \$1/screw-in CFL lamp; \$15/hard-wired CFL lamp (includes all retrofit CFLs, both interior and exterior)	\$0.00
Total retrofit LED Exit Incentive @ \$10/exit sign	\$0.00
Total Lighting Controls Incentive @ \$25/occupancy sensor and \$25/daylight sensor (includes all Lighting Controls, both interior and exterior)	\$0.00

Total Calculated Incentive	\$13,762.40
----------------------------	-------------

Total Fixture Quantity excluding retrofit CFLs and LED Exit Signs	39
Total Lamp Quantity for retrofit Screw-In CFLs	0
Total Lamp Quantity for retrofit Hard-Wired CFLs	0
Total Fixture Quantity for retrofit LED Exit Signs	0
Total Quantity for Occupancy Sensors	0
Total Quantity for Daylight Sensors	0

Please briefly describe how you estimated your coincidence factor (CF) and applicant equivalent full-load hours (EFLH) for facility type "Other" indicated on the Lighting Form tab

Demand Savings (For Internal Use Only)	27.54
--	-------

Mercantile Customer Project Commitment Agreement
Cash Rebate Option

THIS MERCANTILE CUSTOMER PROJECT COMMITMENT AGREEMENT ("Agreement") is made and entered into by and between The Toledo Edison Company, its successors and assigns (hereinafter called the "Company") and Air Liquide Industrial US LP, Taxpayer ID No. 75-3174747 its permitted successors and assigns (hereinafter called the "Customer") (collectively the "Parties" or individually the "Party") and is effective on the date last executed by the Parties as indicated below.

WITNESSETH

WHEREAS, the Company is an electric distribution utility and electric light company, as both of these terms are defined in R.C. § 4928.01(A); and

WHEREAS, Customer is a mercantile customer, as that term is defined in R.C. § 4928.01(A)(19), doing business within the Company's certified service territory; and

WHEREAS, R.C. § 4928.66 (the "Statute") requires the Company to meet certain energy efficiency and peak demand reduction ("EE&PDR") benchmarks; and

WHEREAS, when complying with certain EE&PDR benchmarks the Company may include the effects of mercantile customer-sited EE&PDR projects; and

WHEREAS, Customer has certain customer-sited demand reduction, demand response, or energy efficiency project(s) as set forth in attached Exhibit 1 (the "Customer Energy Project(s)") that it desires to commit to the Company for integration into the Company's Energy Efficiency & Peak Demand Reduction Program Portfolio Plan ("Company Plan") that the Company will implement in order to comply with the Statute; and

WHEREAS, the Customer, pursuant to the Public Utilities Commission of Ohio's ("Commission") September 15, 2010 Order in Case No. 10-834-EL-BBC, desires to pursue a cash rebate of some of the costs pertaining to its Customer Energy Project(s) ("Cash Rebate") and is committing the Customer Energy Project(s) as a result of such incentive.

WHEREAS, Customer's decision to commit its Customer Energy Project(s) to the Company for inclusion in the Company Plan has been reasonably encouraged by the possibility of a Cash Rebate.

WHEREAS, in consideration of, and upon receipt of, said cash rebate, Customer will commit the Customer Energy Project(s) to the Company and will comply with all other terms and conditions set forth herein.

NOW THEREFORE, in consideration of the mutual promises set forth herein, and for other good and valuable consideration, the receipt and sufficiency of which is hereby acknowledged, the parties, intending to be legally bound, do hereby agree as follows:

1. **Customer Energy Projects.** Customer hereby commits to the Company and Company accepts for integration into the Company Plan the Customer Energy Project(s) set forth on attached Exhibit 1. Said commitment shall be for the life of the Customer Energy Project(s). Company will incorporate said project(s) into the Company Plan to the extent that such projects qualify. In so committing, and as evidenced by the affidavit attached hereto as Exhibit A, Customer acknowledges that the information provided to the Company about the Customer Energy Project(s) is true and accurate to the best of its knowledge.

- a. By committing the Customer Energy Project(s) to the Company, Customer acknowledges and agrees that the Company shall control the use of the kWh and/or kW reductions resulting from said projects for purposes of complying with the Statute. By committing the Customer Energy Project(s), Customer further acknowledges and agrees that the Company shall take ownership of the energy efficiency capacity rights associated with said Project(s) and shall, at its sole discretion, aggregate said capacity into the PJM market through an auction. Any proceeds from any such bids accepted by PJM will be used to offset the costs charged to the Customer and other of the Company's customers for compliance with state mandated energy efficiency and/or peak demand requirements
 - b. The Company acknowledges that some of Customer's Energy Projects contemplated in this paragraph may have been performed under certain other federal and/or state programs in which certain parameters are required to be maintained in order to retain preferential financing or other government benefits (individually and collectively, as appropriate, "Benefits"). In the event that the use of any such project by the Company in any way affects such Benefits, and upon written request from the Customer, Company will release said Customer's Energy Project(s) to the extent necessary for Customer to meet the prerequisites for such Benefits. Customer acknowledges that such release (i) may affect Customer's cash rebate discussed in Article 3 below; and (ii) will not affect any of Customer's other requirements or obligations.
 - c. Any future Customer Energy Project(s) committed by Customer shall be subject to a separate application and, upon approval by the Commission, said projects shall become part of this Agreement.
 - d. Customer will provide Company or Company's agent(s) with reasonable assistance in the preparation of the Commission's standard joint application for approval of this Agreement ("Joint Application") that will be filed with the Commission, with such Joint Application being consistent with then current Commission requirements.
 - e. Upon written request and reasonable advance notice, Customer will grant employees or authorized agents of either the Company or the Commission reasonable, pre-arranged access to the Customer Energy Project(s) for purposes of measuring and verifying energy savings and/or peak demand reductions resulting from the Customer Energy Project(s). It is expressly agreed that consultants of either the Company or the Commission are their respective authorized agents.
2. **Joint Application to the Commission.** The Parties will submit the Joint Application using the Commission's standard "Application to Commit Energy Efficiency/Peak Demand Reduction Programs" ("Joint Application") in which they will seek the Commission's approval of (i) this Agreement; (ii) the commitment of the Customer Energy Project(s) for inclusion in the Company Plan; and (iii) the Customer's Cash Rebate.

The Joint Application shall include all information as set forth in the Commission's standard form which, includes without limitation:

- i. A narrative description of the Customer Energy Project(s), including but not limited to, make, model and year of any installed and/or replaced equipment;
- ii. A copy of this Agreement; and
- iii. A description of all methodologies, protocols, and practices used or proposed to be used in measuring and verifying program results.

3. **Customer Cash Rebate.** Upon Commission approval of the Joint Application, Customer shall provide Company with a W-9 tax form, which shall at a minimum include Customer's tax identification number. Within the greater of 90 days of the Commission's approval of the Joint Application or the completion of the Customer Energy Project, the Company will issue to the Customer the Cash Rebate in the amount set forth in the Commission's Finding and Order approving the Joint Application.
 - a. Customer acknowledges: i) that the Company will cap the Cash Rebate at the lesser of 50% of Customer Energy Project(s) costs or \$250,000; ii) the maximum rebate that the Customer may receive per year is \$500,000 per Taxpayer Identification Number per utility service territory; and iii) if the Customer Energy Project qualifies for a rebate program approved by the Commission and offered by the Company, Customer may still elect to file such project under the Company's mercantile customer self direct program, however the Cash Rebate that will be paid shall be discounted by 25%; and
 - b. Customer acknowledges that breaches of this Agreement, include, but are not limited to:
 - i. Customer's failure to comply with the terms and conditions set forth in the Agreement, or its equivalent, within a reasonable period of time after receipt of written notice of such non-compliance;
 - ii. Customer knowingly falsifying any documents provided to the Company or the Commission in connection with this Agreement or the Joint Application.
 - c. In the event of a breach of this Agreement by the Customer, Customer agrees and acknowledges that it will repay to the Company, within 90 days of receipt of written notice of said breach, the full amount of the Cash Rebate paid under this Agreement. This remedy is in addition to any and all other remedies available to the Company by law or equity.

4. **Termination of Agreement.** This Agreement shall automatically terminate:

- a. If the Commission fails to approve the Joint Agreement;
- b. Upon order of the Commission; or
- c. At the end of the life of the last Customer Energy Project subject to this Agreement.

Customer shall also have an option to terminate this Agreement should the Commission not approve the Customer's Cash Rebate, provided that Customer provides the Company with written notice of such termination within ten days of either the Commission issuing a final appealable order or the Ohio Supreme Court issuing its opinion should the matter be appealed.

5. **Confidentiality.** Each Party shall hold in confidence and not release or disclose to any person any document or information furnished by the other Party in connection with this Agreement that is designated as confidential and proprietary ("Confidential Information"), unless: (i) compelled to disclose such document or information by judicial, regulatory or administrative process or other provisions of law; (ii) such document or information is generally available to the public; or (iii) such document or information was available to the receiving Party on a non-confidential basis at the time of disclosure.
 - a. Notwithstanding the above, a Party may disclose to its employees, directors, attorneys, consultants and agents all documents and information furnished by the other Party in connection with this Agreement, provided that such employees, directors, attorneys,

consultants and agents have been advised of the confidential nature of this information and through such disclosure are deemed to be bound by the terms set forth herein.

- b. A Party receiving such Confidential Information shall protect it with the same standard of care as its own confidential or proprietary information.
 - c. A Party receiving notice or otherwise concluding that Confidential Information furnished by the other Party in connection with this Agreement is being sought under any provision of law, to the extent it is permitted to do so under any applicable law, shall endeavor to: (i) promptly notify the other Party; and (ii) use reasonable efforts in cooperation with the other Party to seek confidential treatment of such Confidential Information, including without limitation, the filing of such information under a valid protective order.
 - d. By executing this Agreement, Customer hereby acknowledges and agrees that Company may disclose to the Commission or its Staff any and all Customer information, including Confidential Information, related to a Customer Energy Project, provided that Company uses reasonable efforts to seek confidential treatment of the same.
6. **Taxes.** Customer shall be responsible for all tax consequences (if any) arising from the payment of the Cash Rebate.
7. **Notices.** Unless otherwise stated herein, all notices, demands or requests required or permitted under this Agreement must be in writing and must be delivered or sent by overnight express mail, courier service, electronic mail or facsimile transmission addressed as follows:

If to the Company:

FirstEnergy Service Company
76 South Main Street
Akron, OH 44308
Attn: Victoria Nofziger
Telephone: 330-384-4684
Fax: 330-761-4281
Email: vmnofziger@firstenergycorp.com

If to the Customer:

Air Liquide Industrial US LP
3535 W. 12th Street,
Houston, TX 77008
Attn: Brad Engel
Telephone: 713-438-6358
Fax:
Email: brad.engel@airliquide.com

or to such other person at such other address as a Party may designate by like notice to the other Party. Notice received after the close of the business day will be deemed received on the next business day; provided that notice by facsimile transmission will be deemed to have been received by the recipient if the recipient confirms receipt telephonically or in writing.

8. **Authority to Act.** The Parties represent and warrant that they are represented by counsel in connection with this Agreement, have been fully advised in connection with the execution thereof, have taken all legal and corporate steps necessary to enter into this Agreement, and that the undersigned has the authority to enter into this Agreement, to bind the Parties to all provisions herein and to take the actions required to be performed in fulfillment of the undertakings contained herein.
9. **Non-Waiver.** The delay or failure of either party to assert or enforce in any instance strict performance of any of the terms of this Agreement or to exercise any rights hereunder conferred, shall not be construed as a waiver or relinquishment to any extent of its rights to assert or rely upon such terms or rights at any later time or on any future occasion.
10. **Entire Agreement.** This Agreement, along with related exhibits, and the Company's Rider DSB, or its equivalent, as amended from time to time by the Commission, contains the Parties' entire understanding with respect to the matters addressed herein and there are no verbal or collateral representations, undertakings, or agreements not expressly set forth herein. No change in, addition to, or waiver of the terms of this Agreement shall be binding upon any of the Parties unless the same is set forth in writing and signed by an authorized representative of each of the Parties. In the event of any conflict between Rider DSB or its equivalent and this document, the latter shall prevail.
11. **Assignment.** Customer may not assign any of its rights or obligations under this Agreement without obtaining the prior written consent of the Company, which consent will not be unreasonably withheld. No assignment of this Agreement will relieve the assigning Party of any of its obligations under this Agreement until such obligations have been assumed by the assignee and all necessary consents have been obtained.
12. **Severability.** If any portion of this Agreement is held invalid, the Parties agree that such invalidity shall not affect the validity of the remaining portions of this Agreement, and the Parties further agree to substitute for the invalid portion a valid provision that most closely approximates the economic effect and intent of the invalid provision.
13. **Governing Law.** This Agreement shall be governed by the laws and regulations of the State of Ohio, without regard to its conflict of law provisions.
14. **Execution and Counterparts.** This Agreement may be executed in multiple counterparts, which taken together shall constitute an original without the necessity of all parties signing the same page or the same documents, and may be executed by signatures to electronically or telephonically transmitted counterparts in lieu of original printed or photocopied documents. Signatures transmitted by facsimile shall be considered original signatures.

IN WITNESS WHEREOF, the Parties hereto have caused this Agreement to be executed by their duly authorized officers or representatives as of the day and year set forth below.

The Toledo Edison Company_
(Company)

By: John C. Lugin

Title: V.P. Of Energy Efficiency

Date: 12-3-12

Air Liquide Industrial US LP_
(Customer)

By: Jeremy A. Benner

Title: VP, PRIMARY PRODUCTION

Date: 11/15/2012

Affidavit of Air Liquide Industrial US LP -- Exhibit _A_

STATE OF OHIO)
) SS:
COUNTY OF Lucas)

I, Enter Name ,being first duly sworn in accordance with law, deposes and states as follows:


1. I am the Title of Customer Name ("Customer") As part of my duties, I oversee energy related matters for the Customer.
2. The Customer has agreed to commit certain energy efficiency projects to The Toledo Edison Company ("Company"), which are the subject of the agreement to which this affidavit is attached ("Project(s)").
3. In exchange for making such a commitment, the Company has agreed to provide Customer with Cash ("Incentive"). This Incentive was a critical factor in the Customer's decision to go forward with the Project(s) and to commit the Project(s) to the Company.
4. All information related to said Project(s) that has been submitted to the Company is true and accurate to the best of my knowledge.

FURTHER AFFIANT SAYETH NAUGHT.

Jeremy A. Ben

Sworn to before me and subscribed in my presence this 15 day of 11, 2012

Car
Notary



This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

12/5/2012 4:35:45 PM

in

Case No(s). 12-2927-EL-EEC

Summary: Application to Commit Energy Efficiency/Peak Demand Reduction Programs of The Toledo Edison Company and Air Liquide Industrial US LP electronically filed by Ms. Jennifer M. Sybyl on behalf of The Toledo Edison Company and Air Liquide Industrial US LP