



February 4, 2013

**Case No. 13-0181-EL-REN  
Horn-Lyle-PA-PV-19.68kW Residence  
Staff Interrogatories – Initial Set**

**Question 1:** In Section G.4b of the application, you stated the following:

Total number of PV modules: **43**

**However**

- In Section G of the application, the photograph you have submitted of the generating facility shows more than 43 modules.
- In Section I of the application, the nameplate capacity of the entire facility in kW indicates 82 PV modules each with a rating of 240W.

**Please submit a clear photograph showing all the modules and clarify the total number of PV modules.**

**Answer 1:** There are 82 total modules all with an azimuth of 170 degrees; however, the tilt does differ. For 43 of the modules have a tilt of 20 degrees, and for 39 modules have a tilt of 15 degrees. Please see photo provided below for a clearer understanding of the setup of the modules.



Please let me know if you have any further questions and thank you for your cooperation.

Best,

Anna Nocas  
Associate  
Sol Systems, LLC

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**2/4/2013 6:16:46 PM**

**in**

**Case No(s). 13-0181-EL-REN**

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Horn, Lyle