

Case No. 13-0286-EL-REN
Smale Riverfront Park
Staff Interrogatories – Initial Set

Question 1: In section I.1 the nameplate capacity is listed as 0.025 MW. But in section G.1 you state the facility has twenty eight 195W panels and seventy two 225W panels. Since $(28 \times 195W) + (72 \times 225W) = 21,660 \text{ W}$ or 0.02166 MW. Is the nameplate capacity 0.02166 MW?

Answer 1: The nameplate capacity is 0.02166 MW

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/1/2013 10:54:28 AM

in

Case No(s). 13-0286-EL-REN

Summary: Reply 13-0286-EL-REN Smale Riverfront Park electronically filed by Mr. Gerald R
Checco on behalf of CINCINNATI PARK BOARD SUPERINTENDENT