



Regulatory Operations

March 25, 2013

Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street, 11th Floor
Columbus, Ohio 43215

Re: Case No. 13-402-EL-ESS

Docketing Division:

Pursuant to Rule 10 of the Electric Service and Safety Standards, Ohio Administrative Code 4901:1-10-10(C), The Dayton Power and Light Company herewith electronically submits its Annual Report.

Thank you for your assistance and your attention to this matter. If you have any questions please feel free to call me at (937) 259-7906.

Sincerely,

A handwritten signature in black ink, appearing to read "Robert Adams", written over a horizontal line.

Robert Adams
Regulatory Operations

BEFORE
THE PUBLIC UTILITIES COMMISSION OF OHIO

In the Matter of the Annual Report of

Pursuant to Rule 10 of the Electric
Service and Safety Standards, Ohio
Administrative Code 4901:1-10-10

Case No. 13-0402-EL-ESS

ANNUAL REPORT
OF THE DAYTON POWER AND LIGHT CO. COMPANY

Pursuant to Rule 10 of the Electric Service and Safety Standards, Ohio, Administrative Code
4901:1-10-10, ("DPL") submits the following Annual Report. The Report is attached.

Report Date & Time: March 04, 2013 5:01 pm

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

Jennifer E. Dykes 3/4/13
W. L. Webb 3/5/13
[Signature] 3/18/13

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

1. 4901:1-10-(C)(1)

CAIDI - Customer Average Interruption Duration
Index (In Minutes)

a.	b.	c.
CAIDI Performance Standard	CAIDI After Exclusions	CAIDI Before Exclusions
125.51	120.15	538.23

2. 4901:1-10-(C)(1)

SAIFI - System Average Interruption Frequency Index

a.	b.	c.
SAIFI Performance Standard	SAIFI After Exclusions	SAIFI Before Exclusions
1.07	0.80	1.40

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

3. 4901:1-10-(C)(1) Supporting Data Report

a.	b.	c.	d.	e.
Number Of Customers Served	Number Of Customer Interruptions After Exclusions	Number Of Customer Interruptions Before Exclusions	Number Of Customer Minutes Interrupted After Exclusions	Number Of Customer Minutes Interrupted Before Exclusions
570,714	454,208	796,848	54,574,859	428,885,044

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

4. 4901:1-10-10(C)(2) Major Event Outage (MEO)

a.	b.	c.	d.	e.	f.
Major Event Date	Major Event Description	Customers Interrupted During MEO	Customer Minutes Interrupted During MEO	CAIDI During MEO (in minutes)	SAIFI During MEO
06/29/2012	Two waves of severe thunderstorm with high winds	250,856	318,259,250	1,268.69	1.00

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
01/21/2012	Washington C.H. {T} - Washington C.H. - Wilmington [6637]	12:00 am	69	Ice/Sleet/Snow	113,695
04/16/2012	Logan {T} - Logan - Shelby [13830]	12:00 am	138	High Winds	88,755
05/01/2012	Monument {T} - Monument - Overlook - Greene [13815]	12:00 am	138	Lightning	165,056
05/03/2012	Hutchings - Hutchings - Crystal [6602]	12:00 am	69	Equipment/Hardware Failure	7,653
05/03/2012	Hutchings - Hutchings - Crystal [6602]	12:00 am	69	Equipment/Hardware Failure	142,671

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data ... Continued ...

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
06/29/2012	Amsterdam {T} - Amsterdam - Coldwater [6629]	12:00 am	69	Equipment/Hardware Failure	199,164
06/29/2012	Amsterdam {T} - Amsterdam - Shelby [13827]	12:00 am	138	High Winds	196,795
06/29/2012	Greenville {T} - Greenville - Treaty - Rossburg [6661]	12:00 am	69	High Winds	237,839
06/29/2012	Sidney {T} - Sidney - Amsterdam [6628]	12:00 am	69	Equipment/Hardware Failure	5,368,557
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	202,758

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data ... Continued ...

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	185,639
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	3,512,692
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	4,596,976
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	131,322
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	248,368

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data ... Continued ...

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	999,653
06/29/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	154,308
06/29/2012	Washington C.H. {T} - Washington C.H. - Wilmington [6637]	12:00 am	69	Equipment/Hardware Failure	32,762,175
06/29/2012	Wilmington {T} - Wilmington - Highland (AEP) [6658]	12:00 am	69	Other	4,317,774

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data ... Continued ...

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
06/30/2012	Darby {T} - Darby - Urbana [13811]	12:00 am	138	High Winds	347,579
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	226,488
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	21,092
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	57,615
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	5,366

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data ... Continued ...

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	27,328
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	293,452
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	168,570
06/30/2012	Transmission Bus - Transmission Bus	12:00 am	12	Transmission Trouble	15,585
07/13/2012	Coldwater {T} - Coldwater - Rossburg [6684]	12:00 am	69	Equipment/Hardware Failure	70,536

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data ... Continued ...

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
07/24/2012	Garage Road {T} - Garage Road - New Westville [3302]	12:00 am	33	Forced Outage	11,448
08/04/2012	Bellefontaine {T} - Bellefontaine - Blue Jacket - Indian Lake [6648]	12:00 am	69	Equipment/Hardware Failure	396,083
08/15/2012	Bellefontaine {T} - Bellefontaine - Blue Jacket - Indian Lake [6648]	12:00 am	69	Equipment/Hardware Failure	382,126
10/14/2012	Jamestown {T} - Jamestown - Washington C.H. [6902]	12:00 am	69	High Winds	40,532

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.a. 4901:1-10-10(C)(2) Transmission Circuit Interruption Supporting Data ... Continued ...

1. Date Transmission Outage Began	2. Reference ID Of Transmission Circuit Impacted	3. Time Outage Occurred	4. Size (in kilovolts) Of Transmission Circuit Or Equipment Involved	5. Cause Of Outage Including Specific Type Of Equipment And/Or Facility Causing Interruption	6. Total Length Of Interruption (in minutes)
12/21/2012	Celina - Celina - Coldwater [6688]	12:00 am	69	Galloping Conductors	339,086
12/26/2012	Washington C.H. {T} - Washington C.H. - Wilmington [6637]	12:00 am	69	Equipment/Hardware Failure	86,733

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
01/21/2012	4,001	113,696	6	Air Park - HP1201	333	9,463
				Air Park - HP1203	242	6,877
				Air Park - HP1205	37	1,051
				Air Park - HP1209	525	14,919
				Sabina - HC1202	1,259	35,777
				Sabina - HC1204	1,605	45,609
04/16/2012	1,455	88,755	2	Quincy - EF1202 Quincy - EF1206	875 580	53,375 35,380
05/01/2012	10,316	165,056	4	Overlook {D} - AK1211	2,279	36,464
				Overlook {D} - AK1213	3,661	58,576
				Overlook {D} - AK1215	2,376	38,016
				Overlook {D} - AK1219	2,000	32,000

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data ... Continued ...

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
05/03/2012	8,319	142,671	7	Camden - MK1202 Camden - MK1204 Camden - MK1206 Germantown - QF1202 Germantown - QF1205 Gratis - MG1203 Gratis - MG1205	1,194 1,734 30 1,451 1,544 858 1,508	20,477 29,738 514 24,885 26,480 14,715 25,862
05/03/2012	1,272	7,653	1	Germantown - QF1201	1,272	7,653
06/29/2012	3,761	32,762,175	6	Air Park - HP1201 Air Park - HP1203 Air Park - HP1205 Air Park - HP1209	336 244 36 517	2,915,808 2,117,432 312,408 4,486,526

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data ... Continued ...

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
				Sabina - HC1202	1,259	10,985,111
				Sabina - HC1204	1,369	11,944,890
06/29/2012	493	199,164	1	Chickasaw - KH1202	493	199,164
06/29/2012	4,399	237,839	3	Treaty - LN1215	439	23,735
				Treaty - LN1217	2,039	110,242
				Treaty - LN1219	1,921	103,862
06/29/2012	778	196,795	3	Amsterdam {D} - BB1201	83	20,995
				Amsterdam {D} - BB1205	271	68,549
				Amsterdam {D} - BB1207	424	107,251
06/29/2012	5,083	3,512,692	2	Fairborn {D} - GD1206	1,872	1,293,677
				Fairborn {D} - GD1210	3,211	2,219,015
06/29/2012	6,652	4,596,975	2	Fairborn {D} - GD1201	1,471	1,016,559

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data ... Continued ...

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
				Fairborn {D} - GD1205	5,181	3,580,416
06/29/2012	214	154,308	1	Southwestern {D} - PB1203	214	154,308
06/29/2012	580	185,639	1	Yellow Springs {D} - GC1201	580	185,639
06/29/2012	2,608	4,317,774	4	Martinsville - HD1204	653	1,114,225
				Martinsville - HD1206	632	1,078,392
				New Vienna - JV1202	233	374,272
				New Vienna - JV1204	1,090	1,750,885
06/29/2012	3,613	5,368,557	5	Kuther Road {D} - BR1201	300	445,770
				Kuther Road {D} - BR1203	1,530	2,273,427
				Kuther Road {D} - BR1205	1,140	1,693,926
				McCartysville - BG1201	70	104,013
				McCartysville - BG1202	573	851,421

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data ... Continued ...

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
06/29/2012	325	131,322	1	Coldwater {D} - KA1203	325	131,322
06/29/2012	2,955	248,368	2	Coldwater {D} - KA1202 Coldwater {D} - KA1204	1,432 1,523	120,360 128,008
06/29/2012	1,938	999,653	3	Rockford - KE1201 Rockford - KE1202 Rockford - KE1203	492 1,042 404	253,782 537,481 208,390
06/29/2012	777	202,758	3	Amsterdam {D} - BB1201 Amsterdam {D} - BB1205 Amsterdam {D} - BB1207	83 271 423	21,659 70,717 110,382
06/30/2012	1,308	347,580	2	Mechanicsburg - DE1201 Mechanicsburg - DE1203	9 1,299	2,392 345,188
06/30/2012	1,938	21,092	3	Rockford - KE1201	492	5,355

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data ... Continued ...

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
				Rockford - KE1202	1,042	11,340
				Rockford - KE1203	404	4,397
06/30/2012	2,511	27,328	2	Coldwater {D} - KA1201	2,186	23,791
				Coldwater {D} - KA1203	325	3,537
06/30/2012	1,432	15,585	1	Coldwater {D} - KA1202	1,432	15,585
06/30/2012	493	5,365	1	Chickasaw - KH1202	493	5,365
		57,615	1	Chickasaw - KH1202	493	57,615
06/30/2012	2,511	293,453	2	Coldwater {D} - KA1201	2,186	255,471
				Coldwater {D} - KA1203	325	37,982
06/30/2012	1,432	168,570	1	Coldwater {D} - KA1202	1,432	168,570
06/30/2012	1,938	226,487	3	Rockford - KE1201	492	57,498
				Rockford - KE1202	1,042	121,775

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data ... Continued ...

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
				Rockford - KE1203	404	47,214
07/13/2012	2,079	70,537	3	Ft. Recovery - KG1201 Ft. Recovery - KG1203 Rossburg {D} - LC1201	437 696 946	17,014 27,098 26,425
07/24/2012	1,428	11,448	1	New Westville {D} - MB1201	1,428	11,448
08/04/2012	4,978	396,083	3	Huntsville - EC1201 Huntsville - EC1202 Indian Lake {D} - EG1205	616 165 4,197	49,013 13,129 333,941
08/15/2012	4,970	382,127	3	Huntsville - EC1201 Huntsville - EC1202 Indian Lake {D} - EG1205	616 165 4,189	47,186 12,667 322,274
10/14/2012	1,113	40,532	1	Jamestown {D} - GH1204	1,113	40,532

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.b. 4901:1-10-10(C)(2) Distribution Circuits Impacted By Transmission Outage(s) Supporting Data ... Continued ...

1. Date The Transmission Outage Began	2. Customers Interrupted Per Transmission Outage	3. Customer Minutes Interrupted Per Transmission Outage	4. The Number Of Distribution Circuits Impacted	5. Circuit Reference ID For Each Of The Distribution Circuits Impacted By The Interruption	6. Customers Interrupted By Distribution Circuit Reference ID	7. Customer Minutes Interrupted By Distribution Circuit Reference ID
12/21/2012	1,929	339,087	3	Rockford - KE1201 Rockford - KE1202 Rockford - KE1203	485 1,045 399	85,255 183,694 70,138
12/26/2012	3,771	86,733	6	Air Park - HP1201 Air Park - HP1203 Air Park - HP1205 Air Park - HP1209 Sabina - HC1202 Sabina - HC1204	337 243 36 516 1,267 1,372	7,751 5,589 828 11,868 29,141 31,556

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.c. 4901:1-10-10(C)(2) Index Values During Transmission Outage(s) Supporting Data

1.	2.	3.
Date Transmission Outage Began	CAIDI For Period Of Outage (minutes)	SAIFI For Period Of Outage
01/21/2012	28	0.01
04/16/2012	61	0.00
05/01/2012	16	0.02
05/03/2012	6	0.00
05/03/2012	17	0.01
06/29/2012	253	0.00
06/29/2012	1,486	0.01
06/29/2012	404	0.00
06/29/2012	8,711	0.01

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.c. 4901:1-10-10(C)(2) Index Values During Transmission Outage(s) Supporting Data

1.	2.	3.
Date Transmission Outage Began	CAIDI For Period Of Outage (minutes)	SAIFI For Period Of Outage
06/29/2012	1,656	0.00
06/29/2012	54	0.01
06/29/2012	261	0.00
06/29/2012	320	0.00
06/29/2012	691	0.01
06/29/2012	691	0.01
06/29/2012	404	0.00
06/29/2012	84	0.01
06/29/2012	516	0.00

... Continued ...

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.c. 4901:1-10-10(C)(2) Index Values During Transmission Outage(s) Supporting Data

1.	2.	3.
Date Transmission Outage Began	CAIDI For Period Of Outage (minutes)	SAIFI For Period Of Outage
06/29/2012	721	0.00
06/30/2012	266	0.00
06/30/2012	11	0.00
06/30/2012	117	0.00
06/30/2012	118	0.00
06/30/2012	11	0.00
06/30/2012	117	0.00
06/30/2012	11	0.00
06/30/2012	117	0.00

... Continued ...

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

5.c. 4901:1-10-10(C)(2) Index Values During Transmission Outage(s) Supporting Data

... Continued ...

1.	2.	3.
Date Transmission Outage Began	CAIDI For Period Of Outage (minutes)	SAIFI For Period Of Outage
06/30/2012	11	0.00
07/13/2012	34	0.00
07/24/2012	8	0.00
08/04/2012	80	0.01
08/15/2012	77	0.01
10/14/2012	36	0.00
12/21/2012	176	0.00
12/26/2012	23	0.01

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

6.a. 4901:1-10-10(C)(3)(a) Data Excluding Major Events And Transmission Outages

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
Animal/Bird	2,373	24,030	2,242,706
Blast/Explosion/Fire	7	2,331	248,051
Cold Load Pickup	1	1,709	13,615
Equipment/Hardware Failure	2,235	119,081	54,781,658
Forced Outage	264	43,667	2,578,157
Galloping Conductors	1	1	339,835
High Winds	921	35,062	8,525,922
Ice/Sleet/Snow	0	0	0
Lightning	1,935	59,871	8,324,411
Other	30	3,768	231,653
Other Electric Utility	1	20	2,859
Overload	64	5,297	668,022
Personnel Error	51	4,179	502,020
Scheduled/Planned Outage	373	15,434	867,160
Transmission Trouble	0	0	0
Tree Trimmers, Company	12	88	6,435
Tree Trimmers, Customer	92	6,395	481,095
Trees Inside ROW	273	12,470	1,968,171

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

6.a. 4901:1-10-10(C)(3)(a) Data Excluding Major Events And Transmission Outages ... Continued ...

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
Trees Out of ROW	527	33,081	4,045,283
UG, Const./Dig-Ins	110	7,844	541,989
Undesired Relay Operation	1	2,909	148,955
Unknown	1,126	38,029	3,357,402
Vandalism	29	35	4,378
Vehicle Accident/Auto Damage	288	36,790	4,369,915

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

6.b. 4901:1-10-10(C)(3)(b) Data For Major Events Only

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
Animal/Bird	13	80	144,164
Blast/Explosion/Fire	1	1	27
Cold Load Pickup	0	0	0
Equipment/Hardware Failure	70	12,613	18,067,137
Forced Outage	6	619	551,620
Galloping Conductors	0	0	0
High Winds	1,092	169,432	220,380,398
Ice/Sleet/Snow	0	0	0
Lightning	203	34,294	26,760,253
Other	0	0	0
Other Electric Utility	0	0	0
Overload	3	68	294,241
Personnel Error	5	7,294	59,900
Scheduled/Planned Outage	1	165	478,305
Transmission Trouble	0	0	0
Tree Trimmers, Company	0	0	0
Tree Trimmers, Customer	0	0	0

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

6.b. 4901:1-10-10(C)(3)(b) Data For Major Events Only ... Continued ...

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
Trees Inside ROW	228	16,422	31,478,737
Trees Out of ROW	183	8,669	18,253,610
UG, Const./Dig-Ins	1	27	3,316
Undesired Relay Operation	1	3	18,215
Unknown	21	1,106	1,766,407
Vandalism	1	1	56
Vehicle Accident/Auto Damage	2	62	2,865

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

6.c. 4901:1-10-10(C)(3)(c) Data For Transmission Outages Only

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
Animal/Bird	0	0	0
Blast/Explosion/Fire	0	0	
Cold Load Pickup	0	0	
Equipment/Hardware Failure	9	33,256	
Forced Outage	1	1,428	11,448
Galloping Conductors	1	1,929	
High Winds	5	9,053	911,500
Ice/Sleet/Snow	1	4,001	113,695
Lightning	1	10,316	165,056
Other	1	2,608	4,317,774
Other Electric Utility	0	0	
Overload	0	0	0
Personnel Error	0	0	
Scheduled/Planned Outage	0	0	
Transmission Trouble	18	31,310	10,856,628
Tree Trimmers, Company	0	0	0
Tree Trimmers, Customer	0	0	
Trees Inside ROW	0	0	0

DPL Inc
Dayton Power and Light Co.
Rule #10
2012
Distribution System Reliability Report

6.c. 4901:1-10-10(C)(3)(c) Data For Transmission Outages Only ... Continued ...

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
Trees Out of ROW	0	0	0
UG, Const./Dig-Ins	0	0	0
Undesired Relay Operation	0	0	0
Unknown	0	0	0
Vandalism	0	0	0
Vehicle Accident/Auto Damage	0	0	0

7. 4901:1-10-(C)(4) Momentary Interruptions

Total Number = 804

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/25/2013 5:02:56 PM

in

Case No(s). 13-0402-EL-ESS

Summary: Annual Report pursuant to Rule 10 of the Electric Service and Safety Standards electronically filed by Mr. Robert J Adams on behalf of The Dayton Power and Light Company