



April 17, 2013

**Case No. 13-0690-EL-REN  
Russo-Eric-PA-PV-7.595kW Residence  
Staff Interrogatories – Initial Set**

**Question 1:** In Section N of the application, you stated the following :

N.a

N Inverter Meter(s)

Y Utility Grade Meter(s) (Must meet ANSI 12.1, or demonstrate an accuracy level of  $\pm 2\%$ )

N.1.a Manufacturer: AEE Solar

N.1.b Serial Number: 21240599

N.1.c Type: Centron

N.1.e Report the total meter reading number at the time the photograph was taken and specify the appropriate unit of generation (e.g., kWh): 143.0 KWH

**However**

In Section N.1e of the application the photograph of the meter submitted does not show the serial number and other details regarding the make and type of the meter. Furthermore the meter reading number in the photograph is 663 kWh

Please clarify the details of the meter and submit a photograph of the meter that shows the above details. Indicate the date the photograph was taken.

**Answer 1:** The details of the meter are as follows:

Manufacturer: AEE Solar

Serial Number: 21240599

Type: CL 200

The total meter reading number in the below photograph is 512 kWh and this photo was taken on February 21, 2013.



This is a close up version of the above photo to help show the serial number more clearly.



Please let me know if you have any further questions and thank you for your cooperation.

Best,

Anna Noucas  
Associate  
Sol Systems, LLC

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/17/2013 5:19:46 PM**

**in**

**Case No(s). 13-0690-EL-REN**

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Russo, Eric