


**Case No. 13-0845-EL-REN**

**Ring, Kenny Residence - K Ring**

**Staff Interrogatories – Initial Set**

**Question 1:** In Section A of the application, according to Google maps the facility street address and the facility latitude and longitude are 50 miles apart. According to Yahoo Maps and Bing Maps the street address and the facility latitude and longitude are 0.5 miles apart. Please provide the correct facility street address and the facility latitude and longitude.

**Answer 1:** 39.312160, -77.982621



**Question 2:** In section I.1 the nameplate capacity is listed as 0.0091 MW. But in section G.1 you state the facility has twenty one 235W panels and twenty five 245W panels. Since  $21 \times 235W = 4935W$  and  $25 \times 245W = 6125W$ , which combine for 11,060W or 0.01106MW. Is the nameplate capacity 0.011060 MW?

**Answer 2:** Yes, the nameplate capacity should be 0.011060 MW.

Best regards,

Alisa Hobdy

SRECTrade

Telephone: [\(757\) 598-1553](tel:(757)598-1553)

Fax: [\(732\) 453-0065](tel:(732)453-0065)

Email: [alisa.hobdy@srectrade.com](mailto:alisa.hobdy@srectrade.com)

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/28/2013 12:35:53 AM**

**in**

**Case No(s). 13-0845-EL-REN**

Summary: Memorandum Ring, Kenny Residence address info and system size electronically filed by Mr. Brad Bowery on behalf of Mr. Kenny Ring