



May 21, 2013

**Case No. 13-1068-EL-REN
Hilton-Susan-PA-PV-5.52kW Residence
Staff Interrogatory – Initial Set**

Question 1: In Section I.a of the application, the nameplate capacity is listed as 5.52 kW. However, in section G.4 you list the system as having 24 x 235 watt panels which would give you a nameplate capacity of 5.64 kW. **Is the nameplate capacity 5.64 kW? If not, please explain how the nameplate capacity was determined.**

Answer 1: The nameplate capacity is 5.64 kW determined by 24 modules x 235 watt per module.

Please let me know if you have any further questions and thank you for your cooperation.

Best,

Anna Noulas
Associate
Sol Systems, LLC

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

5/21/2013 6:37:08 PM

in

Case No(s). 13-1068-EL-REN

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Hilton , Susan