

Haviland Wind Facility, Case No. 13-0248-EL-REN

Questions and responses—6/18/13

1) What is the placed in-service date for these 3 turbines? The response to Question H of the application indicates a **projected** in-service date of 12/31/12. Please clarify the actual placed in-service dates for the 3 turbines. **The actual placed in service dates are per the attached certifications.**

2) In response to G2 of the application, the Applicant describes a meter capable of recording flow in both directions. Does this meter record gross generation from the wind turbines? Will the output from this meter be used to report generation data to GATS? **The meter records total production (outbound flow) and total consumption (inbound flow). The number that is used for reporting is the total production (outbound flow) only. The Incoming flow is recorded for operational record keeping only.**

3) How does/will the renewable output from these wind facilities be relied upon during Haviland Plastic Products's marketing/PR efforts?

This project is not intended to be used for marketing and there are no marketing or PR efforts associated with this project.

4) Will the Applicant meet the requirements under the Commission's rules prohibiting double-counting for the renewable energy output of the facility? The Commission's rules (4901:1-40-01, OAC) include the following language pertaining to double-counting:

The Applicant does meet the requirements of the rule and will NOT be double counting in any way.

(M) "Double-counting" means utilizing renewable energy, renewable energy credits, or energy efficiency savings to do any of the following:

- (1) Satisfy multiple Ohio state renewable energy requirements or such requirements for more than one state.
- (2) Comply with both the energy efficiency and advanced energy statutory benchmarks.
- (3) Support multiple voluntary product offerings.
- (4) Substantiate multiple marketing claims.
- (5) Some combination of these.

For related information, please see The Federal Trade Commission's guidelines on green claims, including renewable energy facilities:

<http://www.ftc.gov/opa/2012/10/greenguides.shtm>

This project is intended primarily as an energy cost reducing project and not a marketing project. Any marketing efforts are incidental to the project and will comply with all applicable regulations regarding representation. There will not be any double counting or other prohibited acts related to marketing efforts.



15630 E State Route 12
Unit 6
Findlay, OH 45840
877.298.5853

PLACED IN SERVICE CERTIFICATE

This certificate, when executed by all of the undersigned, certifies that the described wind turbine generator (WTG) is *Placed In Service*, specifically:

1. The foundation and civil construction necessary for operation is complete.
2. The installation and construction of the WTG is complete.
3. The supporting infrastructure required to operate the WTG is installed and tested in accordance with the engineer's sealed and issued for construction drawings and specifications.
4. The WTG has been inspected and energized to the main breaker inside the turbine.
5. The WTG is available and ready to be operated as intended and remains in a state of readiness.
6. The completed WTG has been turned over to the Turbine Manufacturer for testing and start up.

Project:	Haviland Wind Project
Location:	Haviland, Ohio
Turbine:	WTG A
Make:	Goldwind
Model:	GW87-1500 @ 85m Hub Height
Rotor:	87 Meter
Nameplate Rating:	1.5 megawatts
Responsible Constructor:	One Energy LLC
Date Placed in Service:	December 18, 2012


This Certificate is executed by the undersigned. This certificate does not in any way modify the terms of any existing Turbine Supply Agreements or Construction Contracts.

Engineer

By: 

John G. Everett, P.E.
Director of Construction
One Energy LLC

Constructor

By: 

Jereme Kent
General Manager
One Energy LLC

Owner

By:

Craig Stoller
President
Haviland Plastic Products Co.



15630 E State Route 12
Unit 6
Findlay, OH 45840
877.298.5853

PLACED IN SERVICE CERTIFICATE


This certificate, when executed by all of the undersigned, certifies that the described wind turbine generator (WTG) is *Placed In Service*, specifically:

1. The foundation and civil construction necessary for operation is complete.
2. The installation and construction of the WTG is complete.
3. The supporting infrastructure required to operate the WTG is installed and tested in accordance with the engineer's sealed and issued for construction drawings and specifications.
4. The WTG has been inspected and energized to the main breaker inside the turbine.
5. The WTG is available and ready to be operated as intended and remains in a state of readiness.
6. The completed WTG has been turned over to the Turbine Manufacturer for testing and start up.

Project: Haviland Wind Project
Location: Haviland, Ohio
Turbine: WTG B
Make: Goldwind
Model: GW87-1500 @ 85m Hub Height
Rotor: 87 Meter
Nameplate Rating: 1.5 megawatts
Responsible Constructor: One Energy LLC
Date Placed in Service: December 18, 2012

This Certificate is executed by the undersigned. This certificate does not in any way modify the terms of any existing Turbine Supply Agreements or Construction Contracts.

Engineer
 By: 
 John G. Everett, P.E.
 Director of Construction
 One Energy LLC

Constructor
 By: 
 Jereme Kent
 General Manager
 One Energy LLC

Owner
 By:
 Craig Stoller
 President
 Haviland Plastic Products Co.



15630 E State Route 12
Unit 6
Findlay, OH 45840
877.298.5853

PLACED IN SERVICE CERTIFICATE

This certificate, when executed by all of the undersigned, certifies that the described wind turbine generator (WTG) is *Placed In Service*, specifically:

1. The foundation and civil construction necessary for operation is complete.
2. The installation and construction of the WTG is complete.
3. The supporting infrastructure required to operate the WTG is installed and tested in accordance with the engineer's sealed and issued for construction drawings and specifications.
4. The WTG has been inspected and energized to the main breaker inside the turbine.
5. The WTG is available and ready to be operated as intended and remains in a state of readiness.
6. The completed WTG has been turned over to the Turbine Manufacturer for testing and start up.

Project:	Haviland Wind Project
Location:	Haviland, Ohio
Turbine:	WTG C
Make:	Goldwind
Model:	GW87-1500 @ 85m Hub Height
Rotor:	87 Meter
Nameplate Rating:	1.5 megawatts
Responsible Constructor:	One Energy LLC
Date Placed in Service:	December 18, 2012

This Certificate is executed by the undersigned. This certificate does not in any way modify the terms of any existing Turbine Supply Agreements or Construction Contracts.

Engineer

By:

A handwritten signature in black ink, appearing to read "John G. Everett".

John G. Everett, P.E.
Director of Construction
One Energy LLC

Constructor

By:

A handwritten signature in black ink, appearing to read "Jereme Kent".

Jereme Kent
General Manager
One Energy LLC

Owner

By:

Craig Stoller
President
Haviland Plastic Products Co.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/19/2013 11:57:35 AM

in

Case No(s). 13-0248-EL-REN

Summary: Response electronically filed by Ms. Rebekah R Hedahl on behalf of Haviland Plastic Products, Co.