

**Case No. 13-1786-EL-REN
Cynthia Purvis
Staff Interrogatories - Initial Set**

Question 1: In **Section I** of the application, you submitted the following:

I.1 For each generating unit, provide the following information:

Projected Gross Annual Generation: 1

This value for the Projected Gross Annual Generation has resulted in an Expected Annual Capacity Factor % of 7.9. This factor is low for the region. Please clarify the Projected Gross Annual Generation.

Answer 1: The Projected Gross Annual Generation should be 1.73 mWh.

Thank you.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

9/1/2013 10:26:27 AM

in

Case No(s). 13-1786-EL-REN

Summary: Reply in the matter of the incorrect Projected Gross Annual Generation entered on the application for a renewable energy facility electronically filed by Mr. Gary Lakritz on behalf of Cynthia Purvis