

**I will still need to file the Not-Yet-Online form. I have contacted the system owner for an updated picture of the monitoring meter. I live a significant distance from the install. If the system owner is not able to provide this then I will travel to the install and take a photo.**

**Thanks**

**Matt Kuhn**

**Case No. 13-1179-EL-REN**

**840 Tater Knob**

**Staff Interrogatories – Initial Set**

Question 1: Section B of the application is for facility owner information, the legal name of the facility owner representative appears to be for the installer not the facility owner. The facility owner representative should be the facility owner unless the facility owner is a corporation or LLC. Do you or your company own the facility? If not, please submit corrected information for section B.

Barb Rauf

840 Tater Knob Rd  
Peebles, Ohio 45660

Question 2: In section H of the application you state that the facility is not yet online and the projected in-service date as 6/1/13. Is the facility online now? If so, what is the in-service date? If not, what is the new projected in-service date?

The system went online after inspection from AEP. The online date June 25<sup>th</sup> 2013

Question 3: In section G.2 of the application you state that the system will be monitored by a Fronius inverter with remote monitoring and a GE Utility meter. A utility grade meter, a meter with an accuracy of +/- 2%, must be used to record the output of the system? Is the Fronius inverter or GE meter utility grade?

The meter is utility grade with proper accuracy, however the meter was changed to a Duncan Landis & Gyr, the meter was certified on July 26 2012?

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**9/18/2013 8:25:19 PM**

**in**

**Case No(s). 13-1179-EL-REN**

Summary: Reply Answers to  
Case No. 13-1179-EL-REN  
840 Tater Knob  
Staff Interrogatories – Initial Set  
electronically filed by Mr. Matthew T Kuhn on behalf of Rauf, Barb Mrs.