



February 27, 2014

**Case No. 14-0178-EL-REN
Locke-Gordon-PA-PV-11.25kW Residence
Staff Interrogatories – Initial Set**

Question 1: The nameplate capacity provided in section **I.a** of the application is 11.25 kW, but the calculated capacity based on the values in section **G.4** would be 45 modules * 255 watts/module = 11.475 kW. Please explain.

Answer 1: The correct system size is 11.475 kW. This was a typo.

Please let me know if you have any further questions and thank you for your cooperation.

Best,

Anna Nocas
Senior Associate
Sol Systems, LLC

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

2/27/2014 5:17:55 PM

in

Case No(s). 14-0178-EL-REN

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Locke, Gordon