



February 27, 2014

Mr. Klaus Lambeck
The Ohio Power Siting Board
180 East Broad Street
Columbus, Ohio 43215

RE: Pre-Application Notification Letter for DP&L's Proposed West Milton-Eldean 138 kV Transmission Line Project

Dear Mr. Lambeck,

In accordance with Chapter 4906-5-08 of the Ohio Administrative Code (OAC), The Dayton Power and Light Company (DP&L) hereby submits the Pre-Application Notification Letter for its proposed West Milton-Eldean Transmission Line Project---a new 17-mile 138 kV line from the existing West Milton Substation to the existing Eldean Substation located northwest of Troy, Ohio.

The purpose of the proposed new 138 kV line is to ensure that adequate transmission system voltages are maintained in the northwest area of the DP&L transmission system under various outage conditions, as required to comply with the mandatory North American Electric Reliability Corporation (NERC) reliability standards. The proposed project has been approved by both the PJM Board and FERC.

The routes under consideration largely follow road right-of-way (often where electric distribution lines already exist) and DP&L's existing transmission line right-of-way (south and west of West Milton). The proposed routes were also designed to align with property lines. It is anticipated that the new line will be installed on single wood poles, with steel poles at select locations, averaging 70-90 feet in height.

The public informational meeting will be held from 6 to 8 PM on Tuesday, March 25, 2014, in the auditorium of Milton Union School, 7610 Milton-Potsdam Road, West Milton, Ohio 45383.

DP&L anticipates seeking waivers for two requirements in OAC 4906-5-04(A). The first waiver is related to the requirement that the alternate route shall not have more than 20% in common with the preferred route. The second waiver is related to the requirement that all certificate applications for electric transmission facilities shall include fully developed information on two routes.

Should you have any questions regarding this proposed project, please give me a call at (937) 259-7262.

Sincerely,

A handwritten signature in black ink, appearing to read "H. Shamash". The signature is fluid and cursive, with a long, sweeping underline.

Hertz Shamash
Vice President, Resource Planning

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/24/2014 9:25:09 AM

in

Case No(s). 14-0469-EL-BTX

Summary: Application Pre-Application Notification Letter for DP&L's Proposed West Milton-Eldean 138kV Transmission Line Project electronically filed by Mr. Michael A Hassay on behalf of Shamash, Hertzell Mr.