

April 14, 2014

**Case No. 14-0349-EL-REN
Gable-Scott-PA-PV-5.1kW Residence
Staff Interrogatories – Initial Set**

Question 1: In section N.1 you list two meter manufacturers, two serial numbers, and two meter types, but you provide only one photograph of one meter (the first meter). How is the second meter being used? Will it be measuring output for this facility for reporting to PJM-GATS? Is the second meter a utility grade meter or an inverter meter? Will it be measuring output for some of the modules while the first meter will measure output for the other modules? Please explain this configuration, and please provide a photograph of the second meter.

Answer 1: The list of two meters was a mistake. The first meter (Sangamo, CL200, 10013464) is the correct and only revenue grade meter used for this facility. The second meter provided (Enphase, IEMU-03, 121319013746) is the inverter, which also measures production but will not be used for reporting to PJM-GATS. Output for all of the modules will be measured using the Sangamo meter and the readings from that Sangamo meter will be reported to PJM-GATS.

Please let me know if you have any further questions and thank you for your cooperation.

Best,
Anna Noucas
Senior Associate
Sol Systems, LLC

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

4/16/2014 9:47:06 AM

in

Case No(s). 14-0349-EL-REN

Summary: Reply reply to staff interrogatory electronically filed by Ms. Anna Noucas on behalf of Gable, Scott