

Case No. 14-1667-EL-REN

Facility Maintenance Shop (FMS) Richmond

Staff Interrogatories - Initial Set

Question 1: In section I.1 the nameplate capacity is listed as 0.031 MW. But in section G.1 you state the facility has 108 290W panels. Since $108 \times 290W = 31,320W$ or 0.03132 MW. Is the nameplate capacity 0.03132 MW?

Answer 1: Yes, the nameplate capacity is 0.03132 MW.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/10/2014 9:58:07 AM

in

Case No(s). 14-1667-EL-REN

Summary: Reply Response to question sent Tue 10/7/2014 11:20 AM about nameplate capacity for Case No. 14-1667-EL-REN electronically filed by Mr. Jayson S McDonald on behalf of Kentucky Army National Guard