

BEFORE THE PUBLIC UTILITIES COMMISSION OF OHIO

In the Matter of the Commission’s)
Review of the Ohio Power Company’s)
Distribution Investment Rider Work) **Case No. 14-2275 -EL-UNC**
Plan Resulting from Commission)
Case No. 13-2394-EL-UNC et al.)

**Notice of Ohio Power Company’s Commission Requested
Distribution Investment Rider Work Plan**

On August 8, 2012 the Commission approved an Electric Security Plan for Ohio Power Company (“AEP Ohio” or “Company”), including approval of the Distribution Investment Rider (DIR) in Commission docket 11-346-EL-SSO et al. (“*ESP II Order*”).¹ As part of the approval of the DIR, the Commission instructed the Company to work with the Commission Staff and file the resulting plan for Commission review in a separate docket. Specifically the Commission stated:

The Company is directed to work with Staff to develop a plan to emphasize proactive distribution maintenance that focuses spending on where it will have the greatest impact on maintaining and improving reliability for customers. Accordingly, AEP-Ohio shall work with Staff to develop the DIR plan and file the plan for Commission review in a separate docket by December 1, 2012.

In case 13-2394-EL-UNC the Commission clarified the filing requirements for the DIR plan outlining expectations for the filings going forward. AEP Ohio offers the 2015 DIR plan at this time for the entire year, even though the ESP II approval only provides for a

DIR mechanism for part of the 2015 year. AEP Ohio will file an amended document to the extent necessary, if the DIR program is modified in any manner as a result of a final order in the pending electric security plan filing.

The Staff and Company have worked together over the past few months to further review the Company plans to address investment in the distribution system. The Staff and Company discussions resulted in an understanding of how best to move forward and allow the Company to address areas of need. The Staff and Company were able to develop work plan components to guide the Company's proactive management of the distribution system. Listed below are the steps that the Company and Staff have taken to ensure Staff's engagement and input was considered in the development of the 2015 DIR Plan.

Process for 2015 DIR Plan Development

- 1) On September 29, 2014, Ohio Power provided Staff with an update of historical outage-by-cause data. Staff analyzed this data to identify the most-frequent outage causes that could be addressed by DIR programs.
- 2) On October 15, 2014, Ohio Power provided Staff with a draft of all the 2015 DIR Programs along with high level reliability qualifications.
- 3) On November 3, 2014, Staff provided Ohio Power a ranking of the draft DIR Programs based on Staff's rating of relative importance. That rating was based, in part, on Staff's analysis of the outage-by-cause data referred to in Step 1.
- 4) On November 13, 2014, Staff and the Company met to discuss Staff's ranking of programs.
- 5) On November 17, 2014, Ohio Power provided Staff with projected expenditures and associated work units.
- 6) On December 9, 2014, Staff and the Company met to discuss the projected expenditures and the draft DIR plan, and to address any additional Staff concerns prior to filing.

7) On December 15, 2014 Company filed the DIR Plan.

This filing represents the outcome of the cooperative effort outlined above between the Commission Staff and the Company to develop a plan to emphasize proactive distribution investment as directed by the Commission. The DIR plan components consist of several programs which benefit customers and increase spending levels to improve proactive distribution equipment replacement. The attachment of the overall 2015 DIR Plan lists each program that will be included in the DIR plan for 2015.

This attachment includes the following information:

1. **Staff Rating-** the rating Staff assigned to each program, where the higher numbers indicate greater preference.
2. **DIR Component-** the DIR Program Name
3. **Program Description-** this is the detailed information as to what each program consists of as well as the reasoning behind each program. This section also reflects the expected amount of work performed for this program.
4. **Measures for Reliability Improvement-** this section identifies how the program proactively replaces equipment or improves reliability; if reliability is to be improved then the measure of that improvement is quantified.
5. **Expected Reliability Improvements-** this section details the overall program impact and whether the program is expected to reduce outages or maintain system reliability.
6. **2014 Filing Rule 11 Work -** These are the number of the 2014 Rule 11 circuits that each work plan component will address in 2015. The Company enumerated these issues in its plan after discussions with the Office of the Ohio Consumers' Counsel and the Company's understanding that such a description would be appreciated.
7. **Measurement Units-** How the units are measured, i.e. by feet or unit, etc.
8. **Projected 2015-** This is the projected capital spend for 2015 by program.

The Company developed a strategy to look at programs in the plan which would have the most impact to both proactive system infrastructure replacement as well as reliability improvement to customers. In order to develop the 2015 DIR plan, the Company looked at causes of outages on the system, opportunities for proactive replacement, rating values provided by the PUCO Staff, engineering and labor resource availability, and overall impact of each program. The 2015 Plan, as developed, takes into consideration various factors encountered during 2013 and 2014, such as labor resources, and adjusted the 2015 plan accordingly. This comprehensive development of the plan and continual discussions with Staff on its progress provides the best practice to reach the Commission's goal to help ensure that this and future DIR plans will positively impact reliability performance to customers across the service territory. Overall, the plan is developed to provide a more proactive replacement plan as well as components which will maintain or improve reliability to customers. In section A of the 2015 DIR plan, all the programs listed either proactively replace infrastructure or impact reliability to customers.

The Staff and Company also reached an understanding of how best to keep the Staff updated as it exercises its ongoing function of interacting with the Company to monitor reliability performance and investment in Ohio. AEP Ohio will continue to work with Staff annually to review the accounting accuracy, prudence and compliance with the DIR plan as developed.


In order to ensure double recovery does not occur in the DIR there are two items currently in place. The first item in place is that the Company tracks assets recovered through other riders by separately identifiable work-orders which allow those charges to

be appropriately removed from the DIR rider filing. This process has been reviewed and verified during past audits of the DIR program. The second item is that there is an independent audit done on the DIR program expenditures. This audit is completed by an external independent auditor chosen by the PUCO to ensure compliance with the financial side of the program spend. The auditor sends its findings to the Commission and ensures that the Company follows all guidelines when reporting items charged to the DIR Rider.

The Company will continue to provide Staff with quarterly updates consistent with Finding 25 of the Commission's order in case 13-2394-EL-UNC. The Company will send Staff quarterly updates in order to show progress of each of the programs and agrees to meet in person to discuss any questions when requested. The Company will also continue to provide Staff locations to audit DIR work being performed in the field per Finding 25 of case 13-2394-EL-UNC.

The attached 2015 DIR work plan includes estimates of the work to be proactively performed and the expected spending in each category. As expected, anytime there is a proactive program covering an entire year of spending on items as varied as are covered here, there is likely to be some differences in what is expected and what is performed. However, where possible the Company has provided a good faith estimate on the expected areas to be impacted, proactively maintained, or replaced to provide a guidepost for future interactions with Commission Staff. These estimates may change over the course of the year, and the quarterly updates to Staff may reflect these changes as well as an explanation of the change.

Overall, the Company’s average capital spend has increased significantly in the past two years due to the DIR program. This spending will still be audited as outlined by the Commission in the *ESP II Order*. The chart below shows the Capital spend by millions prior to the DIR Program implementation (years 2010 – 2012) and after the implementation (years 2013 – 2015). As shown in the chart below, the levels of spend are greater in the DIR plan years per the approval of the DIR. The values in the charts exclude costs associated with gridSMART and the Enhanced Service Reliability Riders.



Along these same lines the Company and Staff discussed the expected reliability improvements from the proactive maintenance programs. While the overall DIR plan will have a positive effect on reliability improvement experienced by customers, inherently there are some components that may not be measured in a quantitative reduction in the amount of outages. Where investments are made in specific asset categories to proactively address known performance needs, the Company will track reliability

improvements in that asset subset. Because the work plan components involve a proactive approach focused on the best methods to impact long-term reliability improvements, the goal is to prevent the outages that may occur in the future from happening. This is a proactive approach to ensure that things working now will continue to work and no further degradation of the system will result in further outages.

Reflected in the 2015 DIR plan, the Company has added a column to show the number of Worst Performing Circuits being addressed by the DIR program. It is important to address worst performing circuits, and the DIR Program is a tool which allows for these circuits to be addressed by the various programs and thereby improve reliability or proactively reduce future outages. A single circuit may be reflected under several programs. It is also important to note that not all worst performing circuit issues can be addressed by DIR programs because some of those circuits may require non-capital maintenance activities.

The Company was able to show positive reliability results based on programs with a reliability impact as shown on the plan for 2013. Reliability improvement values were shared with Staff per the Finding on Order in case number 12-3129-EL-UNC. The results showed a positive improvement for all reliability programs as well as an estimate for avoided outages. These results reinforce the benefit of the DIR Program.

As ordered in case 13-2394-EL-UNC, the Company will provide to Staff in writing by March 2, 2015 the reliability improvements achieved from the 2014 DIR plan, as well as a quantification of avoided outages.

Going forward, the Company and Staff will continue to work cooperatively evaluating the progress of the programs outlined in the DIR work plan. Various elements

may affect the execution of the plan during 2015 which include items such as storms, resource availability, and mutual assistance to other utilities. These factors will be shared with Staff during the year. The Company provides this filing and attachments, developed in concert with the Commission Staff, detailing the components to satisfy the requirements related to the DIR review from the May 21, 2014 Finding and Order in Case No. 13-2394-EL-UNC.

The Company appreciates the open and cooperative interactions with the Commission Staff in developing these DIR plan components and discussing the process moving forward. As indicated by the Commission in the *ESP II Order*, the move to a proactive distribution focus will allow the Company to prevent issues on the system.

Staff Rating	DIR Component	Program Description	Measures for Reliability Improvements	2014 Filing Rule 11 Work	Expected Reliability Improvements	Measurement Units	Projected 2015
Section A							
9	Forestry - Emerald Ash Borer Mitigation Ash Tree	There is a growing number of Ash trees that have been affected by the Emerald Ash Borer. On average, an Ash tree will die in 2 to 3 years once affected by this insect. This program is designed to remove targeted Ash trees from outside right-of way. This would be a stand alone program separate from the ROW Maintenance Program. The Company intends to implement this program utilizing a work force other than the one engaged with the current vegetation management program.	This is a proactive preventative program. There is some reliability impact related to the prevention of future outages.		Proactive efforts to maintain system reliability	Trees Removed	\$8,000,000.00
9	Animal Mitigation - Station	This program is designed to install electric fences in targeted stations to help mitigate against animal related outages. Approximately 20 electric fences may be targeted in 2015 for work under this station animal mitigation program.	This should reduce non-avian related animal caused outages inside distribution stations by approximately fifty percent for those stations where mitigation was installed beginning in the year following installation.	5	Reduced outages	Fences Installed	\$500,000.00
9	Underground Cable Replacement	This program is to proactively address aging infrastructure based on various factors such as age, previous operational history, cable construction, etc. This would include URD cable, feeder exit cable and station cable, such as transformer cables and bus ties. This program will include approximately 400,000 conductor feet of underground cable work in 2015.	This should reduce URD cable failures by approximately fifty percent on those segments addressed beginning in the year following installation. Feeder exit and station cable replacements are asset renewal programs and as such, there will be some positive impact to reliability, related to the prevention of future outages.		Reduced outages	Span Feet	\$20,000,000.00
9	Cutout & Arrester Program	This program is to proactively address equipment failure issues by replacing targeted porcelain cutouts and associated equipment. Approximately 3,000 cutouts and their associated arresters will be targeted for replacement under this program in 2015.	Proactive asset renewal that will reduce the probability of future outages related to cutout and arrester failures.		Proactive efforts to maintain system reliability	Units Installed	\$1,500,000.00
8	Distribution Circuit Asset Improvement Includes Small Wire Replacement	This program is designed to address various operational, reliability and asset renewal issues as identified by Distribution Line Operations, Distribution Engineering and customer concerns. This program includes circuit improvement projects such as line relocation, reconductoring, OH to UG, multiphasing, fuse size changes, over current protection upgrades and coordination, circuit reconfiguration, and load balancing. The Small wire replacement portion of this will proactively address equipment failure issues by replacing targeted spans of small and deteriorating overhead conductor. In some cases portions of circuits may be relocated and/or rebuilt due to accessibility concerns and/or physical conditions.	Reliability improvements vary based on the type of work performed and can be measured on a circuit or line segment basis. The small wire replacement work should reduce outages due to Equipment/Hardware and conductor failure by fifty percent on those line segments addressed beginning in the year following installation. Projects such as line relocation and reconductoring segments should reduce outages due to Equipment/Hardware and conductor failure by fifty percent on those line segments addressed beginning in the year following installation. Load balancing when completed on a circuit will reduce overload outages by fifty percent beginning the following year after installation. Projects which take overhead lines to underground lines will reduce weather related outages, animal outages, and tree related outages on those segments by fifty percent in the year following when work was completed. Upgrading of overcurrent protection devices (changing from hydraulic to electronic protection devices, changing from three phase to single phase isolation and fuse size and coordination changes) can reduce customer outages by impacting fewer customers affected by an outage. Some projects under this program are solely asset renewal projects with only minor reliability impact related to the prevention of future outages, but are intended for proactive equipment replacement.	18	May reduce customer interruptions and outages; varies by work request.	Completed Hours	\$21,000,000.00
8	Lightning Mitigation	This program is designed to help reduce the number of lightning caused outages on specifically identified circuits. AEP Ohio will target circuits and rank them by lightning caused outages and install lightning mitigation on the highest five percent of circuits with 3 or more lightning caused outages. These circuits will be ranked on an annual basis and may include that year's Rule 11 circuits. Circuits may be added or removed at the Company's discretion. This program will involve approximately 5 circuits in 2015.	This should reduce the aggregate number of lightning caused outages by approximately fifty percent on the circuits addressed beginning in the year following installation.	6	Reduced outages	Circuits	\$20,000.00
8	Station Rebuild / Rehab	This program is designed to replace existing distribution station equipment including transformers, breakers, structures underground facilities, etc. AEP Ohio will target equipment which is approaching end of life and becoming difficult to maintain.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future station equipment caused outages.	2	Proactive efforts to maintain system reliability	Stations	\$4,500,000.00
8	Network Rehab	This program is designed to replace and/or upgrade network cable, vaults, transformers, protectors and install fault indicators.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future network outages.		Proactive efforts to maintain system reliability	Completed Hours	\$5,000,000.00

Staff Rating	DIR Component	Program Description	Measures for Reliability Improvements	2014 Filing Rule 11 Work	Expected Reliability Improvements	Measurement Units	Projected 2015
8	Sectionalizing	This program is designed to enhance the over current protection scheme, operation of Distribution system and reduce the number of customers affected by an outage. It includes the installation/upgrade of sectionalizing devices on circuits, shortening of protection zones and providing additional isolation points. Approximately 35 circuits will be targeted in 2015 for work under this sectionalizing program.	Installation of sectionalizing can reduce SAIFI by impacting fewer customers affected by an outage. There is limited opportunity to continue with a large scale effort.	2	Reduce Customers Interrupted	Circuits	\$1,000,000.00
7	Distribution Asset Improvement Associated with Transmission Work	AEP Transco plans to rebuild a number of transmission lines of which a portion contain Distribution underbuild. Transfer of Distribution facilities or the replacement of conductors with "like kind" are included with the Transmission project. This component will provide Distribution the opportunity to make Distribution system enhancements, such as building a new tie line or increasing conductor size to create a tie line for reliability purposes. AEP Transco/Transmission will also be rebuilding existing or building new station facilities. The replacement of Distribution station breakers and transformers, Distribution SCADA installations, and relocation or replacement of Distribution feeder exits in conjunction with these projects will also be included in this component as either reliability enhancements and/or asset renewal. (This does not include breaker or underground cable replacement or SCADA installations).	Proactive asset renewal that will reduce the probability of future outages. In some cases, new tie lines may be established to enhance reliability to shorten outage durations following an event. A portion of the circuit that is rebuilt will replace existing equipment identified to be near the end of its life that could reduce future Equipment Failure outages.	1	Proactive efforts to maintain system reliability	Completed Hours	\$5,000,000.00
7	Station Breaker Replacement	This program is designed to replace existing distribution station breakers with associated relays, controls, and SCADA when appropriate. AEP Ohio will target equipment which is approaching end of life and becoming difficult to maintain. The existing breakers have limited flexibility to adapt to modern over current protective schemes. Approximately 20 station circuit breakers may be targeted in 2015 for work under this station breaker program.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future station breaker outages.		Proactive efforts to maintain system reliability	Units Installed, Installations	\$4,000,000.00
7	Station Regulator Replacements	This program is designed to replace existing distribution station regulators and associated controls. AEP Ohio will target equipment which is approaching end of life and becoming difficult to maintain. Approximately 3 station regulators may be targeted in 2015 for work under this station regulator program.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future station regulator outages.		Proactive efforts to maintain system reliability	Units Installed	\$500,000.00
7	Underground Duct and Manhole Facilities Inspection and Replacement	This program is designed to inspect and replace non-network underground duct, manhole and associated cable facilities. This program will identify unsafe conditions and correct deficiencies necessary for the safety of employees and the public under the conditions specified in the NESC.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future underground duct and manhole related outages.		Proactive efforts to maintain system reliability	Completed Hours	\$3,500,000.00
6	OVHD Circuit Inspection Repair Program	This program is designed to visually inspect overhead line facilities and to make the appropriate repairs or replacements (asset renewal) when issues are found. Circuits are inspected at least once every five years. Approximately 285 circuits will be targeted for inspection in 2015.	This should reduce equipment caused outages by thirty percent on those circuits addressed beginning in the year following installation.	16	Reduced outages	Completed Work Packets	\$1,500,000.00
6	Line Reclosers Maintenance	This is an asset renewal program. Approximately 690 reclosers may be targeted in 2015.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future outages due to recloser failures. There is also an opportunity to enhance the over current protection scheme on the circuit.		Reduced outage duration	Units Installed	\$4,500,000.00
6	URD Remediation Program	This program is designed to provide a visual public safety inspection of pad mount transformers, switchgear, primary enclosures and secondary pedestals. Each piece of equipment is inspected once every 5 years. Approximately 35,000 units may be targeted for inspection in 2015. Repair work is a subset of previously inspected units.	The majority of this work is proactive asset renewal that will reduce the probability of future outages related to pad mounted URD equipment. This is an inspection program used to identify unsafe conditions.		Maintain system safety and reliability.	Completed Work Packets	\$300,000.00
6	Pole Replacement	This is an asset renewal program. The primary objective of this program is to maintain the mechanical integrity of our wood pole infrastructure necessary for the safety of employees and the public under the conditions specified in the NESC. Approximately 3,000 poles will be targeted in 2015.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future outages due to pole failures.		Proactive efforts to maintain system reliability	Poles Replaced	\$8,000,000.00
6	Pole Reinforcement	This is an asset life extension program. The primary objective of this program is to maintain the mechanical integrity of our wood pole infrastructure necessary for the safety of employees and the public under the conditions specified in the NESC. Approximately 150 poles may be targeted in 2015.	Proactive asset renewal program. There is positive impact to reliability, related to the prevention of future outages due to pole failures.		Proactive efforts to maintain system reliability	Pole Locations	\$200,000.00
Section A Subtotal:							\$89,020,000.00
Section B							
	Network Capacity	This program is designed to install new Distribution network capacity to serve additional load.	There is no reliability impact.		NA	n/a	\$700,000.00
	Capacity Additions	This program is designed to install new Distribution station and line capacity to serve additional load.	There is no reliability impact.		NA	n/a	\$5,000,000.00
	Integrated Volt Var Systems	This program provides improved efficiency through voltage optimization. The program's primary focus is to reduce electrical demand and/or accomplish energy conservation.	There is no reliability impact.		NA	n/a	\$0.00

Staff Rating	DIR Component	Program Description	Measures for Reliability Improvements	2014 Filing Rule 11 Work	Expected Reliability Improvements	Measurement Units	Projected 2015
	Customer Service Work	This component is for work necessary for providing customers electric service in AEP Ohio. It includes capital dollars for providing service to new customers, as well as upgrades to existing commercial, industrial and residential customers.	There is no reliability impact.		NA	n/a	\$19,000,000.00
	Third Party Work Request	This component involves work requested by a third party. This includes work for customer requested relocates, damage claims made by outside parties, and make ready work which includes replacing AEP Ohio owned poles for others who are attached or propose to attach to AEP Ohio owned poles.	There is no reliability impact.		NA	n/a	\$6,600,000.00
	Public Project Relocation	This component involves work requested by a governmental entity such as a township, city, or the state. Public projects generally consist of work associated with road improvement projects which benefit the public. This involves the capital work AEP Ohio does to accommodate these governmental improvement projects within the service territory.	There is no reliability impact.		NA	n/a	\$7,500,000.00
	Service Restoration	This component includes day to day work for service restorations which are excluded from the major event category of outages. This would include capital dollars for such things as equipment replacement from an outage and capital dollars associated with minor storm events.	There is no reliability impact.		NA	n/a	\$9,000,000.00
	Forestry	This program includes all capital vegetation management work performed in AEP Ohio. Incremental capital dollars associated with the ESRR filing will be removed from the DIR filing used to establish the rate.	The reliability impact regarding this program is reflected as an adjustment in the current standards and proposed reliability standards.		NA	n/a	\$4,500,000.00
	Transformer Blanket	This component is for the purchase of Distribution line transformers necessary for providing customers electric service in AEP Ohio. It includes overhead line transformers and pad mounted transformers.	There is no reliability impact.		NA	n/a	\$15,750,000.00
	Engineering & Field Line	This component includes Engineering labor, Fleet and Material & supplies.			NA	n/a	\$24,000,000.00
	Customer Meter Blanket	This component is for the purchase of customer meters for providing customers electric service in AEP Ohio. It includes standard and AMR meters.			NA	n/a	\$8,000,000.00
	Other	This component includes AEP Ohio items which are involved in day to day work components of service to existing customers. The would include such items as other capital base operations, capital overheads, and Distribution Dispatch support.	There is no reliability impact.		NA	n/a	\$3,000,000.00
Section B Subtotal:							\$103,050,000.00
Grand Total:							\$192,070,000.00

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

12/15/2014 5:17:41 PM

in

Case No(s). 14-2275-EL-UNC

Summary: Letter of Notification re 2015 AEP Ohio DIR Project Work Plan electronically filed by Mr. Matthew J Satterwhite on behalf of Ohio Power Company