

Case No. 14-1910-EL-REN
Randaisi, Vincent & Julia Residence - V & J Randaisi
Staff Interrogatories - Initial Set

Question 1: In Sections A through D of the facility application, the facility street address is listed as "13688 U.S. 52, West Portsmouth OH, 45663." This is an invalid street address according to both the United States Postal Service and Google Earth/Maps. Please verify that this address is valid for use by the USPS, and if it is not, please provide a valid street address.

Answer 1: 3688 US HWY 52 West Portsmouth, OH 45663

Question 2: In Section I.a of the facility application, the nameplate capacity of the facility is listed as 11.47 kW (0.01147 MW). According to the information listed in Sections G.4 and G.4.1, specifically that there are 42 modules rated at 270 W each, the nameplate capacity should be $42 \times 0.270 = 11.34$ kW (0.01134 MW). Please explain this discrepancy.

Answer 2: The facility consists of 16 @ 270 w panels (4.320 kWh) and 26 @ 275w panels (7.15 kWh) for a total of 11.47 kWh.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

12/15/2014 9:08:59 PM

in

Case No(s). 14-1910-EL-REN

Summary: Response Staff Interrogatories - Initial Set electronically filed by Mr. Steven Eisenberg on behalf of Vincent & Julia Randaisi