

Case No. 14-2192-EL-REN  
Rose, Douglas Residence - D Rose  
Staff Interrogatories - Initial Set - Response

Question 1: In Section I of the application, you stated the following:

I.a The nameplate capacity of the entire facility kilowatts (kW): 9.69 (megawatts (MW): 0.00969)

However, 38 panels with an individual rating of 240W (as stated in Section G.4.1) would result in a system nameplate capacity of 9.12kW. Please clarify the nameplate capacity submitted in the application.

Answer 1:

This facility has 38 x AU Optronics - PM250MA0 240 (240W DC, Monocrystalline ACPV Module) panels. Accordingly, the system size should be 9.12 kW, or 0.00912 MW.

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**2/11/2015 3:50:14 PM**

**in**

**Case No(s). 14-2192-EL-REN**

Summary: Amended Application Staff Interrogatories - Initial Set - Response electronically filed by Mr. Steven Eisenberg on behalf of Douglas Rose