



March 19, 2015

Mark Bellamy,

I am writing with regards to staff interrogatories for the following case:

**Case No. 15-0128-EL-REN
Denning-Keith-OH-PV-9kW Residence
Staff Interrogatories – Initial Set**

Question 1: In section N you state that you will using an Enphase Envoy inverter meter as your meter that you will using to report generation data to GATS. Since your facility is greater than 6 kW, the meter that will used to report generation data must be “utility grade.” A utility grade meter is one that conforms to ANSI 12.1 which calls for an accuracy of +/- 2% or better. Please submit documentation that shows that the meter that measures the generation data has an accuracy of +/- 2% or better.

Answer 1: This customer has a dedicated solar meter/utility grade meter in addition to the Enphase Envoy inverter with the following specifications:

Manufacturer: GE

Model Number: GE I-70-S

Serial Number: 83 119 363

Reading: 1747 kWh taken on March 18th, 2015



Please let me know if there is any additional information which you will require for this application.

Best,
Bridget Callahan

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/19/2015 10:41:32 AM

in

Case No(s). 15-0128-EL-REN

Summary: Answer to staff interrogatories electronically filed by Ms. Bridget Callahan on behalf of Keith Denning