

April 21, 2015

Docketing Division  
The Public Utilities Commission of Ohio  
180 East Broad Street, 11<sup>th</sup> Floor  
Columbus, Ohio 43215

**Re: Case No. 15-0360-EL-ESS**

Docketing Division:

Pursuant to Rule 10 of the Electric Service and Safety Standards, Ohio Administrative Code 4901:1-10-10(C), The Dayton Power and Light Company herewith electronically submits amended pages to its Annual Report originally submitted March 31<sup>st</sup>, 2015. Pages 24 and 28 of the submission reported incorrect data that was the result of an electronic database transmission error. The error related to customer minutes interrupted for a transmission outage and did not subsequently modify the Company's final 2014 reliability indices.

Thank you for your assistance and your attention to this matter. If you have any questions please feel free to call me at (937) 259-7906.

Sincerely,

A handwritten signature in blue ink, appearing to read "Robert J. Adams".

Robert J. Adams  
Regulatory Operations

DPL Inc  
Dayton Power and Light Co  
Rule #10  
2014  
Distribution System Reliability Report

6.a. 4901:1-10-10(C)(3)(a) Data Excluding Major Events And Transmission Outages ... Continued ...

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
UG, Const./Dig-Ins	96	1,355	224,200
Unbalance	1	1,495	8,173
Undesired Relay Operation	1	1,915	295,369
Unknown	1,008	27,481	2,879,936
Vandalism	46	436	54,549
Vehicle Accident/Auto Damage	276	33,612	3,845,907
Water/Moisture	2	38	16,397

DPL Inc  
Dayton Power and Light Co  
Rule #10  
2014  
Distribution System Reliability Report

6.c. 4901:1-10-10(C)(3)(c) Data For Transmission Outages Only ... Continued ...

Outage Cause	Events	Customers Interrupted	Customer Minutes Interrupted
Trees Out of ROW	1	2,061	139,530
UG, Const./Dig-Ins	0	0	0
Unbalance	0	0	0
Undesired Relay Operation	0	0	0
Unknown	1	985	33,490
Vandalism	0	0	0
Vehicle Accident/Auto Damage	2	11,086	1,247,505
Water/Moisture	0	0	0

7. 4901:1-10-(C)(4) Momentary Interruptions

Total Number = 756

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/21/2015 3:03:26 PM**

**in**

**Case No(s). 15-0360-EL-ESS**

Summary: Annual Report Amended Annual Report of Electric Distribution System Reliability  
Pursuant to Rule 4901:1-10-10 for the year 2014 electronically filed by Mr. Robert J Adams on  
behalf of The Dayton Power and Light Company