

**Case No. 15-1102-EL-REN
Holcomb Ground Mount System
Staff Interrogatories – Initial Set**

Question 1: In Section G.4 of the application, you have submitted the following:

G.4b Total number of Modules: 60

G.4.1.b Model and Rating: TSM-PC14 (40 - 280W) & (20 - 275W)

In **Section I** of the application, you have submitted the following:

I.a The nameplate capacity of the entire facility kilowatts (kW): 16.80 (**megawatts (MW):** 0.0168

An array consisting of 40 PV panels of 280W individual rating and 20 panels of 275W individual rating, will result in a nameplate capacity of 16700W or 16.70kW. Please clarify the nameplate capacity of the facility.

Answer 1: The inclusion of 16.8 kW was a typographical error and should have been listed as 16.70kW given that the array is consisting of 40 PV panels of 280W individual rating and 20 panels of 275W individual rating, which results in a nameplate capacity of 16700W or 16.70kW

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/18/2015 8:56:50 AM

in

Case No(s). 15-1102-EL-REN

Summary: Answer Reply to Staff Inquiries electronically filed by Mr. Matthew D Holcomb on behalf of Holcomb, Matthew Donald Mr.