



COLUMBUS | CLEVELAND
CINCINNATI-DAYTON
MARIETTA

BRICKER & ECKLER LLP
100 South Third Street
Columbus, OH 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

September 1, 2015

Via Electronic Filing

Ms. Barcy McNeal
Administration/Docketing
Public Utilities Commission of Ohio
180 East Broad Street, 11th Floor
Columbus, OH 43215-3793

Re: NTE Ohio, LLC, OPSB Case No. 14-534-EL-BGN

Dear Ms. McNeal:

The November 24, 2014, Opinion, Order, and Certificate ("Certificate") approving NTE Ohio, LLC ("NTE") Certificate of Environmental Compatibility and Public Need to Construct the Middletown Energy Center established a set of conditions as part of the Certificate.

Within this set of conditions, Condition No. 1 stated:

The facility shall be installed at the Applicant's site as presented in the application, and as modified and/or clarified by the Applicant's supplemental filings and further clarified by recommendations in the Staff Report.

In compliance with Condition No. 1 and the recommendations as set forth in the Certificate and Staff Report, NTE states the following:

- All tree clearing necessary for construction has been accomplished. Thus the tree cutting restrictions listed on page 14 of the Staff Report concerning the Indiana bat habitat are moot;
- NTE's Engineering, Procurement and Construction ("EPC") contractor, Gemma Power Systems, LLC ("Gemma") will install a fire protection and detection system to include fixed water fire suppression systems, fire hose stations, hydrants, portable fire extinguishers, and detection and control systems designed and installed in accordance with National Fire Protection Association standards and insurer's recommendations (Staff Report page 15); and
- NTE will train the local emergency response personnel to be familiar with the facility's emergency response system (Staff Report page 17). Please refer to compliance letter dated September 1, 2015 regarding Condition No. 6.

Thus we believe that NTE is in compliance with the recommendations set forth on pages 14, 15 and 17 of the Staff Report. If you have any questions please call at the number listed above.

Sincerely,

Sally W. Bloomfield

cc: Grant Zeto

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

9/1/2015 4:12:07 PM

in

Case No(s). 14-0534-EL-BGN

Summary: Correspondence of NTE Ohio, LLC in Compliance with Certificate Condition No. 1
Pertaining to Staff Report Recommendations electronically filed by Teresa Orahod on behalf
of Sally Bloomfield