



COLUMBUS | CLEVELAND
CINCINNATI-DAYTON
MARIETTA

BRICKER & ECKLER LLP
100 South Third Street
Columbus, OH 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

October 2, 2015

Via Electronic Filing

Ms. Barcy McNeal
Administration/Docketing
Public Utilities Commission of Ohio
180 East Broad Street, 11th Floor
Columbus, OH 43215-3793

Re: Oregon Clean Energy, LLC
Case No. 12-2959-EL-BGN

Dear Ms. McNeal:

The May 1, 2013 Opinion, Order, and Certificate approving Oregon Clean Energy, LLC's ("Oregon") Certificate of Environmental Compatibility and Public Need to Construct an Electric Generation Facility ("Certificate") and the March 15, 2013 Second Supplement to Application established a set of conditions and supplemental commitments as part of the Certificate.

Specifically, in part, **Commitment No. 20**, which included in the Second Supplement filed on March 15, 2013, requires that:

Prior to the commencement of construction activities that require permits or authorizations by federal or state laws and regulations, the Applicant will obtain and comply with such permits or authorizations. The Applicant will provide copies of permits and authorizations, including all supporting documentation, to Staff within seven days of issuance or receipt by the Applicant. The Applicant will provide a schedule of construction activities and acquisition of corresponding permits for each activity at the preconstruction conference.

Though these permits were not required prior to construction, attached for filing is a copy of the Ohio Department of Transportation Aviation crane permits.

If you have any questions please call at the number listed above.

Sincerely,

Sally W. Bloomfield

Attachment

Cc: Grant Zeto (w/Attachment)
Chris Cunningham (w/Attachment)



OHIO DEPARTMENT OF TRANSPORTATION AVIATION

2829 W. DUBLIN-GRANVILLE ROAD • COLUMBUS, OH • 43235-2786

September 29, 2015

Black & Veatch Corp. - Jason Schottler
11401 Lamar Avenue
Overland Park, KS 66211

Proposal: Temporary Crane
Lat: N41°-40'-3.44"
Lon: W83°-26'-34.05"
Height: 300 ft AGL 890 ft AMSL

Subject: CONSTRUCTION/ALTERATION PERMIT
Aeronautical Study No: 2015-DOT-3265-OE

To Whom It May Concern,

In response to the application received on the above date concerning the proposed construction/alteration described above, a study has been conducted under provisions of Ohio State Law Chapter 119, Section 4561.34 of the Revised Code to determine whether proposed construction would be an obstruction to air navigation. The findings of that study are as follows:

The proposed construction exceeds obstruction standards adopted under Section 4561.32 of the Ohio Revised Code, but will not effect the safe and efficient use of the airports nor effect the safety of persons and property on the ground. However, the following applies to the construction proposed:

☒ [X] Notice is required if the project is abandoned or modified; maximum height 890 feet AMSL.

☒ [X] Obstruction Marking and/or Lighting is required.

☒ [X] The structure should be obstruction marked and lighted per current FAA Advisory Circular (AC 70/7460-1K Change 2) "Obstruction Marking and Lighting".

☒ [X] Required lighting SHALL be maintained in operable condition.

☒ [X] Compliance with the FAA conditions of approval.

This authorization to initiate construction/alteration of the subject proposal expires on March 14, 2017 unless it is extended, revised or terminated by the Ohio State Department of Transportation. This permit does not exempt you from contacting local zoning authorities regarding compliance with local zoning ordinances.

If you have any questions, please call; (614) 466-6804.

Respectfully,

ODOT Office of Aviation
2829 W. Dublin-Granville Road
Columbus, OH 43235



OHIO DEPARTMENT OF TRANSPORTATION AVIATION

2829 W. DUBLIN-GRANVILLE ROAD • COLUMBUS, OH • 43235-2786

September 29, 2015

Black & Veatch Corp. - Jason Schottler
11401 Lamar Avenue
Overland Park, KS 66211

Proposal: Temporary Crane
Lat: N41°-40'-4.54"
Lon: W83°-26'-37.19"
Height: 300 ft AGL 890 ft AMSL

Subject: CONSTRUCTION/ALTERATION PERMIT
Aeronautical Study No: 2015-DOT-3264-OE

To Whom It May Concern,

In response to the application received on the above date concerning the proposed construction/alteration described above, a study has been conducted under provisions of Ohio State Law Chapter 119, Section 4561.34 of the Revised Code to determine whether proposed construction would be an obstruction to air navigation. The findings of that study are as follows:

The proposed construction exceeds obstruction standards adopted under Section 4561.32 of the Ohio Revised Code, but will not effect the safe and efficient use of the airports nor effect the safety of persons and property on the ground. However, the following applies to the construction proposed:

☒ [X] Notice is required if the project is abandoned or modified; maximum height 890 feet AMSL.

☒ [X] Obstruction Marking and/or Lighting is required.

☒ [X] The structure should be obstruction marked and lighted per current FAA Advisory Circular (AC 70/7460-1K Change 2) "Obstruction Marking and Lighting".

☒ [X] Required lighting SHALL be maintained in operable condition.

☒ [X] Compliance with the FAA conditions of approval.

This authorization to initiate construction/alteration of the subject proposal expires on March 14, 2017 unless it is extended, revised or terminated by the Ohio State Department of Transportation. This permit does not exempt you from contacting local zoning authorities regarding compliance with local zoning ordinances.

If you have any questions, please call; (614) 466-6804.

Respectfully,

ODOT Office of Aviation
2829 W. Dublin-Granville Road
Columbus, OH 43235

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/2/2015 9:26:04 AM

in

Case No(s). 12-2959-EL-BGN

Summary: Correspondence of Oregon Clean Energy, LLC in Compliance with Condition No. 20 electronically filed by Teresa Orahod on behalf of Sally Bloomfield