



November 19, 2015

Mahila Christopher

With regard to the staff interrogatories for the following case:

**Case No. 15-1609-EL-REN
McGee -Kevin -PA-PV-7.6kW Residence
Staff Interrogatories – Initial Set**

Question 1: In **Section N** of the application, you stated the following:

N.a The meter(s) that are measuring output from the facility are:

No Inverter Meter(s)

Yes Utility Grade Meter(s)

N.1 Please provide the following information for each meter used in your system.

N.1.a Manufacturer: SMA

N.1.b Serial Number: 41283964

N.1.c Type: CL200

N.1.d Date of Last Certification: June 25, 2011

All facilities that are larger than 6 kW must measure the output of the facility with a utility grade meter (*Must meet ANSI 12.1, or demonstrate an accuracy level of $\pm 2\%$*). Please submit proof that the meter submitted under Section N of the application is utility grade.

Answer 1: Section N should read as follows:

N.a The meter(s) that are measuring output from the facility are:

No Inverter Meter(s)

Yes Utility Grade Meter(s)

N.1 Please provide the following information for each meter used in your system.

N.1.a Manufacturer: Sangamo

N.1.b Serial Number: 41283964

N.1.c Type: CL200

N.1.d Date of Last Certification: June 25, 2011

A photograph of the meter is attached.



Please let us know if you will require any additional information.

Bridget Callahan
SREC Operations Analyst

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

11/19/2015 1:57:08 PM

in

Case No(s). 15-1609-EL-REN

Summary: Answer to staff interrogatory electronically filed by Ms. Bridget Callahan on behalf of Kevin McGee