




**To:** Ohio PUC  
**From:** Page Fenimore, SRECTrade, Inc.  
**Subject:** System expansion for **Schnaus, Cale Residence - C Schnaus**  
**Date:** 12/2/2015

**Case Number:** 14-1664-EL-REN  
**Certification #:** 14-SPV-IN-GATS-0562  
**GATS NON#:** NON90481  
**Effective Date:** October 06, 2015

The **Schnaus, Cale Residence - C Schnaus** facility has added an additional **3.08 kW** capacity to their existing solar facility. The total capacity of the system is now **4.36 kW**. The addition consisted of 11 x Hanwha Q-Cells - Q.PLUS G3 280 at 280 watt panels and 11 x Enphase Energy M250-60-2LL-S2x (-ZC) (-NA) (240 W, 240 Vac inverter S2x are connector types, ZC is mount, NA for North American) inverter. The expansion was interconnected on October 06, 2015. The expansion is utilizing Itron Centron C1S (Serial # 106452100) meter. The addition was completed on October 06, 2015 and the enclosed photo was taken on November 13, 2015. This photo shows the original 5 panels on the top row to the right. It also shows the new 11 panels which are the 3 panels on the top row on the left and the 8 on the bottom row.





Please update your records to reflect the expansion. We will also submit a system change request to GATS. If you need any additional information, please feel free to contact me at the email address below.

Thank you,

A handwritten signature in black ink that reads "Page Fenimore".

Page Fenimore  
Administrative Assistant  
SRECTrade, Inc.  
applications@srectrade.com  
Toll Free Number: (877) 466-4606

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**12/2/2015 10:33:07 PM**

**in**

**Case No(s). 14-1664-EL-REN**

Summary: Amended Application Expansion Application for Schnaus, Cale Residence  
electronically filed by Mr. Steven Eisenberg on behalf of Cale Schnaus