



May 16, 2016

Mahila Christopher,

In regard to the staff interrogatories for the following case, answers are provided below.

**Case No. 16-0380-EL-REN
Hensley-Paula-OH-PV-5.4kw Residence
Staff Interrogatories – Initial Set**

Question 1: In Section N of the application, you have submitted the following:

N.a The meter(s) that are measuring output from the facility are:

No Inverter Meter(s)

Yes Utility Grade Meter(s) (Must meet ANSI 12.1, or demonstrate an accuracy level of $\pm 2\%$)

N.1 Please provide the following information for each meter used in your system.

N.1.a Manufacturer: Enphase

N.1.b Serial Number: This inverter does not have a meter identification number

N.1.c Type: m250

N.1.d Date of Last Certification: January 18, 2016

Please clarify whether the Enphase meter submitted in the application is a 'utility grade meter' (Must meet ANSI 12.1, or demonstrate an accuracy level of $\pm 2\%$) or an 'inverter meter.'

Answer 1: The enphase meter is an inverter meter, not a utility grade meter. There is no utility grade meter installed at this facility

Question 2: In Section N of the application, you have submitted the following:


N.1.e Report the total meter reading number at the time the photograph was taken and specify the appropriate unit of generation (e.g., kWh): 148KWH

However, the meter reading number that is visible in the Section N.1.e photograph is different from this submission. Please clarify the meter reading number submission.

Answer 2: The number in the submission was 747 Wh, so it should actually be less than 1 kWh for the reading.

www.SolSystems.com

Headquarters: 1718 Connecticut Avenue, Suite 300, Washington, DC 20009
San Francisco Office: 343 Sansome Street, Suite 510. San Francisco, CA 94104
P: (202) 349-2085 F: (360) 935-7860 info@solsystems.com



Please let me know if any additional information is required to certify this facility.

Best,
Bridget Callahan
SREC Operations Analyst

www.SolSystems.com

Headquarters: 1718 Connecticut Avenue, Suite 300, Washington, DC 20009
San Francisco Office: 343 Sansome Street, Suite 510. San Francisco, CA 94104
P: (202) 349-2085 F: (360) 935-7860 info@solsystems.com

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

5/16/2016 12:18:34 PM

in

Case No(s). 16-0380-EL-REN

Summary: Answer to staff interrogatories electronically filed by Ms. Bridget Callahan on behalf of Paula Hensley