

**Case No.17-0282-EL-REN
Rodger Diehl
Staff Interrogatories – Initial Set**

QUESTION 1:

In Section G of the application, you have submitted the following :

G.4 SOLAR PHOTOVOLTAIC

G.4a Location of the PV Array: Ground

Description:

G.4b Total number of Modules: 24

G.4.1 PV Modules

For each PV module, provide the following information:

G.4.1.a Manufacturer: Solar World

G.4.1.b Model and Rating: SW245 245 watts

Also, in Section I of the application you have submitted the following:

I.a The nameplate capacity of the entire facility kilowatts (kW): 8.28 (**megawatts (MW):** 0.00828)

A system consisting of 24 panels individually rated at 245W, will result in a total nameplate capacity of 5.880kW (.00588MW). Please clarify the nameplate capacity of the system.

ANSWER 1:

Correct system size is 5.88 kWh

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/21/2017 7:01:32 PM

in

Case No(s). 17-0282-EL-REN

Summary: Reply in the matter of the incorrect system size for the Rodger Diehl application for a renewable energy facility electronically filed by Mr. Gary Lakritz on behalf of Rodger Diehl