



COLUMBUS | CLEVELAND
CINCINNATI | DAYTON
MARIETTA

BRICKER & ECKLER LLP

100 South Third Street
Columbus, OH 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

March 23, 2017

Via Electronic Filing

M. Patrick Donlon
Executive Director,
Ohio Power Siting Board
180 East Broad Street, 6th Floor
Columbus, OH 43215

Ms. Barcy McNeal
Administration/Docketing
Ohio Power Siting Board
180 East Broad Street, 11th Floor
Columbus, Ohio 43215-3793

**Re: Clean Energy Future – Trumbull, LLC
Trumbull Energy Center Electrical Interconnection
Village of Lordstown, Trumbull County, Ohio
Case No. 17-819-EL-BLN**

Dear Mr. Donlon and Ms. McNeal:

This letter serves as Clean Energy Future–Trumbull, LLC’s (“Applicant” or “CEF-T”) pre-application notification letter in order for the Ohio Power Siting Board (“Board”) to open a case for the proposed Trumbull Energy Center Electrical Interconnection (“TEC Electrical Interconnection”) Village of Lordstown, Trumbull County, Ohio. This letter is given at least five (5) days prior to CEF-T’s filing of a Letter of Notification.

In accordance with Ohio Administrative Code (“OAC”) Rule 4906-6-03(A), CEF-T provides the following information:

Project Description: The TEC Electrical Interconnection will interconnect CEF-T’s Trumbull Energy Center (“TEC”) to an existing FirstEnergy Corporation 345-kilovolt transmission line. The TEC Electrical Interconnection consists of the three consolidated generator leads that will extend from TEC’s on-site switchyard (“TEC Collector Bus”) approximately 0.25-mile within a 100-foot wide right-of-way (the Interconnection ROW) supported on three vertical, monopole dead-end structures; and the new 3-breaker ringbus, proposed on approximately four (4) acres of land located adjacent to the FirstEnergy 345-kV Highland-Hanna circuit (the Utility Switchyard), into which the generator leads interconnect. The generator leads extend south approximately 200 feet from TEC’s on-site bus yard to a dead-end structure (P1), then turn east approximately 500 feet to a dead-end structure located just north of the Mud Creek wetlands and floodplain (P2). The generator leads will span wetland resources associated with Mud Creek, thereby avoiding direct impact; the span extends southeasterly approximately 300 feet to a dead-end structure southeast of Mud Creek (P3), before extending east approximately 300 feet and entering the Utility Switchyard. An access road from the TEC site will provide access to P1 and P2, while an access road extending north from Hallock

March 23, 2017

Case No. 17-819-EL-BLN

Page 2

Young Road will provide access to P3, thereby avoiding the need to cross Mud Creek; a separate access road will extend north from Hallock Young Road to the Utility Switchyard. The TEC Electrical Interconnection will be capable of delivering the TEC's maximum gross 940-megawatt (MW) capacity to the FirstEnergy 345-kV Highland-Hanna circuit.

Anticipated Project Schedule: Construction of the TEC Electrical Interconnection is expected to begin in the fourth quarter of 2017 and is scheduled to be in-service by the fourth quarter of 2019 (prior to the TEC's in-service date of June 1, 2020 to allow for backfeed availability).

Sincerely on behalf of
CLEAN ENERGY FUTURE – TRUMBULL, LLC



Sally W. Bloomfield

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/23/2017 4:34:49 PM

in

Case No(s). 17-0819-EL-BLN

Summary: Text In the Matter of Clean Energy Future—Trumbull, LLC's Pre-application letter for the Trumbull Energy Center Electrical Interconnection electronically filed by Teresa Orahod on behalf of Sally W. Bloomfield