

Case No.17-0142-EL-REN
Tippett-Steve-OH-PV-9.1kW Residence
Staff Interrogatories – Initial Set

QUESTION 1:

In Section G of the application, you have submitted the following :

G.4 SOLAR PHOTOVOLTAIC

G.4a Location of the PV Array: Roof

Description:

G.4b Total number of Modules: 34

G.4.1 PV Modules

For each PV module, provide the following information:

G.4.1.a Manufacturer: Suniva

G.4.1.b Model and Rating: 270-60-4-IBO & 270

Also, in Section I of the application you have submitted the following:

I.a The nameplate capacity of the entire facility kilowatts (kW): 9.10 (megawatts (MW): 0.0091)

A system consisting of 34 panels individually rated at 270W, will result in a total nameplate capacity of 9.180kW (.00918MW). Please clarify the nameplate capacity of the system.

ANSWER 1:

The correct nameplate capacity for this system is 9.18 kW.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

3/30/2017 9:33:41 AM

in

Case No(s). 17-0142-EL-REN

Summary: Reply reply to staff inquiries electronically filed by Mr. Avery Sellers on behalf of Steve Tippet