

**BEFORE
THE PUBLIC UTILITIES COMMISSION OF OHIO**

In the Matter of the Joint Application)	
of Ohio Power Company and)	Case No. 17-0043-EL-EEC
Sofidel America for Approval)	
of a Special Arrangement Agreement)	

**JOINT APPLICATION FOR APPROVAL OF A SPECIAL ARRANGEMENT
AGREEMENT BETWEEN OHIO POWER COMPANY AND
SOFIDEL AMERICA**

Pursuant to Ohio Revised Code (“R.C.”) sections 4928.66 and 4905.31(E) and Rule 4901:1-39-05(G), Ohio Administrative Code (“O.A.C.”), Ohio Power Company d/b/a AEP Ohio (“Company”) and Sofidel America (“Customer”) (collectively, “Applicants”) submit this Joint Application for Commission approval of the special arrangement described in this Joint Application and accompanying attachments whereby Customer allows combined heat and power (“CHP”) energy efficiency (“EE”) resources to count toward the Company’s compliance with the EE benchmarks set forth in Amended Substitute Senate Bill 221.

Amended Substitute Senate Bill 221 sets forth in R.C. 4928.66 EE benchmarks that electric distribution utilities shall be required to meet or exceed. The statute allows utilities to include EE resources committed by mercantile customers for integration into the utilities programs to be counted toward compliance with a utility’s EE benchmarks. The statute also enables the Commission to approve special arrangements for mercantile customers that commit EE resources to be counted toward compliance with a utility’s EE benchmarks. Further, the statute specifically allows CHP to be an eligible EE resource

and requires the Commission to estimate or approve the estimation methodology herein of the CHP project EE savings, the approved EE Plan allows the CHP project to be counted with incentives determined by the Company and the statute authorizes the Commission to take actions necessary to administer the implementation of existing portfolio plans as this Joint Application is requesting. The Company is an electric distribution utility as defined in R. C. 4928.01(A). The Customer is a Mercantile customer as defined in R.C. 4928.01(A)(19).

In its application to the Company, the Customer has agreed to commit the EE resources identified in this Joint Application to the Company's compliance toward the EE benchmarks in Amended Substitute Senate Bill 221.

The Company has worked with the Customer extensively to develop this project starting late 2016 and will continue to support the Customer's decision to move forward and implement this project in 2018 (the project is not yet in service). The Company has reviewed the details submitted in this Joint Application and based upon a thorough review of the available records believes that the project planned in this Joint Application satisfies the requirements in R.C. 4928.66, meets all existing Company EE Plan requirements as a CHP project and furthers the State of Ohio's policy goals of reducing energy costs in a highly cost effective manner. Further, approval of this application can help reduce costs to all customers due to the project's relative size, energy and demand savings and associated net benefits generated.

This CHP project is a prospective project and eligible under Company's approved EE Program Portfolio Plan, as such the project and costs are already identified as part of the EE and PDR portfolio costs. CHP is allowed by statute to count as an EE resource. This cost effective technology is subject to the Commission's approval of the methodology for and estimation of energy savings as required by

statute. The incentive amounts and strategy provided by the Joint Applicants is determined by the Company based on energy savings and approved by the Commission through the EEC Application process.

Exhibit 1 with attachments (Application to Commit Combined Heat and Power System) to this Joint Application includes a project overview that outlines the project, customer size, project installation date, estimated EE savings resulting from the project, eligible incentive, and the cost effectiveness of the project. Exhibit 1 also provides the signature of the Customer indicating the validity and acceptance of the information, the Customer's support of this Joint Application, and the Customer's intent to participate in the program. The Applicants attest to the fact that the program in this Joint Application complies with the presumption that the mercantile projects are part of a demand response, energy efficiency, or peak demand reduction program to the extent the project either provides for early retirement of functioning equipment which is not yet fully depreciated, or achieves reductions in energy use and peak demand that exceed the reductions that would have occurred had the customer used standard new equipment, to the extent standard is defined by current code or statute.

Consistent with the requirements of Rule 4901:1-39-05(G), O.A.C., Applicants agree that approval by the Commission of the Joint Application will result in an arrangement that: 1) addresses coordination requirements between the electric utility and the mercantile customer with regard to voluntary reductions in load by the mercantile customer, which are not part of an electric utility program, including specific communication procedures, if necessary; 2) grants permission to the electric utility and Commission staff to measure and verify the EE savings resulting from customer-sited projects and resources; and 3) identifies all consequences of noncompliance by the customer with the terms of the commitment. Exhibit 2

(Energy Efficiency Resource Commitment Agreement) is a copy of the formal agreement that commits the Customer's project for integration into the Company's programs to be counted toward compliance with the Company's EE benchmarks and reflects the "Rules and Requirements" agreed to by the Customer.

The Customer has provided the Company documentation necessary to calculate energy and demand savings resulting from the project described in Exhibit 1 and the accompanying attachments. The Company uses methodologies, protocols and/or practices that conform to the general principles of the International Performance Measurement Verification Protocol (IPMVP) in order to justify the energy savings. In the case of this Combined Heat and Power (CHP) project submittal, the Company will rely on the initial estimate of electricity produced by the CHP system and verify those as savings to be counted using the metered electricity production as the measurement of the energy efficiency and demand reduction savings committed to Company.

As shown in Exhibit 1, the Customer must comply with any Commission requirement to provide an annual report on the energy savings and electric utility peak- demand reduction. However, the Customer has agreed and the Company will file as part of its annual EE/PDR Portfolio Status report each year the metered electrical demand and energy production which is equivalent to the energy and demand savings from this project, relieving the Customer of a separate filing requirement if the Commission so approves.

Due to the large size of this project and potential for reducing opportunities other customers may have to participate in energy efficiency programs and to reduce total portfolio program costs over the next two years, the Company requests to count half of the energy and demand savings toward its EE compliance benchmark in 2019 and the

remaining half counted toward its EE compliance benchmark in 2020. In addition, splitting the energy efficiency and demand reductions in two years is supported by revised code 4928.66 (B), which states: "For purposes of a waste energy recovery or combined heat and power system, an electric distribution utility shall not apply more than the total annual percentage of the electric distribution utility's industrial-customer load, relative to the electric distribution utility's total load, to the annual energy efficiency savings requirement." The Company believes it is prudent to split the 100 GWh in annual savings between 2019 and 2020, counting approximately 50 GWh each year to provide opportunities for other customers' CHP projects. The Company expects to file additional projects based on interest received. Approval of this project by the Commission may also further spur interest. Allowing the counting of this large project in this manner maintains opportunities for other customers. Splitting the savings reduces the allowable savings, while maintaining significant opportunities for other customers in 2019 and 2020. Further, splitting the EE savings provides overall cost saving opportunities for all commercial and industrial customers in each year.

Shared Savings for CHP project is clearly allowed and will be counted in the same manner as identified in Case No. 16-0574-EL-POR, recognizing that the Company has an approved EE and PDR Program Portfolio Plan in accordance with amended substitute SB 310. The Company is requesting that the Commission affirm the Company's interpretation that shared savings is allowed for this project. Further, the Company is requesting that shared savings be split in a similar manner as the EE savings with half the shared savings from this project counted in 2019 and the remaining half counted in 2020, in order to directly lower overall energy efficiency plan costs in both 2019 and 2020 for commercial and industrial customers specifically and all customers generally. If all the EE savings and shared savings are counted in 2019 for this large

project, the opportunity is lost to also reduce costs overall in 2020, as the Company will continue to work toward reaching EE savings goals and meeting shared savings goals. Further, opportunities for other commercial and industrial customers will be more limited in 2019 due to the size of this project. Without a split of EE savings and shared savings in 2019 and 2020, the Company will need to spend more than necessary to meet EE savings requirements and achieve shared savings goals in 2020. In addition, counting this large project one hundred percent in 2019 can lead to ramping down commercial and industrial programs in 2019 and then ramping back up to reach goals in 2020, which could raise acquisition costs unnecessarily. This outcome would not be favorable for customers and can be avoided with the requested split.

In Case No. 16-0574-EL-POR, the Stipulation allows counting of shared savings only one time and in the year in which the savings are generated. Shared savings will only be counted once (no double counting) and the CHP project does physically generate the savings each year, providing the Commission flexibility to count the shared savings in a method other than in the year in which the project is completed for this limited exception due to the benefits it provides for all customers. Splitting the shared savings between 2019 and 2020 conforms to all requirements of the Stipulation.

Approval of this project with the customer incentives provided and inclusive of shared savings has the potential to reduce overall costs to achieve energy and demand savings for 2019 and 2020, thereby reducing costs for all customers. This Joint Application is contingent upon the Company receiving approval of shared savings at 100% subject to the cap, calculations shown in Exhibit 3.


For these reasons, the Applicants request that the Commission approve the Joint Application and the Company's methodology for estimating EE savings and applying the Customer's energy efficiency resources to the Company's energy and

demand benchmarks as identified in SB 221 and support the Company's authority to determine and pay the CHP program incentive payment as defined in Exhibit 2 and the EE savings and shared savings split counting methodology outlined in the Joint Application.

As demonstrated above, approval of this is permitted under the Company's existing EE/PDR Portfolio Plan. More specifically, all costs associated with this Application will be recovered as a part of the CHP Program under the 2017 EE/PDR Portfolio Plan. The costs recovered in this Application will reduce program costs in the Business programs portion of the EE/PDR Portfolio Plan. Upon approval, the agreement will be implemented and the Company will reflect the cost recovery and any cost savings as part of the EE/PDR Rider.

While the Company retains the right to respond to any objections or comments that maintain otherwise, the incentives specified are acceptable to the Company and the Customer and should be considered for approval by the Commission.

Respectfully submitted,



Steven T. Nourse
American Electric Power Service Corporation
1 Riverside Plaza, 29th Floor
Columbus, Ohio 43215
Telephone: (614) 716-1915
Email: stnourse@aep.com
Counsel for Ohio Power Company

EXHIBIT 1

Case No.: 17-0043- EL-EEC

Mercantile Customer: Sofidel America

Electric Utility: American Electric Power (AEP) – Ohio Power Company

Program Title or

Description: Sofidel America Tornado Combined Heat and Power

Ohio Revised Code (O.R.C.) 4928.66 (A) (1) (a), allows that an electric utility's energy efficiency program may include a combined heat and power (CHP) system. The following application form is to be used by mercantile customers, either individually or jointly with their electric utility, to apply for commitment of such programs.

Complete a separate application for each customer program. Projects undertaken by a customer as a single program at a single location or at various locations within the same service territory should be submitted together as a single program filing, when possible. Check all boxes that are applicable to your program. For each box checked, be sure to complete all subparts of the question, and provide all requested additional information. Submittal of incomplete applications may result in a suspension of the automatic approval process or denial of the application.

Any confidential or trade secret information may be submitted to Staff on disc or via email at ee-pdr@puc.state.oh.us.

Section 1: Mercantile Customer Information

Name:

Principal Address:

25910 US 23

Circleville, Ohio 43113

Address of facility for which this energy efficiency program applies:

25910 US 23

Circleville, Ohio 43113

Name and telephone number for responses to questions:

Andrea Wong – Process Engineer

Mobile: 918-934-7994

E-mail: Andrea.Wong@sofidelamerica.com

Electricity use by the customer (check the box(es) that apply):

- ☒ The customer uses more than seven hundred thousand kilowatt hours per year at the above facility. (Please attach documentation.)
- ☐ The customer is part of a national account involving multiple facilities in one or more states. (Please attach documentation.)

Section2: Application Information

A) The customer is filing this application (choose which applies):

- ☐ Individually, without electric utility participation.
- ☒ Jointly with the electric utility.

B) The electric utility is: Ohio Power Company (AEP Ohio)

Section 3: Request for Cash Payment Reasonable Arrangement (Option 1) or Exemption from Rider (Option 2)

Under this section, check the box that applies and fill in all blanks relating to that choice.

A) The customer is applying for:

☒ Option 1: A cash payment reasonable arrangement.

OR

☐ Option 2: An exemption from the energy efficiency cost recovery mechanism implemented by the electric utility.

B) The value of the option that the customer is seeking is:

Option 1:

☒ A cash payment of \$0.007 per net kWh for 5 years capped at \$400,000 per year for each plant. The estimated annual incentive at this rate for the two plants is \$700,000.

Sofidel and AEP Ohio have agreed to count each CHP installation as separate projects since they are separate systems, can operate independently and are starting up on different dates. However a lower project cap has been agreed upon to reduce overall costs and encourage additional participants in the program.

Option 2: An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider.

☐ An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for ____ months (not to exceed 24 months). (Attach calculations showing how this time period was determined.)

OR

☐ Ongoing exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for an initial period of 24 months because this program is part of the customer's ongoing efficiency program. (Attach documentation that establishes the ongoing nature of the program.) In order to continue the exemption beyond the initial 24 month period, the customer will need to

provide a future application establishing additional energy savings and the continuance of the organization's energy efficiency program

Section 4: Cost Effectiveness

The CHP system is cost effective because it has a benefit/cost ratio greater than 1 using the (choose which applies):

1. Total Resource Cost Test (TRC). The calculated TRC value is: _____
(Continue to Subsection 1, then skip Subsection 2)
2. Utility Cost Test (UCT). The calculated UCT value is: 26.1_ (Skip to Subsection 2.)

Subsection 1: TRC Test Used (please fill in all blanks).

The TRC value of the CHP system is calculated by dividing the value of our avoided supply costs (generation capacity, energy, and any transmission or distribution) by the sum of our program overhead and installation costs and any incremental measure costs paid by either the customer or the electric utility.

Subsection 2: UCT Used (please fill in all blanks).

We calculated the UCT value of our CHP system by dividing the value of our avoided supply costs (capacity and energy) by the costs to our electric utility (including administrative costs and incentives paid or rider exemption costs) to obtain our commitment.

Section 5: Combined Heat and Power System Information

Additional information to clarify or supplement this Application may also be requested by Staff. Please fill out this form and attach the following supporting documentation to this application:

Criteria 1: CHP Efficiency Level

Ohio Revised Code (ORC) Sec. 4928.01(40)

- 1) State the overall combined heat and power (CHP) systems' efficiency level and describe how it was determined.
The CHP overall efficiency is 79.7%, based on LHV (Lower Heating Value). See Exhibit 1 Attachment 1

Criteria 2: Amount of Useful Thermal Energy

Ohio Revised Code (ORC) Sec. 4928.01(40)

- 1) State the systems' amount of thermal energy produced.
The systems' useful thermal energy produced is 874,875 MMBtu/yr for 2 CHP assuming the heat exchangers are off (not winter) and both paper mills are running the same grade.

There are two CHP plants on the site.

For 1 CHP plant and a designated paper grade:

Steam produced is 27,748 lb/hr at 406F or 1202 Btu/lb. The steam returned is 18,570 lb/hr at 250F or 218.3 Btu/lb. The remaining 9295 lb/hr make up water is supplied from wells at 70F or 381.7 Btu/lb.

Assume there is an average of 730 hrs/month (8760 hrs/yr).

However, it is assumed that there is 240 hours of maintenance or downtime (Co-generation is OFF). Then actual worked hours the co-generation is 8520 hours/yr.

Energy Provided = 27,748 lb/hr * 1202 Btu/lb = 33.35 MMBtu/hr

Returned = 18,570 lb/hr * 218.3 Btu/lb = 4.05 MMBtu/hr

Make-up = 9295 lb/hr * 381.7 Btu/lb = 3.55 MMBtu/hr

Useful thermal energy from Turbine Exhaust is 7500 kW

Energy from Exhaust = 7500 kW * 3412.142 Btu/hr/kW = 25.59 MMBtu/hr

Useful Thermal Energy Supplied for 1 CHP = Energy Provided – Returned –
Makeup + Energy from Exhaust = 51.34 MMBtu/hr = 437,437 MMBtu/yr

Total Useful Thermal Energy for 2 CHP = 874,875 MMBtu/yr

The values may vary since these values are for one type of paper (or "grade"). In this particular example, the values are for the designed grade.

- 2) State the systems' use for that thermal energy (e.g. domestic hot water, process hot water, process steam, space heating, absorption chiller, etc.)
The system is used to provide steam for the paper mill plant for process heat and providing electricity needs for the plant.

Criteria 3: Service Date

Ohio Revised Code (ORC) Sec. 4928.66 (A)(1)(a)

- 1) Provide the date that the system was or will be placed into service.
The system is expected to be placed into service on March 2018 for one CHP facility (CHP1) and October 2018 for the second CHP facility (CHP2). The 12 month implementation meter readings are expected to begin November 15, 2018.
- 2) Provide the date that the system was retrofitted and describe the retrofit (if applicable).
Not available.

Section 6: Additional Information

Please attach the following supporting documentation to this application:

- A copy of the formal declaration or agreement that commits the program or measure to the electric utility, including:
 - 1) any confidentiality requirements associated with the agreement;
 - 2) a description of any consequences of noncompliance with the terms of the commitment;
 - 3) permission by the customer to the electric utility and Commission staff and consultants to measure and verify energy savings and/or peak-demand reductions resulting from your program; and
 - 4) a commitment by the customer to provide an annual report on your energy savings and electric utility peak-demand reductions achieved.
- A description of all methodologies, protocols, and practices used or proposed to be used in measuring and verifying program results. Additionally, identify and explain all deviations from any program measurement and verification guidelines that may be published by the Commission.

1. SYSTEM DESCRIPTION

Provide a description of the Combined Heat and Power (CHP) system.

- a. Describe the technology/configuration, e.g. Combustion Gas Turbine, Power Boiler with Steam Turbine, Reciprocating engine(s) or other.

The CHP system consists of two cogeneration plants (CHP1 and CHP2) that will mirror each other as much as possible. Each cogeneration plant will have a Solar Taurus 70 gas turbine (GT) that will exhaust into a plenum that will be used in the hoods for the paper machine drying process or into a mixer that then the exhaust gas will go to a heat recovery steam generator (HRSG). The GT will have an extended duct for possible addition of a selective catalytic reduction (SCR) system.

The exhaust from the Yankee hoods will then enter the HRSG that will be capable of duct firing to produce steam for normal operating conditions. The auxiliary boiler will supplement the remaining necessary steam.

In normal operation, two HRSGs and one auxiliary boiler will be running to produce the necessary steam for the two paper machines. The second auxiliary boiler will be used as a backup. The auxiliary boilers will alternate when they will be in operation.

- b. Describe the type of business/facility that will benefit from the useful thermal energy to be supplied by the cogeneration. Include a description of how the thermal energy will be used throughout a representative year and whether there are any hourly, daily or seasonal variations in thermal demand. If applicable, describe the system replaced by the CHP facility.

Sofidel America, a Sofidel's US subsidiary, will be starting up two new tissue machines and converting plant in our Greenfield plant currently under construction in Circleville, OH. The CHP will be providing steam to the tissue machines, and electricity to the paper mill plant.

There will be variations in thermal demand due to our process (different grade of paper needs different thermal demand) and seasonal variations (peaks during the winter).

2. EQUIPMENT DESCRIPTION

Provide a complete equipment description for all major components including: Combustion Turbine Generator, Steam Turbine Generator, HRSG, plant control system, air emissions control equipment, cooling system, major pumps, water treatment system, fuel storage facilities, etc.

- a. Equipment manufacturer/model/date of manufacturer.

There will be two CHP facilities, mirror-image of each other. The following list is for one CHP facility.

- Gas Turbine (GT) – Solar 70 Taurus generator package by Solar Turbines – The gas turbine is a Solar Taurus 70 expected to generate 7.5 MW at 59F. The

generator (Serial No 41998) will be manufactured by Kato Engineering (Siemens Industrial Automation). The gas turbine is expected to be manufactured in 2017. The CHP system design, if necessary, can accommodate a future selective catalytic reduction (SCR) system and aqueous ammonia as reductant for the SCR. The SCR can be placed after the GT. The exhaust gas will be expelled to an exhaust plenum that will provide make-up air to the Yankee hood system of the paper machine and/or to a mixer where the gas will go directly to the HRSG.

- Heat Recovery Steam Generator (HRSG) – Victory Energy – The HRSG will be manufactured by Victory Energy and is expected to be completed in 2017. Exhaust air from the paper mill process will enter an exhaust mixer and will be used in the HRSG. In designed conditions, the HRSG will be able to supply 15,039 lb/hr of steam, and up to a maximum of 22,442 lb/hr of steam of 250 psig saturated steam.
- Auxiliary Boiler – Victory Energy – The auxiliary boiler is a package boiler that will be ideally utilized 50% of the time and will take turn in providing the remaining necessary steam for the two paper machines with the other auxiliary boiler in the other CHP facility. Each boiler can supply up to 37,747 lb/hr (nominal) of 250 psig saturated steam at 65F ambient temperature.
- Deaerating Feedwater System – Superior Boilers, Model MSTCO40D290-260 – The deaerator will be supplied by Superior Boilers and manufactured in 2017. It is a pressurized tray type deaerator for 40,000 lb/hr used for two boilers (HRSG and aux boiler) at 260 psig operating pressure. It has a 1200 gallon storage tank (15.8 minutes).
 - The feedwater pumps are two centrifugal pumps by Grundfoss Model CR32-11-2.
- Water Treatment system
 - Softener and Reverse Osmosis (RO) systems will be in use to remove impurities and soften the water before going into the DA feedwater system and to the boilers. The softener and RO systems will be provided by Marlo, Inc. The softener will be a twin alternating water softener (model MRG-900-3) and the RO system will be model MRO-58K-8H.
- Fresh Air fans
 - There will be two fans provided by Valmet that will be providing fresh air into the duct (before the plenum or mixer) to lower the temperature (to process temperature level) of the exhaust gas sent by the turbine.
- 2 Hoods – Although the hoods are not in the CHP building, they are part of recovering the exhaust gas from the turbines and their exhaust gas will be sent to a mixer which then will go to the HRSG. Valmet will be providing the hoods.
- Heat Exchangers
 - There will be four steam heat exchangers provided by Valmet that will be used as heat recovery units to provide heat in the ventilation system during winter.

- Plant Control System: The DCS controllers are from Siemens.

3. OPERATION MODES

- a. Describe and list the major operating modes of the CHP system and projected time period (per annum) that each mode will be utilized.
The CHP system is expected to be in operation 8520 hours of the year in normal conditions. Normal operation consists of utilizing both turbines and HRSGs with additional steam input from one auxiliary boiler at the same time. The second auxiliary boiler will be there as backup in case the HRSGs or the operating auxiliary boiler have unplanned shut downs or have planned maintenance. The remaining 240 hours of the year consists of the CHP starting up, maintenance shut down, HRSG by-pass, and/or turbine by-pass. The turbines will still be able to run and supply electrical power to the plant even if the HRSGs are shut down.
- b. Will the system include a “thermal dump”?
 - i. A “thermal dump” refers to a sub-system of the CHP that rejects heat allowing the system to generate electricity during periods when the full useful thermal output of the heat recovery system cannot be transferred due to insufficient demand.
There will be steam vents and by-pass stacks.

4. PROCESS FLOW DIAGRAM

- a. Provide a process flow diagram for each major operating mode.
See Exhibit 1 Attachment 2
- b. Include locations for all meters.
See Exhibit 1 Attachment 2

5. MATERIALS AND ENERGY BALANCE DIAGRAMS

- a. For each fuel, include the flow (lb/hr), temperature (F), pressure (psia), and enthalpy (BTU/lb) for all water, steam combustion air, and fuel streams entering and exiting the boundaries of the generating unit and of each major equipment component.
See Exhibit 1 Attachment 1

6. ELECTRICAL

- a. ELECTRICAL GENERATOR
 - i. Manufacturer/Model Number/Output Volts/Capacity
Kato Engineering (part of Solar Turbines GT package)/SN41998/12470V/7292kW

- b. Is the generation unit designed or approved to export power onto the electric grid?

No, it is not designed to export power onto the electrical grid.
There will be some "unintentional" export capability.

This is only for rare cases; for example when the paper machine(s) suddenly shuts down and our generators are still running. If exporting does happen, it is expected to be a maximum net export capability of 6 MW for both generators, in a short period of time; afterwards the relay will trip due to having reverse power relay.

See Exhibit 4 Interconnection Application for more information

- c. Does the generation unit has either an approved interconnection plan or submitted an application to the local distribution utility company requesting permission for an interconnection?

The application has been submitted on Nov 30th, 2016. It was received on Dec 5th, 2016.

- d. Provide a single line electrical distribution and interconnection diagram.
In the Interconnection Package

7. METERING

Provide the following information for each meter of the CHP facility. Include locations for all meters on process flow diagram.

a. Fuel Meters for HRSGs and Aux Boilers

- i. Meter Type: Coriolis Flow Meter
- ii. Manufacturer: Rosemount
- iii. Model:
- iv. Is it a revenue grade meter?
- v. What is the guaranteed accuracy (in %) of the meter?

b. Fuel Meter for Turbines

- vi. Meter Type: Mass Flow Meter
- vii. Manufacturer:
- viii. Model:
- ix. Is it a revenue grade meter?
- x. What is the guaranteed accuracy (in %) of the meter?

c. BTU Meters

- i. Meter Type
- ii. Manufacturer
- iii. Model
- iv. Is it a revenue grade meter?
- v. What is the guaranteed accuracy (in %) of the meter?

d. Steam Meters

- i. Meter Type: Steam Flow Transmitter with orifice, 3-way valve
- ii. Manufacturer: Rosemount
- iii. Model:
- iv. Is it a revenue grade meter?
- v. What is the guaranteed accuracy (in %) of the meter?

e. Electric Meters

- i. Meter Type
- ii. Manufacturer
- iii. Model
- iv. Is it a utility grade meter? (i.e. in compliance with paragraph B of rule 4901:1-10-05 of the Ohio Administrative Code) Yes
- v. What is the guaranteed accuracy (in %) of the meter?



**Public Utilities
Commission**

Application to Commit
Combine Heat and Power System
(Mercantile Customers Only)

Case No.: 17-0043-EL-EEC

State of Florida :

Philippe AUGER, Affiant, being duly sworn according to law, deposes and says that:


1. I am the duly authorized representative of:

SOFDEL AMERICA CORP.
(insert customer or EDU company name and any applicable name(s) doing business as)

2. I have personally examined all the information contained in the foregoing application, including any exhibits and attachments. Based upon my examination and inquiry of those persons immediately responsible for obtaining the information contained in the application, I believe that the information is true, accurate and complete.


Signature of Affiant & Title

Sworn and subscribed before me this 10 day of April, 2017 Month/Year


Signature of official administering oath

Jorge A. Altieri
Print Name and Title

My commission expires on February 7, 2018





EXHIBIT 1

ATTACHMENT 1



Efficiency	8520	h				
COGEN OFF and paper mill running	240	h				
PCI gas Valmet	33914	kJ/Nm3	36	MJ/Sm3	10.02	kWh/Sm3
PCI gas Columbia	35.68	MJ/Sm3				
	9.99	kWh/Sm3				
Enthalpy Steam 18 bar	2,795	KJ/kg-vap	→	2419.241	KJ/kg-vap	
Enthalpy Condensate 1 bar	417.51	KJ/kg-cond			product	
Enthalpy Steam 1 bar	743	KJ/kg-vap				
Boiler efficiency	0.84					
Tot. Electricity	10,000.00	kW				

Grade	T70						
	Plein 14	Plein 16,5	Plein 35	Text 14	Text 16,5	Text 19	
ADTPD	181.80	214.30	296.60	163.70	192.90	200.50	ton/day
Steam to Yankee	7,130.00	8,855.00	8,855.00	7,475.00	7,475.00	7,475.00	kg/h
Steam to Box	2,273.00	2,679.00	3,708.00	2,046.00	2,411.00	2,506.00	kg/h
Total steam	9,403.00	11,534.00	12,563.00	9,521.00	9,886.00	9,981.00	kg/h
Tot steam	18,937.21	23,411.91	24,176.09	19,603.27	19,874.33	19,944.88	MJ/h
Tot gas for steam	631.85	781.15	806.64	654.07	663.11	665.47	Sm3/h
Tot gas for steam (normal conditions)	762.52	762.52	762.52	762.52	762.52	762.52	Sm3/h
Tot gas for steam	6,312.40	7,803.97	8,058.70	6,534.42	6,624.78	6,648.29	kW
Tot gas for steam Valmet	6,300.00	7,728.00	8,417.00	6,379.00	6,624.00	6,688.00	kW
HP steam COG ON from recovery boiler	4,210.00	4,180.00	3,280.00	3,200.00	3,330.00	3,290.00	kg/h
	3,922.32	3,894.37	3,055.87	2,981.33	3,102.45	3,065.18	kW
Gas for missing HP steam COG ON-gasBoiler	1,956.00	3,132.00	3,735.00	2,864.00	2,777.00	2,804.00	kW
Gas for hood burners COG OFF	4,928.00	5,015.00	7,500.00	5,898.00	7,455.00	7,455.00	kW
Gas for burners COG ON	0.00	0.00	1,354.00	0.00	1,444.00	1,348.00	kW
Tot Electricity	10,000.00	10,000.00	10,000.00	10,000.00	10,000.00	10,000.00	kW
Electricity produced	7,518.00	7,518.00	7,518.00	7,518.00	7,518.00	7,518.00	kW
Δ Electricity	-2,482.00	-2,482.00	-2,482.00	-2,482.00	-2,482.00	-2,482.00	kW
Gas for turbine @15C/59F	22,033.09	22,033.09	22,033.09	22,033.09	22,033.09	22,033.09	kW
Gas for turbine (normal conditions @ 15C)	22,598.63	22,598.63	22,598.63	22,598.63	22,598.63	22,598.63	kW
Co-Gen Efficiency	76.4%	79.0%	83.3%	78.4%	80.5%	80.8%	79.7%




EXHIBIT 2

CUSTOMER COMBINED HEAT AND POWER
ENERGY EFFICIENCY AND PEAK DEMAND REDUCTION
RESOURCE COMMITMENT AGREEMENT

This Customer Combined Heat and Power Resource ("CHP") Energy Efficiency and Peak Demand Reduction ("EE/PDR") Commitment Agreement ("Agreement") is entered into by and between Ohio Power Company ("Company") and Sofidel America. ("Customer").

In consideration of the mutual covenants, terms and conditions set forth herein, Company and Customer hereto agree as follows:

1. **Commitment:** Customer agrees to commit their prospective planned CHP System electricity generation to Company's energy efficiency and peak demand reduction requirements. CHP projects may count toward meeting energy efficiency and peak demand reduction requirements as allowed under Ohio Amended Substitute Senate Bill 310.
2. **CHP System Description:** The CHP system consists of two cogeneration plants (CHP1 and CHP2) that will mirror each other as much as possible. Each cogeneration plant will have a Solar Taurus 70 gas turbine (GT) that will exhaust into a plenum that will be used in the hoods for the paper machine drying process. The GT will have an extended duct for possible addition of a selective catalytic reduction (SCR) system.
The exhaust from the Yankee hoods will then enter the heat recovery steam generator that will be capable of duct firing to produce steam for normal operating conditions. The auxiliary boiler will supplement the remaining necessary steam.
In normal operation, two HRSGs and one auxiliary boiler will be running to produce the necessary steam for the two paper machines. The second auxiliary boiler will be used as a backup. The auxiliary boilers will alternate when they will be in operation.
3. **Economic Analysis:** The expected customer savings over the life of the project is \$81,646,242 (present value). The cost savings is for both capacity and avoided energy charges but does not include hot water savings.
4. **CHP System Life or CHP supplier Contract Term:** 20-year CHP system life
5. **CHP System efficiency and expected % availability:** 79.7% efficiency and 100% available with the exception of unexpected downtime and maintenance.
6. **Percentage of total usage offset by the CHP system:** The plants that the CHP system will supply are new construction. Approximately 75% of the expected electrical usage (provided by electrical grid through AEP transmission/distribution lines) will be replaced by this new COGEN installation.

7. **Planned annual MWh and MW generation provided from the CHP system and counted as 100% energy and demand savings committed to AEP Ohio:** 15,000 KW; 100,000,000 kWh per year
8. **Economic Benefits:** Utility Cost Test benefit/cost ratio is 26.1. Total net benefits of this project are \$158,634,298 in avoided generation and transmission costs net of Company costs. This project is highly cost effective and compares very favorably to other energy efficiency projects by delivering energy and demand savings at a significantly lower cost than typical projects and the portfolio plan as a whole.
9. **Contract Term:** 5 years
10. **Anticipated commissioning date and full scale start-up of operation that will initiate contract start date:** Full-scale COGEN plant start-up planned in March (CHP1) and October 2018 (CHP2) with both plants beginning the 12 month implementation readings on or before November 15, 2018. If start-up is delayed, Customer will communicate in writing to Company actual full scale start-up date for contract initiation.

11. Non-energy Benefits:

As the largest private investment in Circleville in many years, Sofidel America's Greenfield plant will increase the local economy and surrounding areas.

The construction of the plant itself will generate economic benefits to the surrounding area either directly with companies and/or workers involved in the construction of the plant (equipment and material suppliers, contractors, engineers) or indirectly with companies servicing the needs of these companies and workers (such as food service, hospitality, and transportation industries among others). For example, there is a plan to add a rail spur in order to facilitate shipment of finished products and receipt of materials by freight train in addition to the available trucking transportation.

Even after construction, the local economy will benefit from the establishment of this facility. Sofidel America is committed to enroll 310 employees in the Circleville facility by 2020 and by hiring in both management and manufacturing positions. Furthermore, there will be a need of continuous services from the area. As an example, like any manufacturing facility there will be a need for repair and maintenance. This maintenance would call for skilled workers as well as for supply and manufacturing of standard and custom parts.

Recognizing that the paper manufacturing process requires a lot of energy and has an impact on our resources, Sofidel Group strives to be as environmentally and socially sustainable as possible

and is committed to give more value in products and services by reducing the negative impact on the environment as well as people's lives, hence our motto of "Less is More". Based on this guiding principle, Sofidel continues to innovate and refine its processes. In the case of the Circleville plant, for example, it is not just reducing emissions by building the two co-generation plants but also recycling as much water as possible in our paper mill process and reducing our impact in our rivers by constructing a waste water treatment plant.

Sofidel Group has various Italian and international partners among them are UN's Global Compact initiative, WWF Climate Savers, and Médecins Sans Frontières (Doctors without Borders). In the USA, all our current branches in Sofidel America are PEFC certified, endorsed by an international organization promoting sustainable forest management.

12. CHP system generator output measurement, reporting and auditing: Customer at their sole cost utilizing utility grade metering and in accordance with Company specifications shall measure the generator output and provide monthly readings via e-mail to designated Company personnel. After providing reasonable notice, Company has the right to inspect and validate the meter readings of the CHP system. Company will provide Customer, upon written request, a copy of any report generated as a result of the inspection and audit. Notwithstanding the foregoing, it shall be the sole responsibility of Customer to operate, maintain, repair, and inspect the CHP system to ensure its proper working order during the entire term of the agreement. Customer shall complete an Annual Affidavit of CHP Performance, attached hereto as Attachment A. Customer hereby agrees to submit the Annual Affidavit of Performance to the Company by December 15 for the CHP systems' previous year's generation, attesting to its annual generation of energy and demand in MWhs and MW, respectively, as well as the overall system efficiency for the previous year and current condition of the CHP system.

13. Incentives:

- a. Payments are based on annual net metered kWh produced by the CHP system for internal plant production use. Parasitic loads will be removed from the gross metered kWh generation. If parasitic loads cannot be accurately measured by the customer, then the Department of Energy recommended default value will be used for estimating the net kWh generation.
- b. Payments = \$0.007 per net kWh for 5 years capped at \$400,000 per year per plant.
- c. Annual payments commencing twelve months following the formal commissioning date to full operation and are made for 5 consecutive years.

- d. Estimated annual payments beginning in 2019 are \$700,000 and total payments over 5 years are estimated at \$3,500,000.

- 14. EE/PDR rider and EE/PDR program participation:** Customer agrees to continue paying EE/PDR rider until the end of the incentive payment term in this agreement, and Customer can continue to participate in any EE/PDR programs available to them.
- 15. Interconnection requirements:** Customer application for interconnection has been submitted by Company and the agreement is being prepared. This agreement is subject to Customer and Company execution of the interconnection agreement.
- 16. Standby service requirements:** Customer agrees to adhere to any requirements and costs of such, if applicable.
- 17. Invoicing for Incentives:** Customer shall invoice Company annually for incentives within fifteen days following the end of the twelve month period and Company receipt of the Annual Affidavit of Performance. Company shall pay all such properly submitted incentive invoices within fifteen (15) business days after receipt.
- 18. Penalty:** Customer could be subject to forfeit of annual incentive payment at the sole discretion of the Company if the Annual Affidavit of CHP Performance is not submitted by the due date, monthly meter readings are not provided or reasonable requests for inspection and validation of meter readings are not allowed by the Customer. If Customer terminates early (before the 5 years), the only penalty will be the forfeit of the annual incentive for that year and any subsequent years during the 5-year term.
- 19. Contacts and Notices:** Contacts for each party. All Notices relating to this contract must be effectuated in writing and sent by ordinary US mail, postage prepaid, to:

- a. Customer: Andrea Wong

Process Engineer, Sofidel America
25910 US 23, Circleville, OH 43113
918-934-7994

- b. Company: Jon Williams


Manager, Energy Efficiency and Demand Response
301 Cleveland Avenue, Canton, Ohio 44701
330-438-7742

20. **MODIFICATION.** No modification of this Agreement is effective unless reduced to writing, signed by both parties.

21. **SUCCESSORS AND ASSIGNS.** This Agreement shall be binding upon and inure to the benefit of the parties hereto, and their respective successors and/or assigns, but Customer shall not transfer or assign any of the rights hereby granted to any non-affiliated third-party of Sofidel SpA without the prior written consent of AEP Ohio.

22. **REGULATORY APPROVAL.** The Customer and Company have worked extensively on this project over the last year and agree that we have shown that it provides significant benefits to all customers due to its size and high cost effectiveness compared to other projects. Both parties request expedited review and approval of the agreement. This contract is dependent upon approval of a mercantile arrangement along with cost recovery including shared savings through the EE/PDR rider based on the terms of this contract by the Public Utilities Commission of Ohio (Commission). The parties agree that the goal of the agreement is to help the Customer achieve greater energy efficiency and productivity in its operations and help the Company meet its energy efficiency and peak demand reduction goals, while improving the overall cost effectiveness of goal achievement in each year.

OHIO POWER COMPANY

By: 

Name: Jon Williams

Title: Manager, Energy Efficiency and Demand Response

Date: 4/12/17

CUSTOMER: Sofidel America

By: 

Name: Philippe Augé

Title: CEO

Date: 4/10/2017

By: 

Name: Julia Sloat

Title: AEP Ohio President & COO

Date: 4/13/17

EXHIBIT 2
ATTACHMENT A

Attachment A

State of Ohio: **ANNUAL AFFIDAVIT OF CHP PERFORMANCE** County of:

_____, Affiant, being duly sworn, affirmed according to law,
deposes and says that:

1. I am the duly authorized representative for purposes of this agreement of the _____ CHP generating facility.
2. I have personally examined and am familiar with all information contained in the foregoing Agreement, including any exhibits and attachments, and that based upon my inquiry of those persons immediately responsible for obtaining the information contained in the Agreement; I believe that the information is true, accurate and complete.
3. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

The Statement:

For the twelve month period identified by the Meter Read Dates below, this CHP generating facility continued to be in good working order with no material corrective actions pertaining to safety and/or operation warranting major attention and significant down time. Further, this CHP generating facility delivered _____ MWhs in the twelve month period.

Meter Read Dates (mo/day/yr)

Readings

Start: _____

End: _____

The calculated average annual total system efficiency for the twelve month period of the CHP generating facility is _____ %

Signature of Affiant & Title

Sworn and subscribed before me this _____ day of _____, _____ Month/Year

Notary Signature

Print Name and Title

My commission expires on _____

Exhibit 3

Cost Benefit Analysis

Test	NPV	Benefit/ Cost Ratio
Total Resource	\$ 46,578,961	2.7
Participant	\$ 67,889,109	3.5
RIM	\$ (21,310,148)	0.8
Utility	\$ 70,745,760	26.1
Societal	\$ 78,897,344	3.9

NPV/kWh \$ 0.7075
Shared
Savings
per kWh \$ 0.0920

Shared
Savings \$ 9,196,949

EXHIBIT 4



A unit of American Electric Power

APPLICATION FOR INTERCONNECTION
OF GENERATION EQUIPMENT
20 MEGAWATTS OR LESS
(Standard Form Application)

A Short Form Application is available for inverter-based systems (25 kW or less).

An Application is a complete application when it provides all applicable and correct information required below. Additional information to evaluate a request for interconnection may be required pursuant to the application process after the Application is deemed complete.

Applications for Interconnection meeting Level 2 qualifying criteria are subject to an application fee of \$50 + \$1/kW. Applications for Interconnection meeting Level 3 qualifying criteria are subject to an application fee of \$100 + \$2/kW. Check Attached

Customer

Legal Name: Sofidel America
Mailing Address: 25910 US 23
City: Circleville State: OH Zip: 43113
Phone: (863) 512-3829 Phone: ()
E-mail address: simone.capuano@sofidel.it

Alternate Contact

Name: Andrea R. Wong
Mailing Address: 25910 US 23
City: Circleville State: OH Zip: 43113
Phone: (918) 934-7994 Phone: ()
E-mail address: andrea.wong@sofidelamerica.com

Facility Location

Street Address: 25910 US 23
City: Circleville Zip: 43113

Service Information

Electric Service Account Number: 106-846-664-0
Existing Electric Service: Capacity: 1200 Amperes Voltage: 138,000 Volts
Service Character: () Single Phase (X) Three Phase
Site Maximum Demand: 20,000 kW Annual Energy Consumption 122,640,000 kWh
Requested Point of Interconnection: SEL 351-7 relays (main breakers at Sofidel's substation)
Location of Utility Accessible Lockable Disconnect Switch: At AEP Substation N/E of Sofidel Property, North of utility meter (e.g. West wall next to utility meter)
Requested In-Service Date: Nov 15, 2017

Consulting Engineer or Contractor

Name: Concord Engineering Group

Address: 520 S Burnt Mill Road

City: Voorhees

State: NJ

Zip: 08043

Phone: (856) 427-0200 Phone: (609) 760-4052 E-mail: gmolinari@concord-engineering.com

Generator Qualifications

Energy Source: ☐ Solar ☐ Wind ☐ Hydro: type (e.g. run-of-river) _____
☐ Diesel ☒ Natural Gas ☐ Fuel Oil ☐ Other: (specify) _____

Type of Generator: ☐ Inverter-Based ☒ Synchronous ☐ Induction

Generator Nameplate Ratings: 7518 kW @ 59F, 12470 Volts Connected ☒ Wye ☐ Delta

Number of Generators: 2 Service Character: ☐ 1 Phase ☒ 3 Phase Power Factor: 80%

Inverter AC Ratings: N/A kW _____ Volts Number of Inverters _____

Number of Solar PV Modules: N/A DC Rating: _____ watts

Maximum Net Export Capability: 6 MW Estimated Annual Energy Production: 50,000 mWh (Expected)

Will trip with reverse power relay if exporting more than 6 MW after a period of time

This Generating Equipment is intended to be used to:

- ☐ Emergency/Standby – Operated when AEP service is not available. Paralleling is for short durations.
- ☐ Peak Shaving – Operated during peak demand periods. Paralleling is for extended times.
- ☐ Base Load Power – Operated continuously at a pre-determined output. Paralleling is continuous.
- ☒ Cogeneration – Operated primarily to produce thermal energy. Paralleling is extended or continuous.
- ☐ Renewable non-dispatched – Operated in response to an available renewable resource. Paralleling is for extended times.
- ☐ Other – Describe: _____

List components of the generation equipment that are currently certified by a nationally recognized testing and certification laboratory (NRTL) and/or listed by the Underwriters Laboratory:

Equipment Type	UL Listing or certifying NRTL Certification
1. Gas Turbine Generator	<u>The components of the package are</u>
Package: Solar Turbine	<u>manufactured and tested in accordance with</u>
Model - Taurus 70 Gen Set.	<u>internationally recognized standard and certified</u>
	<u>by nationally recognized testing & certification</u>
	<u>laboratory (NRTL) and/or listed by UL (See</u>
	<u>attachment-6)</u>

Generation Equipment Technical Information

Attach electrical one-line diagram showing the configuration of all generating facility equipment, transformers, switchgear, switches, circuit breakers, fuses, current and potential transformers, and protection and control schemes. (This diagram must be signed and stamped by a licensed Professional Engineer if the facility is larger than 50kW).

Attach site documentation that indicates the precise physical location of the proposed generating facility and location of protective interface equipment, disconnect switch, and utility electric meter (e.g. USGS topographic map or other diagram or documentation).

Attach technical specifications literature for inverters, photovoltaic modules, wind turbines, other generation equipment, battery systems, transformers, switches, or other interface devices and documentation that describes and details the operation of all protection and control schemes.

Attach UL 1741 documentation or installation test procedures for all the tests required by IEEE 1547 and the periodic maintenance schedule recommended by the equipment manufacturer.

NOTE 1

Attach "Certificate of Liability Insurance" or proof of insurance sufficient to meet construction, operating and liability responsibilities.

I hereby certify that, to the best of my knowledge, all the information provided in the Interconnection Application is true and correct.

CUSTOMER'S SIGNATURE: Steve Cooper

TITLE: CHIEF TECHNICAL OFFICER

DATE: 11/30/2016


Return Completed Application to: *AEP Ohio*
Attn: DG Coordinator
850 Tech Center Dr
Gahanna, Ohio 43230-6605
614-883-6775
dgcoordinator-ohio@aep.com

Attachment:

- | | |
|---|-------------------|
| 1. Electrical: Overall One Line Diagram: | E100/0 - 11/22/16 |
| 2. Electrical: One Line Diagram: | E1.01 - 11/22/16 |
| 3. Electrical 12.47kV SWGR SG 1201 One Line Diagram: | E101/0 - 11/22/16 |
| 4. Electrical 12.47kV SWGR SG 1202 One Line Diagram: | E102/0 - 11/22/16 |
| 5. Site General Arrangement Drawing | |
| 6. Solar Turbine Technical Specification - June 20, 2016: Rev 1 | |
| 7. Certificate of Liability Insurance | |

Note 1: The Installation tests will be carried out in accordance with IEEE1547 and the specific procedure will be forwarded on approval of the application.

1. TO CLARIFY & DETERMINE THE STATUS OF THE PROJECT, THE FOLLOWING INFORMATION IS REQUIRED:
a. PROJECT LOCATION (LAT & LONG) & TO THE PROJECT SITE
b. PROJECT DESCRIPTION (TYPE & SIZE)
c. PROJECT OWNER'S NAME & ADDRESS
d. PROJECT BUDGET & FUNDING SOURCE
2. TO CLARIFY & DETERMINE THE STATUS OF THE PROJECT, THE FOLLOWING INFORMATION IS REQUIRED:
a. PROJECT LOCATION (LAT & LONG) & TO THE PROJECT SITE
b. PROJECT DESCRIPTION (TYPE & SIZE)
c. PROJECT OWNER'S NAME & ADDRESS
d. PROJECT BUDGET & FUNDING SOURCE
3. TO CLARIFY & DETERMINE THE STATUS OF THE PROJECT, THE FOLLOWING INFORMATION IS REQUIRED:
a. PROJECT LOCATION (LAT & LONG) & TO THE PROJECT SITE
b. PROJECT DESCRIPTION (TYPE & SIZE)
c. PROJECT OWNER'S NAME & ADDRESS
d. PROJECT BUDGET & FUNDING SOURCE
4. TO CLARIFY & DETERMINE THE STATUS OF THE PROJECT, THE FOLLOWING INFORMATION IS REQUIRED:
a. PROJECT LOCATION (LAT & LONG) & TO THE PROJECT SITE
b. PROJECT DESCRIPTION (TYPE & SIZE)
c. PROJECT OWNER'S NAME & ADDRESS
d. PROJECT BUDGET & FUNDING SOURCE



LEGEND

1	138kV FEEDER
2	138kV FEEDER
3	138kV FEEDER
4	138kV FEEDER
5	138kV FEEDER
6	138kV FEEDER
7	138kV FEEDER
8	138kV FEEDER
9	138kV FEEDER
10	138kV FEEDER
11	138kV FEEDER
12	138kV FEEDER
13	138kV FEEDER
14	138kV FEEDER
15	138kV FEEDER
16	138kV FEEDER
17	138kV FEEDER
18	138kV FEEDER
19	138kV FEEDER
20	138kV FEEDER
21	138kV FEEDER
22	138kV FEEDER
23	138kV FEEDER
24	138kV FEEDER
25	138kV FEEDER
26	138kV FEEDER
27	138kV FEEDER
28	138kV FEEDER
29	138kV FEEDER
30	138kV FEEDER
31	138kV FEEDER
32	138kV FEEDER
33	138kV FEEDER
34	138kV FEEDER
35	138kV FEEDER
36	138kV FEEDER
37	138kV FEEDER
38	138kV FEEDER
39	138kV FEEDER
40	138kV FEEDER
41	138kV FEEDER
42	138kV FEEDER
43	138kV FEEDER
44	138kV FEEDER
45	138kV FEEDER
46	138kV FEEDER
47	138kV FEEDER
48	138kV FEEDER
49	138kV FEEDER
50	138kV FEEDER
51	138kV FEEDER
52	138kV FEEDER
53	138kV FEEDER
54	138kV FEEDER
55	138kV FEEDER
56	138kV FEEDER
57	138kV FEEDER
58	138kV FEEDER
59	138kV FEEDER
60	138kV FEEDER
61	138kV FEEDER
62	138kV FEEDER
63	138kV FEEDER
64	138kV FEEDER
65	138kV FEEDER
66	138kV FEEDER
67	138kV FEEDER
68	138kV FEEDER
69	138kV FEEDER
70	138kV FEEDER
71	138kV FEEDER
72	138kV FEEDER
73	138kV FEEDER
74	138kV FEEDER
75	138kV FEEDER
76	138kV FEEDER
77	138kV FEEDER
78	138kV FEEDER
79	138kV FEEDER
80	138kV FEEDER
81	138kV FEEDER
82	138kV FEEDER
83	138kV FEEDER
84	138kV FEEDER
85	138kV FEEDER
86	138kV FEEDER
87	138kV FEEDER
88	138kV FEEDER
89	138kV FEEDER
90	138kV FEEDER
91	138kV FEEDER
92	138kV FEEDER
93	138kV FEEDER
94	138kV FEEDER
95	138kV FEEDER
96	138kV FEEDER
97	138kV FEEDER
98	138kV FEEDER
99	138kV FEEDER
100	138kV FEEDER

SEL 551-F - FEEDER PROTECTION RELAY

OUT 101	TRIP LOCAL 15kV BREAKER
OUT 102	CLOSE LOCAL 15kV BREAKER
OUT 103	15kV BREAKER TRIP INDICATION
OUT 107	TRIP 6kA LOCKOUT RELAY
OUT 210	15kV BREAKER STATUS (SEL-2500)
OUT 211	15kV BREAKER STATUS (SEL-2500)
OUT 212	15kV BREAKER STATUS (SEL-2500)
IN 101	LOCAL 15kV BREAKER STATUS
IN 102	LOCAL 15kV BREAKER STATUS
IN 103	15kV BREAKER STATUS (SEL-2500)
IN 104	15kV BREAKER STATUS (SEL-2500)

SEL 487B-1 - 15kV BUS A PROTECTION RELAY

OUT 101	TRIP 6kA
---------	----------

SEL 487B-2 - 15kV BUS B PROTECTION RELAY

OUT 101	TRIP 6kA
---------	----------

SEL 551 - OVERCURRENT RELAY

OUT 101	TRIP 15kV BREAKER
OUT 102	TRIP 15kV BREAKER
OUT 103	TRIP 15kV BREAKER
OUT 104	TRIP 15kV BREAKER
OUT 105	TRIP 15kV BREAKER
OUT 106	TRIP 15kV BREAKER
OUT 107	TRIP 15kV BREAKER
OUT 108	TRIP 15kV BREAKER
OUT 109	TRIP 15kV BREAKER
OUT 110	TRIP 15kV BREAKER
OUT 111	TRIP 15kV BREAKER
OUT 112	TRIP 15kV BREAKER
OUT 113	TRIP 15kV BREAKER
OUT 114	TRIP 15kV BREAKER
OUT 115	TRIP 15kV BREAKER
OUT 116	TRIP 15kV BREAKER
OUT 117	TRIP 15kV BREAKER
OUT 118	TRIP 15kV BREAKER
OUT 119	TRIP 15kV BREAKER
OUT 120	TRIP 15kV BREAKER
OUT 121	TRIP 15kV BREAKER
OUT 122	TRIP 15kV BREAKER
OUT 123	TRIP 15kV BREAKER
OUT 124	TRIP 15kV BREAKER
OUT 125	TRIP 15kV BREAKER
OUT 126	TRIP 15kV BREAKER
OUT 127	TRIP 15kV BREAKER
OUT 128	TRIP 15kV BREAKER
OUT 129	TRIP 15kV BREAKER
OUT 130	TRIP 15kV BREAKER
OUT 131	TRIP 15kV BREAKER
OUT 132	TRIP 15kV BREAKER
OUT 133	TRIP 15kV BREAKER
OUT 134	TRIP 15kV BREAKER
OUT 135	TRIP 15kV BREAKER
OUT 136	TRIP 15kV BREAKER
OUT 137	TRIP 15kV BREAKER
OUT 138	TRIP 15kV BREAKER
OUT 139	TRIP 15kV BREAKER
OUT 140	TRIP 15kV BREAKER
OUT 141	TRIP 15kV BREAKER
OUT 142	TRIP 15kV BREAKER
OUT 143	TRIP 15kV BREAKER
OUT 144	TRIP 15kV BREAKER
OUT 145	TRIP 15kV BREAKER
OUT 146	TRIP 15kV BREAKER
OUT 147	TRIP 15kV BREAKER
OUT 148	TRIP 15kV BREAKER
OUT 149	TRIP 15kV BREAKER
OUT 150	TRIP 15kV BREAKER
OUT 151	TRIP 15kV BREAKER
OUT 152	TRIP 15kV BREAKER
OUT 153	TRIP 15kV BREAKER
OUT 154	TRIP 15kV BREAKER
OUT 155	TRIP 15kV BREAKER
OUT 156	TRIP 15kV BREAKER
OUT 157	TRIP 15kV BREAKER
OUT 158	TRIP 15kV BREAKER
OUT 159	TRIP 15kV BREAKER
OUT 160	TRIP 15kV BREAKER
OUT 161	TRIP 15kV BREAKER
OUT 162	TRIP 15kV BREAKER
OUT 163	TRIP 15kV BREAKER
OUT 164	TRIP 15kV BREAKER
OUT 165	TRIP 15kV BREAKER
OUT 166	TRIP 15kV BREAKER
OUT 167	TRIP 15kV BREAKER
OUT 168	TRIP 15kV BREAKER
OUT 169	TRIP 15kV BREAKER
OUT 170	TRIP 15kV BREAKER
OUT 171	TRIP 15kV BREAKER
OUT 172	TRIP 15kV BREAKER
OUT 173	TRIP 15kV BREAKER
OUT 174	TRIP 15kV BREAKER
OUT 175	TRIP 15kV BREAKER
OUT 176	TRIP 15kV BREAKER
OUT 177	TRIP 15kV BREAKER
OUT 178	TRIP 15kV BREAKER
OUT 179	TRIP 15kV BREAKER
OUT 180	TRIP 15kV BREAKER
OUT 181	TRIP 15kV BREAKER
OUT 182	TRIP 15kV BREAKER
OUT 183	TRIP 15kV BREAKER
OUT 184	TRIP 15kV BREAKER
OUT 185	TRIP 15kV BREAKER
OUT 186	TRIP 15kV BREAKER
OUT 187	TRIP 15kV BREAKER
OUT 188	TRIP 15kV BREAKER
OUT 189	TRIP 15kV BREAKER
OUT 190	TRIP 15kV BREAKER
OUT 191	TRIP 15kV BREAKER
OUT 192	TRIP 15kV BREAKER
OUT 193	TRIP 15kV BREAKER
OUT 194	TRIP 15kV BREAKER
OUT 195	TRIP 15kV BREAKER
OUT 196	TRIP 15kV BREAKER
OUT 197	TRIP 15kV BREAKER
OUT 198	TRIP 15kV BREAKER
OUT 199	TRIP 15kV BREAKER
OUT 200	TRIP 15kV BREAKER

SEL 551 - OVERCURRENT RELAY

OUT 101	TRIP 15kV BREAKER
---------	-------------------

SEL 551 - CURRENT DIFFERENTIAL RELAY

OUT 101	TRIP 15kV BREAKER
OUT 102	TRIP 15kV BREAKER
OUT 103	TRIP 15kV BREAKER
OUT 104	TRIP 15kV BREAKER

SEL 551 - FEEDER PROTECTION RELAY


OUT 101	TRIP 15kV BREAKER
OUT 102	TRIP 15kV BREAKER
OUT 103	TRIP 15kV BREAKER

SEL - 2500 (B1)

OUT 1	52 CT-101 5A
OUT 2	52 CT-101 5A
OUT 3	52 CT-101 5A
OUT 4	52 CT-101 5A
OUT 5	52 CT-101 5A
OUT 6	52 CT-101 5A
OUT 7	52 CT-101 5A
OUT 8	52 CT-101 5A
OUT 9	52 CT-101 5A
OUT 10	52 CT-101 5A
OUT 11	52 CT-101 5A
OUT 12	52 CT-101 5A
OUT 13	52 CT-101 5A
OUT 14	52 CT-101 5A
OUT 15	52 CT-101 5A
OUT 16	52 CT-101 5A
OUT 17	52 CT-101 5A
OUT 18	52 CT-101 5A
OUT 19	52 CT-101 5A
OUT 20	52 CT-101 5A
OUT 21	52 CT-101 5A
OUT 22	52 CT-101 5A
OUT 23	52 CT-101 5A
OUT 24	52 CT-101 5A
OUT 25	52 CT-101 5A
OUT 26	52 CT-101 5A
OUT 27	52 CT-101 5A
OUT 28	52 CT-101 5A
OUT 29	52 CT-101 5A
OUT 30	52 CT-101 5A
OUT 31	52 CT-101 5A
OUT 32	52 CT-101 5A
OUT 33	52 CT-101 5A
OUT 34	52 CT-101 5A
OUT 35	52 CT-101 5A
OUT 36	52 CT-101 5A
OUT 37	52 CT-101 5A
OUT 38	52 CT-101 5A
OUT 39	52 CT-101 5A
OUT 40	52 CT-101 5A
OUT 41	52 CT-101 5A
OUT 42	52 CT-101 5A
OUT 43	52 CT-101 5A
OUT 44	52 CT-101 5A
OUT 45	52 CT-101 5A
OUT 46	52 CT-101 5A
OUT 47	52 CT-101 5A
OUT 48	52 CT-101 5A
OUT 49	52 CT-101 5A
OUT 50	52 CT-101 5A
OUT 51	52 CT-101 5A
OUT 52	52 CT-101 5A
OUT 53	52 CT-101 5A
OUT 54	52 CT-101 5A
OUT 55	52 CT-101 5A
OUT 56	52 CT-101 5A
OUT 57	52 CT-101 5A
OUT 58	52 CT-101 5A
OUT 59	52 CT-101 5A
OUT 60	52 CT-101 5A
OUT 61	52 CT-101 5A
OUT 62	52 CT-101 5A
OUT 63	52 CT-101 5A
OUT 64	52 CT-101 5A
OUT 65	52 CT-101 5A
OUT 66	52 CT-101 5A
OUT 67	52 CT-101 5A
OUT 68	52 CT-101 5A
OUT 69	52 CT-101 5A
OUT 70	52 CT-101 5A
OUT 71	52 CT-101 5A
OUT 72	52 CT-101 5A
OUT 73	52 CT-101 5A
OUT 74	52 CT-101 5A
OUT 75	52 CT-101 5A
OUT 76	52 CT-101 5A
OUT 77	52 CT-101 5A
OUT 78	52 CT-101 5A
OUT 79	52 CT-101 5A
OUT 80	52 CT-101 5A
OUT 81	52 CT-101 5A
OUT 82	52 CT-101 5A
OUT 83	52 CT-101 5A
OUT 84	52 CT-101 5A
OUT 85	52 CT-101 5A
OUT 86	52 CT-101 5A
OUT 87	52 CT-101 5A
OUT 88	52 CT-101 5A
OUT 89	52 CT-101 5A
OUT 90	52 CT-101 5A
OUT 91	52 CT-101 5A
OUT 92	52 CT-101 5A
OUT 93	52 CT-101 5A
OUT 94	52 CT-101 5A
OUT 95	52 CT-101 5A
OUT 96	52 CT-101 5A
OUT 97	52 CT-101 5A
OUT 98	52 CT-101 5A
OUT 99	52 CT-101 5A
OUT 100	52 CT-101 5A

SEL - 2500 (B1)

OUT 1	52 CT-101 5A
OUT 2	52 CT-101 5A
OUT 3	52 CT-101 5A
OUT 4	52 CT-101 5A
OUT 5	52 CT-101 5A
OUT 6	52 CT-101 5A
OUT 7	52 CT-101 5A
OUT 8	52 CT-101 5A
OUT 9	52 CT-101 5A
OUT 10	52 CT-101 5A
OUT 11	52 CT-101 5A
OUT 12	52 CT-101 5A
OUT 13	52 CT-101 5A
OUT 14	52 CT-1



QUALIFIER NOTE

THIS ONE LINE DIAGRAM REPRESENTS THE PRELIMINARY CONCEPT OF INTERCONNECTION OF THE CHP GENERATION WITH THE ORIGINAL PLANT DISTRIBUTION SYSTEM. THE PROTECTION, METERING, CONTROL AND MONITORING SYSTEMS SHOWN IS BASED ON TYPICAL APPLICATIONS. THE SYSTEM MAY REQUIRE UPDATES/REVISIONS IN COORDINATION WITH THE PLANT OPERATING PHILOSOPHY AND THE SAFETY INTERCONNECTION REQUIREMENTS.

LEGEND

PCS STAGE (BWP)

PCS CONTROL (BWP)

WATER FUNCTION METER

1 F1 - TEST SWITCH

WFS - RELAY FAILURE ALARM

WCR - RELAYING COORDINATING REACTION

PCS - COORD PLANT CONTROL SYSTEM

WCS - SOLAR RADIANCE CONTROL SYSTEM

WFS - A/C PLANT PROTECTION SWITCH

WEL-2201-1 (F1A-CR1)

OUT-1	WEL-2201-1 (F1A-CR1)
OUT-2	WEL-2201-1 (F1A-CR1)
OUT-3	WEL-2201-1 (F1A-CR1)
OUT-4	WEL-2201-1 (F1A-CR1)
OUT-5	WEL-2201-1 (F1A-CR1)
OUT-6	WEL-2201-1 (F1A-CR1)
OUT-7	WEL-2201-1 (F1A-CR1)
OUT-8	WEL-2201-1 (F1A-CR1)
OUT-9	WEL-2201-1 (F1A-CR1)
OUT-10	WEL-2201-1 (F1A-CR1)
OUT-11	WEL-2201-1 (F1A-CR1)
OUT-12	WEL-2201-1 (F1A-CR1)
OUT-13	WEL-2201-1 (F1A-CR1)
OUT-14	WEL-2201-1 (F1A-CR1)
OUT-15	WEL-2201-1 (F1A-CR1)
OUT-16	WEL-2201-1 (F1A-CR1)
OUT-17	WEL-2201-1 (F1A-CR1)
OUT-18	WEL-2201-1 (F1A-CR1)
OUT-19	WEL-2201-1 (F1A-CR1)
OUT-20	WEL-2201-1 (F1A-CR1)

DRAWING NOTES:

1. REFER TO DRAWING E-101 FOR ELECTRICAL SYMBOLS, ABBREVIATIONS, LEGEND, AND GENERAL NOTES.
2. THE VOLTAGE INDICATES A POSITIVE VOLTAGE AT THE INDICATED TERMINALS IN THE DIRECTION OF THE ARROW.
3. REFER TO PROJECT CABLE SCHEDULE FOR ALL CABLE AND CONDUIT INFORMATION.
4. REFER TO DRAWING E-102 FOR DETAILS SEE SINGLE LINE.
5. WEL-2201-1 IS A BATTERY BACKUP SYSTEM.
6. THE WEL-2201-1 BATTERY SYSTEM SHALL BE USED FOR PROTECTIVE RELAYS AND V/F RELAYING AUXILIARY POWER.
7. UNLESS INDICATED OTHERWISE, WEL-2201-1 SHALL BE USED FOR PROTECTIVE RELAYS AND V/F RELAYING AUXILIARY POWER.
8. ALL LINE AND BUS PROTECTIVE CIRCUITS SHALL BE WEL-2201-1 (F1A-CR1) (SEE F1A-CR1).
9. WEL-2201-1 SHALL BE PROVIDED FOR ALL WEL-2201-1 (F1A-CR1) (SEE F1A-CR1).
10. THE WEL-2201-1 AND WEL-2201-1 (F1A-CR1) SHALL BE WEL-2201-1 (F1A-CR1) (SEE F1A-CR1).



CLIENT:

SOFIDEL America

CONCORD ENGINEERING
P.O. BOX 270570
180 South Street, Suite 100
Tomball, Texas 77375
Phone: 281-291-1111
Fax: 281-291-1111
www.concord-engineering.com

REV	DATE	DESCRIPTION
1	01/15/2011	ISSUED FOR BIDDING
2	01/15/2011	ISSUED FOR BIDDING
3	01/15/2011	ISSUED FOR BIDDING
4	01/15/2011	ISSUED FOR BIDDING
5	01/15/2011	ISSUED FOR BIDDING
6	01/15/2011	ISSUED FOR BIDDING
7	01/15/2011	ISSUED FOR BIDDING
8	01/15/2011	ISSUED FOR BIDDING
9	01/15/2011	ISSUED FOR BIDDING
10	01/15/2011	ISSUED FOR BIDDING

KEY PLAN:



PROJECT:

SOFIDEL AMERICA TORNADO
Combined Heat & Power Plant
Schematic Design Package

SOFIDEL AMERICA
CIRCLEVILLE, OH 43113

DRAWING TITLE:

ELECTRICAL
12.47KV SWGR SG-1201
ONE LINE DIAGRAM
CHP-01 BUILDING

DATE	BY	SCALE	IN	DATE	BY
01/15/2011	01	1/8" = 1'	11	01/15/2011	01
01/15/2011	01	1/8" = 1'	11	01/15/2011	01
01/15/2011	01	1/8" = 1'	11	01/15/2011	01

This document is the property of SOFIDEL AMERICA. It is to be used only for the project and location specified. It is not to be reproduced without the written consent of SOFIDEL AMERICA.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

5/1/2017 11:03:43 AM

in

Case No(s). 17-0043-EL-EEC

Summary: Application Joint application for approval of a special arrangement agreement between Ohio Power Company and Sofidel America electronically filed by Mr. Steven T Nourse on behalf of Ohio Power Company