




1 Marker Placement Along Trench Line
No Scale



3 Bollard (Guard Post) Detail
No Scale



2 Marker Placement Along Roadway
No Scale



4 Typical Guard Post Arrangement At Junction Boxes
No Scale

MATERIAL LIST					
ITEM	QTY	UNITS	DESCRIPTION	MFG.	PART #
1	1	FT	UTILITY MARKER POLE, FLAT, RED, 72"		
2	4	EA	PIPE, GALVANIZED RIGID 4" X 10"		
3	4	EA	GUARD, BUMPER POST SLEEVE, SAFETY YELLOW, 4.75" ID, 56" HEIGHT		

GENERAL NOTES

- ROUTE MARKER POLES SHALL BE PLACED ALONG THE COLLECTOR LINES EVERY 1000 FEET UNLESS DIRECTED OTHERWISE BY ELECTRICAL SUPERINTENDENT. THEY SHALL ALSO BE PLACED AT ALL ROUTING ANGLES, ROAD CROSSINGS, UTILITY CROSSINGS, AND CABLE SPLICES. ADDITIONAL MARKERS MAY BE ADDED AS REQUESTED BY THE OWNER.
- COMPACT NATIVE SOIL.
- ADDITIONAL MARKERS CAN BE ADDED DURING CONSTRUCTION AS REQUESTED BY CLIENT.

Westwood

Phone (852) 937-5150 7500 Anagram Drive
Fax (852) 937-5022 Eden Prairie, MN 55344
Toll Free (888) 937-5150 www.westwoodps.com
Westwood Professional Services, Inc.

Designed BY
Checked AVE
Drawn JAC, JIC

As-Built Drawing

Revisions

DATE	DESCRIPTION
A 09/27/17	30% plans
B 10/03/17	Issued for Procurement - Revised
C 10/19/17	60% plans

Prepared for:



3900 E. White Ave
Chicago, IL 60642

Triske Wind Ohio, LLC
c/o Starwood Energy Group, LLC
5 Greenwich Office Park, 2nd Floor
Greenwich, CT 06831

**Northwest
Ohio Wind
Project**
Paulding County, Ohio

Marker Poles and Bollards

Not For Construction

Array Date: 09/14/2017

Date: 10/19/17

Sheet: E440

0007106_E440_Marker Poles.dwg

Bore ID	Circuit	Sheet #	Bore Type	From	To	Cable Size
MV1.T02-T01.1	MV1	E.310 & E.312	county road	T02	T01	1/0 AWG
MV1.T03-T02.1	MV1	E.312	wetland	T03	T02	1/0 AWG
MV1.T05-T04.1	MV1	E.312 & E.317	county road	T05	T04	4/0 AWG
MV1.T08-T05.1	MV1	E.317 & E.318	county road	T08	T05	500 MCM
MV1.T09-T08.1	MV1	E.318	gas line	T09	T08	500 MCM
MV1.T09-T08.2	MV1	E.318	wetland	T09	T08	500 MCM
MV1.T09-T08.3	MV1	E.318 & E.325	county road	T09	T08	500 MCM
MV1.T25-T10.1	MV1	E.325 & E.326	county road	T25	T10	1000 MCM
MV1.T25-T10.2	MV1	E.325 & E.326	wetland	T25	T10	1000 MCM
MV1.T25-T10.3	MV1	E.326 & E.327	wetland	T25	T10	1000 MCM
MV1.SUB-T25.1	MV1	E.327	gas line	SUB	T25	1250 MCM
MV1.SUB-T25.2	MV1	E.327 & E.331	state highway	SUB	T25	1250 MCM
MV2.T15-T14.1	MV2	E.313 & E.319	county road	T15	T14	1/0 AWG
MV2.T15-T07.1	MV2	E.318 & E.319	county road	T15	T07	4/0 AWG
MV2.T07-T16.1	MV2	E.319	wetland	T07	T16	1/0 AWG
MV2.T07-T16.2	MV2	E.318 & E.319	county road	T07	T16	1/0 AWG
MV2.T17-T15.1	MV2	E.319	wetland	T17	T15	500 MCM
MV2.T17-T15.2	MV2	E.319	county road	T17	T15	500 MCM
MV2.T17-T15.3	MV2	E.319 & E.326	wetland	T17	T15	500 MCM
MV2.T17-T15.4	MV2	E.319 & E.326	wetland	T17	T15	500 MCM
MV2.JB2/J1-T17.1	MV2	E.326 & E.327	wetland	JB2/J1	T17	750 MCM
MV2.JB2/J1-T22.1	MV2	E.320	wetland	JB2/J1	T22	4/0 AWG
MV2.JB2/J1-T22.2	MV2	E.320 & E.327	county road	JB2/J1	T22	4/0 AWG
MV2.T22-T29.1	MV2	E.321 & E.328	county road	T22	T29	1/0 AWG
MV2.T22-T29.2	MV2	E.320 & E.321	county road	T22	T29	1/0 AWG
MV2.T21-T20.1	MV2	E.314 & E.320	county road	T21	T20	1/0 AWG
MV2.T21-T20.2	MV2	E.320	wetland	T21	T20	1/0 AWG
MV2.T21-T20.3	MV2	E.320	wetland	T21	T20	1/0 AWG
MV2.SUB-JB2/J1.1	MV2	E.327	wetland	SUB	JB2/J1	1250 MCM
MV2.SUB-JB2/J1.2	MV2	E.327 & E.331	county road	SUB	JB2/J1	1250 MCM
MV2.SUB-JB2/J1.3	MV2	E.327	gas line	SUB	JB2/J1	1250 MCM
MV2.SUB-JB2/J1.4	MV2	E.327, E.331	state highway	SUB	JB2/J1	1250 MCM
MV3.T32-T31.1	MV3	E.315	wetland	T32	T31	1/0 AWG
MV3.T32-T31.2	MV3	E.315 & E.322	county road	T32	T31	1/0 AWG
MV3.T34-T36.1	MV3	E.322 & E.323	county road	T34	T36	1/0 AWG
MV3.T34-T39.1	MV3	E.329	wetland	T34	T39	1/0 AWG
MV3.T34-T39.2	MV3	E.323 & E.329	county road	T34	T39	1/0 AWG
MV3.T34-T39.3	MV3	E.322 & E.323	county road	T34	T39	1/0 AWG
MV3.T28-T33.1	MV3	E.321 & E.322	state highway	T28	T33	750 MCM
MV3.T28-T33.2	MV3	E.321	wetland	T28	T33	750 MCM
MV3.T23-T28.1	MV3	E.320 & E.321	wetland	T23	T28	1250 MCM
MV3.SUB-T23.1	MV3	E.320	wetland	SUB	T23	1250 MCM
MV3.SUB-T23.2	MV3	E.320 & E.327	county road	SUB	T23	1250 MCM
MV3.SUB-T23.3	MV3	E.327	gas line	SUB	T23	1250 MCM
MV3.SUB-T23.4	MV3	E.327 & E.331	state highway	SUB	T23	1250 MCM
MV4.T49-T50.1	MV4	E.311	wetland	T49	T50	1/0 AWG
MV4.T49-T50.2	MV4	E.311	wetland	T49	T50	1/0 AWG
MV4.T49-T48.1	MV4	E.311	turbine access	T49	T48	1/0 AWG
MV4.T49-T48.2	MV4	E.311	wetland	T49	T48	1/0 AWG
MV4.T42-T49.1	MV4	E.311 & E.316	county road	T42	T49	4/0 AWG
MV4.T42-T49.2	MV4	E.316	county road	T42	T49	4/0 AWG
MV4.T44-JB4/J1.1	MV4	E.316 & E.324	county road	T44	JB4/J1	500 MCM
MV4.T46-T45.1	MV4	E.324 & E.330	county road	T46	T45	1000 MCM
MV4.T45-T44.1	MV4	E.324	wetland	T45	T44	750 MCM
MV4.T45-T44.2	MV4	E.324	county road	T45	T44	750 MCM
MV4.T40-T46.1	MV4	E.329 & E.330	county road	T40	T46	1000 MCM
MV4.SUB-T40.1	MV4	E.329	wetland	SUB	T40	1250 MCM
MV4.SUB-T40.2	MV4	E.323 & E.329	county road	SUB	T40	1250 MCM
MV4.SUB-T40.3	MV4	E.322 & E.323	county road	SUB	T40	1250 MCM
MV4.SUB-T40.4	MV4	E.321 & E.322	state highway	SUB	T40	1250 MCM
MV4.SUB-T40.5	MV4	E.321	wetland	SUB	T40	1250 MCM
MV4.SUB-T40.6	MV4	E.320 & E.321	county road	SUB	T40	1250 MCM
MV4.SUB-T40.7	MV4	E.320	MVAC circuit 3	SUB	T40	1250 MCM
MV4.SUB-T40.8	MV4	E.320	wetland	SUB	T40	1250 MCM
MV4.SUB-T40.9	MV4	E.320 & E.327	county road	SUB	T40	1250 MCM
MV4.SUB-T40.10	MV4	E.327	gas line	SUB	T40	1250 MCM
MV4.SUB-T40.11	MV4	E.327 & E.331	state highway	SUB	T40	1250 MCM

Westwood

Phone (852) 937-5150 7500 Anagram Drive
Fax (852) 937-5822 Eden Prairie, MN 55344
Toll Free (888) 937-5150 www.westwoodps.com

Westwood Professional Services, Inc.

Designed BY

Checked AVE

Drawn BAC, BIC

As-Built Drawings

Revisions

A 09/27/17 30% plans

B 10/03/17 Issued for Procurement - Revised

C 10/19/17 60% plans

Prepared for:



3900 E. White Ave
Clinton, IN 47602

Trike Wind Ohio, LLC
c/o Starwood Energy Group, LLC
5 Greenwich Office Park, 2nd Floor
Greenwich, CT 06031

Northwest Ohio Wind Project

Paulding County, Ohio

Boring Schedule

Not For Construction

Array Date: 09/14/2017

Date: 10/19/17

Sheet: E.801

0007186_E.800_Schedules.dwg

KLJ REVIEW Trische Wind Updated: 9/6/2017 								
Comment	From	Responsible	Date Received	Response	Response Date	Document	Status	
No Comments	KLJ	UEI	9/6/2017	NA		0101-Northwest Wind Power Transformer Specification.pdf		
No Comments	KLJ	UEI	9/6/2017	NA		0101- Northeast Wind Power Transformer Attachment A.pdf		
No Comments	KLJ	UEI	9/6/2017	NA		0101- Northeast Wind Power Transformer Attachment B.pdf		
No Comments	KLJ	UEI	9/6/2017	NA		0201 - NW Ohio SF6 Breaker Specification.pdf		
No Comments	KLJ	UEI	9/6/2017	NA		0201 - NW Ohio SF6 Breaker Attachment A1.pdf		
No Comments	KLJ	UEI	9/6/2017	NA		0201 - NW Ohio SF6 Breaker Attachment A2.pdf		
12.02.2: Recommend AWG 10	KLJ	UEI	9/6/2017	NA		0202 - NW Ohio Vacuum Breaker Specification.pdf		
No Comments	KLJ	UEI	9/6/2017	NA		0202 - NW Ohio Vacuum Breaker Attachment A1.pdf		
No Comments	KLJ	UEI	9/6/2017	NA		0202 - NW Ohio Vacuum Breaker Attachment A2 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0202 - NW Ohio Vacuum Breaker Attachment B1 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0202 - NW Ohio Vacuum Breaker Attachment B2 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0204 - NW Ohio Capacitor Switcher Attachment A KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0204 - NW Ohio Capacitor Switcher Attachment B KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0204 - NW Ohio Capacitor Switcher Specification KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0302 - NW Ohio GOAB Switch Attachment A1 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0302 - NW Ohio GOAB Switch Attachment A2 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0302 - NW Ohio GOAB Switch Attachment B1 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0302 - NW Ohio GOAB Switch Attachment B2 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0302 - NW Ohio GOAB Switch Specification KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0303 - NW Ohio Disconnect Switch - Hookstick Attachment A KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0303 - NW Ohio Disconnect Switch - Hookstick Attachment B KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0303 - NW Ohio Disconnect Switch - Hookstick Specification KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0401 - NW Ohio CCVT Attachment A KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0401 - NW Ohio CCVT Attachment B KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0401 - NW Ohio CCVT Specification KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0501 - NW Ohio Neutral Grounding Reactor Attachment A KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0501 - NW Ohio Neutral Grounding Reactor Attachment B KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0501 - NW Ohio Neutral Grounding Reactor Specification KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0502 - NW Ohio Capacitor Bank Attachment A KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0502 - NW Ohio Capacitor Bank Attachment B KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0502 - NW Ohio Capacitor Bank Specification KLJ REVIEW		

4.: WILL AN INSULATION COORDINATION CALCULATION CHECKING PROTECTIVE MARGINS BE PROVIDED?	KLJ	UEI	9/6/2017	NA		Northwest Ohio Wind Substation Design Basis 7.14.2017 REV_A KLJ REVIEW		
6.: THIS CAN BE CONFUSING; CONSIDER USING A SHORT STATEMENT "A reactor is not anticipated at this time, but may be required based on the project reactive power study"	KLJ	UEI	9/6/2017	NA		Northwest Ohio Wind Substation Design Basis 7.14.2017 REV_A KLJ REVIEW		
7.: WHERE IN THIS DOCUMENT ARE THE EXPECTED REQUIRED RATINGS OUTLINED? USE THIS SECTION TO SHOW YOUR WIRE AND BUS MEET THE REQUIREMENTS OF THE WIND FARM	KLJ	UEI	9/6/2017	NA		Northwest Ohio Wind Substation Design Basis 7.14.2017 REV_A KLJ REVIEW		
8.: ARE YOU USING A SOFTWARE FOR CALCUS? IF SO, WHICH ONE?	KLJ	UEI	9/6/2017	NA		Northwest Ohio Wind Substation Design Basis 7.14.2017 REV_A KLJ REVIEW		
8.: MAY WANT TO CONSIDER THESE ARE "TBD" AT THIS STAGE, PRIOR TO YOUR AC LOADING STUDY (EVEN THOUGH BEING A SMALL STATION IT'S LIKELY THESE SPECS ARE FINE)	KLJ	UEI	9/6/2017	NA		Northwest Ohio Wind Substation Design Basis 7.14.2017 REV_A KLJ REVIEW		
16.02: IS THERE A REFERENCE LOADING CALC TO SUPPORT THIS AT THIS TIME?	KLJ	UEI	9/6/2017	NA		0600 - NWO Wind Electrical Equipment Enclosure Attachment A KLJ REVIEW		
16.03: IS THERE A REFERENCE LOADING CALC TO SUPPORT THIS AT THIS TIME?	KLJ	UEI	9/6/2017	NA		0600 - NWO Wind Electrical Equipment Enclosure Attachment A KLJ REVIEW		
16.04: IS THERE A CALC OR SIMULATION TO SUPPORT THIS RATING?	KLJ	UEI	9/6/2017	NA		0600 - NWO Wind Electrical Equipment Enclosure Attachment A KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0600 - NWO Wind Electrical Equipment Enclosure Specification KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0602 - NWO Control and Relay Panel Specification KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0602 - NWO Control Panel Attachment A KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0602 - NWO Control Panel Attachment B KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-CH1-001 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-EQ1-001 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-OL1-001 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-SW1-001 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-FE-001 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-FE-002 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-FE-003 KLJ REVIEW		
WILL THERE BE A "MAINTENANCE MODE FOR THE ARC FLASH ON THE FEEDER RELAYS?	KLJ	UEI	9/6/2017	NA		NWO-FE-004 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-FE-005 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-FE-006 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-FE-007 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		NWO-FE-008 KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0202 - NW Ohio Vacuum Breaker Attachment A1_revB KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0202 - NW Ohio Vacuum Breaker Attachment A2_revB KLJ REVIEW		
No Comments	KLJ	UEI	9/6/2017	NA		0501 - NW Ohio Neutral Grounding Reactor Attachment A_revB KLJ REVIEW		

KLJ REVIEW TRISCHE WIND Updated: 9/6/2017 							
Comment	From	Responsible	Date	Response	Document	Status	
What is "WW"?	KLJ	Westwood	10/12/2017	This was an abbreviation for Westwood Professional Services.	20170927_NW_OH_Wind_BOD_Rev0 KLJ Review 10-12-17		
Are these feeder breaker setting trip times?	KLJ	Westwood	10/12/2017	Yes, trip times per Ulteig Engineers.	20170927_NW_OH_Wind_BOD_Rev0 KLJ Review 10-12-17		
	KLJ	Westwood	10/12/2017	The design basis for selection of the concentric neutral was for an individual phase conductor to have capacity for a minimum of the available fault current (with allowance for future increase) for the expected clearing time. Clearing time of 8.5 cycles for phase faults and 3.5 cycles for ground faults was provided by Ulteig Engineers. Based on final cable selected, neutrals have a minimum of 10.5 cycle withstand and trench ground conductor will share a percentage of ground fault current.	20170927_NW_OH_Wind_BOD_Rev0 KLJ Review 10-12-17		
Has any consideration been taken for a feeder breaker failure event?							
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.100		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.101		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.105		
This symbol should be defined in the legend.	KLJ	Westwood	10/12/2017	This has been revised.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.200		
For consistency, this should say "MV2.T22-2X".	KLJ	Westwood	10/12/2017	This has been revised.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.200		
Are the GSU transformers being purchased with the ability to have (2) sets of load side elbows connected to the bushings?	KLJ	Westwood	10/12/2017	Transformers are purchased as loop feed, i.e. they have two sets of bushings	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.200		
Are the 600 Amp elbows being piggy-backed?	KLJ	Westwood	10/12/2017	Yes, 600 amp elbows are piggy-backed at several turbine locations.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.200		
Are the bushings rated for the weight of (2) elbows and (2) lengths of cable?	KLJ	Westwood	10/12/2017	Vendor has been requested to supply rating of bushing. In addition, cable support struts are being investigated.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.200		
In the event of a fault, how will isolation be accomplished to re-energize the maximum amount of turbines to keep production going while maintenance is occurring?	KLJ	Westwood	10/12/2017	For medium voltage cable or transformer faults, elbows will be parked and grounded at the next upstream transformer, which can then be placed back into service. Cables and transformers downstream of the fault will remain out of service.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.200		
This symbol should be defined in the legend.	KLJ	Westwood	10/12/2017	This has been revised.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.201		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.210		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.211		
Key map is somewhat confusing as it appears non-participating landowners are not shaded and participating are shaded. This is opposite of sheet E300 and the shading methodology utilized on the plan sheets E310-E331.	KLJ	Westwood	10/12/2017	Key map adjusted for clarity	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.310		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.311		
LV Power routing variance from the MV trench should be shown here.	KLJ	Westwood	10/12/2017	This has been revised to show the LV routing trench	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.312		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.313		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.314		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.315		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.316		

Can property corners be "split" like this or does a small easement need to be procured for this crossing? Different jurisdictions vary on rulings and enforcements of these types of crossings.	KLJ	Westwood	10/12/2017	Yes, County right of way is available for this route to be taken.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.317		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.318		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.319		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.320		
Is there an agreement to go across/under this non-participating piece of land?	KLJ	Westwood	10/12/2017	The thin strip of land shown as "non-participating" is the highway right of way, and therefore available.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.321		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.322		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.323		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.324		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.325		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.326		
I haven't seen a cable ampacity report for the project, but please verify that mutual heating in this small of an easement will not be detrimental to the ratings of the cable.	KLJ	Westwood	10/12/2017	Ampacity study has been revised and is issued with 60% package.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.327		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.328		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.329		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.330		
No Comments	KLJ	Westwood	10/12/2017		Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.331		
URD stands for Underground Residential Distribution. Most medium voltage cable is commonly referred to as "URD" but it is not believed that the intention here is actually for a "URD" cable to installed for this renewable energy installation.	KLJ	Westwood	10/12/2017	Cable designed and procured is MV-90 cable. This has been changed.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.400		
This will need to be included as part of the cable sizing and studies work and be included.	KLJ	Westwood	10/12/2017	Ampacity study has been revised and is issued with 60% package.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.400		
What size are these?	KLJ	Westwood	10/12/2017	Materials listed (with sizes) in Section View.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.410		
What size are these?	KLJ	Westwood	10/12/2017	Materials listed (with sizes) in Section View.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.410		
What size is this?	KLJ	Westwood	10/12/2017	Materials listed (with sizes) in Section View.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.410		
What is the intent for getting the 35 kV cable into the transformer box pad?	KLJ	Westwood	10/12/2017	MV Conduits routing included in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.410		
Per Key Note 1, this is not shown in Detail A.	KLJ	Westwood	10/12/2017	This is resolved in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.411		
How does PES6 penetrate the concrete or transformer box pad to connect the transformer ground to the grounding ring?	KLJ	Westwood	10/12/2017	Conductor enters box bad underneath through slurry.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.411		
Is the box pad large enough to allow this slack coil without exceeding the bend radius for all sizes?	KLJ	Westwood	10/12/2017	Min bend radius is 12 x cable diameter, or 30" for 1250 kcmil cable. Boxpad dimensions typically accommodate this.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.420		
Verify you are in compliance with NESC separation of grounding requirements.	KLJ	Westwood	10/12/2017	Design does not violate applicable sections of NESC 2017, Rule 097	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.420		
Are the bushings rated for this much weight when larger sized cables may be piggy-backed?	KLJ	Westwood	10/12/2017	See Item 16	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.420		
Material list states "Cap Screw" this states "Bolt". Which is it?	KLJ	Westwood	10/12/2017	Both cap screws and bolts are used. Materials have been updated.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.420		
Item 6 states a "Cap Screw" not 4/0 AWG Copper Ground Bus.	KLJ	Westwood	10/12/2017	This is resolved in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.420		
Is the box pad large enough to allow this slack coil without exceeding the bend radius for all sizes?	KLJ	Westwood	10/12/2017	Min bend radius is 12 x cable diameter, or 30" for 1250 kcmil cable. Boxpad dimensions typically accommodate this.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.421		
Verify you are in compliance with NESC separation of grounding requirements.	KLJ	Westwood	10/12/2017	Design does not violate applicable sections of NESC 2017, Rule 097	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.421		
Material list states "Cap Screw" this states "Bolt". Which is it?	KLJ	Westwood	10/12/2017	Both cap screws and bolts are used. Materials have been updated.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.421		
Item 6 states a "Cap Screw" not 4/0 AWG Copper Ground Bus.	KLJ	Westwood	10/12/2017	This is resolved in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.421		
"JUNCTION"	KLJ	Westwood	10/12/2017	This is resolved in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.422		

This is a detail for a 3-Way Junction Box but the project contains a 4-Way Junction Box as well. Please revise/append/develop a detail/sheet to incorporate the 4-Way Junction Box.	KLJ	Westwood	10/12/2017	4-way junction added.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.422		
Item 6 is a connector not a 4/0 AWG Copper Ground Bus.	KLJ	Westwood	10/12/2017	This is resolved in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.422		
No 400 kcmil Copper on this sheet.	KLJ	Westwood	10/12/2017	400 copper removed.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.422		
There is no transformer grounding pad on this sheet.	KLJ	Westwood	10/12/2017	This is resolved in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.422		
Use of "T" or not is not consistent for labeling.	KLJ	Westwood	10/12/2017	This has been updated for consistency.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.800		
No turbine documents have been provided so can not verify these values.	KLJ	Westwood	10/12/2017	Turbine Grid Interconnection document attached.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.800		
No studies have been supplied to verify this information.	KLJ	Westwood	10/12/2017	Studies provided include AC cable ampacity, AC short circuit, AC load flow. AC harmonic study, grounding study, TOV study, and LVRT study forthcoming.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.800		
Overlapping text.	KLJ	Westwood	10/12/2017	This is resolved in latest version.	Northwest Ohio Wind Project - 30 pct Electrical Plans KLJ Review 10-12-17 E.800		

[illegible]

[illegible]

[illegible]

[illegible]

Technical Documentation

Wind Turbine Generator Systems

2.5-116 - 50/60 Hz



Grid Interconnection



imagination at work

www.gepower.com

Visit us at
<http://renewables.gepower.com>

All technical data is subject to change in line with ongoing technical development!

Copyright and patent rights

This document is to be treated confidentially. It may only be made accessible to authorized persons. It may only be made available to third parties with the expressed written consent of General Electric Company.

All documents are copyrighted within the meaning of the Copyright Act. The transmission and reproduction of the documents, also in extracts, as well as the exploitation and communication of the contents are not allowed without express written consent. Contraventions are liable to prosecution and compensation for damage. We reserve all rights for the exercise of commercial patent rights.

© 2016 General Electric Company. All rights reserved.

GE and  are trademarks and service marks of General Electric Company.

Other company or product names mentioned in this document may be trademarks or registered trademarks of their respective companies.



imagination at work

Table of Contents

1	Technology	5
2	Step-Up Transformer	5
3	Frequency Tolerance	6
4	Voltage Tolerance and Fault Ride-Thru	6
5	Protection	9
6	Minimum Grid Strength	9
7	Reactive Power Capability	10
8	WindFREE Reactive Power	10
9	WindINERTIA	10
10	Series Compensation Compatibility	10
11	Voltage Regulation	11
12	Harmonic Distortion	13
12.1	IEEE 60 Hz Distortions	13
13	System Modeling	13
13.1	Wind Turbine Short Circuit Modeling	13
13.2	Wind Turbine Dynamic Modeling	13
13.3	Wind Turbine Transient Modeling	14
13.4	Wind Turbine Dynamic Model Validation	14
13.5	Wind Turbine Transient Model Validation	14
14	Power Demand	14
15	Representative Generator Data: Equivalent Circuit Diagram	14
16	Wind Farm Open Circuit Protection	15
17	Step-Up Transformer Protection	15
18	Reactive Power Capability Curves	16
19	Doubly-Fed Induction Generator (for reference only)	20
	Appendix I – 2.5-116 – 50 Hz and 60 Hz	21

1 Technology

The 1&2MW Platform – 2.5-116 50 Hz and 60 Hz wind turbine is variable speed and employs a doubly-fed induction generator with a power converter interfacing the rotor to the grid. The wind turbine is capable of supplying/drawing reactive power to/from the grid thus contributing to grid voltage support. The turbine employs the Electrically Simplified System (ESS). The wind turbine is capable of quickly regulating voltage on a continuous basis and providing dynamic reactive power to the power system that corresponds to a selection of under excited/overexcited power factor offerings.

Unless stated otherwise, all the data shown is referenced to 690 V side of the WTG transformer.

2 Step-Up Transformer

The individual wind turbines are connected through a step-up transformer to the collection system. The turbine operating performance, arc flash protection, and certification requirements listed in this and other documents are based on the assumption that the (pad mount) transformer at the turbine is designed to these requirements:

- 690 VAC L-L (wye-grounded): 2000-34500 VAC (Delta)
- Impedance of 5.75% with a tolerance of +/- 0.575 percentage points
- kVA rating in the range of 2700kVA to 3000kVA and selected in relation to impedance and the connected grid MVA such that the available short circuit current is no less than 8.4 kA or 12 kA (for turbines with voltage ride-through not enabled and enabled, respectively), and is less than the Maximum symmetrical short circuit withstand capability (at LV side of pad-mount transformer) value listed in the appendix. For kVA ratings outside this range, please consult with GE.

The customer is responsible for ensuring the size of the transformer size and type meets industry acceptable practices with respect to thermal management and its impact on reliability.

The collector system design, grid strength size, and impedance of the transformer determine available short circuit current.

Low voltage side protection may or may not be included. The decision not to supply protection on the low-voltage side of the wind turbine's step-up transformer can only be taken under the assumption that proper fusing is selected for the medium-voltage. Equipment experiencing this level of intake may be significantly damaged with likely hardware replacement.

The voltage tolerance in section 4 is a dynamic range in which the turbine operates. Long term changes to the steady state voltage at the LV terminals due to changes of the MV level in the grid or collector system may result in a reduction of the active and reactive power range or in a turbine trip. Transformer tap changers can help keep collector system voltage centered and maximize turbine capability. Taps of +/- 2 x 2.5 % are recommended.

3 Frequency Tolerance

Frequency limits for the 2.5-116 50 Hz and 60 Hz wind turbine follow:

Frequency (Hz)	Withstand time (s)
45.0 – 47.0	60
47.0 – 53.0	Continuous
53.0 – 55.0	60

Table 1: Frequency Tolerance 50 Hz

Frequency (Hz)	Withstand time (s)
55.0 – 57.0	60
57.0 – 63.0	Continuous
63.0 – 65.0	60

Table 2: Frequency Tolerance 60 Hz

4 Voltage Tolerance and Fault Ride-Thru

Wind Ride-Thru packages enable the wind turbine to continue to operate during (“ride-through”) and after transmission system faults resulting in a severe voltage dip at the wind farm. Available options are Low Voltage Ride-Thru (LVRT) & Zero Voltage Ride-Thru (ZVRT). The table below and Figure 1 summarize voltage ride through capabilities for a single event.

It is possible to adjust the behavior of active and reactive current during and immediately after a fault to meet a variety of grid codes.

Dynamic Voltage Range (%)	Time (s)	
	LVRT	ZVRT
90 ¹ -100	Continuous	Continuous
85-90 ¹	600	600
75-85	10	10
15-75	0.625 to 2.5 ²	
0-15	-	1.0-3.0 ^{3 4}

Table 3: Voltage Tolerance & Fault Ride-Thru

¹ 690 V terminals clamped at 90%. MV side voltage will depend on reactive power command.

² Ramp from 15% at 0.625s to 75 % at 2.5s

³ Ramp from 0% at 1.0s to 70 % at 3.0s

⁴ Converter may stop pulsing during this period




Figure 1: Low voltage ride thru

The turbine high voltage ride-through capability for a single event is summarized in Table 4 and Figure 2.

Dynamic Voltage Range (%)	Time (s)
	HVRT
100-112 ⁵	Continuous
112 ⁵ -115	300
115-120	30
120-125	2
125-138	0.5
138-150	0.3
150-160	0.03 ⁶

Table 4: Voltage Tolerance

⁵ 690V terminals clamped at 110%. MV side voltage will depend on reactive power command.

⁶ Capacitor switching transients




Figure 2: High voltage ride thru

The turbines are also capable of riding through three reclosing events of 160 ms with a minimum of 1.5 s time lag between the end of the previous closure and the start of the next ZVRT event. The Figure below represents the multiple fault ride-through capability of the turbine.

It is not recommended or envisioned for the wind farm to be radially connected to the grid via auto-reclosers.




Figure 3: Reclosing

5 Protection

The GE wind turbine has the following built-in protection functions:

- Over Voltage (ANSI-59) / Under Voltage (ANSI-27)
- Over Frequency (ANSI-81O) / Under Frequency (ANSI-81U)
- Voltage Imbalance (ANSI-60)

Additionally, the main circuit breaker, located in the control cabinet at the bottom of the tower, provides over current protection (ANSI-51) and comes with instantaneous, short-time and long-time settings. Note that these functions are designed for protection of the wind turbine hardware.

6 Minimum Grid Strength

The 1&2MW Platform 50 Hz and 60 Hz wind turbine is designed to operate with a composite short circuit ratio (CSCR) above 1.7 (on a MW base) at the medium voltage side of the turbine transformer. Composite SCR is defined as the ratio of the Composite short circuit MVA to the sum of the nameplate MW of all electrically close wind turbine generators within and outside the wind farm of interest. The composite short circuit MVA is calculated for a 3 phase short circuit applied to the medium voltage side of all the turbine transformers that are electrically close within and outside the wind farm of interest, interconnected with zero impedance between each other. The composite short circuit MVA calculation should reflect the maximum grid impedance under which the wind farm is expected to continue normal operation. The composite short circuit MVA should not include the short circuit contribution from the wind turbine generators themselves. The denominator in the calculation of CSCR is the sum of the nameplate MW and must include all wind turbine generators in the proposed wind farm as well as other nearby wind farms that are electrically close. For complex networks with multiple wind farms in the vicinity of each other the information required to calculate CSCR accurately may be available only to the grid operator.

Note that the CSCR capability of 1.7 is determined based on a broad set of operating points, network parameters and grid contingencies. However, the turbines can operate at CSCR values as low as 1.1 depending on evaluation of actual condition associated with the wind farm. The evaluation of operation at low CSCR values is typically based on transient simulations of the network considering a range of operating points, network parameters and grid contingencies, which differ from project to project. If a grid operator has a concern on the short circuit ratio, GE can provide a black box PSCAD model of the wind farm that can be used for transient simulations of the network for the purpose of determining expected performance. If a grid operator decides to perform such a study, it is essential that GE be involved to highlight how changes within the product capability can achieve the desired performance. Alternatively, if the grid operator can define the requirements for such a study and is willing to provide GE with the details of the network, then GE Energy Consulting can be contracted to perform the study.



In situations where there is a low grid strength and therefore low fault current available, there is an increased risk of arc flash hazards in the down tower of the turbine unless additional protection/procedures are utilized on the secondary (LV) side of the pad-mount transformer. In all cases there is an absolute minimum LV side 3 phase fault current at each turbine of 12 kA. This means that for projects with a small numbers of units, the ratio given above may not be adequate for protection purposes. In all cases the guidelines of Section 17 apply related to step up transformer protection.

7 Reactive Power Capability

Standard power factor range for all 1&2MW Platform wind turbines is ± 0.95 . Enhanced reactive power capability (range of ± 0.90) is available as an option and in many cases can be used to meet a ± 0.95 requirement at the point-of-interconnection. It is possible that high altitude and/or high temperature conditions and low terminal voltage may lead to real power de-rating especially if there is a concurrent high demand for reactive power.

Reactive power capability curves for these machines are shown in section 18.

8 WindFREE Reactive Power

As an optional feature, the 2.5-116 - 50 Hz and 60 Hz wind turbine can provide reactive power (+/-400 kVAR) even when there is no active power generation (i.e. wind speed below cut-in or above cut-out). This is achieved by utilizing capabilities of the line side converter.

9 WindINERTIA

With the optional “WindINERTIA” feature, the 2.5-116 - 50 Hz and 60 Hz wind turbine can provide inertial response to help stabilize grid frequency. This feature supports the grid during under frequency events by providing a temporary increase in power production (6-7 %) increase in kW) for a short duration (10 sec), contributing towards frequency recovery. This is achieved by tapping into the stored kinetic energy in the rotor mass. The response is equivalent to that of a synchronous generator with an inertia constant of 3.5 sec.

10 Series Compensation Compatibility

Wind turbine generators (WTGs) connected to series compensated transmission can exhibit sub-synchronous interaction (SSI). For 1&2MW turbines, an option exists to allow the WTGs to operate with series compensated transmission lines, where the series compensation is up to 50 %. This option presents a positive resistance to the grid for the range of sub-synchronous frequencies where resonance is likely to occur, and thereby provides damping to reduce the effect of SSI and sub-synchronous resonances (SSR). Should the option for operation with series compensated transmission not be selected, the base capability of the 1&2MW turbines includes a detection algorithm for SSR. When a SSR situation is detected, the WTG is tripped.

11 Voltage Regulation

GE's WindCONTROL is a voltage / power factor / VAR controller that exploits the reactive power capability of the individual wind turbine to meet a voltage / power factor / VAR set point at the point of interconnection. It measures the voltage and current at the point of interconnection (POI) and controls the wind farm's reactive power to regulate the voltage, power factor or VAR at the POI. Through a graphical user interface (GUI), the user selects the mode of operation and enters the set points for voltage, power factor or VAR control. Set points can also be read using communication interfaces or hardwired inputs.

WindCONTROL is available with the following optional grid friendly features (see WindCONTROL overview for more info):

- Dynamic VAR Control (Voltage, PF or VAR control)
- Line Drop Compensation
- Voltage Droop
- Power Curtailment with capability to curtail segments
- Capacitor/Reactor Bank Control
- Ramp Rate Control
- Frequency Droop Control

The figures below plot the simulated response of a wind farm with GE wind turbines connected to a weak grid. The wind farm is subjected to ten minutes of highly variable wind near rated wind speed. The red traces show the response with Dynamic VAR control operational. The black traces show the response with Dynamic VAR control disabled, namely the individual wind turbines operating in conventional local fixed power factor mode. At the point of interconnection (44 miles / 77 km from the wind farm), the system voltage with conventional power factor control exhibits unacceptable fluctuations. With the WindCONTROL controlled system, the host utility voltage is tightly regulated and voltage variation is quite limited. GE's WindCONTROL provides tight voltage regulation, effectively eliminating concerns about flicker.




Figure 4: System Performance with and without WindCONTROL

12 Harmonic Distortion

Harmonic distortion data for the 2.5-116 - 50 Hz and 60 Hz machines can be provided as required by IEC 61400-21. Scaled up values based on the tests conducted on the sub-2MW turbines will be provided till test results are available.

12.1 IEEE 60 Hz Distortions

The 1&2MW wind turbine current harmonic distortion measured at the 690 V terminals of a turbine is within limits specified below in IEEE Std. 519-1992, "IEEE Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems." Limits are summarized in Table 5.

- PCC is the point of common coupling
- TDD is the total demand distortion (THD normalized by the current I_n)
- I_n is the maximum fundamental frequency current at PCC
- Even Harmonics shall be limited to 25 % of the odd harmonics limits.

Voltage @ PCC	$h < 11$	$11 \leq h < 17$	$17 \leq h < 23$	$23 \leq h < 35$	$h \geq 35$	Current TDD%
$V \leq 69 \text{ kV}$	4.0	2.0	1.5	0.6	0.3	5.0

Table 5: IEEE Current Distortion Limits

13 System Modeling

13.1 Wind Turbine Short Circuit Modeling

The 1&2MW Platform 2.5-116 - 50 Hz and 60 Hz wind turbine is a doubly-fed asynchronous generator with the stator directly connected to the grid while the rotor is interfaced through a frequency converter to the grid. For most faults that occur on the grid, the turbine will act as a controlled current source- contributing up to 3 per unit fault current for up to 5 cycles, after which it returns to normal current contribution (i.e. 1 per unit). For faults on the grid, the contribution from the turbines is minimal compared to that from the grid.

One exception is for "close-in" faults (e.g.: inside the wind farm, at the wind farm substation etc.) where, depending on the severity, the converter may "crowbar" (i.e. disconnect itself to protect the power electronics within). In this case the turbine rotor is short-circuited like that of a squirrel cage induction generator. The behavior can be approximated to $X' = 0.2$, contributing a max of 5 per unit fault current.

13.2 Wind Turbine Dynamic Modeling

A dynamic model of the GE wind turbine is available in GE's dynamic simulation program known as Positive Sequence Load Flow (PSLF -- from GE Energy Consulting) and Power System Simulation for Engineering (PSS/E). Any user with a valid license and current maintenance and support (M&S) agreement of the respective software can obtain the latest GE wind turbine model in that software directly from GE or PTI. The model comes with documentation and default data. This is intended to save time, reduce data entry efforts and

copying errors, and get rid of unnecessary mechanical work. The dynamic model is based on GE's document "Modeling of GE Wind Turbine-Generators for Grid Studies".

13.3 Wind Turbine Transient Modeling

GE Energy Consulting maintains a transient model of the GE wind turbine and can be contracted to perform detailed studies.

13.4 Wind Turbine Dynamic Model Validation

The dynamic model of the GE wind turbine implemented in PSLF, has been validated by comparing the response to simulations performed in WindTRAP (transient program). Simulations show closely matching results with a small offset in the wind turbine's reactive power and reactive current. High-frequency transients in WindTRAP are not expected to be present in PSLF simulations. Details of PSLF Validation are in the document "Modeling of GE Wind Turbine-Generators for Grid Studies".

13.5 Wind Turbine Transient Model Validation


The transient model of the GE wind turbine has been validated against factory tests for three-phase and line-to-ground faults at the generator terminals. Results show that simulations closely matched recorded data.

14 Power Demand

The power demand of the wind turbine generator system during calm wind periods can include the yaw motor, control system, cold weather package, lighting and hydraulic pump and amount to a maximum 40 kW if all loads are operating at the same time.

The annual energy demand at a site with an average wind speed is 4000 to 10000 kWh/a.

15 Representative Generator Data: Equivalent Circuit Diagram



The above diagram is an operating equivalent circuit. Equivalent circuit parameters will vary according to generator installed. Data can be provided for specific generator models upon request.

16 Wind Farm Open Circuit Protection

Wind turbines are controlled current sources and need to be connected to the grid for proper operation. The effect of an open circuit event (islanding) on the wind turbine's converter is related to the charging capacitance that is present in the island. Islanding under high capacitance may result in transient over voltages that can lead to power converter component damage. To protect the power converter against this condition, GE wind turbines utilize a proprietary algorithm to detect an open-circuit event and initiate a shut-down to safely take the turbine off line while protecting against high voltage excursions. Open-circuit detection is determined based on analysis of three elements: voltage, frequency, and real power output. Since the machine behaves as a controlled current source, overvoltage is typically a first indicator, but other diagnostics, such as frequency deviation and reduction in real power output are used to confirm the open-circuit condition. The algorithms differentiate open-circuit events, which require the unit to shut down, from voltage and frequency ride-through events, which require turbines to stay on-line and ride-through the event.

Since charging capacitance plays a vital role in the level of protection that can be achieved, it is important that the per turbine charging capacitance be calculated. In this calculation, the wind farm collection system and the portion of the transmission lines outside the wind farm that may be part of the island should be considered. Guidelines for calculation per turbine charging capacitance are provided in a GE white paper. Protection against an open-circuit event is achieved if the per turbine charging capacitance is less than 1200kVAR at the time of the event.

17 Step-Up Transformer Protection

Arc hazard resulting from a phase-to-phase or phase-to-ground fault within the cable entry area of the Power Distribution Cabinet (PDC) of the Down tower Assembly (DTA) can be significant and needs to be controlled. Low voltage protection at the turbine step up transformer is the preferred method of controlling the amount of energy released into the cabinet during a fault. Design effort has been taken to increase robustness of the PDC and to isolate incoming conductors.

1. Access to the cable entry area of the PDC, where incoming cables connect to the circuit breaker, is restricted. The enclosure around the cable entry area has been reinforced. This configuration aids in the prevention of an arc hazard. No access is allowed to the cable entry area of the PDC when energized. Any special need to troubleshoot this area of the cabinet requires the step-up transformer to be de-energized at the medium-voltage side unless a circuit breaker exists on the low voltage side of the pad mounted transformer to isolate the wind turbine generator that can be locked out.
2. All incoming power to the other areas within the DTA is protected by fuses and circuit breakers. Access to these cabinets is acceptable while the incoming power to the PDC is energized as long as Log-out Tag-out (LOTO) and standard safety precautions are followed and personal protection equipment (PPE) is employed.

Factors that influence the time duration and energy released during a fault include the impedance of the step-up transformer, the medium-voltage fuse on the step-up transformer, and the type of fault (3-phase, line-to-line, or line-to-ground). The larger the impedance of the arcing fault, the longer the fault and the greater the danger potential to personnel and equipment.

The equipment owner should conduct an arc flash analysis that is based on the expected maintenance and operating procedures, LOTO procedures, personnel protective equipment, transformer impedance and available short circuit MVA. This analysis should determine what protection should be applied to the MV side of the transformer (breakers, fuses) and if any LV side protection is required. If LV side protection is determined to be required then it should be in the form of a circuit breaker with LSIG protection with settings coordinated with the Q1 breaker in the wind turbine.

18 Reactive Power Capability Curves

The reactive power capability of the 2.5-116 MW - 50 Hz and 60 Hz turbines for sites at altitude less than 1000 m is represented here. These curves are shown at different ambient temperatures and terminal voltages. For high ambient temperature and/or low voltage, de-rating may be necessary to meet the demanded reactive power output. The turbine will operate in a Q priority mode, which will provide the demanded reactive power and reduce, if necessary, the real power. An example of this de-rating is shown by the rounded corners in the graph below.

The rectangular curves show the reactive power capability of turbines rated at 0.9PF when the plant is operating in voltage control mode. The max reactive power capability in MVAR of turbines rated at 0.95 PF is 0.328 times the MW rating. When the turbines are operating in the power factor control mode, their capability is shown by the dotted lines. Reactive power capability may be reduced during noise reduced operation modes.




Figure 5: 60 Hz Reactive Power Capability – from 1.0pu to 1.05pu voltage

CONFIDENTIAL - Proprietary Information. DO NOT COPY without written consent from GE Electric Company.

UNCONTROLLED when printed or transmitted electronically.

© 2016 GE Electric Company. All rights reserved




Figure 6: 60 Hz Reactive Power Capability – 0.95pu voltage




Figure 7: 60 Hz Reactive Power Capability – 0.9pu voltage

CONFIDENTIAL - Proprietary Information. DO NOT COPY without written consent from GE Electric Company.

UNCONTROLLED when printed or transmitted electronically.

© 2016 GE Electric Company. All rights reserved




Figure 8: 50 Hz Reactive Power Capability – from 1.0pu to 1.05pu voltage




Figure 9: 50 Hz Reactive Power Capability – 0.95pu voltage

CONFIDENTIAL - Proprietary Information. DO NOT COPY without written consent from GE Electric Company.

UNCONTROLLED when printed or transmitted electronically.

© 2016 GE Electric Company. All rights reserved




Figure 10: 50 Hz Reactive Power Capability – 0.9pu voltage




Note



These reactive power curves do not represent the capability of turbines for installation in Canada. The cable derating requirements in the Canadian Electric code result in a slight derating of the reactive power curves. Please contact your GE representative to obtain reactive power curves for Canadian projects.

19 Doubly-Fed Induction Generator (for reference only)



CONFIDENTIAL - Proprietary Information. DO NOT COPY without written consent from GE Electric Company.

UNCONTROLLED when printed or transmitted electronically.

© 2016 GE Electric Company. All rights reserved

Appendix I – 2.5-116 – 50 Hz and 60 Hz

General Data (Reference Only)

Parameter	50 Hz	60 Hz	Units
Turbine Rated Output	2500		kW
Generator Rating	2600		kW
Rated Voltage	690		V
Apparent Power [@ PF = 0.95 lag]	2632		kVA
Rated Frequency	50	60	Hz
Poles	4	6	--
Power Factor – Options	+/-0.95; +/- 0.90		--
Rated Current:			
Stator	2000		A
Rotor	800		A
Locked Rotor Voltage	1895	1933	V
Connection:			
Stator	Delta or Star		--
Rotor	Star		--
Synchronous Speed	1500	1200	rpm
Rated Speed	1820	1497	rpm
Slip at Rated Speed	21	25	%
Speed Range	1000-2038	800-1665	rpm
Max Frequency Drift	4		Hz/sec
Maximum symmetrical short circuit withstand capability (at LV side of Pad-mount Transformer)	35		kA
Max Voltage Imbalance	4		%

Table 6



SHORT CIRCUIT STUDY

Northwest Ohio Wind Project

Paulding, Ohio

September 25, 2017

Prepared for:



Prepared by:

Westwood

Westwood

Project Name: NW OH Wind Project	
Title	J.O. or W.O. Number
Short Circuit Study	0007186.00

Approvals		Revision Number	Date	Description
Preparer(s) Name	Reviewer(s) Name			
Josh Venden	Drew Szabo	0	09/25/2017	Original Release

Westwood

TABLE OF CONTENTS

INTRODUCTION	4
OBJECTIVE	4
INPUTS & ASSUMPTIONS	4
METHODOLOGY	5
CONCLUSION	5
APPENDIX A: SHORT CIRCUIT SUMMARY REPORTS.....	A
APPENDIX B: ETAP SINGLE LINE DIAGRAM	B
APPENDIX C: ETAP MODEL INPUTS	C

Westwood

INTRODUCTION

NW OH Wind Project is a 100 MW wind generation installation in Paulding, OH consisting 42 of GE 2.5 MW wind turbines. The turbines are grouped into four medium voltage (MV) feeders with 10 turbines on Feeders 1 and 4 and 11 turbines on Feeders 2 and 3. The feeders are connected to a main power transformer that steps the voltage up to 138kV where it interconnects with the AEP transmission system via a short overhead line segment.

OBJECTIVE

The objective of this report is to determine the fault currents at the medium and low voltage buses within the NW OH wind generation plant. The fault current information is used to determine minimum conductor and concentric neutral sizes required to withstand the short circuit current for a set time.

INPUTS & ASSUMPTIONS

- Short circuit analysis performed with ETAP v16.0.0C power system simulation software.
- Medium voltage AC collector electrical layout is per the Westwood Professional Services Electrical Drawings, MVAC Collection One-Line Diagrams E.200 & E.210.
- ETAP model parameters for equipment such as turbines (WTG), step-up transformers (GSU) and main power transformer (MPT) based on manufacturer data when available or typical ETAP values when information is not available.
- ETAP model parameters for MV cables based on thermal analysis using CYME Cymcap Underground Cable Thermal Analysis software.
- ETAP model parameters for overhead transmission line data based on ETAP library of standard overhead conductors.
- ETAP model parameters for utility equivalent impedance information provided by AEP.
- The short circuit contribution of the wind turbines, as provided by GE, is a maximum of five times the rated current for up to 5 cycles (~12kA).
- The grounded wye connection of the main power transformer secondary is connected to ground reactor of 0.6 ohms.
- Per the Ulteig Relay Settings Philosophy, the maximum clearing times are assumed to be 8.5 cycles for phase faults and 3.5 cycles for ground faults; it is also assumed for CN sizing that 100% of ground fault current flows in the concentric neutral.
- An operating temperature (T_{OP}) of 90°C is assumed for phase conductors and 80°C for concentric neutrals.
- The maximum, or short circuit temperature (T_{SC}), is assumed to be 250°C for phase conductors and 200°C for the concentric neutrals.
- A parallel ground conductor is included in all of the MV cable trenches and is assumed to be 7#8 copper-clad steel.
- Appendix C shows the various ETAP inputs used.

Westwood

METHODOLOGY

- This analysis utilizes the Short Circuit module of ETAP to calculate bus fault currents at all medium and low voltage buses in the NW OH wind generation facility.
- For each bus the maximum 3-phase (3PH), line-to-ground (SLG), line-to-line (L2L) and double-line-to-ground (LLG) fault currents are shown with the wind farm in and out of service.
- The maximum phase fault current is used to verify conductor sizing; maximum ground fault current is used to determine minimum CN sizing and trench ground conductor withstand time.
- Conductor and concentric neutral (CN) sizing worksheet based on the following ICEA cable temperature rise equation:

$$A = \frac{I * \sqrt{t}}{\sqrt{K * \log_{10} \left[\frac{T_{SC} + \lambda}{T_{OP} + \lambda} \right]}}$$

Where:

A = cross-sectional area (Circular mils);

I = short circuit current (A);

t = fault clearing time (s);

K = time/temp coefficient (0.0125 Al; 0.0297 Cu);

T_{SC} = short circuit temperature;

T_{OP} = operating temperature;

λ = base temperature (228°C Al; 234°C Cu)

- Appendix A shows the fault currents for each MV and LV bus in the wind farm.

CONCLUSION

- The maximum phase fault current for each cable size is determined from the ETAP analysis. This current corresponds to the minimum required cross-sectional area of phase conductor necessary to withstand the respective fault current for up to 8.5 cycles.
- The table below confirms the cross-sectional area of the phase conductors is larger than the required minimum for every cable size. Cable ampacities are also shown.

Westwood

Table 1: Phase Conductor Summary

Cable	Material	Maximum 3PH Fault Current	Min. Required Area	Phase Conductor Area	Ampacity & Configuration	
1/0	Al	10486	83908	105600	142.3	Trefoil
4/0	Al	13367	106961	211600	212.9	Trefoil
500	Al	6848	54797	500000	334.7	Trefoil
750	Al	11533	92286	750000	408.6	Trefoil
1000	Al	10238	81923	1000000	477.1	Trefoil
1250	Al	12754	102056	1250000	540.5	Trefoil
1250*	Al	12754	102056	1250000	570.5	Trefoil

* Increased ampacity based on 90% soil compaction in trenches with 11 turbines on the ckt

- The maximum ground fault current for each cable size is determined from the ETAP analysis. This current is used to determine a minimum required total cross-sectional area of concentric neutral conductors necessary to withstand the respective fault current for up to 3.5 cycles. The cross-sectional area is a combined area of several smaller gauge conductors concentrically wrapped around the phase conductor.
- The following table summarizes the fault current, cross-sectional area and concentric neutral sizes for the cables used at the NW OH wind generation facility. A list of stock cables was provided by White Construction and the cross-sectional area of all CN sizes as indicated below exceed the required minimums.

Table 2: Concentric Neutral Summary

Cable	CN Material	Maximum SLG Fault Current	Fault Location	CN Min. Required Area	Conc Neut SC Withstand Min. Size	
1/0	Cu	7303	T-21	27299	2/3	18x16AWG
4/0	Cu	9801	T-24	36637	1/2	17x14AWG
500	Cu	5922	T-15	22137	1/3	16x12AWG
750	Cu	8634	T-17	32275	1/6	19x14AWG
1000	Cu	7634	T-10	28537	1/6	25x14AWG
1250	Cu	10692	T-25	39968	1/6	20x12AWG

- Future utility system data was also provided based on 2022 projected power flow models. The model was adjusted to reflect the future utility equivalent data and the resulting bus fault currents within the collector system were analyzed to ensure CN sizing was adequate for near term projected increases in fault current. The following table shows the increase in fault current does not result in the need for larger concentric neutrals.

Westwood

Table 3: Projected Fault Current and CN Sizing

Cable	CN Material	Projected SLG Fault Current	Fault Location	Min. Required cmils neutral	Conc Neut SC Withstand Min. Size	
1/0	Cu	7362	T-21	27520	2/3	18x16AWG
4/0	Cu	9920	T-24	37082	1/2	17x14AWG
500	Cu	7142	T-15	22242	1/3	16x12AWG
750	Cu	8535	T-17	32600	1/6	19x14AWG
1000	Cu	7699	T-10	28780	1/6	25x14AWG
1250	Cu	10834	T-25	40498	1/6	20x12AWG

- The trench ground and low voltage conductors' short circuit withstand time is based on a simplified version of the ICEA equation shown above. Taking Equation (42) from the IEEE 80-2000 standard and solving for time (t) results in the following equation. K_f is the material constant based on Table 2 in IEEE 80-2000.

$$t = \left(\frac{Area_{kCMIL}}{K_f * I_{kA}} \right)^2$$

- K_f is equal to 10.45 for copper-clad steel wire with a conductivity of 40%. The short circuit withstand for the parallel trench ground is approximately 0.725 seconds or 43.5 cycles. This is adequate to withstand maximum ground fault current until protective devices can interrupt the fault.

$$t = \left(\frac{115.570}{10.45 * 12.975} \right)^2 = 0.727 \text{ sec}$$

- K_f is equal to 7.00 for soft-drawn copper wire. The connections between the turbine and transformer are 9x1000kCMIL cables. The short circuit withstand for the low voltage cables is over 10 minutes. This is adequate to withstand maximum ground fault current until protective devices can interrupt the fault.

$$t = \left(\frac{9000}{7.00 * 49.876} \right)^2 = 664.5 \text{ sec}$$

APPENDIX A: SHORT CIRCUIT SUMMARY REPORTS

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 1
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: WTG OFFLINE

Short-Circuit Summary Report

1/2 Cycle - 3-Phase, LG, LL, & LLG Fault Currents

Prefault Voltage = 100 % of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	kV	Real	Imag.	Mag.	Real	Imag.	Mag.	Real	Imag.	Mag.	Real	Imag.	Mag.
89F1A	34.500	0.682	-8.285	8.313	0.529	-8.434	8.451	7.175	0.591	7.200	6.993	4.881	8.528
89F2A	34.500	0.682	-8.285	8.313	0.529	-8.434	8.451	7.175	0.591	7.200	6.993	4.881	8.528
89F3A	34.500	0.682	-8.285	8.313	0.529	-8.434	8.451	7.175	0.591	7.200	6.993	4.881	8.528
89F4A	34.500	0.682	-8.285	8.313	0.529	-8.434	8.451	7.175	0.591	7.200	6.993	4.881	8.528
89T1A	138.000	1.600	-7.007	7.187	1.491	-7.268	7.419	6.068	1.386	6.224	5.388	5.156	7.457
89T1B	34.500	0.682	-8.285	8.313	0.529	-8.434	8.451	7.175	0.591	7.200	6.993	4.881	8.528
HV BUS MPT	138.000	1.600	-7.007	7.187	1.491	-7.268	7.419	6.068	1.386	6.224	5.388	5.156	7.457
JB-2/1	34.500	0.964	-7.347	7.410	1.975	-6.522	6.814	6.362	0.835	6.417	-7.651	1.973	7.901
JB-4/1	34.500	2.346	-3.482	4.199	2.145	-2.057	2.972	3.016	2.032	3.636	-3.914	-1.349	4.140
MV BUS T-01	34.500	2.638	-2.019	3.322	2.418	-1.720	2.968	1.749	2.284	2.877	-2.862	-1.539	3.250
MV BUS T-02	34.500	2.773	-2.302	3.603	2.555	-1.976	3.230	1.993	2.401	3.121	-3.174	-1.540	3.528
MV BUS T-03	34.500	2.884	-2.591	3.877	2.670	-2.241	3.485	2.244	2.498	3.357	-3.482	-1.514	3.797
MV BUS T-04	34.500	2.963	-2.734	4.032	2.761	-2.414	3.667	2.368	2.566	3.492	-3.657	-1.489	3.949
MV BUS T-05	34.500	3.054	-2.912	4.220	2.865	-2.635	3.892	2.522	2.645	3.655	-3.869	-1.443	4.130
MV BUS T-06	34.500	3.150	-3.100	4.419	2.971	-2.781	4.070	2.684	2.728	3.827	-4.088	-1.470	4.344
MV BUS T-07	34.500	3.217	-3.434	4.705	3.044	-3.109	4.351	2.974	2.786	4.075	-4.416	-1.368	4.623
MV BUS T-08	34.500	2.951	-4.308	5.222	2.922	-3.517	4.573	3.731	2.556	4.522	-5.131	-1.097	5.247
MV BUS T-09	34.500	1.282	-6.356	6.484	2.454	-4.999	5.569	5.504	1.110	5.615	-6.904	0.766	6.946
MV BUS T-10	34.500	1.207	-6.582	6.692	2.392	-5.324	5.837	5.700	1.045	5.795	-7.109	1.010	7.180
MV BUS T-13	34.500	3.040	-2.582	3.988	2.874	-2.344	3.709	2.236	2.633	3.454	-3.597	-1.561	3.921
MV BUS T-14	34.500	3.144	-2.867	4.255	2.981	-2.630	3.976	2.483	2.723	3.685	-3.899	-1.509	4.181
MV BUS T-15	34.500	3.337	-3.807	5.062	3.172	-3.593	4.793	3.297	2.890	4.384	-4.808	-1.189	4.953
MV BUS T-16	34.500	3.050	-2.754	4.109	2.865	-2.446	3.767	2.385	2.641	3.559	-3.732	-1.544	4.039
MV BUS T-17	34.500	1.110	-7.014	7.101	2.202	-6.012	6.402	6.074	0.962	6.150	-7.448	1.519	7.602
MV BUS T-20	34.500	2.850	-4.822	5.601	3.030	-3.683	4.769	4.176	2.468	4.851	-5.645	-1.045	5.741
MV BUS T-21	34.500	2.137	-6.184	6.543	2.799	-4.985	5.717	5.356	1.850	5.666	-6.853	0.132	6.855
MV BUS T-22	34.500	1.603	-6.721	6.910	2.508	-5.599	6.135	5.821	1.389	5.984	-7.265	0.883	7.319
MV BUS T-23	34.500	1.061	-6.916	6.997	2.272	-5.648	6.087	5.990	0.919	6.060	-7.356	1.295	7.469
MV BUS T-24	34.500	1.289	-7.385	7.496	2.021	-6.807	7.100	6.395	1.117	6.492	-7.667	1.965	7.915
MV BUS T-25	34.500	0.857	-7.744	7.791	1.511	-7.356	7.509	6.706	0.742	6.747	-7.727	2.706	8.188
MV BUS T-26	34.500	2.279	-5.481	5.936	2.779	-3.900	4.789	4.746	1.974	5.141	-6.100	-0.568	6.127
MV BUS T-27	34.500	1.786	-6.103	6.359	2.644	-4.492	5.213	5.285	1.547	5.507	-6.655	0.089	6.655
MV BUS T-28	34.500	1.113	-6.640	6.732	2.372	-5.120	5.643	5.750	0.964	5.830	-7.098	0.933	7.159
MV BUS T-29	34.500	2.750	-5.120	5.812	3.021	-3.947	4.970	4.434	2.382	5.033	-5.922	-0.850	5.983
MV BUS T-31	34.500	2.571	-4.113	4.851	2.610	-2.687	3.746	3.562	2.227	4.201	-4.732	-1.300	4.907

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 2
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: WTG OFFLINE

1/2 Cycle - 3-Phase, LG, LL, & LLG Fault Currents

Prefault Voltage = 100 % of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	kV	Real	Imag.	Mag.	Real	Imag.	Mag.	Real	Imag.	Mag.	Real	Imag.	Mag.
MV BUS T-32	34.500	1.734	-5.671	5.930	2.579	-3.942	4.710	4.911	1.501	5.135	-6.197	-0.139	6.199
MV BUS T-33	34.500	1.310	-6.052	6.192	2.462	-4.348	4.996	5.241	1.134	5.362	-6.538	0.381	6.549
MV BUS T-34	34.500	1.541	-5.769	5.972	2.517	-4.012	4.736	4.997	1.334	5.172	-6.269	0.041	6.269
MV BUS T-36	34.500	2.282	-4.779	5.296	2.622	-3.141	4.091	4.139	1.976	4.586	-5.349	-0.906	5.426
MV BUS T-37	34.500	2.440	-4.401	5.032	2.605	-2.860	3.869	3.811	2.113	4.358	-4.990	-1.138	5.118
MV BUS T-39	34.500	2.528	-4.108	4.824	2.577	-2.653	3.699	3.558	2.189	4.177	-4.708	-1.283	4.880
MV BUS T-40	34.500	1.244	-5.513	5.652	2.309	-3.336	4.057	4.775	1.078	4.895	-5.848	-0.044	5.848
MV BUS T-41	34.500	2.379	-3.204	3.990	2.102	-1.899	2.833	2.774	2.060	3.456	-3.648	-1.425	3.917
MV BUS T-42	34.500	2.346	-3.475	4.192	2.143	-2.051	2.967	3.009	2.031	3.631	-3.906	-1.350	4.133
MV BUS T-43	34.500	2.378	-3.219	4.002	2.105	-1.908	2.841	2.787	2.059	3.465	-3.663	-1.422	3.929
MV BUS T-44	34.500	1.329	-4.890	5.068	2.161	-2.714	3.469	4.235	1.151	4.389	-5.182	-0.349	5.193
MV BUS T-45	34.500	1.293	-5.082	5.243	2.205	-2.879	3.626	4.401	1.120	4.541	-5.380	-0.260	5.387
MV BUS T-46	34.500	1.267	-5.336	5.485	2.270	-3.143	3.877	4.621	1.097	4.750	-5.657	-0.138	5.659
MV BUS T-48	34.500	2.277	-2.629	3.478	1.908	-1.529	2.445	2.277	1.972	3.012	-3.055	-1.463	3.387
MV BUS T-49	34.500	2.286	-2.889	3.683	1.964	-1.666	2.575	2.502	1.979	3.190	-3.306	-1.430	3.602
MV BUS T-50	34.500	2.277	-2.637	3.484	1.910	-1.533	2.449	2.284	1.972	3.017	-3.063	-1.462	3.394
POI	138.000	1.607	-7.030	7.211	1.499	-7.298	7.451	6.088	1.392	6.245	5.403	5.181	7.486

All fault currents are symmetrical (1/2 Cycle network) values in rms kA.

* LLG fault current is the larger of the two faulted line currents.

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 4
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: WTG OFFLINE

Bus		Positive Seq. Imp. (ohm)			Negative Seq. Imp. (ohm)			Zero Seq. Imp. (ohm)			Fault Zf (ohm)		
ID	kV	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance
MV BUS T-49	34.500	3.35538	4.24063	5.40755	3.35538	4.24063	5.40755	10.98652	6.52819	12.77971	0.00000	0.00000	0.00000
MV BUS T-50	34.500	3.73660	4.32671	5.71687	3.73660	4.32671	5.71687	11.55448	6.61925	13.31617	0.00000	0.00000	0.00000
POI	138.000	2.46184	10.77056	11.04833	2.46184	10.77056	11.04833	1.53107	9.88268	10.00058	0.00000	0.00000	0.00000

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 1
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Normal

Short-Circuit Summary Report

1/3 Cycle - / -Phase, L3 , LL, & LL3 Fault Currents

Prefault Voltage G 100 = of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	%/	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.
59F1A	/ 4.800	2.117	-18.99/	16.1/ 2	0.996	-12.866	12.608	1/ .570	1.548	1/ .99/	1/ .6/ 7	6.959	18./ 2/
59F2A	/ 4.800	2.117	-18.99/	16.1/ 2	0.996	-12.866	12.608	1/ .570	1.548	1/ .99/	1/ .6/ 7	6.959	18./ 2/
59F/ A	/ 4.800	2.117	-18.99/	16.1/ 2	0.996	-12.866	12.608	1/ .570	1.548	1/ .99/	1/ .6/ 7	6.959	18./ 2/
59F4A	/ 4.800	2.117	-18.99/	16.1/ 2	0.996	-12.866	12.608	1/ .570	1.548	1/ .99/	1/ .6/ 7	6.959	18./ 2/
59T1A	1/ 5.000	1.741	-5.17/	5./ 86	1.88/	-5.060	5.205	7.050	1.805	7.2/ 9	6./ 92	8.475	5.415
59T1B	/ 4.800	2.117	-18.99/	16.1/ 2	0.996	-12.866	12.608	1/ .570	1.548	1/ .99/	1/ .6/ 7	6.959	18./ 2/
HV BUS k PT	1/ 5.000	1.741	-5.17/	5./ 86	1.88/	-5.060	5.205	7.050	1.805	7.2/ 9	6./ 92	8.475	5.415
JB-2M	/ 4.800	2.897	-1/ .824	1/ .771	/ .82/	-5.70/	9./ 59	11.728	2.289	11.940	-1/ ./ 49	0.547	1/ ./ 76
JB-4M	/ 4.800	/ .5/ 9	-8.211	6.472	2.655	-2/ .00	/ .8/ 7	4.844	/ ./ 1	8.6/ 4	-8.810	-2.6/ 8	6.105
LV BUS T-01	0.690	82.578	-8/ .662	78./ 8	85.717	-89.705	5/ .742	46.465	48.796	68.242	1/ .47/	79.446	50.851
LV BUS T-02	0.690	8/ .577	-88.929	77.685	89.8/ 9	-61.860	58.641	45.4/ 1	46.668	67.284	-51.655	-12.4/ 0	52.625
LV BUS T-0/	0.690	84.508	-87.521	79.667	60.298	-6/ .079	57.261	80.070	47.465	65.994	-5/ .86/	-12.767	54.8/ /
LV BUS T-04	0.690	88.4/ 2	-85.850	50.680	60.500	-6/ .650	55.044	80.727	45.012	69.548	-54./ 76	-1/ .129	58./ 91
LV BUS T-08	0.690	86.165	-89./ 78	51.7/ /	61./ 59	-64./ 04	55.902	81.418	45.680	70.754	-58.244	-1/ .850	56./ 19
LV BUS T-06	0.690	86.9/ 8	-89.8/ /	52./ 78	61.99/	-64.42/	59.406	81.881	49./ 14	71./ 40	-58.861	-14.210	56.7/ /
LV BUS T-07	0.690	87.60/	-61.278	54.100	62.827	-68.779	90.788	8/ .060	49.59/	72.5/ 4	-57.2/ 2	-14./ 55	55.411
LV BUS T-05	0.690	85.817	-68.042	57.492	6/ .250	-65.689	9/ ./ 7/	86./ 2/	80.656	78.772	-90.7/ 0	-14./ 45	91.587
LV BUS T-09	0.690	60.162	-7/ .479	94.967	64.74/	-74.568	95.977	6/ .6/ 2	82.114	52.249	-95.819	-14.060	99.817
LV BUS T-10	0.690	60.647	-7/ .921	98.618	68.110	-78.164	99.444	64.014	82.8/ 4	52.511	-99.008	-14.408	100.047
LV BUS T-1/	0.690	88.599	-86.825	79.499	61.165	-62.041	57.128	45.949	45.416	65.549	18.194	52.798	54.175
LV BUS T-14	0.690	86.687	-85.266	51.271	61.771	-6/ .426	55.8/ 8	80.488	49.07/	70./ 54	-54./ 96	-14.269	58.894
LV BUS T-18	0.690	85.685	-62.721	58.576	6/ ./ 88	-66.556	92.127	84./ 1/	80.507	74./ 72	-55.7/ 0	-14.952	59.956
LV BUS T-16	0.690	86.11/	-87.842	50./ 7/	61./ / 5	-62.581	57.522	49.525	45.602	69.606	-5/ .6/ 5	-1/ .971	54.797
LV BUS T-17	0.690	61.689	-74.601	96.754	68.562	-78.614	100.276	64.60/	8/ .411	5/ .52/	-99.50/	-18.172	100.980
LV BUS T-20	0.690	89.286	-68.125	55.081	6/ .542	-65.71/	9/ .794	86./ 95	81./ 27	76.285	-90.968	-14.975	92.190
LV BUS T-21	0.690	60.796	-70.62/	9/ .157	68.109	-72.766	97.642	61.185	82.66/	50.707	-96.116	-18.157	97./ 05
LV BUS T-22	0.690	61./ 82	-72.946	98./ 16	68.854	-74.4/ 6	99.207	6/ .170	8/ .148	52.882	-95.275	-18.220	99.480
LV BUS T-2/	0.690	61.478	-74.750	96.508	68.7/ 5	-78.749	100.296	64.785	8/ .281	5/ .541	-99.927	-14.974	101.04/
LV BUS T-24	0.690	62.407	-74.151	96.940	66/ 52	-78.255	100./ 74	64.2/ 9	84.089	5/ .989	-99.87/	-18.918	100.5/ 7
LV BUS T-28	0.690	62.957	-78.60/	95.40/	66.544	-76.279	101.42/	68.471	84.862	58.226	-100.942	-16.189	102.227
LV BUS T-26	0.690	89.6/ 4	-65.726	90.991	64.201	-71.400	96.019	89.818	81.688	75.508	-94.206	-14.849	98./ 2/
LV BUS T-27	0.690	60./ 17	-71.617	9/ .6/ /	64.759	-7/ .807	97.954	62.019	82.247	51.09/	-96.599	-14.868	97.957
LV BUS T-25	0.690	60.90/	-74.46/	96.195	68./ 16	-78.844	99.568	64.454	82.786	5/ ./ 18	-99.8/ 6	-14.825	100.891
LV BUS T-29	0.690	89.6/ 0	-66.248	59.1/ 0	64.14/	-69.845	94.611	87./ 66	81.682	77.19/	-92.024	-18.066	9/ .249
LV BUS T-/ 1	0.690	87.145	-6/ .4/ 5	58./ 5/	62.208	-67.485	91.761	84.9/ 8	49.800	7/ .947	-59.020	-1/ .802	90.0/ 5

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 2
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Normal

1 Cycle - / -Phase, L3 , LL, & LL3 Fault Currents

Prefault Voltage G 100 = of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	%	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.
LV BUS T-/2	0.690	89.145	-71.194	92.889	6/.919	-7/.2/7	97.207	61.68/	81.2/8	50.16/	-96.290	-1/.614	97.247
LV BUS T-/	0.690	89.870	-7/.12	94.46/	64/.05	-74.767	95.619	6/.457	81.601	51.512	-95.284	-1/.867	99.157
LV BUS T-/4	0.690	89.054	-72.1/9	9/.246	6/.907	-7/.9/2	97.724	62.471	81.179	50.785	-97.118	-1/.67	95.0/0
LV BUS T-/6	0.690	87.595	-67.168	55.678	62.560	-70.250	94.290	85.16/	80.180	76.799	-92.468	-1/.48	9/.42/
LV BUS T-/7	0.690	87/.94	-68.25/	56.924	62.4/1	-65.566	92.982	86.8/	49.71/	78.252	-90.696	-1/.09	91.667
LV BUS T-/9	0.690	86.951	-6/.859	58/.54	62.079	-67.875	91.764	88.066	49/.86	7/.945	-59.118	-1/.22	90.106
LV BUS T-40	0.690	85.208	-72.792	9/.201	6/.20	-74.48/	97.7/5	6/.045	80.481	50.745	-97.814	-12.479	95/.10
LV BUS T-41	0.690	84.45/	-62.166	52.662	60.148	-66.897	59.7/6	8/.914	47.2/0	71.678	-57/.28	-11.808	55.079
LV BUS T-42	0.690	84.968	-6/.968	54/.6	60.601	-69/.16	92.072	86/.76	47.675	7/.5/4	-59.86/	-11.256	90.271
LV BUS T-4/	0.690	84.812	-62.267	52.787	60.205	-67.995	90.52/	84.904	47.256	72.489	-57.985	-11.259	55.650
LV BUS T-44	0.690	86.806	-71.806	91.1/7	62.022	-7/.890	96.240	61.94/	45.992	75.976	-96.02/	-11.2/8	96.675
LV BUS T-48	0.690	87.046	-71.991	91.58/	62.440	-7/.921	96.76/	62/.89	49.488	79.890	-96.866	-11.614	97.262
LV BUS T-46	0.690	87.788	-72.454	92.650	62.979	-74.249	97/.62	62.75/	80.064	50/.00	-97.149	-12.142	97.908
LV BUS T-45	0.690	82.414	-85.500	75.769	85.427	-6/.960	56.6/0	80.955	48.4/7	65.298	-5/.587	-10.456	54.810
LV BUS T-49	0.690	8/.021	-60.791	50.668	85.985	-68.842	55.185	82.716	48.96/	69.940	-58.762	-10.8/5	56.407
LV BUS T-80	0.690	82.4/4	-85.56/	75.5/0	85.448	-64.011	56.679	81.04/	48.484	65/.45	-5/.915	-10.455	54.871
k V BUS T-01	/4.800	/4.474	-2.845	4/.05	2.5/2	-1.944	/4/8	2.206	/0.009	/7/1	-/99	-2.228	4.062
k V BUS T-02	/4.800	/7.742	-2.975	4.75/	/0/	-2.268	/7.756	2.875	/2.242	4.142	-/.581	-2./0	4.801
k V BUS T-0/	/4.800	/9.999	-/40/	8.281	/2.215	-2.891	4.1/2	2.946	/4.468	4.845	-4.290	-2.420	4.928
k V BUS T-04	/4.800	4.174	-/.892	8.807	/62	-2.501	4/76	/109	/617	4.769	-4.818	-2.465	8.146
k V BUS T-08	/4.800	4/9/	-/.508	8.512	/8/6	-/.068	4.650	/29/	/507	8.0/4	1.518	8.090	8.404
k V BUS T-06	/4.800	4.627	-/.5/7	6.011	/711	-/.1/8	4.585	/21	4.009	8.206	1.774	8./4	8.621
k V BUS T-07	/4.800	4.574	-4.40/	6.865	/570	-/.879	8.271	/511	4.224	8.659	2.209	8.7/2	6.14/
k V BUS T-05	/4.800	8.101	-8.96/	7.547	/922	-4.067	8.681	8.16/	4.422	6.795	-6.74/	-2.556	7./8
k V BUS T-09	/4.800	/0.080	-10.576	11.298	/569	-6.068	7.194	9.428	2.649	9.791	-11.07/	-0.657	11.094
k V BUS T-10	/4.800	2.989	-11.427	11.504	/572	-6.879	7.6/4	9.904	2.871	10.2/2	-11.854	-0.401	11.890
k V BUS T-1/	/4.800	4.2/2	-/.047	8.218	/491	-2.879	4/41	2.6/7	/666	4.816	1.18/	4.754	4.921
k V BUS T-14	/4.800	4.808	-/.47/	8.655	/654	-2.94/	4.718	/006	/90/	4.926	1.480	8.179	8/75
k V BUS T-18	/4.800	8.278	-4.987	7.2/9	4.18/	-4.222	8.922	4.291	4.872	6.270	2.855	6.404	6.907
k V BUS T-16	/4.800	4/29	-/.296	8.441	/807	-2.701	4.427	2.58/	/780	4.712	1/50	4.598	8.056
k V BUS T-17	/4.800	2.576	-12.890	12.914	/769	-7.765	5.6/4	10.914	2.800	11.196	-12.608	0.190	12.606
k V BUS T-20	/4.800	8.444	-6.065	5.182	4.181	-/.921	8.710	8.284	4.720	7.06/	-6.909	-/.256	7.681
k V BUS T-21	/4.800	8.044	-9.622	10.564	4/1/	-8.59/	7/0/	5/6	4/75	9.418	-10.102	-2/02	10/60
k V BUS T-22	/4.800	4.086	-11.428	12.12/	4.098	-6.969	5.05/	9.901	/82/	10.809	-11.648	-1.098	11.696
k V BUS T-2/	/4.800	2.627	-12.806	12.779	/775	-7.16/	5.095	10.541	2.254	11.079	-12.490	0.058	12.490
k V BUS T-24	/4.800	/679	-1/.060	1/.865	/662	-9.091	9.501	11/21	/197	11.764	-12.981	0.247	12.98/
k V BUS T-28	/4.800	2.489	-14.467	14.674	2.560	-10/02	10.692	12.844	2.140	12.728	-1/557	1.516	14.008

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: /
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Normal

1 Cycle - / -Phase, L3 , LL, & LL3 Fault Currents

Prefault Voltage G 100 = of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	%	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.
k V BUS T-26	/ 4.800	8.022	-5.081	9.459	/ .986	-4./ 21	8.589	6.974	4./ 86	5.222	-5.807	-2.925	5.996
k V BUS T-27	/ 4.800	4.262	-9.996	10.567	/ .975	-8.2/ 5	6.877	5.661	/ .700	9.415	-10.242	-2.010	10.4/ 7
k V BUS T-25	/ 4.800	2.645	-11.57/	12.168	/ .755	-6./ 01	7./ 82	10.291	2./ 01	10.846	-11.552	-0./ 06	11.556
k V BUS T-29	/ 4.800	8.820	-6.679	5.668	4.2/ 9	-4.272	6.015	8.75/	4.756	7.807	-7.478	-/ .2/ 4	5.148
k V BUS T-/ 1	/ 4.800	4.680	-8.159	6.967	/ ./ 60	-2.77/	4./ 87	4.49/	4.0/ 0	6.0/ 6	-8.770	-/ .112	6.888
k V BUS T-/ 2	/ 4.800	/ .547	-9.196	9.965	/ .725	-4.499	8.54/	7.967	/ ./ 5	5.6/ 5	-9.428	-1.947	9.624
k V BUS T-/	/ 4.800	2.597	-10.418	10.510	/ .696	-8.1/	6./ 28	9.028	2.816	9./ 69	-10.814	-0.984	10.887
k V BUS T-/ 4	/ 4.800	/ ./ 84	-9.614	10.15/	/ .668	-4.6/	8.905	5./ / 1	2.911	5.528	-9.774	-1.804	9.559
k V BUS T-/ 6	/ 4.800	4.810	-6.549	5.200	/ .822	-/ ./ 97	4.59/	8.9/ 1	/ .911	7.108	-7.271	-2.5/ 6	7.504
k V BUS T-/ 7	/ 4.800	4.858	-8.945	7.810	/ .412	-/ .026	4.861	8.181	/ .978	6.806	-6.444	-/ .000	7.105
k V BUS T-/ 9	/ 4.800	4.877	-8.2/ 6	6.984	/ ./ 12	-2.744	4./ 01	4.8/ /	/ .967	6.024	-8.755	-/ .065	6.881
k V BUS T-40	/ 4.800	2.680	-9.428	9.791	/ .2/ 7	-/ .7/ 0	4.9/ 5	5.159	2./ 07	5.807	-9./ 74	-1.266	9.489
k V BUS T-41	/ 4.800	/ .525	-4.895	8.952	2.601	-2.096	/ ./ 40	4.007	/ ./ 24	8.207	-4.944	-2.679	8.62/
k V BUS T-42	/ 4.800	/ .5/ 8	-8.197	6.485	2.654	-2.294	/ .8/ 1	4.8/ 2	/ ./ 25	8.622	-8.496	-2.6/ 4	6.098
k V BUS T-4/	/ 4.800	/ .5/ 0	-4.629	6.009	2.606	-2.107	/ ./ 81	4.0/ 5	/ ./ 28	8.2/ 1	-4.976	-2.677	8.680
k V BUS T-44	/ 4.800	2.6/ /	-5.195	5.610	2.906	-2.968	4.182	7.125	2.292	7.457	-5.187	-1.490	5.292
k V BUS T-48	/ 4.800	2.618	-5.856	5.976	2.999	-/ .16/	4./ 85	7.464	2.277	7.50/	-5.8/ /	-1.417	5.649
k V BUS T-46	/ 4.800	2.640	-9.056	9.462	/ .14/	-/ .455	4.698	7.598	2.295	5.22/	-9.0/ /	-1./ / 8	9.1/ 1
k V BUS T-45	/ 4.800	/ .416	-/ .6/ 1	4.958	2.290	-1.672	2.5/ 6	/ .161	2.965	4./ / 8	-/ .957	-2.480	4.650
k V BUS T-49	/ 4.800	/ .497	-4.1/ 5	8.415	2./ 54	-1.541	/ .012	/ .604	/ .0/ 7	4.71/	-4.461	-2.477	8.102
k V BUS T-80	/ 4.800	/ .419	-/ .646	4.999	2.29/	-1.677	2.541	/ .174	2.970	4./ 47	-4.001	-2.482	4.69/
POI	1/ 5.000	1.747	-5.198	5./ 50	1.862	-5.092	5.242	7.099	1.814	7.289	6.406	8.808	5.446

All fault currents are symmetrical (1 Cycle network) values in rms %.

* LL3 fault current is the larger of the two faulted line currents.

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 8
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Normal

Bus		Positive Seq. Imp. (ohm)			Negative Seq. Imp. (ohm)			Zero Seq. Imp. (ohm)			Fault Zf (ohm)		
ID	%	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance
LV BUS T-49	0.690	0.00/ 28	0.00/ 72	0.00494	0.00/ 24	0.00/ 71	0.0049/	0.00285	0.00264	0.00/ 70	0.00000	0.00000	0.00000
LV BUS T-80	0.690	0.00/ 6	0.00/ 77	0.00808	0.00/ 8	0.00/ 77	0.00804	0.00285	0.00264	0.00/ 70	0.00000	0.00000	0.00000
k V BUS T-01	/ 4.800	/ .7277/	2.7/ 468	4.62/ 2/	/ .72971	2.7/ 202	4.62/ 27	6.55850	4./ 5042	5.16102	0.00000	0.00000	0.00000
k V BUS T-02	/ 4.800	/ .28585	2.89/ 60	4.16478	/ .26084	2.89098	4.1646/	6.12909	4.28911	7.46/ 6/	0.00000	0.00000	0.00000
k V BUS T-0/	/ 4.800	2.55568	2.48528	/ .79/ 08	2.59087	2.48888	/ .79277	8.4569/	4.18616	6.55/ 1	0.00000	0.00000	0.00000
k V BUS T-04	/ 4.800	2.74154	2./ 8904	/ .61701	2.74/ 78	2./ 86/ 0	/ .61667	8.00879	4.02814	6.42/ 7	0.00000	0.00000	0.00000
k V BUS T-08	/ 4.800	2.89074	2.24/ 64	/ .42722	2.89262	2.24054	/ .42651	4.46670	/ .575/ 4	8.91849	0.00000	0.00000	0.00000
k V BUS T-06	/ 4.800	2.88065	2.1184/	/ .1/ 1/ 76	2.88281	2.11246	/ .1/ 1/ 25	4.29441	/ .710/ 7	8.67825	0.00000	0.00000	0.00000
k V BUS T-07	/ 4.800	2.280/ 7	2.0/ 26/	/ .0/ 248	2.28215	2.02964	/ .0/ 179	/ .51950	/ .6/ 425	8.27246	0.00000	0.00000	0.00000
k V BUS T-05	/ 4.800	1.68007	1.9257/	2.8/ 526	1.6816/	1.9286/	2.8/ 692	4.0/ 595	/ .78511	8.81698	0.00000	0.00000	0.00000
k V BUS T-09	/ 4.800	0.4762/	1.69759	1.76/ 42	0.47727	1.694/ 9	1.760/ 2	/ .81/ 70	/ .61048	8.0/ 500	0.00000	0.00000	0.00000
k V BUS T-10	/ 4.800	0.42/ 0/	1.6/ 89	1.65747	0.42406	1.6/ 00/	1.65429	/ .1229/	/ .45268	4.67777	0.00000	0.00000	0.00000
k V BUS T-1/	/ 4.800	/ .09967	2.2/ 204	/ .51965	/ .10188	2.22911	/ .51949	4.57220	/ .71541	6.12902	0.00000	0.00000	0.00000
k V BUS T-14	/ 4.800	2.77/ 46	2.1/ 505	/ .80192	2.778/ 1	2.1/ 81/	/ .80189	4./ 8/ 45	/ .6/ 828	8.67167	0.00000	0.00000	0.00000
k V BUS T-18	/ 4.800	2.00815	1.55428	2.78187	2.00696	1.55120	2.78075	/ .064/ 5	/ .42585	4.8954/	0.00000	0.00000	0.00000
k V BUS T-16	/ 4.800	2.91260	2.21756	/ .66059	2.91444	2.21491	/ .66085	4.56556	/ .50247	6.17778	0.00000	0.00000	0.00000
k V BUS T-17	/ 4.800	0./ 4/ 45	1.80/ 62	1.842/ 8	0./ 4481	1.49999	1.8/ 908	2./ 1/ 0	/ .22/ 07	/ .97900	0.00000	0.00000	0.00000
k V BUS T-20	/ 4.800	1.6/ 164	1.51566	2.44/ 2	1.6/ 25/	1.51811	2.44146	4./ 4/ 05	/ .88/ 21	8.611/ 9	0.00000	0.00000	0.00000
k V BUS T-21	/ 4.800	0.581/ 2	1.62/ 58	1.5/ 47	0.58248	1.62028	1.5/ 052	/ .12556	/ .8584	4.89016	0.00000	0.00000	0.00000
k V BUS T-22	/ 4.800	0.84966	1.845/ 0	1.64295	0.88078	1.84465	1.6/ 99/	2.644/ /	/ .25056	4.21/ 58	0.00000	0.00000	0.00000
k V BUS T-2/	/ 4.800	0./ 2042	1.828/ 5	1.88567	0./ 2146	1.82151	1.888/ 9	2.50021	/ .47951	4.46687	0.00000	0.00000	0.00000
k V BUS T-24	/ 4.800	0./ 9508	1.41/ 08	1.46504	0./ 9906	1.40922	1.46464	1.4511/	2.5/ 02	/ .1965/	0.00000	0.00000	0.00000
k V BUS T-28	/ 4.800	0.22749	1./ 520	1./ 8740	0.22580	1./ 4/ 6	1./ 8/ 79	1.0/ 595	2.71261	2.90475	0.00000	0.00000	0.00000
k V BUS T-26	/ 4.800	1.11059	1.75105	2.09912	1.11201	1.77768	2.09651	4.66446	/ .96404	6.121/ 4	0.00000	0.00000	0.00000
k V BUS T-27	/ 4.800	0.71596	1.65609	1.5/ 297	0.72008	1.65264	1.5/ 024	4.08851	/ .56646	8.60/ 49	0.00000	0.00000	0.00000
k V BUS T-25	/ 4.800	0./ 8644	1.89505	1.6/ 7/ 8	0./ 8749	1.89460	1.6/ 415	/ .47/ 49	/ .77/ 10	8.12549	0.00000	0.00000	0.00000
k V BUS T-29	/ 4.800	1.46480	1.77196	2.2955/	1.46868	1.765/ 9	2.29650	4.06/ 72	/ .80542	8./ 6569	0.00000	0.00000	0.00000
k V BUS T-/ 1	/ 4.800	1.90756	2.12917	2.58590	1.90906	2.12892	2.58727	6.76095	4.47662	5.10570	0.00000	0.00000	0.00000
k V BUS T-/ 2	/ 4.800	0.77112	1.54/ 47	1.99528	0.77224	1.54017	1.99864	4.95120	4.19125	6.8099/	0.00000	0.00000	0.00000
k V BUS T-/ /	/ 4.800	0.49/ 77	1.77815	1.54285	0.49456	1.77158	1.5/ 966	4.8/ 159	4.11928	6.1242/	0.00000	0.00000	0.00000
k V BUS T-/ 4	/ 4.800	0.644/ 4	1.54694	1.98611	0.64847	1.54/ 68	1.98/ 5	4.95814	4.24267	6.84614	0.00000	0.00000	0.00000
k V BUS T-/ 6	/ 4.800	1./ 890	2.02589	2.42598	1./ 712	2.028/ 7	2.4269/	6.11764	4.4242/	7.84979	0.00000	0.00000	0.00000
k V BUS T-/ 7	/ 4.800	1.61925	2.10072	2.682/ 7	1.62081	2.09781	2.68085	6.86280	4.49888	7.98468	0.00000	0.00000	0.00000
k V BUS T-/ 9	/ 4.800	1.55809	2.18661	2.564/ 6	1.556/ 0	2.18/ 5	2.56272	6.927/ 8	4.88408	5.29021	0.00000	0.00000	0.00000
k V BUS T-40	/ 4.800	0.88062	1.98547	2.0/ 440	0.84914	1.94451	2.02058	6.5/ 122	8.2/ 878	5.60659	0.00000	0.00000	0.00000
k V BUS T-41	/ 4.800	2.1/ 0/ 6	2.8855/	/ .72985	2.10012	2.84119	/ .29669	9.699/ /	6.12/ 8	11.47080	0.00000	0.00000	0.00000
k V BUS T-42	/ 4.800	1.5/ 120	2.45168	/ .0541/	1.50070	2.46418	/ .08197	9.2/ 44/	6.08109	11.040/ 9	0.00000	0.00000	0.00000
k V BUS T-4/	/ 4.800	2.11/ 20	2.8842/	/ .71807	2.079/ 1	2.8/ 7/ 9	/ .2508/	9.67195	6.11596	11.4480/	0.00000	0.00000	0.00000
k V BUS T-44	/ 4.800	0.707/ 8	2.20286	2./ 1/ 8	0.70/ 41	2.15407	2.29488	5.6647/	8.59112	10.47774	0.00000	0.00000	0.00000
k V BUS T-48	/ 4.800	0.64662	2.12251	2.21910	0.64/ 72	2.10896	2.20218	5.14/ 76	8.72074	9.98227	0.00000	0.00000	0.00000
k V BUS T-46	/ 4.800	0.857/ /	2.02185	2.10817	0.858/ 4	2.0067/	2.090/ 8	7./ 4622	8.42604	9.1/ 254	0.00000	0.00000	0.00000
k V BUS T-45	/ 4.800	2.7/ 791	2.90959	/ .99848	2.70904	2.59142	/ .9622/	11.87/ 62	6.622/ 2	1./ 4/ 1	0.00000	0.00000	0.00000
k V BUS T-49	/ 4.800	2./ 7299	2.505/ 1	/ .67664	2./ 4/ 90	2.79002	/ .64/ 91	10.95682	6.82519	12.77971	0.00000	0.00000	0.00000
k V BUS T-80	/ 4.800	2.72604	2.90684	/ .95455	2.69716	2.55505	/ .98167	11.88445	6.61928	1./ 1617	0.00000	0.00000	0.00000
POI	1/ 5.000	1.95266	9.29921	9.80522	1.95248	9.29/ 77	9.80256	1.8/ 107	9.55265	10.00085	0.00000	0.00000	0.00000

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 1
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Future

Short-Circuit Summary Report

1/2 Cycle - / -Phase, L3 , LL, & LL3 Fault Currents

Prefault Voltage G 100 = of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	%/	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.
89F1A	/ 5.400	2.082	-16.590	16.621	0.961	-12.767	12.805	15./ 01	1.814	15.516	15.074	6.994	14.718
89F2A	/ 5.400	2.082	-16.590	16.621	0.961	-12.767	12.805	15./ 01	1.814	15.516	15.074	6.994	14.718
89F/ A	/ 5.400	2.082	-16.590	16.621	0.961	-12.767	12.805	15./ 01	1.814	15.516	15.074	6.994	14.718
89F5A	/ 5.400	2.082	-16.590	16.621	0.961	-12.767	12.805	15./ 01	1.814	15.516	15.074	6.994	14.718
89T1A	1/ 8.000	2.1/ 0	-9.879	10.104	1.776	-9.215	9./ 8/	8.447	1.854	8.745	7.810	6.146	9.954
89T1B	/ 5.400	2.082	-16.590	16.621	0.961	-12.767	12.805	15./ 01	1.814	15.516	15.074	6.994	14.718
HV BUS k PT	1/ 8.000	2.1/ 0	-9.879	10.104	1.776	-9.215	9./ 8/	8.447	1.854	8.745	7.810	6.146	9.954
JB-2M	/ 5.400	2.621	-1/. 862	15.107	/ .471	-8.797	9.595	12.017	2.280	12.2/ 1	-1/. 641	0.8/ 8	1/ .677
JB-5M	/ 5.400	/ .892	-4.2/ 0	6.419	2.699	-2.299	/ .454	5.460	/ / 78	4.674	-4.428	-2.682	6.155
LV BUS T-01	0.690	4/. 018	-4/. 6/ 2	74.515	48.8/ 4	-49.68/	8/ .807	56.552	54.919	64./ 10	1/ .509	79.462	80.685
LV BUS T-02	0.690	45.0/ 1	-44.901	77.754	49.662	-61.4/ 7	84.711	58.507	56.797	67./ 29	-81.70/	-12.469	82.665
LV BUS T-0/	0.690	45.968	-47.798	79.762	60.524	-6/ .049	87./ / 6	40.059	57.609	69.077	-8/ .48/	-12.915	85.475
LV BUS T-05	0.690	44.600	-48.448	80.759	60.9/ /	-6/ .661	88.12/	40.708	58.147	69.9/ 1	-85./ 97	-1/ .281	84.5/ 6
LV BUS T-04	0.690	46./ 55	-49./ 44	81.8/ 9	61.427	-65.287	88.984	41./ 98	58.801	70.874	-84.268	-1/ .7/ 7	86/ .67
LV BUS T-06	0.690	47.119	-49.417	82.591	62.1/ 8	-65.510	89.597	41.4/ 8	59.57/	71.550	-84.490	-15./ 75	86.789
LV BUS T-07	0.690	47.796	-61.26/	85.22/	62.676	-64.768	90.840	4/ .040	40.060	72.950	-87.266	-15.449	88.572
LV BUS T-08	0.690	48.724	-64.044	87.650	6/ .5/ 7	-68.664	9/ .585	46./ / 5	40.866	74.900	-90.786	-15.427	91.951
LV BUS T-09	0.690	60.507	-7/ .46/	94.187	65.92/	-75.916	99.1/ /	6/ .704	42./ 24	82.5/ 9	-98.652	-15.260	99.667
LV BUS T-10	0.690	60.898	-75.008	94.852	64.295	-74.218	99.605	65.090	42.741	8/ .007	-99.1/ 1	-15.610	100.202
LV BUS T-1/	0.690	46.070	-46.405	79.602	61./ 04	-62.02/	87.207	58.929	58.465	68.9/ 8	14.1/ 2	82.9/ 7	85/ .06
LV BUS T-15	0.690	46.8/ 7	-48.256	81./ 82	61.912	-6/ .509	88.622	40.5/ 7	59.228	70.579	-85.521	-15.529	84.656
LV BUS T-14	0.690	48.862	-62.71/	86.009	6/ .410	-66.877	92.229	45/ .06	40.98/	75.587	-88.769	-14.161	90.045
LV BUS T-16	0.690	46.288	-47.422	80.580	61.577	-62.8/ 6	87.908	59.810	58.74/	69.699	14.962	8/ / 75	85.888
LV BUS T-17	0.690	61.921	-75.692	97.021	66.042	-74.669	100.55/	65.682	4/ .6/ 7	85.028	-99.9/ 5	-14/ .86	101.111
LV BUS T-20	0.690	49.579	-64.172	88.2/ 5	65.011	-68.752	9/ .9/ 1	46.5/ 6	41.420	76.516	-91.042	-14.165	92/ .06
LV BUS T-21	0.690	61.055	-70.690	9/ / 99	64.291	-72.808	97.796	61.216	42.876	80.891	-96.224	-14/ .92	97.558
LV BUS T-22	0.690	61.610	-7/ .026	94.45/	64.772	-75.586	99/ 68	6/ .2/ 9	4/ / 67	82.758	-98/ 99	-14.5/ 1	99.602
LV BUS T-2/	0.690	61.7/ /	-75.869	97.0/ 8	64.924	-74.80/	100.560	65.8/ 4	4/ .575	85.052	-100.044	-14.186	101.201
LV BUS T-25	0.690	62.682	-75.276	97.190	66.482	-74./ 57	100.440	65/ 22	45.297	85.174	-99.710	-16.150	101.008
LV BUS T-24	0.690	6/ .270	-74.704	98.66/	67.057	-76/ 51	101.60/	64.460	45.807	84.541	-101.084	-16/ 91	102.506
LV BUS T-26	0.690	49.861	-68.782	91.18/	65./ 70	-71.5/ 6	96.149	49.465	41.841	78.970	-95./ 0/	-15.7/ 7	94.558
LV BUS T-27	0.690	60.444	-71.686	9/ .850	65.965	-7/ .459	98.1/ 2	62.079	42.54/	81.272	-97.008	-15.762	98.125
LV BUS T-28	0.690	61.14/	-75.458	96.521	64.598	-74.494	100.02/	65.447	42.972	8/ .408	-99.660	-15.7/ /	100.75/
LV BUS T-29	0.690	49.849	-66.294	89/ 20	65/ 14	-69.481	95.742	47.509	41.859	77./ 47	-92.116	-14.246	9/ / 71
LV BUS T-/ 1	0.690	47./ 5/	-6/ .572	84.4/ 9	62./ 44	-67.581	91.880	45.965	59.669	75.082	-89.095	-1/ .664	90.1/ 6

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: 2
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Future

1M Cycle - / -Phase, L3 , LL, & LL3 Fault Currents

Prefault Voltage G 100 = of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	%	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.
LV BUS T-/2	0.690	49./75	-71.248	92.74/	65.086	-7/./276	97./57	61.708	41.5/0	80./0	-96./92	-1/./801	97./74
LV BUS T-/	0.690	49.805	-7/./87	95.669	65.580	-75.812	98.764	6/./442	41.802	81.990	-98./67	-1/./749	99./24
LV BUS T-/5	0.690	49./11	-72.206	9/./55/	65.074	-7/./972	97.864	62.429	41./74	80.928	-97.220	-1/./444	98.161
LV BUS T-/6	0.690	48.104	-67.209	88.855	6/./017	-70./07	95.516	48.201	40./0	76.954	-92.458	-1/./419	9/./4/0
LV BUS T-/7	0.690	47.495	-64./20	87.085	62.485	-68.890	9/./07/	46.464	59.886	74.520	-90.77/	-1/./576	91.767
LV BUS T-/9	0.690	47.176	-6/./62/	84.4/9	62.229	-67.600	91.882	44.094	59.425	75.082	-89.189	-1/./585	90.20/
LV BUS T-50	0.690	48.519	-72.865	9/./91	6/./578	-75.597	97.87/	6/./110	40.6/4	80.912	-97.622	-12.645	98.5/9
LV BUS T-51	0.690	45.651	-62.167	82.767	60.268	-66.495	89.816	4/./914	57./66	71.766	-87./6/	-11.65/	88.1/6
LV BUS T-52	0.690	44.1/0	-6/./971	85.559	60.729	-69./16	92.146	46./81	57.820	7/./9/0	-89.607	-11.5/0	90.///
LV BUS T-5/	0.690	45.671	-62.269	82.86/	60./12	-67.996	90.90/	45.904	57.52/	72.440	-87.998	-11.528	88.7/7
LV BUS T-55	0.690	46.699	-71.468	91./06	62.167	-7/./627	96./62	61.996	59.148	79.120	-96.118	-11./95	96.791
LV BUS T-54	0.690	47.254	-72.046	92.028	62.488	-7/./960	96.889	62.516	59.627	79.750	-96.664	-11.777	97./80
LV BUS T-56	0.690	47.962	-72.44/	92.865	6/./1//	-75.291	97.59/	62.85/	40.25/	80.548	-97.24/	-12./1/	98.0/0
LV BUS T-58	0.690	42.445	-48.79/	78.848	48.4/9	-6/./942	86.699	40.981	54.447	68./71	-8/./886	-10.610	85.445
LV BUS T-59	0.690	4/./169	-60.788	80.760	49.075	-64.4/6	88.2/1	42.715	56.090	70.022	-84.794	-10.668	86.546
LV BUS T-40	0.690	42.475	-48.846	78.919	48.447	-65.002	86.758	41.0/6	54.474	68.525	-8/./957	-10.61/	85.614
k V BUS T-01	/5.400	/./400	-2.4/8	5./2/	2.852	-1.9/9	/./551	2.197	/./0/1	/./755	-/./92	-2.259	5.069
k V BUS T-02	/5.400	/./774	-2.968	5.802	/./057	-2.260	/./795	2.470	/./270	5.149	-/./854	-2./49	5.411
k V BUS T-0/	/5.400	5.050	-/./94	4.277	/./2/4	-2.486	5.152	2.9/8	/./400	5.470	-5.284	-2.546	5.9/9
k V BUS T-05	/5.400	5.220	-/./48/	4.4/6	/./82	-2.797	5/./88	/./101	/./646	5.795	-5.411	-2.408	4.161
k V BUS T-04	/5.400	5.554	-/./796	4.854	/./449	-/./061	5.695	/./286	/./841	4.062	1.80/	4.1/5	4.551
k V BUS T-06	/5.400	5.68/	-/./827	6.058	/./7/6	-/./1/1	5.874	/./1/1	5.048	4.2/8	1.761	4/./82	4.66/
k V BUS T-07	/5.400	5.95/	-5/./97	6.616	/./900	-/./478	4.29/	/./806	5.28/	4.7/0	2.198	4.791	6.195
k V BUS T-08	/5.400	4.196	-4.988	7.928	/./946	-5.072	4.678	4.185	5.405	6.867	-6.770	-2.968	7/./92
k V BUS T-09	/5.400	/./107	-11.085	11.411	/./915	-6.105	7.241	9.606	2.698	9.978	-11.261	-0.7/2	11.284
k V BUS T-10	/5.400	/./010	-11.661	12.05/	/./919	-6.627	7.699	10.106	2.614	10.5/9	-11.795	-0.550	11.802
k V BUS T-1/	/5.400	5.27/	-/./0/1	4.250	/./411	-2.47/	5/./4/	2.624	/./701	5.4/8	1.1/7	5.818	5.941
k V BUS T-15	/5.400	5.444	-/./560	4.720	/./708	-2.9/8	5.7/1	2.995	/./956	5.945	1.5/5	4.221	4.515
k V BUS T-14	/5.400	4/./60	-5.944	7.299	5.191	-5.225	4.940	5.289	5.654	6/./22	2.478	6.578	6.972
k V BUS T-16	/5.400	5/./75	-/./285	4.570	/./428	-2.694	5.550	2.852	/./790	5.7/7	1/./66	5.9/1	4.118
k V BUS T-17	/5.400	2.920	-12.879	1/./206	/./820	-7.850	8.721	11.165	2.4/8	11.558	-12.864	0.161	12.866
k V BUS T-20	/5.400	4.441	-6.108	8.245	5.188	-/./928	4.752	4.288	5.81/	7.140	-6.940	-/./78	7.727
k V BUS T-21	/5.400	4.177	-9.779	11.064	5/./66	-4.927	7/./62	8.571	5.59/	9.489	-10.256	-2.51/	10.426
k V BUS T-22	/5.400	5.147	-11.662	12/./81	5.159	-7.025	8.148	10.106	/./610	10.7/2	-11.849	-1.176	11.917
k V BUS T-2/	/5.400	2.662	-12.786	1/./060	/./826	-7.222	8.17/	11.08/	2/./15	11/./22	-12.750	0.061	12.750
k V BUS T-25	/5.400	/./748	-1/./90	1/./907	/./714	-9.198	9.920	11.606	/./266	12.047	-1/./257	0.194	1/./259
k V BUS T-24	/5.400	2.566	-15.864	14.068	2.892	-10.551	10.8/5	12.888	2.156	1/./066	-15.250	1.8/2	15/./47

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: SC

Page: /
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Future

1 Cycle - / -Phase, L3 , LL, & LL3 Fault Currents

Prefault Voltage G 100 = of the Bus Nominal Voltage

Bus		3-Phase Fault			Line-to-Ground Fault			Line-to-Line Fault			*Line-to-Line-to-Ground		
ID	%	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.	Real	Imag.	k ag.
k V BUS T-26	/ 5.400	4.1/ 6	-8.158	9.6/ 2	/ .99/	-5. / / 5	4.89/	7.047	5.545	8/ 56	-8.496	- / .024	9.11/
k V BUS T-27	/ 5.400	5/ 64	-10.164	11.062	5.020	-4.26/	6.622	8.807	/ .788	9.487	-10/ 95	-2.097	10.60/
k V BUS T-28	/ 5.400	2.688	-12.119	12.515	/ .8/ 2	-6. / 55	7.512	10.405	2/ / 4	10.761	-12.102	-0. / / 6	12.106
k V BUS T-29	/ 5.400	4.6/ 7	-6.7/ 4	8.78/	5.280	-5.28/	6.044	4.8/ 2	5.888	7.609	-7.4/ 0	- / . / 5	8.2/ 4
k V BUS T- / 1	/ 5.400	5.72/	-4.21/	7.0/ 5	/ . / 80	-2.775	5/ 7/	5.415	5.09/	6.095	-4.795	- / .174	6.607
k V BUS T- / 2	/ 5.400	/ .9/ 0	-9. / / 2	10.126	/ .762	-5.414	4.877	8.084	/ .511	8.774	-9.458	-2.019	9.749
k V BUS T- / /	/ 5.400	2.941	-10.497	11.000	/ .7/ /	-4.147	6/ 66	9.182	2.462	9.4/ /	-10.676	-0.998	10.72/
k V BUS T- / 5	/ 5.400	/ .525	-9.766	10/ 59	/ .699	-5.641	4.952	8.561	2.972	8.968	-9.910	-1.46/	10.0/ 2
k V BUS T- / 6	/ 5.400	5.497	-6.910	8/ 00	/ .457	- / .501	5.915	4.985	/ .986	7.190	-7. / 28	-2.911	7.884
k V BUS T- / 7	/ 5.400	5.664	-4.987	7.490	/ .5/ 5	- / .028	5.479	4.184	5.055	6.474	-6.581	- / .070	7.171
k V BUS T- / 9	/ 5.400	5.659	-4.262	7.021	/ . / / 2	-2.755	5/ 17	5.446	5.029	6.082	-4.81/	- / .1/ 0	6.60/
k V BUS T-50	/ 5.400	2.692	-9.466	9.9/ 7	/ .260	- / .7/ 9	5.961	8/ 10	2/ 55	8.6/ 5	-9.598	-1. / 02	9.487
k V BUS T-51	/ 5.400	/ .874	-5.608	6.020	2.611	-2.095	/ . / 57	5.016	/ . / 64	4.2/ 9	-5.945	-2.720	4.641
k V BUS T-52	/ 5.400	/ .888	-4.214	6.404	2.694	-2.292	/ .4/ 8	5.458	/ . / 75	4.66/	-4.415	-2.681	6.1/ 1
k V BUS T-5/	/ 5.400	/ .878	-5.650	6.057	2.616	-2.104	/ . / 48	5.057	/ . / 66	4.265	-5.986	-2.719	4.679
k V BUS T-55	/ 5.400	2.67/	-8.296	8.716	2.92/	-2.969	5.166	7.212	2/ 28	7.479	-8.25/	-1.426	8/ 8/
k V BUS T-54	/ 5.400	2.646	-8.697	9.09/	/ .017	- / .168	5/ 75	7.449	2/ 1/	7.904	-8.6/ 0	-1.542	8.741
k V BUS T-56	/ 5.400	2.682	-9.21/	9.496	/ .165	- / .596	5.714	8.006	2/ / 4	8/ / 9	-9.156	-1. / 71	9.258
k V BUS T-58	/ 5.400	/ .559	- / .6/ 2	4.009	2.297	-1.670	2.850	/ .162	2.996	5/ 46	- / .989	-2.579	5.697
k V BUS T-59	/ 5.400	/ .4/ 4	-5.155	4.557	2/ 92	-1.8/ 9	/ .017	/ .609	/ .070	5.7/ 8	-5.567	-2.410	4.125
k V BUS T-40	/ 5.400	/ .542	- / .658	4.022	2/ 00	-1.674	2.854	/ .174	2.999	5/ 67	-5.005	-2.581	5.710
POI	1/ 8.000	2.150	-9.915	10.152	1.788	-9.248	9.529	8.487	1.845	8.784	7.8/ 4	6.190	9.984

All fault currents are symmetrical (1 Cycle network) values in rms %.

* LL3 fault current is the larger of the two faulted line currents.

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C


Study Case: SC

Page: 4
Date: 09-21-2017
SN: WESTWOODP
Revision: Base
Config.: Future

Bus		Positive Seq. Imp. (ohm)			Negative Seq. Imp. (ohm)			Zero Seq. Imp. (ohm)			Fault Zf (ohm)		
ID	%	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance	Resistance	Reactance	Impedance
LV BUS T-59	0.690	0.00/ 24	0.00/ 71	0.0059/	0.00/ 25	0.00/ 71	0.00592	0.00248	0.00265	0.00/ 70	0.00000	0.00000	0.00000
LV BUS T-40	0.690	0.00/ / 6	0.00/ 76	0.00404	0.00/ / 4	0.00/ 76	0.00405	0.00248	0.00265	0.00/ 70	0.00000	0.00000	0.00000
k V BUS T-01	/ 5.400	/ .72990	2.70401	5.60742	/ .7/ 179	2.70246	5.60762	6.88457	5./ 7865	8.14979	0.00000	0.00000	0.00000
k V BUS T-02	/ 5.400	/ .26056	2.46/ 85	5.15776	/ .262/ 5	2.461/ 6	5.15770	6.12877	5.247/ 2	7.562/ 5	0.00000	0.00000	0.00000
k V BUS T-0/	/ 5.400	2.89002	2.52829	/ .77576	2.89186	2.52477	/ .77544	4.58661	5.145/ 7	6.88198	0.00000	0.00000	0.00000
k V BUS T-05	/ 5.400	2.75289	2./ 2888	/ .49822	2.75572	2./ 26/ 2	/ .49794	4.00456	5.02/ / 4	6.52200	0.00000	0.00000	0.00000
k V BUS T-04	/ 5.400	2.491/ 0	2.21/ 18	/ .50778	2.49/ 10	2.21046	/ .50754	5.566/ 8	/ .87644	4.91507	0.00000	0.00000	0.00000
k V BUS T-06	/ 5.400	2.44005	2.08/ 90	/ .29/ 2/	2.44180	2.08112	/ .2928/	5.29508	/ .70849	4.67/ 87	0.00000	0.00000	0.00000
k V BUS T-07	/ 5.400	2.2594/	2.00105	/ .01075	2.24127	1.99824	/ .01018	/ .81957	/ .6/ 240	4.27100	0.00000	0.00000	0.00000
k V BUS T-08	/ 5.400	1.65675	1.89745	2.41254	1.65824	1.89565	2.41124	5.0/ 864	/ .746/ 2	4.41459	0.00000	0.00000	0.00000
k V BUS T-09	/ 5.400	0.56696	1.66612	1.7/ 0/ 2	0.56798	1.6628/	1.7275/	/ .41/ / 8	/ .60867	4.0/ 640	0.00000	0.00000	0.00000
k V BUS T-10	/ 5.400	0.51/ 52	1.60154	1.64/ 96	0.5155/	1.49811	1.64097	/ .12260	/ .58086	5.67622	0.00000	0.00000	0.00000
k V BUS T-1/	/ 5.400	/ .09948	2.20047	/ .801/ 0	/ .101/ 8	2.1978/	/ .80118	5.87188	/ .71662	6.12768	0.00000	0.00000	0.00000
k V BUS T-15	/ 5.400	2.77/ 15	2.10645	/ .58241	2.7759/	2.10/ 78	/ .58226	5./ 4/ 16	/ .6/ / 56	4.67028	0.00000	0.00000	0.00000
k V BUS T-14	/ 5.400	2.00/ 77	1.842/ 6	2.72880	2.00458	1.85941	2.72812	/ .06504	/ .52679	5.49688	0.00000	0.00000	0.00000
k V BUS T-16	/ 5.400	2.91220	2.18651	/ .65161	2.91/ 97	2.18/ 66	/ .651/ 7	5.86845	/ .80068	6.17650	0.00000	0.00000	0.00000
k V BUS T-17	/ 5.400	0./ / / 4/	1.57098	1.408/ 1	0./ / 545	1.56747	1.40422	2./ / 297	/ .22128	/ .977/ 7	0.00000	0.00000	0.00000
k V BUS T-20	/ 5.400	1.62/ 22	1.78485	2.51/ / 1	1.625/ 8	1.78240	2.51162	5./ 5276	/ .44152	4.61000	0.00000	0.00000	0.00000
k V BUS T-21	/ 5.400	0.852/ 1	1.49098	1.80020	0.85/ 52	1.48761	1.79775	/ .12845	/ . / 4676	5.4886/	0.00000	0.00000	0.00000
k V BUS T-22	/ 5.400	0.45019	1.41452	1.60882	0.45126	1.41202	1.60498	2.65501	/ .27908	5.21226	0.00000	0.00000	0.00000
k V BUS T-2/	/ 5.400	0./ 1088	1.59/ 16	1.42418	0./ 1190	1.58981	1.42211	2.79988	/ .5780/	5.56598	0.00000	0.00000	0.00000
k V BUS T-25	/ 5.400	0./ 870/	1./ 7899	1.5/ 227	0./ 880/	1./ 7450	1.52909	1.58081	2.8/ 12/	/ .19410	0.00000	0.00000	0.00000
k V BUS T-24	/ 5.400	0.216/ 5	1./ 0511	1./ 219/	0.217/ /	1./ 0041	1./ 1845	1.0/ 866	2.7108/	2.90/ 00	0.00000	0.00000	0.00000
k V BUS T-26	/ 5.400	1.10264	1.7594/	2.06802	1.10/ 74	1.756/ 1	2.06488	5.6651/	/ .96224	6.1199/	0.00000	0.00000	0.00000
k V BUS T-27	/ 5.400	0.71055	1.64542	1.80060	0.71142	1.64129	1.79806	5.04458	/ .86567	4.60202	0.00000	0.00000	0.00000
k V BUS T-28	/ 5.400	0./ 57/ 9	1.46658	1.60545	0./ 5852	1.46/ 22	1.60148	/ .57/ 16	/ .771/ 1	4.12696	0.00000	0.00000	0.00000
k V BUS T-29	/ 5.400	1.54471	1.7/ 911	2.26794	1.5468/	1.7/ 476	2.26610	5.06/ / 9	/ .40665	4./ 6728	0.00000	0.00000	0.00000
k V BUS T-/ 1	/ 5.400	1.90102	2.09847	2.8/ 148	1.90218	2.09442	2.8/ 010	6.76066	5.5758/	8.10755	0.00000	0.00000	0.00000
k V BUS T-/ 2	/ 5.400	0.76/ 59	1.81280	1.96702	0.76549	1.80970	1.96548	5.98087	5.18959	6.4084/	0.00000	0.00000	0.00000
k V BUS T-/ /	/ 5.400	0.58475	1.75558	1.81085	0.58681	1.751/ 4	1.80812	5.4/ 147	5.11756	6.12279	0.00000	0.00000	0.00000
k V BUS T-/ 5	/ 5.400	0.6/ 680	1.816/ 7	1.92577	0.6/ 790	1.81/ 28	1.92222	5.98582	5.25088	6.4557/	0.00000	0.00000	0.00000
k V BUS T-/ 6	/ 5.400	1./ 29/ 4	1.99812	2./ 999/	1./ / 045	1.99410	2./ 9807	6.117/ 2	5.52254	7.45859	0.00000	0.00000	0.00000
k V BUS T-/ 7	/ 5.400	1.61292	2.07027	2.62552	1.61512	2.06727	2.62278	6.46218	5.59/ 77	7.94/ / 7	0.00000	0.00000	0.00000
k V BUS T-/ 9	/ 5.400	1.87851	2.1261/	2.8/ 704	1.87948	2.12/ 10	2.8/ 444	6.9270/	5.44226	8.28896	0.00000	0.00000	0.00000
k V BUS T-50	/ 5.400	0.45/ 00	1.92940	2.00554	0.45146	1.91625	1.991/ 0	6.8/ 089	4.2/ / 96	8.60444	0.00000	0.00000	0.00000
k V BUS T-51	/ 5.400	2.12942	2.4/ 207	/ / 0841	2.09944	2.41596	/ .27614	9.69901	6.12146	11.56927	0.00000	0.00000	0.00000
k V BUS T-52	/ 5.400	1.8/ 020	2.54585	/ .06200	1.79997	2.5/ 788	/ .0/ 0/ 7	9.2/ 510	6.059/ 0	11.0/ 915	0.00000	0.00000	0.00000
k V BUS T-5/	/ 5.400	2.112/ 4	2.42754	/ .29/ 95	2.07874	2.41118	/ .24995	9.67164	6.11717	11.55/ 80	0.00000	0.00000	0.00000
k V BUS T-55	/ 5.400	0.70098	2.17415	2.284/ 0	0.69709	2.14711	2.26694	8.66551	4.889/ 5	10.57656	0.00000	0.00000	0.00000
k V BUS T-54	/ 5.400	0.6/ 984	2.09596	2.19040	0.6/ 701	2.07846	2.17/ 98	8.15/ 55	4.71896	9.94098	0.00000	0.00000	0.00000
k V BUS T-56	/ 5.400	0.48008	1.99/ 09	2.07479	0.4781/	1.97865	2.061/ 8	7./ 5489	4.52526	9.1/ 142	0.00000	0.00000	0.00000
k V BUS T-58	/ 5.400	2.7/ 820	2.88/ 75	/ .97664	2.70946	2.86482	/ .95/ 95	11.47/ / 0	6.6204/	1/ / / 15	0.00000	0.00000	0.00000
k V BUS T-59	/ 5.400	2./ 7/ 07	2.78210	/ .64671	2./ 5522	2.765/ 4	/ .62540	10.98619	6.42651	12.77841	0.00000	0.00000	0.00000
k V BUS T-40	/ 5.400	2.726/ 2	2.880/ 9	/ .96605	2.69768	2.86257	/ .9/ / / 5	11.44514	6.61756	1/ / 1400	0.00000	0.00000	0.00000
POI	1/ 8.000	1.64768	7.6790/	7.84491	1.64741	7.674/ 2	7.84224	1.59129	9.4/ 4/ 5	9.64124	0.00000	0.00000	0.00000

APPENDIX B: ETAP SINGLE LINE DIAGRAM

One-Line Diagram - NW_OH (Short-Circuit Analysis)



Westwood

APPENDIX C: ETAP MODEL INPUTS

Power Grid Editor - Haviland

Info Rating Short Circuit Time Domain Harmonic Reliability Energy Price Remarks Comment

138 kV Swing

Grounding

SC Rating

	MVA _{sc}	MVA _{sc}	X/R	kA _{sc}
3-Phase	1723.7		4.375	7.211
1-Phase	1612.8	537.6	5.068	6.747

sqrt(3)V_L I_f V_n I_f

SC Impedance (100 MVA_b)

	% R	% X
Pos.	1.29271	5.65562
Neg.	1.29271	5.65562
Zero	1.35513	6.86778

Power Grid Editor - Future System (2022)

Info Rating Short Circuit Time Domain Harmonic Reliability Energy Price Remarks Comment

138 kV Swing

Grounding

SC Rating

	MVA _{sc}	MVA _{sc}	X/R	kA _{sc}
3-Phase	2145		4.375	8.974
1-Phase	1875	625	5.068	7.844

sqrt(3)V_L I_f V_n I_f

SC Impedance (100 MVA_b)

	% R	% X
Pos.	1.03881	4.5448
Neg.	1.03881	4.5448
Zero	1.2927	6.55141

Figure 1: Utility Equivalent Data

Westwood

3-Winding Transformer Editor - MPT

Reliability		Remarks		Comment	
Info	Rating	Impedance	Tap	Grounding	Protection
70.2	70.2	70.2 MVA			138 34.5 13.8 kV

Impedance

	Positive		Zero		MVA Base
	% Z	X/R	% Z	X/R	
PS	10.103	40.4	9.903	39.6	70.2
PT	16.204	36.38	14.561	32.69	70.2
ST	4.192	12.2	3.765	10.95	70.2

Z Variation

@ - 5 % Tap
0 %

@ + 5 % Tap
0 %

No Load Losses (Unbalanced Load Flow only)

	% FLA	kW	% G	% B
Positive	0	0	0	0
Zero	0	0	0	0

☐ Buried Delta Winding

Zero Seq. Impedance

Z Tolerance
± 0 %

Figure 2: Main Power Transformer Impedance

Westwood

2-Winding Transformer Editor - GSU T-01

Reliability		Remarks			Comment																				
Info	Rating	Impedance	Tap	Grounding	Sizing	Protection	Harmonic																		
2.75 MVA ANSI Liquid-Fill Other 65 C						34.5	0.69 kV																		
Impedance <table border="1"> <thead> <tr> <th></th> <th>%Z</th> <th>X/R</th> <th>R/X</th> <th>%X</th> <th>%R</th> </tr> </thead> <tbody> <tr> <td>Positive</td> <td>5.75</td> <td>9.03</td> <td>0.111</td> <td>5.715</td> <td>0.633</td> </tr> <tr> <td>Zero</td> <td>5.75</td> <td>9.03</td> <td>0.111</td> <td>5.715</td> <td>0.633</td> </tr> </tbody> </table> Typical Z & X/R Typical X/R							%Z	X/R	R/X	%X	%R	Positive	5.75	9.03	0.111	5.715	0.633	Zero	5.75	9.03	0.111	5.715	0.633	Z Base MVA 2.75 Other 65	
	%Z	X/R	R/X	%X	%R																				
Positive	5.75	9.03	0.111	5.715	0.633																				
Zero	5.75	9.03	0.111	5.715	0.633																				
Z Variation <table border="1"> <thead> <tr> <th></th> <th>%Z</th> <th>% Z Variation</th> </tr> </thead> <tbody> <tr> <td>@ -5 % Tap</td> <td>5.75</td> <td>0</td> </tr> <tr> <td>@ 5 % Tap</td> <td>5.75</td> <td>0</td> </tr> </tbody> </table>							%Z	% Z Variation	@ -5 % Tap	5.75	0	@ 5 % Tap	5.75	0	Z Tolerance + 0 % - 0 %										
	%Z	% Z Variation																							
@ -5 % Tap	5.75	0																							
@ 5 % Tap	5.75	0																							
No Load Test Data (Used for Unbalanced Load Flow only) <table border="1"> <thead> <tr> <th></th> <th>% FLA</th> <th>kW</th> <th>% G</th> <th>% B</th> </tr> </thead> <tbody> <tr> <td>Positive</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Zero</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> </tbody> </table> ☐ Buried Delta Winding Zero Seq. Impedance Typical Value									% FLA	kW	% G	% B	Positive	0	0	0	0	Zero	0	0	0	0			
	% FLA	kW	% G	% B																					
Positive	0	0	0	0																					
Zero	0	0	0	0																					

GSU T-01 OK Cancel

Figure 3: Step-Up Transformer Impedance Data

Westwood

Wind Turbine Generator - WTG T-01

Info Rating Imp/Model Turbine Wind Controls Pitch Control Inertia Time Domain Reliability Rv

Generic 0.69 kV 2.5 MW Voltage Control

Locked Rotor

LRC 600 %

PF 11.15 %

ANSI Short-Circuit Z

Xsc

Std MF 20 1/2 cy

Xsc 20 1.5-4 cy

Parameters

Xo 20 X2 20

X/R 45.093 Td' 0.2

Grounding

Connection  Type Solid

Earthing Type NEC

Model

Model Type

WT3G

Sample Data

X" 0.2 T1 0 T2 0 T3 0 Lvplsw 0

Lvpl1 1.11 Lvpl2 0 zerox 0.5 brkpt 0.9 mpwr 0

☐ None ☒ Current Injection

WTG T-01

OK Cancel

Figure 4: Turbine Impedance/Short Circuit Data

NW_OH 1/C AL XLPE 35 kV 100 % Non-Mag. 60 Hz Ohms/1000ft RHO 200°C.cm/W														
Ampacity	Impedance	Physical	Cable Pulling											
	Phase			Ground/Neutral		R	X	L	Y	Ro	Xo	Lo	Yo	Rdc
	Avail.	Code	Size	#	Size	90°C	60 Hz	60 Hz	60 Hz	90°C	60 Hz	60 Hz	60 Hz	25°C
1	Yes	1/0 - 2/3 CN	1/0	18	16	0.24087	0.05182	0.00014	1.77E-05	0.35886	0.05482	0.00015	1.77E-05	0.18596
2	Yes	4/0 - 1/2 CN	4/0	17	14	0.11303	0.04679	0.00012	2.2E-05	0.28416	0.07373	0.0002	2.2E-05	0.08673
3	Yes	500 - 1/3 CN	500	16	12	0.4939	0.04115	0.00011	3.05E-05	0.16756	0.04488	0.00012	3.05E-05	0.0361
4	Yes	750 - 1/6 CN	750	19	14	0.0343	0.03865	0.0001	3.56E-05	0.18978	0.05914	0.00016	3.56E-05	0.0248
5	Yes	1000 - 1/6 CN	1000	25	14	0.02568	0.03703	0.0001	3.98E-05	0.20941	0.07373	0.0002	3.98E-05	0.01814
6	Yes	1250 - 1/6 CN	1250	20	12	0.02048	0.03537	9E-05	4.36E-05	0.23977	0.09952	0.00026	4.36E-05	0.01422

Figure 5: Cable Impedance Data



AC CABLE SIZING STUDY

Northwest Ohio Wind Project

Paulding, Ohio

September 27, 2017

Prepared for:



Prepared by:

Westwood

Westwood

Project Name: NW OH Wind Project	
Title	J.O. or W.O. Number
AC Cable Sizing Study	0007186.00

Approvals		Revision Number	Date	Description
Preparer(s) Name	Reviewer(s) Name			
Josh Venden	Drew Szabo	0	09/27/2017	Original Release

TABLE OF CONTENTS

INTRODUCTION	4
OBJECTIVE	4
INPUTS & ASSUMPTIONS	4
METHODOLOGY	5
THERMAL ANALYSIS RESULTS AND CONCLUSION	5
APPENDIX A: SINGLE CIRCUIT CYMCAP REPORTS.....	A
APPENDIX B: PARALLEL CIRCUIT CYMCAP REPORTS.....	A

Westwood

INTRODUCTION

NW OH Wind Project is a 100 MW wind generation installation in Paulding, OH consisting 42 of GE 2.5 MW wind turbines. The turbines are grouped into four medium voltage (MV) feeders with 10 turbines on Feeders 1 and 4 and 11 turbines on Feeders 2 and 3. The feeders are connected to a main power transformer that steps the voltage up to 138kV where it interconnects with the AEP transmission system via a short overhead line segment.

OBJECTIVE

The objective of this report is to provide the design basis for determining the ampacity ratings of the medium and low voltage AC cables between the turbines, transformers, and junction boxes.

INPUTS & ASSUMPTIONS

- The native soil thermal resistivity is 150°C-cm/W as per the assessment of Westwood Professional Services based on the Geotechnical Engineering Report for Northwest Ohio Wind Project; completed by BARR, December 2014.
- Thermal resistivity of the disturbed soil in the cable trench is based on considerations of residual moisture, such that it indicates a worst case rho value of 200°C-cm/W at the specified 85% compaction.
- Thermal resistivity of the concrete ductbank is assumed to be 55 C-cm/W per NEC.
- Appendix D, has the excerpts for the dry out curves of the soil at various test points.
- Soil ambient temperature at various depths is shown in the following table.

Depth [ft]	Depth [m]	T _{max} [C]
3	0.91	22
4	1.22	21
5	1.52	20
6	1.83	19
7	2.13	18
8	2.44	18
9	2.74	17
10	3.05	17

- Cables are analyzed at their maximum allowable continuous operating temperature of 90° C.
- Load factor assumed conservatively at 100% for determining the cable ampacities.
- Direct buried medium voltage AC Cables are evaluated with minimum 48" soil cover.
- Medium voltage AC collector electrical layout is per the Westwood Professional Services Electrical Drawings, MVAC Collection One-Line Diagrams E.200 & E.210 and Trench Details E.600.
- The standard installation is based on a trefoil arrangement of cables, aluminum conductors with copper concentric neutral wires bonded at both ends.
- The nameplate rating of the turbines is 2.5MW with reactive power capability of 0.9 lead/lag. Maximum cable amp loadings are based on maximum total turbine MVA output; approximately 49A at 34.5 kV.

Westwood

METHODOLOGY

- Thermal analysis of underground cables is conducted with CYME Cymcap software, which uses the Neher-McGrath methodology to determine reduced cable ratings based on project specific thermal constraints.
- CYMCAP analysis is conducted for single and multiple circuit trenches for all of the MV cable sizes and configurations used in the underground collection design.
- CYMCAP analysis is also performed to verify the ampacity of the low voltage cables passing through the turbine foundation.

THERMAL ANALYSIS RESULTS AND CONCLUSION

SINGLE CIRCUIT AMPACITY

- Table 1 shows a summary of the single circuit cable ampacities and maximum number of turbines that can be connected to each cable size without violating its respective ampacity rating.

Cable	Material	Maximum 3PH Fault Current	Phase Conductor SC Withstand	Ampacity & Configuration	
1/0	Al	7814	PASS	142.3	Trefoil
4/0	Al	12637	PASS	212.9	Trefoil
500	Al	8304	PASS	334.7	Trefoil
750	Al	10974	PASS	408.6	Trefoil
1000	Al	9865	PASS	477.1	Trefoil
1250	Al	12101	PASS	540.5	Trefoil
1250*	Al	12101	PASS	570.5	Trefoil

** Increased ampacity based on 90% soil compaction in trenches with 11 turbines on the ckt*

Table 1: Cable Ampacity Summary

- As the final two rows of the above table indicate, for 1250 kCMIL cable with an ampacity rating large enough to accommodate 11 turbines, a soil compaction of at least 90% must be achieved in the trenches, which reduces the soil thermal resistivity closer to the native soil value of 150°C-cm/W. Feeders 2 and 3 require this compaction level for the MV cable trenches from the substation to the first wind turbine on each feeder.

MULTIPLE CIRCUIT TRENCHES

- In several locations, multiple MV circuits will run parallel to one another in the same right of way (ROW). Further thermal analysis was performed on these areas to determine the minimum spacing between circuits required to maintain acceptable operating temperatures.
- The following table summarizes the locations where multiple circuits will occupy the same parallel trench paths. The table indicates the number of turbines and corresponding loading on each cable segment.
- The worst case from a thermal standpoint occurs in the ROW from Turbine 25 to the Substation where all four fully loaded feeders run parallel to one another. To achieve adequate thermal performance from the

Westwood

cables, a concrete duct bank installation must be used for the four homerun circuits from T-25 to the Sub. The ductbank must be a minimum of 18" thick and 10' long with the cable ducts spaced 2.5' apart.

Table 2: Multiple Circuit Trench Summary

TRENCH SEGMENT		FEEDERS IN TRENCH			Cable Sizes	Ckt Spacing (center-to-center)
FROM	TO	FDR	TURBINES	AMPS		
SUB	T-25	1	10	516.51	1250	1.5' x 10' duct bank rho <= 0.55 C-m/W 2.5' duct spacing
		2	11	568.16	1250	
		3	11	568.16	1250	
		4	10	516.51	1250	
T-25	T-24	1	10	516.51	1250	four 12" trenches; 25' ROW backfill rho <= 1.00 C-m/W 7' FDR1-FDR2, 11' FDR2-FDR3, 3' FDR3-FDR4
		2	11	568.16	1250	
		3	11	568.16	1250	
		4	1	51.65	4/0	
T-24	JB-2/1	1	10	516.51	1250	triple 12" trenches; 50' ROW 23.5' FDR1-FDR2 & 23.5' FDR2-FDR3
		2	11	568.16	1250	
		3	11	568.16	1250	
JB-2/1	T-22	1	10	516.51	1250	triple 12" trenches; 35' ROW w/ 4/0 conductor in center trench; 9.5' FDR1-FDR3 & 21' FDR3-FDR2
		2	11	568.16	1250	
		3	4	206.60	4/0	
T-22	T-23	1	10	516.51	1250	triple 12" trenches; 12' ROW w/ 1/0 conductor in center trench; 4.5' between all circuits
		2	11	568.16	1250	
		3	1	51.65	1/0	
T-23	T-28	1	10	516.51	1250	double 12" trenches; 18' ROW 7.5' FDR1-FDR2
		2	10	516.51	1250	
T-28	T-33	1	10	516.51	1250	double 12" trenches; 15' ROW 6' FDR1-FDR2
		2	7	361.55	750	
T-33	T-34	1	10	516.51	1250	double 12" trenches; 20' ROW 9' FDR1-FD2
		2	4	206.60	4/0	
T-34	T-39	1	10	516.51	1250	single 18" trench; 3' ROW 1' FDR1-FDR2
		2	1	51.65	1/0	

WETLANDS, ROAD AND PIPELINE CROSSINGS

- There are several designated wetland areas, road and gas pipeline crossings throughout the site that require directional drill boring installation. The depth of the borings vary by crossing but are assumed a minimum of 10' depth at the time of this study.

APPENDIX A: SINGLE CIRCUIT CYMCAP REPORTS

Study Summary

CYMCAP Version	7.2 Revision 3
Study:	UG Collector Circuits
Execution:	Single Ckt 1_0 - 2_3 CN AL XLPE
Date:	9/18/2017 2:00:06 PM


General Simulation Data

Steady State Option	Equally Loaded
Consider Electrical interaction between circuits	No
Induced currents in metallic layers as a fraction of conductor current (applied to all single phase circuits) :	0.0
Conductor Resistances Computation Option:	IEC-228

Installation Type:Multiple Ductbanks/Backfills

Ambient Soil Temperature at Installation Depth	[°C]	21.0
Native Soil Thermal Resistivity	[K.m/W]	1.5
Consider Non-Isothermal Earth Surface		No

Layer Name	X [ft]	Y [ft]	Width [ft]	Height [ft]	Thermal Resistivity [K.m/W]
Backfill	0.0	2.25	1.5	4.5	2.0



Results Summary

Cable No.	Cable ID	Circuit No.	Feeder ID	Cable Phase	Cable Frequency	Daily Load Factor	X coordinate [ft]	Y coordinate [ft]	Conductor temperature [°C]	Ampacity [A]
1	1_0 AL - 2_3 CN	1	1_0 - 2_3	A	60.0	1.0	-0.06	4.28	89.7	142.3
2	1_0 AL - 2_3 CN	1	1_0 - 2_3	B	60.0	1.0	0.06	4.28	89.6	142.3
3	1_0 AL - 2_3 CN	1	1_0 - 2_3	C	60.0	1.0	0.0	4.18	90.0	142.3

Study Summary

CYMCAP Version	7.2 Revision 3
Study:	UG Collector Circuits
Execution:	Single Ckt 4_0 - 1_2CN AL XLPE
Date:	9/18/2017 12:57:47 PM


General Simulation Data

Steady State Option	Equally Loaded
Consider Electrical interaction between circuits	No
Induced currents in metallic layers as a fraction of conductor current (applied to all single phase circuits) :	0.0
Conductor Resistances Computation Option:	IEC-228

Installation Type:Multiple Ductbanks/Backfills

Ambient Soil Temperature at Installation Depth	[°C]	21.0
Native Soil Thermal Resistivity	[K.m/W]	1.5
Consider Non-Isothermal Earth Surface		No

Layer Name	X [ft]	Y [ft]	Width [ft]	Height [ft]	Thermal Resistivity [K.m/W]
Backfill	0.0	2.25	1.5	4.5	2.0



Results Summary

Cable No.	Cable ID	Circuit No.	Feeder ID	Cable Phase	Cable Frequency	Daily Load Factor	X coordinate [ft]	Y coordinate [ft]	Conductor temperature [°C]	Ampacity [A]
1	4_0 AL - 1_2 CN	1	4_0 - 1_2	A	60.0	1.0	-0.07	4.29	89.4	212.9
2	4_0 AL - 1_2 CN	1	4_0 - 1_2	B	60.0	1.0	0.07	4.29	89.6	212.9
3	4_0 AL - 1_2 CN	1	4_0 - 1_2	C	60.0	1.0	0.0	4.17	90.0	212.9

Study Summary

CYMCAP Version	7.2 Revision 3
Study:	UG Collector Circuits
Execution:	Single Ckt 500 - 1_3CN AL XLPE
Date:	9/18/2017 2:06:09 PM


General Simulation Data

Steady State Option	Equally Loaded
Consider Electrical interaction between circuits	No
Induced currents in metallic layers as a fraction of conductor current (applied to all single phase circuits) :	0.0
Conductor Resistances Computation Option:	IEC-228

Installation Type:Multiple Ductbanks/Backfills

Ambient Soil Temperature at Installation Depth	[°C]	21.0
Native Soil Thermal Resistivity	[K.m/W]	1.5
Consider Non-Isothermal Earth Surface		No

Layer Name	X [ft]	Y [ft]	Width [ft]	Height [ft]	Thermal Resistivity [K.m/W]
Backfill	0.0	2.25	1.5	4.5	2.0



Results Summary

Cable No.	Cable ID	Circuit No.	Feeder ID	Cable Phase	Cable Frequency	Daily Load Factor	X coordinate [ft]	Y coordinate [ft]	Conductor temperature [°C]	Ampacity [A]
1	500 AL - 1_3 CN	1	500 - 1_3	A	60.0	1.0	-0.08	4.3	89.6	334.7
2	500 AL - 1_3 CN	1	500 - 1_3	B	60.0	1.0	0.08	4.3	89.6	334.7
3	500 AL - 1_3 CN	1	500 - 1_3	C	60.0	1.0	0.0	4.16	90.0	334.7

CYMCAP Version	7.2 Revision 3
Study:	UG Collector Circuits
Execution:	Single Ckt 750 - 1_6CN AL XLPE
Date:	9/18/2017 2:11:08 PM


General Simulation Data

Steady State Option	Equally Loaded
Consider Electrical interaction between circuits	No
Induced currents in metallic layers as a fraction of conductor current (applied to all single phase circuits) :	0.0
Conductor Resistances Computation Option:	IEC-228

Installation Type:Multiple Ductbanks/Backfills

Ambient Soil Temperature at Installation Depth	[°C]	21.0
Native Soil Thermal Resistivity	[K.m/W]	1.5
Consider Non-Isothermal Earth Surface		No

Layer Name	X [ft]	Y [ft]	Width [ft]	Height [ft]	Thermal Resistivity [K.m/W]
Backfill	0.0	2.25	1.5	4.5	2.0



Results Summary

Cable No.	Cable ID	Circuit No.	Feeder ID	Cable Phase	Cable Frequency	Daily Load Factor	X coordinate [ft]	Y coordinate [ft]	Conductor temperature [°C]	Ampacity [A]
1	750 AL - 1_6 CN	1	750 - 1_6	A	60.0	1.0	-0.09	4.3	89.7	408.6
2	750 AL - 1_6 CN	1	750 - 1_6	B	60.0	1.0	0.09	4.3	89.6	408.6
3	750 AL - 1_6 CN	1	750 - 1_6	C	60.0	1.0	0.0	4.15	90.0	408.6

CYMCAP Version	7.2 Revision 3
Study:	UG Collector Circuits
Execution:	Single Ckt 1000 - 1_6CN AL XLPE
Date:	9/18/2017 1:55:04 PM


General Simulation Data

Steady State Option	Equally Loaded
Consider Electrical interaction between circuits	No
Induced currents in metallic layers as a fraction of conductor current (applied to all single phase circuits) :	0.0
Conductor Resistances Computation Option:	IEC-228

Installation Type:Multiple Ductbanks/Backfills

Ambient Soil Temperature at Installation Depth	[°C]	21.0
Native Soil Thermal Resistivity	[K.m/W]	1.5
Consider Non-Isothermal Earth Surface		No

Layer Name	X [ft]	Y [ft]	Width [ft]	Height [ft]	Thermal Resistivity [K.m/W]
Backfill	0.0	2.25	1.5	4.5	2.0



Results Summary

Cable No.	Cable ID	Circuit No.	Feeder ID	Cable Phase	Cable Frequency	Daily Load Factor	X coordinate [ft]	Y coordinate [ft]	Conductor temperature [°C]	Ampacity [A]
1	000 AL - 1_6 CN	1	1000 - 1_6	A	60.0	1.0	-0.09	4.3	89.7	477.1
2	000 AL - 1_6 CN	1	1000 - 1_6	B	60.0	1.0	0.09	4.3	89.7	477.1
3	000 AL - 1_6 CN	1	1000 - 1_6	C	60.0	1.0	0.0	4.14	90.0	477.1

CYMCAP Version	7.2 Revision 3
Study:	UG Collector Circuits
Execution:	Single Ckt 1250 - 1_6CN AL XLPE
Date:	9/18/2017 1:52:28 PM


General Simulation Data

Steady State Option	Equally Loaded
Consider Electrical interaction between circuits	No
Induced currents in metallic layers as a fraction of conductor current (applied to all single phase circuits) :	0.0
Conductor Resistances Computation Option:	IEC-228

Installation Type:Multiple Ductbanks/Backfills

Ambient Soil Temperature at Installation Depth	[°C]	21.0
Native Soil Thermal Resistivity	[K.m/W]	1.5
Consider Non-Isothermal Earth Surface		No

Layer Name	X [ft]	Y [ft]	Width [ft]	Height [ft]	Thermal Resistivity [K.m/W]
Backfill	0.0	2.25	1.5	4.5	2.0



Results Summary

Cable No.	Cable ID	Circuit No.	Feeder ID	Cable Phase	Cable Frequency	Daily Load Factor	X coordinate [ft]	Y coordinate [ft]	Conductor temperature [°C]	Ampacity [A]
1	250 AL - 1_6 CN	1	1250 - 1_6	A	60.0	1.0	-0.1	4.31	89.7	540.5
2	250 AL - 1_6 CN	1	1250 - 1_6	B	60.0	1.0	0.1	4.31	89.7	540.5
3	250 AL - 1_6 CN	1	1250 - 1_6	C	60.0	1.0	0.0	4.14	90.0	540.5

CYMCAP Version	7.2 Revision 3
Study:	UG Collector Circuits
Execution:	Single Ckt 1250 - 1_6CN AL XLPE 150rho
Date:	9/18/2017 2:24:58 PM


General Simulation Data

Steady State Option	Equally Loaded
Consider Electrical interaction between circuits	No
Induced currents in metallic layers as a fraction of conductor current (applied to all single phase circuits) :	0.0
Conductor Resistances Computation Option:	IEC-228

Installation Type:Multiple Ductbanks/Backfills

Ambient Soil Temperature at Installation Depth	[°C]	21.0
Native Soil Thermal Resistivity	[K.m/W]	1.5
Consider Non-Isothermal Earth Surface		No

Layer Name	X [ft]	Y [ft]	Width [ft]	Height [ft]	Thermal Resistivity [K.m/W]
Backfill	0.0	2.25	1.5	4.5	1.5




Results Summary

Cable No.	Cable ID	Circuit No.	Feeder ID	Cable Phase	Cable Frequency	Daily Load Factor	X coordinate [ft]	Y coordinate [ft]	Conductor temperature [°C]	Ampacity [A]
1	250 AL - 1_6 CN	1	1250 - 1_6	A	60.0	1.0	-0.1	4.31	90.0	570.5
2	250 AL - 1_6 CN	1	1250 - 1_6	B	60.0	1.0	0.1	4.31	90.0	570.5
3	250 AL - 1_6 CN	1	1250 - 1_6	C	60.0	1.0	0.0	4.14	90.0	570.5


Westwood

APPENDIX B: PARALLEL CIRCUIT CYMCAP REPORTS

ROW: T-34 to T39




ROW: T-33 to T-34



ROW: T-28 to T-33


Westwood

Fig-60.0 Hz R- IEC-228 Ambient temp. = 21.0°C




ROW: T-23 to T-28

Fig-60.0 Hz R- IEC-228 Ambient temp. = 21.0°C




ROW: T-22 to T-23


Westwood



ROW: JB-2/1 – T-22




ROW: T-25 to T-25



ROW: T-25 to SUB

Westwood

Fq=60.0 Hz R= IEC-228 Ambient temp.= 21.0°C





ANNUAL AND PEAK LOSSES STUDY

Paulding, Ohio
September 27, 2017

Prepared for:



Prepared by:

Westwood

Westwood

Project Name: NW OH Wind Project	
Title	J.O. or W.O. Number
Annual and Peak Losses Study	0007186.00

Approvals		Revision Number	Date	Description
Preparer(s) Name	Reviewer(s) Name			
Abhishek Kulkarni	Drew Szabo	0	09/27/2017	Original Release

TABLE OF CONTENTS

INTRODUCTION	4
OBJECTIVE	4
INPUTS & ASSUMPTIONS	4
METHODOLOGY	5
CONCLUSION	8
APPENDIX A: SHORT CIRCUIT SUMMARY REPORTS	A
APPENDIX B: ETAP SINGLE LINE DIAGRAM	B

Westwood

INTRODUCTION

NW OH Wind Project is a 100 MW wind generation installation in Paulding, OH consisting 42 of GE 2.5 MW wind turbines. The turbines are grouped into four medium voltage (MV) feeders with 10 turbines on Feeders 1 and 4 and 11 turbines on Feeders 2 and 3. The feeders are connected to a main power transformer that steps the voltage up to 138kV where it interconnects with the AEP transmission system via a short overhead line segment.

OBJECTIVE

The objective of this report is to determine the peak and annual electrical losses in the wind farm. Language from the draft BOP contract between the owner and Contractors states, *“Contractor shall provide calculations demonstrating the system design loss is less than or equal to two (2) percent annualized, unless otherwise approved by Owner, and shall be based on the wind frequency power curve provided by others as found in Exhibit E-1, Attachment 7 (Energy Production Report). The system losses shall be calculated for the complete electrical system from the WTG controller terminations at the bottom of the WTG to the permanent point of interconnection at the Utility’s Switchyard. This shall include the permanent transmission span between the Haviland 138kV Switchyard and the Trishe Wind Substation, the main power transformers, MV collection cable, WTG transformers, and medium voltage cable..”*

This study assess the losses for all components described above based on the design at the 30% Review stage (9/22/2017).

INPUTS & ASSUMPTIONS

- A data file with the expected typical year output of the 42-turbine wind farm on an hourly basis (8,760 hours) was provided by the owner for use in the loss calculation. The data file had a built-in, fixed loss estimate of 2.5% of production. Since the present study is intended to calculate the losses explicitly, the hourly production estimates from the data file were processed as follows prior to conducting the study:

$$\frac{1.025 \times \text{raw output data [W]}}{42} = \text{gross output per turbine before electrical losses [W]}$$

The raw output data provided gives an annual capacity factor for the plant of 35.35%

Following the pre-processing, the annual capacity factor before losses is 34.65%

- Medium voltage AC collector electrical layout is per the Westwood Professional Services Electrical Drawings, MVAC Collection One-Line Diagrams E.200 & E.210.
- Parameters for equipment such as turbines (WTG), step-up transformers (GSU) and main power transformer (MPT) based on manufacturer data.
- Parameters for MV cables based on thermal analysis using CYME Cymcap Underground Cable Thermal Analysis software.
- Parameters for overhead transmission line data based on values from the Southwire SW Rate software program.
- Parameters used in this study are shown in Appendix A.
- Appendix B shows the MVAC Schedule

METHODOLOGY

- This analysis accounts for all electrical losses between the 690 volt terminals of the low voltage breaker in the WTG tower base and the 138 kV bus of the Haviland substation. Losses consist of no-load and load losses for each cable section and piece of equipment.
- Losses are calculated assuming all wind turbines are rated for 2.5 MW.
- No-load losses are fixed when equipment is energized at a fixed voltage. For the purpose of the study, all components of the system are assumed to be energized at 1.0 pu voltage. Mathematically then, the no-load losses (peak, and annual) can be described as follows:

$$NLL_{peak} [kW] = NLL(1.0pu) [W] \times \frac{1 [kW]}{1000 [W]} \quad (\text{Eq. 1})$$

$$NLL_{annual} [kWh] = NLL(1.0pu) [W] \times \frac{1 [kW]}{1000 [W]} \times 8760 [h] \quad (\text{Eq. 2})$$

- It can then be seen that peak or annual no-load losses for the entire wind farm can be determined by simply adding the losses calculated by Equations 1 and 2 for each piece of equipment.
- Load losses at any operating point are losses related to electrical current flow in conductors or transformers and are therefore proportional to the square of the load current. For conductors, the peak losses (losses when all turbines are operating at their nameplate output, i.e. 2.5 MW) are given by:

$$LL_{Peak_{conductor}} [kW] = 3 \times I_{peak}^2 \times R \times \frac{1 [kW]}{1000 [W]} \quad (\text{Eq. 3})$$

- For transformers, peak load losses are given by:

$$LL_{Peak_{transformer}} [kW] = \text{Guaranteed Load Loss} [W] \times \left(\frac{I_{peak}}{I_{rated}} \right)^2 \times \frac{1 [kW]}{1000 [W]} \quad (\text{Eq. 4})$$

- Annual load losses for each conductor or transformer are calculated based on the annual distribution of operating points, with the load losses for each hour proportional to the square of the ratio of $I_{operating}/I_{peak}$. Since $I_{operating}/I_{peak}$ can be interpreted as an hourly load factor (or hourly capacity factor), the annual losses are just the peak losses x the sum of squares of the hourly load factor:

$$LL_{Annual_{conductor}} [kWh] = LL_{Peak_{conductor}} \times \Sigma HLL^2 \times 8760 [h] \quad (\text{Eq. 5})$$

$$LL_{Annual_{transformer}} [kWh] = LL_{Peak_{transformer}} \times \Sigma HLL^2 \times 8760 [h] \quad (\text{Eq. 6})$$

- Peak losses for each conductor or transformer are calculated based on the equations listed above. The hourly load factor would be 1 assuming that the turbine produces at full capacity which in this case is limited to 2,233.234kW per turbine per hour.

RESULTS

Based on the 8760 hour production file provided by the owner, the annual capacity factor before is losses is 35.35%. The annual average of sum of squares of hourly load factor is 21.76%.

- Low Voltage cables – The 8 parallel runs of 1000 kcmil Al have a resistance value of 1.14E-04 ohms. No-load losses are very low and neglected in this study. Based on the previous equations, load losses are calculated as:

$$LL_{Peak_{conductor}} \left[\frac{kW}{turbine} \right] = 3 \times I_{peak}^2 \times R \times \frac{1 [kW]}{1000 [W]} \quad (\text{Eq. 3})$$

$$Total LL_{peak} = 1.49 \left[\frac{kW}{turbine} \right] \times 42 turbines = 62.92 [kW]$$

Annual load losses per turbine come to:

$$LL_{Peak_{annual}} = 2,857.38 \left[\frac{kWh}{turbine} \right]$$

Total annual losses for low voltage cables are:

$$Total LL = 2,857.38 \left[\frac{kWh}{turbine} \right] \times 42 turbines = 117.2 [MWh]$$

Peak load losses per turbine come to:

$$LL_{Peak_{annual}} = 13,129.25 \left[\frac{kWh}{turbine} \right]$$

Total peak losses for low voltage cables are:

$$Total LL = 13,129.25 \left[\frac{kWh}{turbine} \right] \times 42 turbines = 583.3 [MWh]$$

- Padmount Transformers – Guaranteed no-load losses (NLL) or Core Losses and load losses (LL) for the 2750 kVA padmount transformers were provided in the form a proposal from the equipment vendor. The guaranteed no-load losses are 3.92 kW and load losses (LL) are 18.72 kW.

$$LL_{Peak} [kW] = \text{Guaranteed Load Loss } 18720 [W] \times \left(\frac{I_{peak}}{I_{rated}} \right)^2 \times \frac{1 [kW]}{1000 [W]} \\ = 15.47 [kW] \quad (\text{Eq. 4})$$

$$NLL_{peak} \left[\frac{kW}{turbine} \right] = NLL(1.0pu) 3920 [W] \times \frac{1 [kW]}{1000 [W]} = 3.92 [kW] \quad (\text{Eq. 1})$$

$$NLL_{annual} \left[\frac{kWh}{turbine} \right] = NLL(1.0pu) 3920 [W] \times \frac{1 [kW]}{1000 [W]} \times 8760 [h] = 34339.2 [kWh] \quad (\text{Eq. 2})$$

$$LL_{annual} \left[\frac{kWh}{turbine} \right] = 15.47 LL_{Peak} [kW] \times \Sigma HLL^2 \times 8760 [h] = 29,495.3 [kWh] \quad (\text{Eq. 6})$$

$$LL_{Peak} \left[\frac{kWh}{turbine} \right] = 15.47 LL_{Peak} [kW] \times \Sigma HLL^2 \times 8760 [h] = 3,762,787 [kWh] \quad (\text{Eq. 7})$$

Total Annual Losses for Padmount Transformers are:

$$\begin{aligned} \text{Total Losses} &= (34,339.2 \text{ NLL}_{\text{annual}} \left[\frac{\text{kWh}}{\text{turbine}} \right] + 24,495.3 \text{ LL}_{\text{annual}} \left[\frac{\text{kWh}}{\text{turbine}} \right]) \\ &\times 42 \text{ turbines} = 2,681.0 \text{ [MWh]} \end{aligned}$$

Total Peak Losses for Padmount Transformers are:

$$\begin{aligned} \text{Total Losses} &= (34,339.2 \text{ NLL}_{\text{annual}} \left[\frac{\text{kWh}}{\text{turbine}} \right] + 3,762,787.64 \text{ LL}_{\text{annual}} \left[\frac{\text{kWh}}{\text{turbine}} \right]) \\ &\times 42 \text{ turbines} = 4,165,747.64 \text{ [MWh]} \end{aligned}$$

- Medium voltage cable – No load losses for XLPE insulated MV Cable are quite low and are neglected in this study. Load losses vary in each cable section based on length, loading (number of turbines carried) and conductor cross sectional area.

$$\text{LL Peak}_{\text{conductor}} [\text{kW}] = 3 \times I_{\text{peak}}^2 \times R \times \frac{1 [\text{kW}]}{1000 [\text{W}]} \text{ (Eq. 3)}$$

$$\text{Total LL}_{\text{peak}} = 1,286.53 [\text{kW}]$$

$$\text{LL Annual}_{\text{conductor}} [\text{kWh}] = \text{LL Peak}_{\text{conductor}} \times \Sigma \text{HLL}^2 \times 8760 [\text{h}] \text{ (Eq. 5)}$$

Annual load losses for all the circuits together come to:

$$\text{LL}_{\text{annual}} = 2,476 [\text{MWh}]$$

Peak load losses for all the circuits together come to:

$$\text{LL}_{\text{Peak}} = 11,379.7 [\text{MWh}]$$

- Substation Main Transformer – Guaranteed no-load losses (NLL) or Core Losses and load losses (LL) for the 70200 kVA padmount transformers were provided in the form a proposal from the equipment vendor. The guaranteed no-load losses are 46 kW and load losses (LL) are 192 kW.

$$\begin{aligned} \text{LL Peak}_{\text{transformer}} [\text{kW}] &= \text{Guaranteed Load Loss } 192000 [\text{W}] \times \left(\frac{I_{\text{peak}}}{I_{\text{rated}}} \right)^2 \times \frac{1 [\text{kW}]}{1000 [\text{W}]} \\ &= 429.54 [\text{kW}] \text{ (Eq. 4)} \end{aligned}$$

$$\text{NLL}_{\text{peak}} \left[\frac{\text{kW}}{\text{turbine}} \right] = \text{NLL}(1.0\text{pu}) 46000 [\text{W}] \times \frac{1 [\text{kW}]}{1000 [\text{W}]} = 46 [\text{kW}] \text{ (Eq. 1)}$$

$$\text{NLL}_{\text{annual}} \left[\frac{\text{kWh}}{\text{turbine}} \right] = \text{NLL}(1.0\text{pu}) 46000 [\text{W}] \times \frac{1 [\text{kW}]}{1000 [\text{W}]} \times 8760 [\text{h}] = 402,960 [\text{kWh}] \text{ (Eq. 2)}$$

$$\begin{aligned} \text{LL}_{\text{annual}} \left[\frac{\text{kWh}}{\text{turbine}} \right] &= 429.54 \text{ LL Peak}_{\text{transformer}} [\text{kW}] \times \Sigma \text{HLL}^2 \times 8760 [\text{h}] \\ &= 818,913.30 [\text{kWh}] \text{ (Eq. 6)} \end{aligned}$$

Westwood

Total Annual Losses for Main Power Transformers are:

$$\begin{aligned} \text{Total Losses} &= (402,960 \text{ } NLL_{\text{annual}} \left[\frac{kWh}{\text{turbine}} \right] + 818,913.3 \text{ } LL_{\text{annual}} \left[\frac{kWh}{\text{turbine}} \right]) \\ &= 1,221.9 \text{ [MWh]} \end{aligned}$$

Total Peak Losses for Main Power Transformers are:

$$\begin{aligned} \text{Total Losses} &= (402,960 \text{ } NLL_{\text{annual}} \left[\frac{kWh}{\text{turbine}} \right] + 3,762,787.64 \text{ } LL_{\text{annual}} \left[\frac{kWh}{\text{turbine}} \right]) \\ &= 4,165.7 \text{ [MWh]} \end{aligned}$$

- 138 kV Transmission line – The 250' section of 954 kcmil ACSR has a resistance value of 0.0052 ohms. No-load losses are very low and neglected in this study. Based on the previous equations, load losses are calculated as:

$$LL \text{ Peak}_{\text{conductor}} \text{ [kW]} = 3 \times I_{\text{peak}}^2 \times R \times \frac{1 \text{ [kW]}}{1000 \text{ [W]}} \text{ (Eq. 3)}$$

$$\text{Total } LL_{\text{peak}} = 0.0272 \text{ [kW]}$$

$$LL \text{ Annual}_{\text{conductor}} \text{ [kWh]} = LL \text{ Peak}_{\text{conductor}} \times \Sigma HLL^2 \times 8760 \text{ [h]} \text{ (Eq. 5)}$$

Annual load losses for the 138kV overhead transmission line:

$$LL \text{ Peak}_{\text{annual}} = 51.94 \text{ [kWh]}$$

Peak load losses for the 138kV overhead transmission line:

$$LL \text{ Peak}_{\text{annual}} = 236.88 \text{ [kWh]}$$

- All the above results have been summarized in table 1 and 2.

Table 1: Overall Annual Losses Summary

Collector System Annual Losses Summary						
	No Load Loss (MWh)	%	Load Loss (MWh)	%	Total Loss (MWh)	%
LV Cable Losses	0.0	0.000%	117.2	0.036%	117.2	0.036%
Pad-Mount Xfmr Losses	1,238.8	0.381%	1,442.2	0.444%	2,681.0	0.824%
Underground MVAC Cable Losses	0.0	0.000%	2,476.6	0.762%	2,476.6	0.762%
Grounding Xfmr Losses	0.0	0.000%	0.0	0.000%	0.0	0.000%
Substation Main Power Transformer	403.0	0.124%	818.9	0.25%	1,221.9	0.376%
T Line Losses	0.000	0.000%	0.052	0.000%	0.052	0.000%
Total Losses	1,641.8	0.505%	4,855.0	1.493%	6,496.8	1.998%
Total Energy	325,176.5	100.00%	325,176.5	100.00%	325,176.5	100.00%
Capacity Factor (Before Losses)						35.35%
Capacity Factor (After Losses)						34.65%

Westwood

Table 2: Overall Annual Losses Summary

Collector System Peak Losses Summary						
	No Load Loss (MWh)	%	Load Loss (MWh)	%	Total Loss (MWh)	%
LV Cable Losses	0.0	0.000%	538.3	0.066%	538.3	0.066%
Pad-Mount Xfrmr Losses	5,692.1	0.693%	1,442.2	0.176%	7,134.4	0.868%
Underground MVAC Cable Losses	0.0	0.000%	11,379.7	1.385%	11,379.7	1.385%
Grounding Xfrmr Losses	0.0	0.000%	0.0	0.000%	0.0	0.000%
Substation Main Power Transformer	403.0	0.049%	3,762.8	0.458%	4,165.7	0.507%
T Line Losses	0.000	0.000%	0.239	0.000%	0.239	0.000%
Total Losses	6,095.1	0.742%	17,123.3	2.084%	23,218.4	2.826%
Total Energy	821,651.5	100.00%	821,651.5	100.00%	821,651.5	100.00%
Capacity Factor (Before Losses)					89.33%	
Capacity Factor (After Losses)					86.81%	

CONCLUSION

- The overall annual energy losses are calculated to be 6,496.8 MWh which is 1.998% of the total energy production estimated based on the expected annual output file provided by the client.
- The expected losses meet the language from the draft BOP contract between the owner and Contractors states, *"Contractor shall provide calculations demonstrating the system design loss is less than or equal to two (2) percent annualized, unless otherwise approved by Owner, and shall be based on the wind frequency power curve provided by others as found in Exhibit E-1, Attachment 7 (Energy Production Report).*

APPENDIX A: EQUIPMENT PARAMETERS USED IN THE STUDY

Transmission Line Parameters (Assumption)

Cable	R1 ohms per 1000'
954 ACSR 45/7	0.0208

MVAC Cable Parameters Derived in Cymcap Software Program

Cable	R1 ohms per 1000'
1/0 - 2/3	0.2409
4/0 - 1/2	0.1130
500 - 1/3	0.0494
750 - 1/6	0.0343
1000 - 1/6	0.0257
1250 - 1/6	0.0205
1250 - 1/6	0.0205

LVAC Cable Parameters (Assumption)

Cable	R1 ohms per 1000'
1000kCMIL	0.0228

Main Power Transformer Guaranteed Losses (Vendor Quote)

Main Power Transformer	
Xfmr Rating (kVA)	70200
Load Loss @ rated kVA (kW)	192.0
Core Loss Per Xfmr (kW)	46.0

Pad Mount Transformer Guaranteed Losses (Vendor Quote)

Padmount Transformer	
Xfmr Rating (kVA)	2750
Load Loss @ rated kVA (kW)	18.720
Core Loss Per Xfmr (kW)	3.92



**ELECTRICAL EQUIPMENT
AND MATERIAL SPECIFICATION
ATTACHMENT B – BID FORM**

POWER TRANSFORMER
ULTEIG PROJECT NO. R17.01246

ULTEIG SPECIFICATION NO. 0101-B

ATTACHMENT B

Quotation Date: 07/19/2017
Quotation Number: X172701A
RFQ Inquiry#: ULTEIG PROJECT # R17.01246
Shipping Location: HAVILAND, OH

Quantity: 01

VENDOR INFORMATION:

Vendor Name:	<u>VIRGINIA TRANSFORMER CORP.</u>
Factory Location:	<u>RINCON, GA, U.S.A</u>
Base Price, FOB Destination (incl shipping)	<u>\$ 1,108,186.00 PER UNIT</u>
Field Service Price:	<u>\$ Included in Base Price</u>
Spare Parts Price:	<u>\$ Included in Base Price</u>
Factory Warranty:	<u>24/30 MONTHS WITH First Year IN/OUT COVERAGE</u>
Delivery of Equipment:	<u>Shipment 30</u> Weeks ARO
Delivery of Review Drawings:	<u>8-9</u> Weeks ARO
Delivery of Certified Drawings:	<u>10-11</u> Weeks ARO

(1 - 2 WEEKS APPROVAL TIME)

RATINGS

Continuous Self-Cooled (Base) Capacity:	<u>70.2 MVA</u>
Continuous Capacity with Stage 1 Cooling:	<u>93.6 MVA</u>
Continuous Capacity with Stage 2 Cooling:	<u>117 MVA</u>
Percent Impedance at Self-Cooled Rating:	<u>10.00 % ± 10% ANSI TOLE.</u>
Guaranteed Losses at 100% Rated Voltage and Nominal Tap:	
No-Load Losses:	<u>46.00 KW</u>
Load Losses at Maximum Capacity:	<u>534.00 KW</u>
Auxiliary Losses at Maximum Capacity:	<u>7.50 KW</u>
Total Auxiliary AC Power Requirements:	<u>125 V DC</u>
Total Auxiliary DC Power Requirements:	<u>120 / 240 V</u>
Maximum Sound Level at Maximum Capacity:	<u>82dBA @ ONAF2</u>
X/R Ratio (p.u):	<u>36.55 approx</u>
High Voltage Winding BIL Rating:	<u>650KV BIL</u>
Low Voltage Winding BIL Rating:	<u>200KV BIL</u>
Neutral Voltage Winding BIL Rating:	<u>200KV BIL</u>
Maximum Operation Altitude at Rated BIL:	<u>< 3300 FT</u>
Operating Temperature:	<u>65°C</u>



**ELECTRICAL EQUIPMENT
AND MATERIAL SPECIFICATION
ATTACHMENT B – BID FORM**

POWER TRANSFORMER
ULTEIG PROJECT NO. R17.01246

ULTEIG SPECIFICATION NO. 0101-B

CONSTRUCTION DETAILS APPROXIMATE INCH

Overall Height of Transformer:	<u>245</u>
Overall Width of Transformer:	<u>385</u>
Overall Depth of Transformer:	<u>265</u>
Height to Top of Transformer Tank:	<u>155</u>
Height to High Voltage Bushings:	<u>245</u>
Height to Low Voltage Bushings:	<u>175</u>
Total Transformer Weight, Including Oil:	<u>301500</u>
Total Number of Gallons of Oil:	<u>11,000 GAL APPROX.</u>
Type of Oil Preservation System:	<u>CONSERVATOR</u>
Description of Insulating Oil:	<u>TYPE II MINERAL</u>
Voltage Range for Auxiliary AC System:	<u>120 / 240 V</u>
Voltage Phases for Auxiliary AC System:	<u>1 - PHASE</u>
Voltage Range for Auxiliary DC System:	<u>125V DC</u>

ACCESSORIES

Hot Spot Winding Temperature Detector (RTD):	☒ Yes ☐ No
Hot Spot Winding Temperature Indicator Relay:	☒ Yes ☐ No
Top Oil Temperature Detector (RTD):	☒ Yes ☐ No
Top Oil Temperature Indicator Relay:	☒ Yes ☐ No
Transformer Monitoring Device:	☒ Yes ☐ No
Type of Transformer Monitoring Device:	<u>HYDRAN</u>
Annunciator and/or Remote I/O:	☒ Yes ☐ No
Type of Annunciator and/or Remote I/O:	<u>SEL 2411</u>
Automatic Transfer Switch for Power Supplies (ATS):	☐ Yes ☒ No
Type of ATS:	<u>N/A</u>
Load Tap Changer:	☒ Yes ☐ No
Number of Taps of LTC:	<u>± 16 STEPS</u>
Taps Steps of LTC:	<u>5/8% PER STEP</u>
Type of LTC Controller:	<u>BECKWITH</u>
High Voltage MCOV:	☒ Yes ☐ No
High Voltage MCOV Rating:	<u>98KV MCOV</u>
Low Voltage MCOV:	☒ Yes ☐ No
Low Voltage MCOV Rating:	<u>24.4KV MCOV</u>
Bushing CT Quantity on High Side (per phase):	<u>2 / 1</u>
Bushing CT Accuracy Class on High Side:	<u>C800 / 0.3B1.8</u>
Bushing CT BIL Rating on High Side:	<u>STANDARD</u>
Bushing CT Connection Type on High Side:	<u>STANDARD</u>
Bushing CT Quantity on Low Side (per phase):	<u>3</u>
Bushing CT Accuracy Class on Low Side:	<u>C800</u>
Bushing CT BIL Rating on Low Side:	<u>STANDARD</u>
Bushing CT Connection Type on Low Side:	<u>STANDARD</u>
Ability to Add Metering Class CT to High-Side:	☐ Yes ☒ No
Ability to Add Metering Class CT to Low-Side:	☐ Yes ☒ No



**ELECTRICAL EQUIPMENT
AND MATERIAL SPECIFICATION
ATTACHMENT B – BID FORM**

POWER TRANSFORMER
ULTEIG PROJECT NO. R17.01246

ULTEIG SPECIFICATION NO. 0101-B

ADDITIONAL TESTS

Front-of-Wave Impulse Test:	☐ Yes	☒ No
Switching Impulse Test:	☐ Yes	☒ No
Zero Phase Sequence Impedance Voltage Test:	☒ Yes	☐ No
Partial Discharge Test:	☒ Yes	☐ No
Insulation Power Factor Test:	☒ Yes	☐ No
Insulation Resistance (Megger) Tests:	☒ Yes	☐ No
Audible Noise Test:	☒ Yes	☐ No
Temperature Rise Test:	☒ Yes	☐ No

FIELD SERVICES

Offload:	☒ Yes	☐ No
Assembly and Oil Filling:	☒ Yes	☐ No
Field Inspections and Testing:	☒ Yes	☐ No

SPARE PARTS

Complete Set of Gaskets:	☒ Yes	☐ No
One Gallon of Touch-Up Paint:	☒ Yes	☐ No
One High Voltage Line Bushing:	☒ Yes	☐ No
One Low Voltage Line Bushing:	☒ Yes	☐ No
One Neutral Bushing (Each Type):	☒ Yes	☐ No

STORAGE

Can Storage for the Unit Be Provided:	☒ Yes	☐ No
---------------------------------------	---	-----------------------------

Cost of Storage:

FREE STORAGE FOR UPTO 2 WEEK.
\$ 800 PER WEEK AFTER 2nd WEEK WITH
ONE TIME CRANE CHARGE OF \$ 7,500.00

DRAWINGS

The list below outlines the information required to be included as part of the approval set. Additional drawings may be required and requested. The information can be on a separate drawing or included within one of the drawings in the drawing package.

Outline Drawing:	☒ Yes	☐ No
Detailed Dimensions:	☒ Yes	☐ No
Weight:	☒ Yes	☐ No
Center of Gravity:	☒ Yes	☐ No
Base Detail and Foundation Drawing:	☒ Yes	☐ No
Power and Control Cable Entrance Location:	☒ Yes	☐ No
Installation and Maintenance Clearances:	☐ Yes	☒ No
Bill of Material:	☐ Yes	☒ No
Nameplates:		
Transformer Rating Nameplate:	☒ Yes	☐ No
Bushing CT Nameplate(s):	☒ Yes	☐ No
AC & DC Schematics:	☒ Yes	☐ No
Wiring Diagrams:	☒ Yes	☐ No
Bushing Detail and Outline Drawings:	☒ Yes	☐ No



**ELECTRICAL EQUIPMENT
AND MATERIAL SPECIFICATION
ATTACHMENT B – BID FORM**

POWER TRANSFORMER

ULTEIG PROJECT NO. R17.01246

ULTEIG SPECIFICATION NO. 0101-B

CT Characteristic Curves:

☒ Yes ☐ No

Volt/Hertz Curve:

☒ Yes ☐ No

VENDOR CONTACT

Name: SACHIN GUPTA, ASSISTANT SALE MANAGER

Address: 220 GLADE VIEW DRIVE, NE
ROANOKE, VA - 24012

Phone: 540-588-9333

Email: Sachin_Gupta@vatransformer.com

NOTES:

1. Attach vendor original quotation including any exceptions taken to the specifications or attachments.
2. Attached any preliminary outline drawings or associated material that would aid in review of bid.
3. If storage for the unit can be provided, please provide terms and details on storage and maintenance during storage for the unit.

**CG Power Systems USA Inc**

Registered Office & Plant:
One Pauwels Drive, Washington, Missouri 63090, USA
T: +1 636 239 9300 F: +1 636 239 9395 W: www.cgglobal.com

TECHNICAL SPECS

Date: 8/22/2017
Quotation Number: 95918145
Item Number: 10

Customer Line No.:		Quantity:	44
Unit Price:		Extended Price:	\$1,360,348.00
Three Phase Pad-Mount Transformer(s)			
kVA Rating:		Model #:	
2750 kVA		Cooling Class:	ONAN
Mineral Oil Immersed		Frequency:	60 Hz
		Avg. Winding Temp.	65 °C
Primary Voltage:	34500 Delta volts	Secondary Voltage:	690Y/398 volts
Primary BIL Rating:	200 kV	Secondary BIL Rating:	30 kV
HV Winding Matl:	Aluminum	LV Winding Matl:	Aluminum
High Voltage Taps:	B Taps - Two 2.5% Taps below Nominal and Two 2.5% Taps above Nominal		
No Load Loss:	3915 Watts	Load Loss:	18720 Watts
Impedance:	5.75 %	Total Loss:	22635 Watts

Tank Enclosure:

Welded Cover w/(1) Handhole(s) - 14x24
Cabinet Depth: 24 Inches, Pentahead Security Bolts
Steel HV-LV Barrier

Bushings:

Loop Feed ANSI Minimum Dimensions
Dead Front Primary Terminations: Integral Non-Loadbreak Bushings 600A
Secondary Terminations: Epoxy Bushings w/Non-removable 10 Hole Spades, Spade Support

Protection:

PRCLF (38kV OS Shorty 140A), Weak Link Cartridge (34.5kV Curve 10)

Accessories:

Pressure Relief Valve , Drain valve w/Sampler
Liquid Level Gauge, Liquid Temperature Gauge, Pressure Vacuum Gauge

CG WINDPAD Gen II: Stadium Style Stacked Core Construction with Semi-Round Windings, Reduced Flux Density, Increased Cooling, Cover Mounted Pressure Relief Device, Door Gasketing, Hold down anchoring (x4 holes), Drain Valve & Sampler in External Box, Isolated Core Ground, Nitrogen Blanket + Schrader Valve, UL Listed

- 200kV BIL HV windings, 150kV accessories
- Gauges are mounted to the tankfront
- (1) IR Viewing window on the LV door
- Externally mounted MV switch in pad lockable enclosure with viewing window
- Losses are at 20C core and 85C winding and are reference values. Quoted losses are subject to ANSI tolerance.

Switching:

L.V. Neutral Bushing with Removable Grounding Strap, One ON/OFF Transformer Switch (300 Amps)

Paint Color:

GREEN (Munsell 7.0GY3.29/1.5), Touch-up Paint Spray Can,

Standards:

Quoted in compliance with the latest applicable ANSI standards unless otherwise specified by the customer.

Shipment: 12 to 14 weeks



Order/Quotation: 495918145-0010

kVA: 2750

HV: 34500 Delta


LV: 690Y/398

Cabinet Height (mm): 2007 (79")

Weight (lbs): 14871

Coolant (gallons): 575


TRANSFORMER OVERHEAD VIEW



Dimensions are preliminary and not for construction.

Distribution Transformer Configuration	Recommendations
Phase 3 Phase kVA 2750 kV 34.5 Transformer Rated Current: 46.0 A Bolted Secondary Fault Current: 800.4 A Minimum Imp % 5.75 Primary Connection DELTA Secondary Connection gndY Preferred Expulsion Fuse ABB Weak Link	Voltage: 38 kV Current: 140 A Hi-Tech Fuse Part#: HTSS372140 Maximum FT: 99,000Amp ² -Sec Min IC: 715A Max IC: 26kA Expulsion Fuse: Curve #10 ▪ The expulsion fuses selected is based on expulsion fuse manufacturer recommendations ▪ ABB Transformer Components

2750kVA / 34.5kV Delta/Gnd-Y Transformer (Imp >= 5.75%)



APPENDIX B: MVAC SCHEDULE

MVAC WIRING SCHEDULE													
CONDUCTOR LOCATION CODE	ORIGINATING EQUIPMENT	TERMINATING EQUIPMENT	Rated V _{oc} (kV)	I _{sc} (A)	# OF TURBINES	LENGTH (FT)	CONDUCTOR SIZE	CONDUCTOR MATERIAL	# OF PARALLEL CONDUCTORS	GROUND CONDUCTOR SIZE	GROUND CONDUCTOR MATERIAL	DRAWING REFERENCE	CONDUCTOR SPECIFICS
MV1.5UB-125	SUB	T25	34.5	460.2267363	10	4616	3#1250 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV1.125-10	T25	T10	34.5	368.165389	8	10172	3#1000 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV1.10-09	T10	T09	34.5	322.1447154	7	2161	3#750 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV1.09-08	T09	T08	34.5	276.1260418	6	3297	3#500 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV1.08-05	T08	T05	34.5	230.1033682	5	2679	3#500 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV1.05-04	T05	T04	34.5	384.0826945	4	1991	3#440 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV1.04-03	T04	T03	34.5	138.0620209	3	1777	3#440 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV1.03-02	T03	T02	34.5	92.04134726	2	3378	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV1.02-01	T02	T01	34.5	46.0267363	1	2213	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV1.125-24	T25	T24	34.5	46.0267363	1	1633	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV2.SUB-IB2/1	SUB	IB2/1	34.5	506.2274099	11	8109	3#1250 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV2.1B2/1-22	IB2/1	T22	34.5	92.04134726	2	2964	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV2.122-29	T22	T29	34.5	46.0267363	1	4171	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV2.23-21	T22	T21	34.5	92.04134726	2	1417	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV2.21-20	T21	T20	34.5	46.0267363	1	3551	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV2.1B2/1-17	IB2/1	T17	34.5	384.0826945	4	2718	3#750 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV2.17-15	T17	T15	34.5	138.0620209	3	4579	3#500 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV2.15-14	T15	T14	34.5	92.04134726	2	5770	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV2.14-13	T14	T13	34.5	46.0267363	1	1517	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV2.15-07	T15	T07	34.5	92.04134726	2	2790	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV2.07-06	T07	T06	34.5	46.0267363	1	1388	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV2.07-16	T07	T16	34.5	46.0267363	1	3068	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV3.5UB-123	SUB	T23	34.5	506.2274099	11	12285	3#1250 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV3.123-28	T23	T28	34.5	138.0620209	3	2947	3#1250 KCMIL	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV3.128-27	T28	T27	34.5	92.04134726	2	1703	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV3.127-26	T27	T26	34.5	46.0267363	1	1780	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 200	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV3.128-33	T28	T33	34.5	138.0620209	3	5853	3#750 KCMIL	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV3.133-32	T33	T32	34.5	92.04134726	2	1314	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV3.132-31	T32	T31	34.5	46.0267363	1	5205	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV3.133-34	T33	T34	34.5	138.0620209	3	1674	3#440 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV3.134-36	T34	T36	34.5	92.04134726	2	3312	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV3.136-37	T36	T37	34.5	46.0267363	1	1301	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV3.134-39	T34	T39	34.5	46.0267363	1	5680	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV4SUB-140	SUB	T40	34.5	460.2267363	10	29905	3#1250 KCMIL	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV4.T40-T46	T40	T46	34.5	276.1260418	6	2581	3#1000 KCMIL	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV4.146-45	T46	T45	34.5	230.1033682	5	3997	3#1000 KCMIL	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV4.45-44	T45	T44	34.5	384.0826945	4	2881	3#750 KCMIL	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/6 Cu CN, Type MV-90
MV4.44-IB4/1	T44	IB4/1	34.5	138.0620209	3	3486	3#500 KCMIL	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/3 Cu CN, Type MV-90
MV4.1B4/1-42	IB4/1	T42	34.5	138.0620209	3	30	3#440 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV4.42-49	T42	T49	34.5	92.04134726	2	6471	3#440 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 1/2 Cu CN, Type MV-90
MV4.49-48	T49	T48	34.5	46.0267363	1	1717	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV4.48-50	T49	T50	34.5	46.0267363	1	1661	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV4.1B4/1-43	IB4/1	T43	34.5	46.0267363	1	1349	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90
MV4.1B4/1-41	IB4/1	T41	34.5	46.0267363	1	1386	3#410 AWG	AL	1	7#6	Copper Clad Steel	E 201	35kV, (B) 17C, 100% insulation, 2/3 Cu CN, Type MV-90



DESIGN BASIS REPORT FOR
ELECTRICAL COLLECTION SYSTEM

Northwest Ohio Wind Farm

Located in Paulding, Ohio

September 27, 2017

Prepared For:



Prepared By:

Westwood

Introduction

This document will serve as a guideline in considering the parameters, design criteria and concepts appropriate to the design of the 34.5 kV collection system of the Northwest Ohio Wind Farm. This Design Basis Report covers the electrical engineering discipline and touches on civil and geotechnical considerations that impact the electrical design.

The material presented herein includes information and methods to assure that the design complies with minimum requirements, applicable standards and codes, industry standards, and local governing authority requirements. The use of the methods presented is not meant to be all-inclusive or restrict the designer from using other means of sound engineering practice or more conservative means to accomplish meeting the project requirements. However, exceptions and/or modifications to the material contained herein shall be well documented and only be made with prior approval of the design engineering group and if required by the client.

REVISIONS			
REV.	DATE	DOCUMENT CHANGES	PAGES REVISED
0	09/27/2017	Version 0	-

Table of Contents

<u>SECTION</u>	<u>DESCRIPTION</u>
Introduction	2
Table of Contents	3
1.0 Project Description	4
2.0 Project Location.....	4
3.0 Project Contacts	4
4.0 Applicable Standards and Interconnecting Authorities	4
5.0 Project Coordinate System.....	5
6.0 Geotechnical Considerations for Electrical Design	5
7.0 Electrical Collection Design Criteria.....	5
8.0 Substation Interface	7

1.0 Project Description

White Construction (Client) is contractor selected to construct the Northwest Ohio wind project, with an overall rating of 105 MW-AC. The project will consist of the following:

- 42 GE 2.5-116 wind turbine generators, each with a 2750 kVA GSU transformer.
- 600 A dead-front connections
- 34.5 kV collection system utilizing MV-90 concentric neutral cable
- 1 Substation with 138kV Interconnection to POI at AEP Haviland substation
- Transmission tap: 138 kV line of 270', 954 (Rail) conductor
- 1 Operation and Maintenance building

2.0 Project Location

The Project is located outside of Paulding, in Paulding County, Ohio.

3.0 Project Contacts

Title	Company	Name	Phone	Email
Engineering Manager	IEA	Al Downes	608-320-2818	Al.downes@iea.net
Project Manager	IEA/White Construction	Michael Kreuzman		Mike.kreuzman@iea.net
Project Executive	IEA/White Construction	Brian Johnston	812-298-4340	Brian.johnston@iea.net
Civil EOR and Project Manager	Westwood	Steve Battaglia	952-906-7405	Steve.battaglia@westwoodps.com
Electrical EOR	Westwood	Josh Venden	608-662-5175	Josh.venden@westwoodps.com
Electrical Project Manager and QC	Westwood	Drew Szabo	608-662-5345	Drew.szabo@westwoodps.com

4.0 Applicable Standards and Interconnecting Authorities

Interconnecting Utility: AEP
Interconnecting ISO: PJM

The design shall meet the requirements detailed in the interconnection agreement as well as all applicable codes and standards, and manufacturer specifications.

The latest locally adopted editions of the following codes and regulations are also applicable and will be taken into account by the engineer during the design of the Project:

- Applicable State, County and Local Codes and Regulations
 - o County Regulations
 - o Local Codes and Ordinances
- ANSI - American National Standards Institute
- ICEA - Insulated Cable Engineers Association
- IEEE - Institute of Electrical and Electronics Engineers
- NEC - National Electrical Code, 2014 edition, as adopted in the state of Ohio
- NEMA - National Electrical Manufacturers Association
- NESC - National Electrical Safety Code
- UL Underwriters Laboratories
- NFPA – National Fire Protection Agency
- IEC – International Electric Code

5.0 Project Coordinate System

All drawings used for the design of the project will be HARN/OH Ohio State Planes, North Zone, US Foot coordinate system.

6.0 Geotechnical Considerations for Electrical Design

A geotechnical evaluation for the Northwest Ohio site, dated December, 2014, was prepared by Barr Engineering for Starwood Energy Group Global. The geotechnical analysis included select boring locations at the substation and at turbine locations. Field and laboratory tests included soil electrical and thermal resistivity tests, which are used as the basis for grounding analysis and cable thermal analysis.

7.0 Electrical Collection Design Criteria

The medium voltage collection system design is based on the maximum number of turbines that can be grouped on a single feeder; this will determine the total number of feeders required for the collection system. Geographical restrictions such as property easements or access, wetlands, rough terrain or other site specific constraints define the feeder routing.

Below is a list of the criteria used in designing the electrical infrastructure.

34.5 kV circuits will be designed in accordance the following:

Circuit and Trench Layout

- Collection lines will use compacted native backfill material unless design constraints require use of material which has lower thermal resistivity.
- Cable installation will be primarily through open trenching, except where crossings of roads or other features or infrastructure require use of directional boring.
- Trench design will generally consist of a direct buried three phase cable set in triangular arrangement, a bare “trench ground” and a fiber optic cable installed in HDPE duct. Cables will be buried with a minimum cover of 4’ in order to be below the typical depth of drain tile. Code minimum is 3’.
- Trench ground serve dual purpose as an extended grounding electrode between substation and wind turbines, as well as a ground fault return path (equipment grounding conductor). Preliminary trench ground will be 7#8 copperclad steel, to be confirmed by short circuit and grounding analysis.
- 34.5 kV junctions will be achieved through either separate sectionalizing cabinets, or stacked separable connectors on padmount transformer bushings (“piggy-backing”). Stacked connectors will be utilized if the stacked cable can be 750 kcmil or less.

WTG Foundation Conduits and Grounding

Wind turbine generation foundation conduits will be designed in accordance with the following:

- Applicable codes and standards
- GE Renewable Energy document *“Technical Documentation – Wind Turbine Generator Systems – Information on the Design, Detailing and Execution of the Foundation for ON-shore Wind Turbines with Tubular Steel Towers.”*, provided by White Construction

Fiber Optic Communications

Fiber optic lines will be laid out according to medium voltage cable routing per the following:

- Single mode fiber, 12 –strands per cable
- Optical loss calculation will be performed based on supplied equipment data, including optical power budget.
- Field Fiber cable splice panels will be placed where necessary at medium voltage junction boxes and will be above grade type.
- Patch panels at wind turbines have capacity for up to 48 fibers.

8.0 Substation Interface

Key points of substation interface are being coordinated with the substation engineer.

- Per input from White Construction, preference is to maintain original collection system circuit designation. Specifically, collection feeder 1 will be the feeder that enters the substation in the southernmost position at the west side of the substation. Therefore feeders will be numbered 4, 3, 2, 1, North to South. Ulteig substation single line will be modified accordingly.
- Per Ulteig Substation General Arrangement NOW-EQ1-001 Rev. A, collection feeders enter from west of substation. Ulteig will extend min. 8" Sch. 40 PVC conduits 10' past fence at 4' burial depth (below finished grade), perpendicularly out from riser structures. Conduits will need to accommodate 3 x 1250 kcmil 35 kV cables (100% insulation)+ expected 7#8 copper clad steel trench ground.
- Per Ulteig Substation General Arrangement NOW-EQ1-001 Rev. A, equipment enclosure is on northern edge of substation yard. WW has determined that Ulteig will extend PVC conduit(s) 10' north of substation fence, at minimum 24" depth below finished grade, suitable for minimum 6 x 1.25" HDPE innerduct with fiber.
- An O&M building will be located north of the collector substation. Ulteig will provide a conduit extending 10' past the edge of the substation fence to accommodate a fiber run to the O&M building. Westwood will include the trenching route in the collection layout drawings so that it can be included in the underground collection contractor's SOW.

Protective Relaying for Feeders

- Per RFI to Ulteig engineers, the substation feeder settings for phase faults are set at a 5 cycle delay to account for GSU inrush and the settings for ground faults are set to instantaneous w/ approximate clearing times of 8 1/2 cycles for phase faults and 3 1/2 cycles for ground faults.
- Collection circuit conductors and concentric neutrals will be designed to withstand available short circuit currents for a minimum duration of the clearing times previously stated. Available short circuit current will account for future levels provided by AEP and identified in the Westwood Short Circuit Study.



REACTIVE POWER STUDY

Northwest Ohio Wind Project

Paulding, Ohio

October 6, 2017

Prepared for:



Prepared by:

Westwood

Westwood

Project Name: NW OH Wind Project	
Title	J.O. or W.O. Number
Reactive Power Study	0007186.00

Approvals		Revision Number	Date	Description
Preparer(s) Name	Reviewer(s) Name			
Josh Venden	Drew Szabo	0	10/06/2017	Original Release

TABLE OF CONTENTS

INTRODUCTION	4
OBJECTIVE	4
INPUTS & ASSUMPTIONS	4
METHODOLOGY	5
CONCLUSION	5
APPENDIX A: SHORT CIRCUIT SUMMARY REPORTS	A
APPENDIX B: ETAP SINGLE LINE DIAGRAM	B
APPENDIX C: ETAP MODEL INPUTS.....	C

INTRODUCTION

NW OH Wind Project is a 100 MW wind generation installation in Paulding, OH consisting 42 of GE 2.5 MW wind turbines. The turbines are grouped into four medium voltage (MV) feeders with 10 turbines on Feeders 1 and 4 and 11 turbines on Feeders 2 and 3. The feeders are connected to a main power transformer that steps the voltage up to 138kV where it interconnects with the AEP transmission system via a short overhead line segment.

OBJECTIVE

The objective of this study is to verify that the Northwest Ohio wind generation plant is capable of operating across the full range of real power while also delivering reactive power to the range of power factors at the Point of Interconnection (POI) required by the interconnection agreement. According to the interconnection agreement, the plant must be able to operate across the power factor range of 0.95 lag (supplying VARs to the POI) to 0.95 lead (absorbing VARs from the POI), at all output levels, independent of voltage. In performing this evaluation, the present study determines if there is any need for reactive compensation beside the capability of the wind turbines themselves.

INPUTS & ASSUMPTIONS

- Power flow analysis performed with ETAP v16.0.0C power system simulation software.
- Medium voltage AC collector electrical layout is per the Westwood Professional Services Electrical Drawings, MVAC Collection One-Line Diagrams E.200 & E.210.
- ETAP model parameters for equipment such as turbines (WTG), step-up transformers (GSU) and main power transformer (MPT) based on manufacturer data. These parameters are documented in Appendix C.
- ETAP model parameters for MV cables based on thermal analysis and electrical parameters derived using CYME Cymcap Underground Cable Thermal Analysis software.
- ETAP model parameters for overhead transmission line data based on ETAP library of standard overhead conductors.
- ETAP model parameters for utility equivalent impedance information provided by AEP.
- The 2.5 MW GE wind turbines are equipped with the extended reactive power option and are capable of delivering a maximum leading or lagging power factor of 0.9. Turbines are also equipped with “Wind Free” Option and are therefore capable of providing or absorbing up to 400 kVAR per turbine when wind is not available.
- The neutral of the main power transformer 34.5 kV secondary wiring is connected to ground through a neutral grounding reactor of 0.6 ohms.
- The MPT has a load tap changer (LTC) on the high side winding consisting of 16 steps above and below nominal, each at 5/8% of the 138 kV nominal voltage. This allows a range of 10% above and below the nominal voltage. The high side LTC will be controlled so as to maintain the 34.5 kV bus voltage as close as possible to 1.0 pu.
- Reactive power direction and power factor are defined as follows:
 - A *leading* power factor at the POI when plant is generating indicates the wind farm is *absorbing* VARs from the utility.
 - A *lagging* power factor at the POI when plant is generating indicates the wind farm is *supplying* VARs to the utility.

METHODOLOGY

- This calculation utilizes the ETAP Load Flow Analysis module, which employs the Newton-Raphson method for power flow iterative solution. See Appendix A for the ETAP Load Flow and Losses output reports.
- 5 different cases were analyzed for each of 5 different real power generation levels. Within the ETAP model, all turbines were set to generate varying levels of rated real power output (0%, 25%, 50%, 75% and 100%). The turbine reactive power contribution was then adjusted to verify the wind plant can meet the required power factor at the POI.

CONCLUSION

- Case 00-1 shows the real and reactive power demand of the wind farm with all turbines offline.
- Cases 00-2 through 00-5 demonstrate the turbines' WindFree capabilities which can provide limited var support in zero wind conditions. A maximum of 400kvar can be supplied or absorbed; for this wind plant, approximately 145kvar is necessary to counteract the cable charging of the collection system.
- The remaining cases show the individual turbine kW and kvar output necessary to achieve the required range of power factors and voltages at the POI.
- Cases 100-2 and 100-3 verify the need for a 4 Mvar capacitor bank at the substation 34.5 kV bus. Even with the turbines at their maximum reactive power output, additional VARs are required to meet the 0.95 lagging pf with 0.95 p.u. voltage at the POI.

Table 1: Load Flow Summary

TURBINE OUTPUT (% of PMAX)	CASE		POI	MPT	2500 kW TURBINES (42)				Total Plant Output MW	CAP BANK (Mvar)	NET AT POI				VOLTAGE SUMMARY			
	#	NAME			kW per Turbine	kvar per Turbine	kVA per Turbine	Turbine PF			MW	MVar	MVA	pf	POI (138kV)	MPT Lowside (34.5 kV)	Extreme MV (34.5kV)	Extreme LV (690V)
0%	00-1	NO GEN	1.00	+1.25%	0	0	0.0	N/A	0.00	0.00	-0.231	6.116	6.120	1.000	1.000	1.002	1.004	1.004
	00-2	1PU 1LAG	1.00	nom.	0	-146	146.0	N/A	0.00	0.00	-0.229	0.017	0.229	1.000	1.000	1.000	1.000	0.997
	00-3	95PU 1LAG	0.95	-5.00%	0	-146	146.0	N/A	0.00	0.00	-0.223	0.004	0.223	1.000	0.950	1.000	1.000	0.997
	00-4	1PU 1LEAD	1.00	nom.	0	-145	145.0	N/A	0.00	0.00	-0.229	-0.026	0.230	1.000	1.000	1.000	1.000	0.997
	00-5	105PU 1LEAD	1.05	+5.00%	0	-145	145.0	N/A	0.00	0.00	-0.234	-0.011	0.234	1.000	1.050	1.000	1.000	0.997
25%	25-1	UNITY PF	1.00	+0.625%	625	0	625.0	1.000	26.25	0.00	25.873	4.739	26.303	0.984	1.000	1.003	1.010	1.012
	25-2	1PU 95LAG	1.00	+1.25%	625	93	631.9	0.989	26.25	0.00	25.868	8.542	27.242	0.950	1.000	1.002	1.011	1.014
	25-3	95PU 95LAG	0.95	-3.75%	625	93	631.9	0.989	26.25	0.00	25.873	8.546	27.248	0.950	1.001	1.010	1.010	1.013
	25-4	1PU 95LEAD	1.00	-1.25%	625	-312	698.5	0.895	26.25	0.00	25.856	-8.512	27.221	0.950	1.002	1.006	1.006	0.997
	25-5	105PU 95LEAD	1.05	+3.75%	625	-312	698.5	0.895	26.25	0.00	25.851	-8.536	27.224	0.950	1.002	1.005	1.005	0.997
50%	50-1	UNITY PF	1.00	+0.625	1350	0	1350.0	1.000	56.70	0.00	55.802	-0.420	55.804	1.000	1.000	0.999	1.013	1.016
	50-2	1PU 95LAG	1.00	+3.125%	1350	467	1428.5	0.945	56.70	0.00	55.717	18.333	58.656	0.950	1.000	1.003	1.023	1.035
	50-3	95PU 95LAG	0.95	-1.875%	1350	467	1428.5	0.945	56.70	0.00	55.721	18.306	58.651	0.950	1.001	1.021	1.021	1.033
	50-4	1PU 95LEAD	1.00	-1.875%	1350	-415	1412.3	0.956	56.70	0.00	55.748	-18.325	58.683	0.950	1.000	0.999	1.008	0.993
	50-5	105PU 95LEAD	1.05	+3.125%	1350	-415	1412.3	0.956	56.70	0.00	55.741	-18.366	58.689	0.950	1.050	0.998	1.007	0.992
75%	75-1	UNITY PF	1.00	nom.	1875	0	1875.0	1.000	78.75	0.00	77.250	-6.360	77.511	0.997	1.000	1.000	1.019	1.022
	75-2	1PU 95LAG	1.00	+5.00%	1875	810	2042.5	0.918	78.75	0.00	77.030	25.328	81.087	0.950	1.000	1.001	1.029	1.049
	75-3	95PU 95LAG	0.95	nom.	1875	810	2042.5	0.918	78.75	0.00	77.029	25.248	81.061	0.950	0.998	1.027	1.047	1.047
	75-4	1PU 95LEAD	1.00	-2.50%	1875	-433	1924.3	0.974	78.75	0.00	77.174	-25.241	81.197	0.950	1.000	0.999	1.012	1.007
	75-5	105PU 95LEAD	1.05	+2.50%	1875	-433	1924.3	0.974	78.75	0.00	77.166	-25.308	81.210	0.950	1.050	0.998	1.011	1.006
100%	100-1	UNITY PF	1.00	-0.625%	2500	0	2500.0	1.000	105.00	0.00	102.552	-16.056	103.801	0.988	1.000	0.998	1.022	1.027
	100-2	1PU 95LAG	1.00	+7.50%	2500	1210	2777.4	0.900	105.00	4.00	102.115	33.714	107.537	0.950	1.000	0.999	1.038	1.066
	100-3	95PU 95LAG	0.95	1.875%	2500	1210	2773.1	0.902	105.00	4.00	102.130	33.511	107.487	0.950	1.001	1.039	1.067	1.067
	100-4	105PU 95LAG	1.05	+13.125%	2500	1210	2777.4	0.900	105.00	4.00	102.101	33.571	107.478	0.950	1.050	0.997	1.036	1.064
	100-4	1PU 95LEAD	1.00	-3.125%	2500	-400	2531.8	0.987	105.00	0.00	102.475	-33.531	107.821	0.950	1.000	1.000	1.019	1.015
	100-5	95PU 95LEAD	0.95	-7.50%	2500	-395	2531.0	0.988	105.00	0.00	102.459	-33.613	107.832	0.950	0.994	1.013	1.013	1.009
100-6	105PU 95LEAD		1.05	+1.875%	2500	-400	2531.8	0.987	105.00	0.00	102.463	-33.646	107.846	0.950	1.050	0.998	1.017	1.013

APPENDIX A: LOAD FLOW SUMMARY REPORTS

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: NO GEN

Page: 1
Date: 10-06-2017
SN: WESTWOODP
Revision: 0% GEN
Config.: WTG OFFLINE

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap	
89F1A	34.500	100.285	0.0	0	0	0	0	MV BUS T-25	0.041	-1.228	20.5	-3.4		
								89T1B	-0.041	1.228	20.5	-3.4		
89F2A	34.500	100.285	0.0	0	0	0	0	JB-2/1	0.046	-1.218	20.3	-3.7		
								89T1B	-0.046	1.218	20.3	-3.7		
89F3A	34.500	100.285	0.0	0	0	0	0	MV BUS T-23	0.046	-1.478	24.7	-3.1		
								89T1B	-0.046	1.478	24.7	-3.1		
89F4A	34.500	100.285	0.0	0	0	0	0	MV BUS T-40	0.043	-2.390	39.9	-1.8		
								89T1B	-0.043	2.390	39.9	-1.8		
89T1A	138.000	100.001	0.0	0	0	0	0	POI	-0.231	6.110	25.6	-3.8		
								HV BUS MPT	0.231	-6.110	25.6	-3.8		
89T1B	34.500	100.285	0.0	0	0	0	0	89F4A	0.043	-2.390	39.9	-1.8		
								89F3A	0.046	-1.478	24.7	-3.1		
								89F2A	0.046	-1.218	20.3	-3.7		
								89F1A	0.041	-1.228	20.5	-3.4		
								MPT-3	-0.176	6.315	105.4	-2.8		
								& HV BUS MPT						
HV BUS MPT	138.000	100.001	0.0	0	0	0.054	0.147	89T1A	-0.231	6.110	25.6	-3.8		
								89T1B	0.177	-6.257	26.2	-2.8	0.625	
								& MPT-3						
JB-2/1	34.500	100.309	0.0	0	0	0	0	MV BUS T-17	0.029	-0.537	9.0	-5.4		
								MV BUS T-22	0.017	-0.257	4.3	-6.4		
								89F2A	-0.045	0.794	13.3	-5.7		
JB-4/1	34.500	100.447	-0.1	0	0	0	0	MV BUS T-41	0.004	-0.026	0.4	-15.8		
								MV BUS T-42	0.017	-0.229	3.8	-7.2		
								MV BUS T-43	0.004	-0.025	0.4	-16.3		
								MV BUS T-44	-0.025	0.279	4.7	-8.8		
LV BUS T-01	0.690	100.331	-0.1	0	0	0	0	MV BUS T-01	0.000	0.000	0.0	0.0		
LV BUS T-02	0.690	100.331	-0.1	0	0	0	0	MV BUS T-02	0.000	0.000	0.0	0.0		
LV BUS T-03	0.690	100.331	-0.1	0	0	0	0	MV BUS T-03	0.000	0.000	0.0	0.0		
LV BUS T-04	0.690	100.331	0.0	0	0	0	0	MV BUS T-04	0.000	0.000	0.0	0.0		
LV BUS T-05	0.690	100.330	0.0	0	0	0	0	MV BUS T-05	0.000	0.000	0.0	0.0		
LV BUS T-06	0.690	100.319	0.0	0	0	0	0	MV BUS T-06	0.000	0.000	0.0	0.0		
LV BUS T-07	0.690	100.319	0.0	0	0	0	0	MV BUS T-07	0.000	0.000	0.0	0.0		
LV BUS T-08	0.690	100.328	0.0	0	0	0	0	MV BUS T-08	0.000	0.000	0.0	0.0		
LV BUS T-09	0.690	100.325	0.0	0	0	0	0	MV BUS T-09	0.000	0.000	0.0	0.0		
LV BUS T-10	0.690	100.322	0.0	0	0	0	0	MV BUS T-10	0.000	0.000	0.0	0.0		

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: NO GEN

Page: 2

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: WTG OFFLINE

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
LV BUS T-13	0.690	100.318	0.0	0	0	0	0	MV BUS T-13	0.000	0.000	0.0	0.0	
LV BUS T-14	0.690	100.318	0.0	0	0	0	0	MV BUS T-14	0.000	0.000	0.0	0.0	
LV BUS T-15	0.690	100.318	0.0	0	0	0	0	MV BUS T-15	0.000	0.000	0.0	0.0	
LV BUS T-16	0.690	100.319	0.0	0	0	0	0	MV BUS T-16	0.000	0.000	0.0	0.0	
LV BUS T-17	0.690	100.313	0.0	0	0	0	0	MV BUS T-17	0.000	0.000	0.0	0.0	
LV BUS T-20	0.690	100.311	0.0	0	0	0	0	MV BUS T-20	0.000	0.000	0.0	0.0	
LV BUS T-21	0.690	100.311	0.0	0	0	0	0	MV BUS T-21	0.000	0.000	0.0	0.0	
LV BUS T-22	0.690	100.311	0.0	0	0	0	0	MV BUS T-22	0.000	0.000	0.0	0.0	
LV BUS T-23	0.690	100.327	0.0	0	0	0	0	MV BUS T-23	0.000	0.000	0.0	0.0	
LV BUS T-24	0.690	100.300	0.0	0	0	0	0	MV BUS T-24	0.000	0.000	0.0	0.0	
LV BUS T-25	0.690	100.300	0.0	0	0	0	0	MV BUS T-25	0.000	0.000	0.0	0.0	
LV BUS T-26	0.690	100.333	0.0	0	0	0	0	MV BUS T-26	0.000	0.000	0.0	0.0	
LV BUS T-27	0.690	100.333	0.0	0	0	0	0	MV BUS T-27	0.000	0.000	0.0	0.0	
LV BUS T-28	0.690	100.333	0.0	0	0	0	0	MV BUS T-28	0.000	0.000	0.0	0.0	
LV BUS T-29	0.690	100.311	0.0	0	0	0	0	MV BUS T-29	0.000	0.000	0.0	0.0	
LV BUS T-31	0.690	100.343	-0.1	0	0	0	0	MV BUS T-31	0.000	0.000	0.0	0.0	
LV BUS T-32	0.690	100.342	-0.1	0	0	0	0	MV BUS T-32	0.000	0.000	0.0	0.0	
LV BUS T-33	0.690	100.342	0.0	0	0	0	0	MV BUS T-33	0.000	0.000	0.0	0.0	
LV BUS T-34	0.690	100.343	-0.1	0	0	0	0	MV BUS T-34	0.000	0.000	0.0	0.0	
LV BUS T-36	0.690	100.343	-0.1	0	0	0	0	MV BUS T-36	0.000	0.000	0.0	0.0	
LV BUS T-37	0.690	100.343	-0.1	0	0	0	0	MV BUS T-37	0.000	0.000	0.0	0.0	
LV BUS T-39	0.690	100.344	-0.1	0	0	0	0	MV BUS T-39	0.000	0.000	0.0	0.0	
LV BUS T-40	0.690	100.426	-0.1	0	0	0	0	MV BUS T-40	0.000	0.000	0.0	0.0	
LV BUS T-41	0.690	100.447	-0.1	0	0	0	0	MV BUS T-41	0.000	0.000	0.0	0.0	
LV BUS T-42	0.690	100.447	-0.1	0	0	0	0	MV BUS T-42	0.000	0.000	0.0	0.0	
LV BUS T-43	0.690	100.447	-0.1	0	0	0	0	MV BUS T-43	0.000	0.000	0.0	0.0	
LV BUS T-44	0.690	100.443	-0.1	0	0	0	0	MV BUS T-44	0.000	0.000	0.0	0.0	
LV BUS T-45	0.690	100.439	-0.1	0	0	0	0	MV BUS T-45	0.000	0.000	0.0	0.0	
LV BUS T-46	0.690	100.432	-0.1	0	0	0	0	MV BUS T-46	0.000	0.000	0.0	0.0	
LV BUS T-48	0.690	100.450	-0.1	0	0	0	0	MV BUS T-48	0.000	0.000	0.0	0.0	
LV BUS T-49	0.690	100.450	-0.1	0	0	0	0	MV BUS T-49	0.000	0.000	0.0	0.0	
LV BUS T-50	0.690	100.450	-0.1	0	0	0	0	MV BUS T-50	0.000	0.000	0.0	0.0	
MV BUS T-01	34.500	100.331	-0.1	0	0	0.004	0.004	MV BUS T-02	-0.004	-0.004	0.1	74.5	
								LV BUS T-01	0.000	0.000	0.0	0.0	
MV BUS T-02	34.500	100.331	-0.1	0	0	0.004	0.004	MV BUS T-01	0.004	-0.043	0.7	-9.5	
								MV BUS T-03	-0.008	0.040	0.7	-20.4	
								LV BUS T-02	0.000	0.000	0.0	0.0	
MV BUS T-03	34.500	100.331	-0.1	0	0	0.004	0.004	MV BUS T-02	0.008	-0.079	1.3	-10.3	
								MV BUS T-04	-0.012	0.076	1.3	-16.1	

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: NO GEN

Page: 3

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: WTG OFFLINE

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
MV BUS T-04	34.500	100.331	0.0	0	0	0.004	0.004	LV BUS T-03	0.000	0.000	0.0	0.0	
								MV BUS T-03	0.012	-0.123	2.1	-10.1	
								MV BUS T-05	-0.017	0.119	2.0	-13.8	
MV BUS T-05	34.500	100.330	0.0	0	0	0.004	0.004	LV BUS T-04	0.000	0.000	0.0	0.0	
								MV BUS T-04	0.017	-0.171	2.9	-9.6	
								MV BUS T-08	-0.021	0.168	2.8	-12.2	
MV BUS T-06	34.500	100.319	0.0	0	0	0.004	0.004	LV BUS T-05	0.000	0.000	0.0	0.0	
								MV BUS T-07	-0.004	-0.004	0.1	74.5	
								LV BUS T-06	0.000	0.000	0.0	0.0	
MV BUS T-07	34.500	100.319	0.0	0	0	0.004	0.004	MV BUS T-06	0.004	-0.026	0.4	-15.8	
								MV BUS T-16	0.004	-0.061	1.0	-6.7	
								MV BUS T-15	-0.012	0.083	1.4	-14.7	
MV BUS T-08	34.500	100.328	0.0	0	0	0.004	0.004	LV BUS T-07	0.000	0.000	0.0	0.0	
								MV BUS T-05	0.021	-0.266	4.4	-7.7	
								MV BUS T-09	-0.025	0.262	4.4	-9.4	
MV BUS T-09	34.500	100.325	0.0	0	0	0.004	0.004	LV BUS T-08	0.000	0.000	0.0	0.0	
								MV BUS T-08	0.025	-0.382	6.4	-6.5	
								MV BUS T-10	-0.029	0.379	6.3	-7.6	
MV BUS T-10	34.500	100.322	0.0	0	0	0.004	0.004	LV BUS T-09	0.000	0.000	0.0	0.0	
								MV BUS T-09	0.029	-0.471	7.9	-6.1	
								MV BUS T-25	-0.033	0.467	7.8	-7.1	
MV BUS T-13	34.500	100.318	0.0	0	0	0.004	0.004	LV BUS T-10	0.000	0.000	0.0	0.0	
								MV BUS T-14	-0.004	-0.004	0.1	74.5	
								LV BUS T-13	0.000	0.000	0.0	0.0	
MV BUS T-14	34.500	100.318	0.0	0	0	0.004	0.004	MV BUS T-13	0.004	-0.028	0.5	-14.3	
								MV BUS T-15	-0.008	0.025	0.4	-31.6	
								LV BUS T-14	0.000	0.000	0.0	0.0	
MV BUS T-15	34.500	100.318	0.0	0	0	0.004	0.004	MV BUS T-07	0.012	-0.157	2.6	-7.9	
								MV BUS T-14	0.008	-0.105	1.8	-7.9	
								MV BUS T-17	-0.025	0.258	4.3	-9.6	
MV BUS T-16	34.500	100.319	0.0	0	0	0.004	0.004	LV BUS T-15	0.000	0.000	0.0	0.0	
								MV BUS T-07	-0.004	-0.004	0.1	74.5	
								LV BUS T-16	0.000	0.000	0.0	0.0	
MV BUS T-17	34.500	100.313	0.0	0	0	0.004	0.004	JB-2/1	-0.029	0.422	7.0	-6.8	
								MV BUS T-15	0.025	-0.425	7.1	-5.8	
								LV BUS T-17	0.000	0.000	0.0	0.0	
MV BUS T-20	34.500	100.311	0.0	0	0	0.004	0.004	MV BUS T-21	-0.004	-0.004	0.1	74.5	
								LV BUS T-20	0.000	0.000	0.0	0.0	
								MV BUS T-20	0.004	-0.072	1.2	-5.8	

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: NO GEN

Page: 4

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: WTG OFFLINE

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
MV BUS T-22	34.500	100.311	0.0	0	0	0.004	0.004	MV BUS T-22	-0.008	0.068	1.1	-12.1	
								LV BUS T-21	0.000	0.000	0.0	0.0	
								JB-2/1	-0.016	0.179	3.0	-9.2	
								MV BUS T-21	0.008	-0.098	1.6	-8.4	
								MV BUS T-29	0.004	-0.085	1.4	-4.9	
MV BUS T-23	34.500	100.327	0.0	0	0	0.004	0.004	LV BUS T-22	0.000	0.000	0.0	0.0	
								89F3A	-0.045	0.838	14.0	-5.4	
								MV BUS T-28	0.041	-0.841	14.0	-4.9	
MV BUS T-24	34.500	100.300	0.0	0	0	0.004	0.004	LV BUS T-23	0.000	0.000	0.0	0.0	
								MV BUS T-25	-0.004	-0.004	0.1	74.5	
MV BUS T-25	34.500	100.300	0.0	0	0	0.004	0.004	LV BUS T-24	0.000	0.000	0.0	0.0	
								89F1A	-0.041	0.987	16.5	-4.2	
								MV BUS T-10	0.033	-0.952	15.9	-3.5	
MV BUS T-26	34.500	100.333	0.0	0	0	0.004	0.004	MV BUS T-24	0.004	-0.039	0.7	-10.4	
								LV BUS T-25	0.000	0.000	0.0	0.0	
								MV BUS T-27	-0.004	-0.004	0.1	74.5	
MV BUS T-27	34.500	100.333	0.0	0	0	0.004	0.004	LV BUS T-26	0.000	0.000	0.0	0.0	
								MV BUS T-26	0.004	-0.034	0.6	-12.0	
								MV BUS T-28	-0.008	0.030	0.5	-26.2	
MV BUS T-28	34.500	100.333	0.0	0	0	0.004	0.004	LV BUS T-27	0.000	0.000	0.0	0.0	
								MV BUS T-23	-0.041	0.687	11.5	-6.0	
								MV BUS T-27	0.008	-0.066	1.1	-12.3	
MV BUS T-29	34.500	100.311	0.0	0	0	0.004	0.004	MV BUS T-33	0.029	-0.625	10.4	-4.6	
								LV BUS T-28	0.000	0.000	0.0	0.0	
								MV BUS T-22	-0.004	-0.004	0.1	74.5	
MV BUS T-31	34.500	100.343	-0.1	0	0	0.004	0.004	LV BUS T-29	0.000	0.000	0.0	0.0	
								MV BUS T-32	-0.004	-0.004	0.1	74.5	
								LV BUS T-31	0.000	0.000	0.0	0.0	
MV BUS T-32	34.500	100.342	-0.1	0	0	0.004	0.004	MV BUS T-31	0.004	-0.107	1.8	-3.9	
								MV BUS T-33	-0.008	0.103	1.7	-8.0	
								LV BUS T-32	0.000	0.000	0.0	0.0	
MV BUS T-33	34.500	100.342	0.0	0	0	0.004	0.004	MV BUS T-28	-0.029	0.375	6.3	-7.7	
								MV BUS T-32	0.008	-0.131	2.2	-6.3	
								MV BUS T-34	0.017	-0.248	4.1	-6.7	
MV BUS T-34	34.500	100.343	-0.1	0	0	0.004	0.004	LV BUS T-33	0.000	0.000	0.0	0.0	
								MV BUS T-33	-0.017	0.204	3.4	-8.1	
								MV BUS T-36	0.008	-0.090	1.5	-9.1	
								MV BUS T-39	0.004	-0.117	1.9	-3.5	
								LV BUS T-34	0.000	0.000	0.0	0.0	

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: NO GEN

Page: 5

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: WTG OFFLINE

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
MV BUS T-36	34.500	100.343	-0.1	0	0	0.004	0.004	MV BUS T-34	-0.008	0.020	0.4	-37.8	
								MV BUS T-37	0.004	-0.024	0.4	-17.0	
								LV BUS T-36	0.000	0.000	0.0	0.0	
MV BUS T-37	34.500	100.343	-0.1	0	0	0.004	0.004	MV BUS T-36	-0.004	-0.004	0.1	74.5	
								LV BUS T-37	0.000	0.000	0.0	0.0	
MV BUS T-39	34.500	100.344	-0.1	0	0	0.004	0.004	MV BUS T-34	-0.004	-0.004	0.1	74.5	
								LV BUS T-39	0.000	0.000	0.0	0.0	
MV BUS T-40	34.500	100.426	-0.1	0	0	0.004	0.004	89F4A	-0.041	0.830	13.8	-5.0	
								MV BUS T-46	0.037	-0.833	13.9	-4.5	
								LV BUS T-40	0.000	0.000	0.0	0.0	
MV BUS T-41	34.500	100.447	-0.1	0	0	0.004	0.004	JB-4/1	-0.004	-0.004	0.1	74.5	
								LV BUS T-41	0.000	0.000	0.0	0.0	
MV BUS T-42	34.500	100.447	-0.1	0	0	0.004	0.004	JB-4/1	-0.017	0.228	3.8	-7.2	
								MV BUS T-49	0.012	-0.232	3.9	-5.4	
								LV BUS T-42	0.000	0.000	0.0	0.0	
MV BUS T-43	34.500	100.447	-0.1	0	0	0.004	0.004	JB-4/1	-0.004	-0.004	0.1	74.5	
								LV BUS T-43	0.000	0.000	0.0	0.0	
MV BUS T-44	34.500	100.443	-0.1	0	0	0.004	0.004	JB-4/1	0.025	-0.407	6.8	-6.1	
								MV BUS T-45	-0.029	0.403	6.7	-7.2	
								LV BUS T-44	0.000	0.000	0.0	0.0	
MV BUS T-45	34.500	100.439	-0.1	0	0	0.004	0.004	MV BUS T-44	0.029	-0.527	8.8	-5.5	
								MV BUS T-46	-0.033	0.523	8.7	-6.3	
								LV BUS T-45	0.000	0.000	0.0	0.0	
MV BUS T-46	34.500	100.432	-0.1	0	0	0.004	0.004	MV BUS T-40	-0.037	0.710	11.8	-5.2	
								MV BUS T-45	0.033	-0.714	11.9	-4.6	
								LV BUS T-46	0.000	0.000	0.0	0.0	
MV BUS T-48	34.500	100.450	-0.1	0	0	0.004	0.004	MV BUS T-49	-0.004	-0.004	0.1	74.5	
								LV BUS T-48	0.000	0.000	0.0	0.0	
MV BUS T-49	34.500	100.450	-0.1	0	0	0.004	0.004	MV BUS T-42	-0.012	0.061	1.0	-20.0	
								MV BUS T-48	0.004	-0.033	0.6	-12.5	
								MV BUS T-50	0.004	-0.032	0.5	-13.0	
								LV BUS T-49	0.000	0.000	0.0	0.0	
MV BUS T-50	34.500	100.450	-0.1	0	0	0.004	0.004	MV BUS T-49	-0.004	-0.004	0.1	74.5	
								LV BUS T-50	0.000	0.000	0.0	0.0	
* POI	138.000	100.000	0.0	0.231	-6.116	0	0	89T1A	0.231	-6.116	25.6	-3.8	
MPT~3	13.800	100.372	0.0	0	0	0	0	HV BUS MPT	0.000	0.000	0.0	0.0	
								& 89T1B					

* Indicates a voltage regulated bus (voltage controlled or swing type machine connected to it)

Indicates a bus with a load mismatch of more than 0.1 MVA

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: 1PU UNITY PF

Page: 1

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: Normal

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap	
89F1A	34.500	100.017	0.0	0	0	0	0	MV BUS T-25	0.042	0.244	4.1	16.9		
								89T1B	-0.042	-0.244	4.1	16.9		
89F2A	34.500	100.017	0.0	0	0	0	0	JB-2/1	0.046	0.401	6.8	11.4		
								89T1B	-0.046	-0.401	6.8	11.4		
89F3A	34.500	100.017	0.0	0	0	0	0	MV BUS T-23	0.046	0.142	2.5	30.8		
								89T1B	-0.046	-0.142	2.5	30.8		
89F4A	34.500	100.017	0.0	0	0	0	0	MV BUS T-40	0.042	-0.911	15.3	-4.6		
								89T1B	-0.042	0.911	15.3	-4.6		
89T1A	138.000	100.000	0.0	0	0	0	0	POI	-0.229	-0.023	1.0	99.5		
								HV BUS MPT	0.229	0.023	1.0	99.5		
89T1B	34.500	100.017	0.0	0	0	0	0	89F4A	0.042	-0.911	15.3	-4.6		
								89F3A	0.046	0.142	2.5	30.8		
								89F2A	0.046	0.401	6.8	11.4		
								89F1A	0.042	0.244	4.1	16.9		
								MPT~3	-0.175	0.124	3.6	-81.5		
HV BUS MPT	138.000	100.000	0.0	0	0	0.054	0.147	& HV BUS MPT						
								89T1A	-0.229	-0.023	1.0	99.5		
								89T1B	0.175	-0.124	0.9	-81.6		
								& MPT~3						
JB-2/1	34.500	100.002	0.0	0	0	0	0	MV BUS T-17	0.029	0.491	8.2	5.9		
								MV BUS T-22	0.017	0.330	5.5	5.0		
								89F2A	-0.046	-0.822	13.8	5.6		
JB-4/1	34.500	100.003	0.0	0	0	0	0	MV BUS T-41	0.004	0.121	2.0	3.4		
								MV BUS T-42	0.017	0.359	6.0	4.6		
								MV BUS T-43	0.004	0.122	2.0	3.4		
								MV BUS T-44	-0.025	-0.602	10.1	4.1		
LV BUS T-01	0.690	99.666	0.0	0.000	-0.146	0	0	MV BUS T-01	0.000	-0.146	122.6	0.0		
LV BUS T-02	0.690	99.667	0.0	0.000	-0.146	0	0	MV BUS T-02	0.000	-0.146	122.6	0.0		
LV BUS T-03	0.690	99.669	0.0	0.000	-0.146	0	0	MV BUS T-03	0.000	-0.146	122.6	0.0		
LV BUS T-04	0.690	99.672	0.0	0.000	-0.146	0	0	MV BUS T-04	0.000	-0.146	122.6	0.0		
LV BUS T-05	0.690	99.676	0.0	0.000	-0.146	0	0	MV BUS T-05	0.000	-0.146	122.6	0.0		
LV BUS T-06	0.690	99.679	0.0	0.000	-0.146	0	0	MV BUS T-06	0.000	-0.146	122.6	0.0		
LV BUS T-07	0.690	99.680	0.0	0.000	-0.146	0	0	MV BUS T-07	0.000	-0.146	122.6	0.0		
LV BUS T-08	0.690	99.681	0.0	0.000	-0.146	0	0	MV BUS T-08	0.000	-0.146	122.6	0.0		
LV BUS T-09	0.690	99.688	0.0	0.000	-0.146	0	0	MV BUS T-09	0.000	-0.146	122.5	0.0		
LV BUS T-10	0.690	99.692	0.0	0.000	-0.146	0	0	MV BUS T-10	0.000	-0.146	122.5	0.0		

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: 1PU UNITY PF

Page: 2

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: Normal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
LV BUS T-13	0.690	99.678	0.0	0.000	-0.146	0	0	MV BUS T-13	0.000	-0.146	122.6	0.0	
LV BUS T-14	0.690	99.679	0.0	0.000	-0.146	0	0	MV BUS T-14	0.000	-0.146	122.6	0.0	
LV BUS T-15	0.690	99.683	0.0	0.000	-0.146	0	0	MV BUS T-15	0.000	-0.146	122.6	0.0	
LV BUS T-16	0.690	99.678	0.0	0.000	-0.146	0	0	MV BUS T-16	0.000	-0.146	122.6	0.0	
LV BUS T-17	0.690	99.692	0.0	0.000	-0.146	0	0	MV BUS T-17	0.000	-0.146	122.5	0.0	
LV BUS T-20	0.690	99.689	0.0	0.000	-0.146	0	0	MV BUS T-20	0.000	-0.146	122.5	0.0	
LV BUS T-21	0.690	99.691	0.0	0.000	-0.146	0	0	MV BUS T-21	0.000	-0.146	122.5	0.0	
LV BUS T-22	0.690	99.693	0.0	0.000	-0.146	0	0	MV BUS T-22	0.000	-0.146	122.5	0.0	
LV BUS T-23	0.690	99.695	0.0	0.000	-0.146	0	0	MV BUS T-23	0.000	-0.146	122.5	0.0	
LV BUS T-24	0.690	99.707	0.0	0.000	-0.146	0	0	MV BUS T-24	0.000	-0.146	122.5	0.0	
LV BUS T-25	0.690	99.708	0.0	0.000	-0.146	0	0	MV BUS T-25	0.000	-0.146	122.5	0.0	
LV BUS T-26	0.690	99.685	0.0	0.000	-0.146	0	0	MV BUS T-26	0.000	-0.146	122.5	0.0	
LV BUS T-27	0.690	99.687	0.0	0.000	-0.146	0	0	MV BUS T-27	0.000	-0.146	122.5	0.0	
LV BUS T-28	0.690	99.689	0.0	0.000	-0.146	0	0	MV BUS T-28	0.000	-0.146	122.5	0.0	
LV BUS T-29	0.690	99.690	0.0	0.000	-0.146	0	0	MV BUS T-29	0.000	-0.146	122.5	0.0	
LV BUS T-31	0.690	99.674	0.0	0.000	-0.146	0	0	MV BUS T-31	0.000	-0.146	122.6	0.0	
LV BUS T-32	0.690	99.677	0.0	0.000	-0.146	0	0	MV BUS T-32	0.000	-0.146	122.6	0.0	
LV BUS T-33	0.690	99.678	0.0	0.000	-0.146	0	0	MV BUS T-33	0.000	-0.146	122.6	0.0	
LV BUS T-34	0.690	99.675	0.0	0.000	-0.146	0	0	MV BUS T-34	0.000	-0.146	122.6	0.0	
LV BUS T-36	0.690	99.671	0.0	0.000	-0.146	0	0	MV BUS T-36	0.000	-0.146	122.6	0.0	
LV BUS T-37	0.690	99.671	0.0	0.000	-0.146	0	0	MV BUS T-37	0.000	-0.146	122.6	0.0	
LV BUS T-39	0.690	99.673	0.0	0.000	-0.146	0	0	MV BUS T-39	0.000	-0.146	122.6	0.0	
LV BUS T-40	0.690	99.723	0.0	0.000	-0.146	0	0	MV BUS T-40	0.000	-0.146	122.5	0.0	
LV BUS T-41	0.690	99.698	0.0	0.000	-0.146	0	0	MV BUS T-41	0.000	-0.146	122.5	0.0	
LV BUS T-42	0.690	99.698	0.0	0.000	-0.146	0	0	MV BUS T-42	0.000	-0.146	122.5	0.0	
LV BUS T-43	0.690	99.698	0.0	0.000	-0.146	0	0	MV BUS T-43	0.000	-0.146	122.5	0.0	
LV BUS T-44	0.690	99.705	0.0	0.000	-0.146	0	0	MV BUS T-44	0.000	-0.146	122.5	0.0	
LV BUS T-45	0.690	99.711	0.0	0.000	-0.146	0	0	MV BUS T-45	0.000	-0.146	122.5	0.0	
LV BUS T-46	0.690	99.718	0.0	0.000	-0.146	0	0	MV BUS T-46	0.000	-0.146	122.5	0.0	
LV BUS T-48	0.690	99.689	0.0	0.000	-0.146	0	0	MV BUS T-48	0.000	-0.146	122.5	0.0	
LV BUS T-49	0.690	99.690	0.0	0.000	-0.146	0	0	MV BUS T-49	0.000	-0.146	122.5	0.0	
LV BUS T-50	0.690	99.689	0.0	0.000	-0.146	0	0	MV BUS T-50	0.000	-0.146	122.5	0.0	
MV BUS T-01	34.500	99.970	0.0	0	0	0.004	0.004	MV BUS T-02	-0.004	-0.150	2.5	2.8	
								LV BUS T-01	0.000	0.146	2.5	0.0	
MV BUS T-02	34.500	99.972	0.0	0	0	0.004	0.004	MV BUS T-01	0.004	0.104	1.7	4.0	
								MV BUS T-03	-0.008	-0.254	4.2	3.3	
								LV BUS T-02	0.000	0.146	2.5	0.0	
MV BUS T-03	34.500	99.974	0.0	0	0	0.004	0.004	MV BUS T-02	0.008	0.214	3.6	3.9	
								MV BUS T-04	-0.012	-0.364	6.1	3.4	

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: 1PU UNITY PF

Page: 3

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: Normal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
MV BUS T-04	34.500	99.976	0.0	0	0	0.004	0.004	LV BUS T-03	0.000	0.146	2.5	0.0	
								MV BUS T-03	0.012	0.318	5.3	3.9	
								MV BUS T-05	-0.017	-0.468	7.8	3.6	
MV BUS T-05	34.500	99.980	0.0	0	0	0.004	0.004	LV BUS T-04	0.000	0.146	2.5	0.0	
								MV BUS T-04	0.017	0.416	7.0	4.0	
								MV BUS T-08	-0.021	-0.566	9.5	3.7	
MV BUS T-06	34.500	99.983	0.0	0	0	0.004	0.004	LV BUS T-05	0.000	0.146	2.5	0.0	
								MV BUS T-07	-0.004	-0.150	2.5	2.8	
								LV BUS T-06	0.000	0.146	2.5	0.0	
MV BUS T-07	34.500	99.984	0.0	0	0	0.004	0.004	MV BUS T-06	0.004	0.121	2.0	3.4	
								MV BUS T-16	0.004	0.086	1.4	4.9	
								MV BUS T-15	-0.012	-0.356	6.0	3.5	
MV BUS T-08	34.500	99.985	0.0	0	0	0.004	0.004	LV BUS T-07	0.000	0.146	2.5	0.0	
								MV BUS T-05	0.021	0.469	7.9	4.4	
								MV BUS T-09	-0.025	-0.619	10.4	4.0	
MV BUS T-09	34.500	99.992	0.0	0	0	0.004	0.004	LV BUS T-08	0.000	0.146	2.5	0.0	
								MV BUS T-08	0.025	0.499	8.4	5.0	
								MV BUS T-10	-0.029	-0.649	10.9	4.5	
MV BUS T-10	34.500	99.996	0.0	0	0	0.004	0.004	LV BUS T-09	0.000	0.146	2.5	0.0	
								MV BUS T-09	0.029	0.558	9.3	5.2	
								MV BUS T-25	-0.033	-0.708	11.9	4.7	
MV BUS T-13	34.500	99.982	0.0	0	0	0.004	0.004	LV BUS T-10	0.000	0.146	2.5	0.0	
								MV BUS T-14	-0.004	-0.150	2.5	2.8	
								LV BUS T-13	0.000	0.146	2.5	0.0	
MV BUS T-14	34.500	99.983	0.0	0	0	0.004	0.004	MV BUS T-13	0.004	0.118	2.0	3.5	
								MV BUS T-15	-0.008	-0.268	4.5	3.1	
								LV BUS T-14	0.000	0.146	2.5	0.0	
MV BUS T-15	34.500	99.988	0.0	0	0	0.004	0.004	MV BUS T-07	0.012	0.283	4.7	4.4	
								MV BUS T-14	0.008	0.189	3.2	4.4	
								MV BUS T-17	-0.025	-0.622	10.4	4.0	
MV BUS T-16	34.500	99.982	0.0	0	0	0.004	0.004	LV BUS T-15	0.000	0.146	2.5	0.0	
								MV BUS T-07	-0.004	-0.150	2.5	2.8	
								LV BUS T-16	0.000	0.146	2.5	0.0	
MV BUS T-17	34.500	99.997	0.0	0	0	0.004	0.004	JB-2/1	-0.029	-0.606	10.2	4.8	
								MV BUS T-15	0.025	0.456	7.6	5.5	
								LV BUS T-17	0.000	0.146	2.5	0.0	
MV BUS T-20	34.500	99.994	0.0	0	0	0.004	0.004	MV BUS T-21	-0.004	-0.150	2.5	2.8	
								LV BUS T-20	0.000	0.146	2.5	0.0	
								MV BUS T-20	0.004	0.075	1.3	5.5	

Project: NW OH WIND

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: NW_OH

ETAP

16.0.0C

Study Case: 1PU UNITY PF

Page: 4

Date: 10-06-2017

SN: WESTWOODP

Revision: 0% GEN

Config.: Normal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
MV BUS T-22	34.500	99.997	0.0	0	0	0.004	0.004	MV BUS T-22	-0.008	-0.225	3.8	3.7	
								LV BUS T-21	0.000	0.146	2.5	0.0	
								JB-2/1	-0.017	-0.408	6.8	4.1	
								MV BUS T-21	0.008	0.196	3.3	4.2	
								MV BUS T-29	0.004	0.062	1.0	6.7	
MV BUS T-23	34.500	99.999	0.0	0	0	0.004	0.004	LV BUS T-22	0.000	0.146	2.5	0.0	
								89F3A	-0.046	-0.779	13.1	5.9	
								MV BUS T-28	0.042	0.629	10.6	6.6	
MV BUS T-24	34.500	100.011	0.0	0	0	0.004	0.004	LV BUS T-23	0.000	0.146	2.5	0.0	
								MV BUS T-25	-0.004	-0.150	2.5	2.8	
MV BUS T-25	34.500	100.012	0.0	0	0	0.004	0.004	LV BUS T-24	0.000	0.146	2.5	0.0	
								89F1A	-0.042	-0.483	8.1	8.6	
								MV BUS T-10	0.033	0.226	3.8	14.6	
MV BUS T-26	34.500	99.990	0.0	0	0	0.004	0.004	MV BUS T-24	0.004	0.107	1.8	3.9	
								LV BUS T-25	0.000	0.146	2.5	0.0	
								MV BUS T-27	-0.004	-0.150	2.5	2.8	
MV BUS T-27	34.500	99.991	0.0	0	0	0.004	0.004	LV BUS T-26	0.000	0.146	2.5	0.0	
								MV BUS T-26	0.004	0.113	1.9	3.7	
								MV BUS T-28	-0.008	-0.263	4.4	3.2	
MV BUS T-28	34.500	99.993	0.0	0	0	0.004	0.004	LV BUS T-27	0.000	0.146	2.5	0.0	
								MV BUS T-23	-0.042	-0.782	13.1	5.3	
								MV BUS T-27	0.008	0.227	3.8	3.7	
MV BUS T-29	34.500	99.995	0.0	0	0	0.004	0.004	MV BUS T-33	0.029	0.405	6.8	7.2	
								LV BUS T-28	0.000	0.146	2.5	0.0	
								MV BUS T-22	-0.004	-0.150	2.5	2.8	
MV BUS T-31	34.500	99.979	0.0	0	0	0.004	0.004	LV BUS T-29	0.000	0.146	2.5	0.0	
								MV BUS T-32	-0.004	-0.150	2.5	2.8	
								LV BUS T-31	0.000	0.146	2.5	0.0	
MV BUS T-32	34.500	99.981	0.0	0	0	0.004	0.004	MV BUS T-31	0.004	0.041	0.7	10.2	
								MV BUS T-33	-0.008	-0.191	3.2	4.4	
								LV BUS T-32	0.000	0.146	2.5	0.0	
MV BUS T-33	34.500	99.983	0.0	0	0	0.004	0.004	MV BUS T-28	-0.029	-0.653	10.9	4.5	
								MV BUS T-32	0.008	0.163	2.7	5.1	
								MV BUS T-34	0.017	0.340	5.7	4.9	
MV BUS T-34	34.500	99.980	0.0	0	0	0.004	0.004	LV BUS T-33	0.000	0.146	2.5	0.0	
								MV BUS T-33	-0.017	-0.384	6.4	4.3	
								MV BUS T-36	0.008	0.203	3.4	4.1	
								MV BUS T-39	0.004	0.031	0.5	13.5	
								LV BUS T-34	0.000	0.146	2.5	0.0	

Project: NW OH WIND
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: NW_OH

ETAP
16.0.0C

Study Case: 1PU UNITY PF

Page: 5
Date: 10-06-2017
SN: WESTWOODP
Revision: 0% GEN
Config.: Normal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ID	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ID	MW	Mvar	Amp	%PF	%Tap
MV BUS T-36	34.500	99.976	0.0	0	0	0.004	0.004	MV BUS T-34	-0.008	-0.273	4.6	3.0	
								MV BUS T-37	0.004	0.123	2.1	3.4	
								LV BUS T-36	0.000	0.146	2.5	0.0	
MV BUS T-37	34.500	99.975	0.0	0	0	0.004	0.004	MV BUS T-36	-0.004	-0.150	2.5	2.8	
								LV BUS T-37	0.000	0.146	2.5	0.0	
MV BUS T-39	34.500	99.977	0.0	0	0	0.004	0.004	MV BUS T-34	-0.004	-0.150	2.5	2.8	
								LV BUS T-39	0.000	0.146	2.5	0.0	
MV BUS T-40	34.500	100.027	0.0	0	0	0.004	0.004	89F4A	-0.042	-0.642	10.8	6.5	
								MV BUS T-46	0.038	0.492	8.3	7.6	
								LV BUS T-40	0.000	0.146	2.5	0.0	
MV BUS T-41	34.500	100.002	0.0	0	0	0.004	0.004	JB-4/1	-0.004	-0.150	2.5	2.8	
								LV BUS T-41	0.000	0.146	2.5	0.0	
MV BUS T-42	34.500	100.003	0.0	0	0	0.004	0.004	JB-4/1	-0.017	-0.360	6.0	4.6	
								MV BUS T-49	0.013	0.210	3.5	6.0	
								LV BUS T-42	0.000	0.146	2.5	0.0	
MV BUS T-43	34.500	100.002	0.0	0	0	0.004	0.004	JB-4/1	-0.004	-0.150	2.5	2.8	
								LV BUS T-43	0.000	0.146	2.5	0.0	
MV BUS T-44	34.500	100.010	0.0	0	0	0.004	0.004	JB-4/1	0.025	0.475	8.0	5.3	
								MV BUS T-45	-0.029	-0.625	10.5	4.7	
								LV BUS T-44	0.000	0.146	2.5	0.0	
MV BUS T-45	34.500	100.015	0.0	0	0	0.004	0.004	MV BUS T-44	0.029	0.503	8.4	5.8	
								MV BUS T-46	-0.033	-0.653	10.9	5.1	
								LV BUS T-45	0.000	0.146	2.5	0.0	
MV BUS T-46	34.500	100.022	0.0	0	0	0.004	0.004	MV BUS T-40	-0.038	-0.614	10.3	6.1	
								MV BUS T-45	0.033	0.464	7.8	7.2	
								LV BUS T-46	0.000	0.146	2.5	0.0	
MV BUS T-48	34.500	99.993	0.0	0	0	0.004	0.004	MV BUS T-49	-0.004	-0.150	2.5	2.8	
								LV BUS T-48	0.000	0.146	2.5	0.0	
MV BUS T-49	34.500	99.995	0.0	0	0	0.004	0.004	MV BUS T-42	-0.012	-0.379	6.3	3.3	
								MV BUS T-48	0.004	0.114	1.9	3.6	
								MV BUS T-50	0.004	0.115	1.9	3.6	
								LV BUS T-49	0.000	0.146	2.5	0.0	
MV BUS T-50	34.500	99.993	0.0	0	0	0.004	0.004	MV BUS T-49	-0.004	-0.150	2.5	2.8	
								LV BUS T-50	0.000	0.146	2.5	0.0	
* POI	138.000	100.000	0.0	0.229	0.017	0	0	89T1A	0.229	0.017	1.0	99.7	
MPT~3	13.800	100.019	0.0	0	0	0	0	HV BUS MPT	0.000	0.000	0.0	0.0	
								& 89T1B					

* Indicates a voltage regulated bus (voltage controlled or swing type machine connected to it)

Indicates a bus with a load mismatch of more than 0.1 MVA

Project: DF OH F 2D_
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: DF IOH

ETAP
60WMC

Study Case: NGP1 6P.

Page: 6
Date: 6/7/2016
SD: F ESnf OO_P
Revision: Tk AED
ConcW Dorj al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR
2_	pV	k 9 agW	8 ngW	9 F	9 far	9 F	9 far	2_	9 F	9 far	8 j 3	k P.	k m3
4N 68	5B6HT	6T1W6v	TW	T	T	T	T	9 V U1 S m7RG	TWER	TWERB	BW	60W	
								4Nm6U	7TWER	7TWERB	BW	60W	
4N R8	5B6HT	6T1W6v	TW	T	T	T	T	JU7R/6	TWB0	TWB16	0W	66W	
								4Nm6U	7TWB0	7TWB16	0W	66W	
4N 58	5B6HT	6T1W6v	TW	T	T	T	T	9 V U1 S m7R5	TWB0	TWER	R6	5TW	
								4Nm6U	7TWB0	7TWER	R6	5TW	
4N B8	5B6HT	6T1W6v	TW	T	T	T	T	9 V U1 S m7BT	TWER	7TW66	6G6	7B6	
								4Nm6U	7TWER	TW66	6G6	7B6	
4Nm68	654WTT	NGWTT	TW	T	T	T	T	PO2	7TWR5	7TWIN	6W	NNW	
								HV U1 S 9 Pm	TWR5	TWIN	6W	NNW	
4Nm6U	5B6HT	6T1W6v	TW	T	T	T	T	4N B8	TWER	7TW66	6G6	7B6	
								4N 58	TWB0	TWER	R6	5TW	
								4N R8	TWB0	TWB16	0W	66W	
								4N 68	TWER	TWERB	BW	60W	
								9 Pm-5	7TW6G	TWRB	5W	746W	
								& HV U1 S 9 Pm					
HV U1 S 9 Pm	654WTT	NGWTT	TW	T	T	TWB4	TW55	4Nm68	7TWR5	7TWIN	6W	NNW	
								4Nm6U	TW6G	7TWRB	TW	746W	7GWT
								& 9 Pm-5					
JU7R/6	5B6HT	6T1W1R	TW	T	T	T	T	9 V U1 S m76v	TWRN	TWN6	4W	GN	
								9 V U1 S m7RR	TW6v	TW5T	G6	GW	
								4N R8	7TWB0	7TWR	65W	GW	
JU7B/6	5B6HT	6T1WT5	TW	T	T	T	T	9 V U1 S m7B6	TWTB	TWR6	RW	5W	
								9 V U1 S m7BR	TW6v	TWCN	0W	BW	
								9 V U1 S m7B5	TWTB	TWRR	RW	5W	
								9 V U1 S m7BB	7TWRG	7TW1R	6TW	BW	
LV U1 S m7I6	TWNT	NN00	TW	TWTT	7TWB0	T	T	9 V U1 S m7I6	TWTT	7TWB0	6RRW	TW	
LV U1 S m7IR	TWNT	NN00v	TW	TWTT	7TWB0	T	T	9 V U1 S m7IR	TWTT	7TWB0	6RRW	TW	
LV U1 S m7I5	TWNT	NN00N	TW	TWTT	7TWB0	T	T	9 V U1 S m7I5	TWTT	7TWB0	6RRW	TW	
LV U1 S m7IB	TWNT	NN00vR	TW	TWTT	7TWB0	T	T	9 V U1 S m7IB	TWTT	7TWB0	6RRW	TW	
LV U1 S m7IG	TWNT	NN00v0	TW	TWTT	7TWB0	T	T	9 V U1 S m7IG	TWTT	7TWB0	6RRW	TW	
LV U1 S m7IO	TWNT	NN00vN	TW	TWTT	7TWB0	T	T	9 V U1 S m7IO	TWTT	7TWB0	6RRW	TW	
LV U1 S m7Iv	TWNT	NN04T	TW	TWTT	7TWB0	T	T	9 V U1 S m7Iv	TWTT	7TWB0	6RRW	TW	
LV U1 S m7I4	TWNT	NN046	TW	TWTT	7TWB0	T	T	9 V U1 S m7I4	TWTT	7TWB0	6RRW	TW	
LV U1 S m7IN	TWNT	NN044	TW	TWTT	7TWB0	T	T	9 V U1 S m7IN	TWTT	7TWB0	6RRW	TW	
LV U1 S m7IT	TWNT	NN0NR	TW	TWTT	7TWB0	T	T	9 V U1 S m7IT	TWTT	7TWB0	6RRW	TW	

Project: DF OH F 2D_

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: DF IOH

ETAP

60WMC

Study Case: NGP1 6P.

Page: R

Rate: 6T7I07KI6v

SD: F ESnf OO_ P

Definition: Tk AED

Conductor: Dorj al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
2_	pV	k 9 agW	8 ngW	9 F	9 far	9 F	9 far	2_	9 F	9 far	8 j 3	k P.	k ma3
LV U1 S m765	TONT	NNv4	TW	TWTT	7TWB0	T	T	9 V U1 S m765	TWTT	7TWB0	6RRW	TW	
LV U1 S m76B	TONT	NNvN	TW	TWTT	7TWB0	T	T	9 V U1 S m76B	TWTT	7TWB0	6RRW	TW	
LV U1 S m76G	TONT	NN45	TW	TWTT	7TWB0	T	T	9 V U1 S m76G	TWTT	7TWB0	6RRW	TW	
LV U1 S m760	TONT	NNv4	TW	TWTT	7TWB0	T	T	9 V U1 S m760	TWTT	7TWB0	6RRW	TW	
LV U1 S m76v	TONT	NNNR	TW	TWTT	7TWB0	T	T	9 V U1 S m76v	TWTT	7TWB0	6RRW	TW	
LV U1 S m7RT	TONT	NN4N	TW	TWTT	7TWB0	T	T	9 V U1 S m7RT	TWTT	7TWB0	6RRW	TW	
LV U1 S m7R6	TONT	NNN6	TW	TWTT	7TWB0	T	T	9 V U1 S m7R6	TWTT	7TWB0	6RRW	TW	
LV U1 S m7RR	TONT	NNN5	TW	TWTT	7TWB0	T	T	9 V U1 S m7RR	TWTT	7TWB0	6RRW	TW	
LV U1 S m7R5	TONT	NNNG	TW	TWTT	7TWB0	T	T	9 V U1 S m7R5	TWTT	7TWB0	6RRW	TW	
LV U1 S m7RB	TONT	NNWv	TW	TWTT	7TWB0	T	T	9 V U1 S m7RB	TWTT	7TWB0	6RRW	TW	
LV U1 S m7RG	TONT	NNWt4	TW	TWTT	7TWB0	T	T	9 V U1 S m7RG	TWTT	7TWB0	6RRW	TW	
LV U1 S m7R0	TONT	NN4G	TW	TWTT	7TWB0	T	T	9 V U1 S m7R0	TWTT	7TWB0	6RRW	TW	
LV U1 S m7Rv	TONT	NN4v	TW	TWTT	7TWB0	T	T	9 V U1 S m7Rv	TWTT	7TWB0	6RRW	TW	
LV U1 S m7R4	TONT	NN4N	TW	TWTT	7TWB0	T	T	9 V U1 S m7R4	TWTT	7TWB0	6RRW	TW	
LV U1 S m7RN	TONT	NNNT	TW	TWTT	7TWB0	T	T	9 V U1 S m7RN	TWTT	7TWB0	6RRW	TW	
LV U1 S m756	TONT	NNvB	TW	TWTT	7TWB0	T	T	9 V U1 S m756	TWTT	7TWB0	6RRW	TW	
LV U1 S m75R	TONT	NNvv	TW	TWTT	7TWB0	T	T	9 V U1 S m75R	TWTT	7TWB0	6RRW	TW	
LV U1 S m755	TONT	NNv4	TW	TWTT	7TWB0	T	T	9 V U1 S m755	TWTT	7TWB0	6RRW	TW	
LV U1 S m75B	TONT	NNvG	TW	TWTT	7TWB0	T	T	9 V U1 S m75B	TWTT	7TWB0	6RRW	TW	
LV U1 S m750	TONT	NNv6	TW	TWTT	7TWB0	T	T	9 V U1 S m750	TWTT	7TWB0	6RRW	TW	
LV U1 S m75v	TONT	NNv6	TW	TWTT	7TWB0	T	T	9 V U1 S m75v	TWTT	7TWB0	6RRW	TW	
LV U1 S m75N	TONT	NNv5	TW	TWTT	7TWB0	T	T	9 V U1 S m75N	TWTT	7TWB0	6RRW	TW	
LV U1 S m7BT	TONT	NNR5	TW	TWTT	7TWB0	T	T	9 V U1 S m7BT	TWTT	7TWB0	6RRW	TW	
LV U1 S m7B6	TONT	NNN4	TW	TWTT	7TWB0	T	T	9 V U1 S m7B6	TWTT	7TWB0	6RRW	TW	
LV U1 S m7BR	TONT	NNN4	TW	TWTT	7TWB0	T	T	9 V U1 S m7BR	TWTT	7TWB0	6RRW	TW	
LV U1 S m7B5	TONT	NNN4	TW	TWTT	7TWB0	T	T	9 V U1 S m7B5	TWTT	7TWB0	6RRW	TW	
LV U1 S m7BB	TONT	NNWtG	TW	TWTT	7TWB0	T	T	9 V U1 S m7BB	TWTT	7TWB0	6RRW	TW	
LV U1 S m7BG	TONT	NNW66	TW	TWTT	7TWB0	T	T	9 V U1 S m7BG	TWTT	7TWB0	6RRW	TW	
LV U1 S m7B0	TONT	NNW64	TW	TWTT	7TWB0	T	T	9 V U1 S m7B0	TWTT	7TWB0	6RRW	TW	
LV U1 S m7B4	TONT	NN4N	TW	TWTT	7TWB0	T	T	9 V U1 S m7B4	TWTT	7TWB0	6RRW	TW	
LV U1 S m7BN	TONT	NNNT	TW	TWTT	7TWB0	T	T	9 V U1 S m7BN	TWTT	7TWB0	6RRW	TW	
LV U1 S m7GT	TONT	NN4N	TW	TWTT	7TWB0	T	T	9 V U1 S m7GT	TWTT	7TWB0	6RRW	TW	
9 V U1 S m7I6	SBWGT	NNWt	TW	T	T	TWtB	TWtB	9 V U1 S m7IR	7TWtB	7TWGt	RW	RW	
								LV U1 S m7I6	TWTT	7TWB0	RW	TW	
9 V U1 S m7IR	SBWGT	NNWR	TW	T	T	TWtB	TWtB	9 V U1 S m7I6	TWtB	TWtB	6W	BW	
								9 V U1 S m7I5	7TWt4	7TWCB	BW	5W	
								LV U1 S m7IR	TWTT	7TWB0	RW	TW	
9 V U1 S m7I5	SBWGT	NNWB	TW	T	T	TWtB	TWtB	9 V U1 S m7IR	TWt4	7TWB0	5W	5W	
								9 V U1 S m7IB	7TW6R	7TW0B	0W	5W	

Project: DF OH F 2D_
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: DF IOH

ETAP
60WMC
Study Case: NGP1 6P.

Page: 5
Date: 6/7/2016
SD: F ES mF OO_P
Definition: Tk AED
ConNGW Dorj al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
2	pV	k 9 agW	8 ngW	9 F	9 far	9 F	9 far	2	9 F	9 far	8 j 3	k P.	k ma3
9 V U1 S m7IB	5B6GTT	NNW0	TW	T	T	TWIB	TWIB	LV U1 S m7IS	TWIT	TWBO	R6	TW	
								9 V U1 S m7IS	TW6R	TW64	G6	5W	
								9 V U1 S m7IG	7TW6v	7TW04	vW	5W	
9 V U1 S m7IG	5B6GTT	NNW4T	TW	T	T	TWIB	TWIB	LV U1 S m7IB	TWIT	TWBO	R6	TW	
								9 V U1 S m7IB	TW6v	TW60	vW	BW	
								9 V U1 S m7I4	7TW6	7TW00	NG	5W	
9 V U1 S m7IO	5B6GTT	NNW4S	TW	T	T	TWIB	TWIB	LV U1 S m7IG	TWIT	TWBO	R6	TW	
								9 V U1 S m7Iv	7TWIB	7TWGT	R6	RW	
								LV U1 S m7IO	TWIT	TWBO	R6	TW	
9 V U1 S m7Iv	5B6GTT	NNW4B	TW	T	T	TWIB	TWIB	9 V U1 S m7IO	TWIB	TW6	RW	5W	
								9 V U1 S m760	TWIB	TW40	6W	BW	
								9 V U1 S m76G	7TW6R	7TWCD	0W	5W	
9 V U1 S m7I4	5B6GTT	NNW4G	TW	T	T	TWIB	TWIB	LV U1 S m7Iv	TWIT	TWBO	R6	TW	
								9 V U1 S m7IG	TW6	TW0N	vW	BW	
								9 V U1 S m7IN	7TW6	7TW6N	6TW	BW	
9 V U1 S m7IN	5B6GTT	NNW4R	TW	T	T	TWIB	TWIB	LV U1 S m7I4	TWIT	TWBO	R6	TW	
								9 V U1 S m7I4	TW6	TW6N	4W	GW	
								9 V U1 S m76T	7TWRN	7TWBN	6TW	BW	
9 V U1 S m76T	5B6GTT	NNW4D	TW	T	T	TWIB	TWIB	LV U1 S m7IN	TWIT	TWBO	R6	TW	
								9 V U1 S m7IN	TWRN	TW64	NW	GW	
								9 V U1 S m76G	7TW5S	7TWI4	66W	BW	
9 V U1 S m76S	5B6GTT	NNW4R	TW	T	T	TWIB	TWIB	LV U1 S m76T	TWIT	TWBO	R6	TW	
								9 V U1 S m76B	7TWIB	7TWGT	R6	RW	
								LV U1 S m76S	TWIT	TWBO	R6	TW	
9 V U1 S m76B	5B6GTT	NNW4S	TW	T	T	TWIB	TWIB	9 V U1 S m76S	TWIB	TW64	RW	5W	
								9 V U1 S m76G	7TWI4	7TW04	BW	5W	
								LV U1 S m76B	TWIT	TWBO	R6	TW	
9 V U1 S m76G	5B6GTT	NNW44	TW	T	T	TWIB	TWIB	9 V U1 S m7Iv	TW6R	TW4S	BW	BW	
								9 V U1 S m76B	TWI4	TW4N	5W	BW	
								9 V U1 S m76v	7TW6	7TWR	6TW	BW	
9 V U1 S m760	5B6GTT	NNW4R	TW	T	T	TWIB	TWIB	LV U1 S m76G	TWIT	TWBO	R6	TW	
								9 V U1 S m7Iv	7TWIB	7TWGT	R6	RW	
								LV U1 S m760	TWIT	TWBO	R6	TW	
9 V U1 S m76v	5B6GTT	NNW4v	TW	T	T	TWIB	TWIB	JU7R/6	7TWRN	7TWI0	6TW	BW	
								9 V U1 S m76G	TW6	TWCD	vW	GW	
								LV U1 S m76v	TWIT	TWBO	R6	TW	
9 V U1 S m7RT	5B6GTT	NNW4B	TW	T	T	TWIB	TWIB	9 V U1 S m76	7TWIB	7TWGT	R6	RW	
								LV U1 S m7RT	TWIT	TWBO	R6	TW	
								9 V U1 S m7RT	TWIB	TWvG	6W	GW	

Project: DF OH F 2D_
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: DF IOH

ETAP
60WMC
Study Case: NGP1 6P.

Page: B
Date: 6/7/2021 6v
SD: F ES mF OO_P
Definition: Tk AED
ConNGW Dorj al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
2_	pV	k 9 agW	8 ngW	9 F	9 far	9 F	9 far	2_	9 F	9 far	8 j 3	k P.	k ma3
9 V U1 S m7R	5B6GHT	NNNNv	TW	T	T	TWIB	TWIB	9 V U1 S m7RR	7IW14	7IWRG	5W	5W	
								LV U1 S m7R6	TW1T	TWB0	RG	TW	
								JU7R/6	7IW6v	7IWB14	0W	BW	
								9 V U1 S m7R6	TW14	TWN0	5W	BW	
								9 V U1 S m7RN	TW1B	TWOR	6W	0W	
9 V U1 S m7S	5B6GHT	NNNNN	TW	T	T	TWIB	TWIB	LV U1 S m7RR	TW1T	TWB0	RG	TW	
								4N 58	7IWB0	7IWvN	65W	GW	
								9 V U1 S m7R4	TWER	TWRN	6TW	0W	
9 V U1 S m7RB	5B6GHT	6TTW66	TW	T	T	TWIB	TWIB	LV U1 S m7R5	TW1T	TWB0	RG	TW	
								9 V U1 S m7RG	7IWTB	7IWGT	RG	RW	
9 V U1 S m7RG	5B6GHT	6TTW6R	TW	T	T	TWIB	TWIB	LV U1 S m7RB	TW1T	TWB0	RG	TW	
								4N 68	7IWER	7IW45	4W	4W	
								9 V U1 S m76T	TW55	TWR0	5W	6BW	
9 V U1 S m7R0	5B6GHT	NNNNT	TW	T	T	TWIB	TWIB	9 V U1 S m7RB	TW1B	TWTv	6W	5W	
								LV U1 S m7RG	TW1T	TWB0	RG	TW	
								9 V U1 S m7Rv	7IWTB	7IWGT	RG	RW	
								LV U1 S m7R0	TW1T	TWB0	RG	TW	
9 V U1 S m7Rv	5B6GHT	NNNN6	TW	T	T	TWIB	TWIB	9 V U1 S m7R0	TW1B	TW65	6W	5W	
								9 V U1 S m7R4	7IW14	7IWR05	BW	5W	
								LV U1 S m7Rv	TW1T	TWB0	RG	TW	
9 V U1 S m7R4	5B6GHT	NNNN5	TW	T	T	TWIB	TWIB	9 V U1 S m7R5	7IWER	7IW4R	65W	GW	
								9 V U1 S m7Rv	TW14	TWRv	5W	5W	
								9 V U1 S m7S5	TWRN	TW1G	0W	vW	
								LV U1 S m7R4	TW1T	TWB0	RG	TW	
9 V U1 S m7RN	5B6GHT	NNNNG	TW	T	T	TWIB	TWIB	9 V U1 S m7RR	7IWTB	7IWGT	RG	RW	
								LV U1 S m7RN	TW1T	TWB0	RG	TW	
								9 V U1 S m7SR	7IWTB	7IWGT	RG	RW	
9 V U1 S m7S6	5B6GHT	NNNNN	TW	T	T	TWIB	TWIB	LV U1 S m7S6	TW1T	TWB0	RG	TW	
								9 V U1 S m7SR	TW1B	TWB6	TW	6TW	
								9 V U1 S m7S5	7IW14	7IWN6	5W	BW	
9 V U1 S m7S5	5B6GHT	NNNN45	TW	T	T	TWIB	TWIB	LV U1 S m7SR	TW1T	TWB0	RG	TW	
								9 V U1 S m7R4	7IWRN	7IWG5	6TW	BW	
								9 V U1 S m7SR	TW14	TW05	RW	GW	
								9 V U1 S m7SB	TW6v	TWBT	GW	BW	
9 V U1 S m7SB	5B6GHT	NNNN4T	TW	T	T	TWIB	TWIB	LV U1 S m7S5	TW1T	TWB0	RG	TW	
								9 V U1 S m7S5	7IW6v	7IW4B	0W	BW	
								9 V U1 S m7S0	TW14	TW15	5W	BW	
								9 V U1 S m7SN	TW1B	TW56	TW	65W	
								LV U1 S m7SB	TW1T	TWB0	RG	TW	

Project: DF OH F 2D_
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: DF IOH

ETAP
60WMC

Study Case: NGP1 6P.

Page: G
Date: 6/7/2021 6v
SD: F ES mF OO_P
Definition: Tk AED
Concurrence: Dorj al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
2	pV	k 9 agW	8 ngW	9 F	9 far	9 F	9 far	2	9 F	9 far	8 j 3	k P.	k m3
9 V U1 S m750	5B6GHT	NNW0	TW	T	T	TWIB	TWIB	9 V U1 S m75B	7TW14	7TW5	BW	5W	
								9 V U1 S m75v	TWIB	TW5	RW	5W	
								LV U1 S m750	TWIT	TWB0	RW	TW	
9 V U1 S m75v	5B6GHT	NNW6G	TW	T	T	TWIB	TWIB	9 V U1 S m750	7TWIB	7WGT	RW	RW	
								LV U1 S m75v	TWIT	TWB0	RW	TW	
9 V U1 S m75N	5B6GHT	NNWv	TW	T	T	TWIB	TWIB	9 V U1 S m75B	7TWIB	7WGT	RW	RW	
								LV U1 S m75N	TWIT	TWB0	RW	TW	
9 V U1 S m7BT	5B6GHT	6T1WRv	TW	T	T	TWIB	TWIB	4N B8	7TWER	7TWER	6TW	0W	
								9 V U1 S m7B0	TW54	TWNR	4W	vW	
								LV U1 S m7BT	TWIT	TWB0	RW	TW	
9 V U1 S m7B6	5B6GHT	6T1WIR	TW	T	T	TWIB	TWIB	JU7B6	7TWIB	7WGT	RW	RW	
								LV U1 S m7B6	TWIT	TWB0	RW	TW	
9 V U1 S m7BR	5B6GHT	6T1TW5	TW	T	T	TWIB	TWIB	JU7B6	7TW6v	7W0T	0W	BW	
								9 V U1 S m7BN	TW65	TW6T	5W	0W	
								LV U1 S m7BR	TWIT	TWB0	RW	TW	
9 V U1 S m7B5	5B6GHT	6T1WIR	TW	T	T	TWIB	TWIB	JU7B6	7TWIB	7WGT	RW	RW	
								LV U1 S m7B5	TWIT	TWB0	RW	TW	
9 V U1 S m7BB	5B6GHT	6T1W6T	TW	T	T	TWIB	TWIB	JU7B6	TWRG	TW6G	4W	GW	
								9 V U1 S m7BG	7TWRN	7TWRG	6TW	BW	
								LV U1 S m7BB	TWIT	TWB0	RW	TW	
9 V U1 S m7BG	5B6GHT	6T1W6G	TW	T	T	TWIB	TWIB	9 V U1 S m7BB	TWRN	TW65	4W	GW	
								9 V U1 S m7B0	7TW55	7TW65	6TW	GW	
								LV U1 S m7BG	TWIT	TWB0	RW	TW	
9 V U1 S m7B0	5B6GHT	6T1WRR	TW	T	T	TWIB	TWIB	9 V U1 S m7BT	7TW54	7TW6B	6TW	0W	
								9 V U1 S m7BG	TW55	TW0B	vW	vW	
								LV U1 S m7B0	TWIT	TWB0	RW	TW	
9 V U1 S m7B4	5B6GHT	NNW5	TW	T	T	TWIB	TWIB	9 V U1 S m7BN	7TWIB	7WGT	RW	RW	
								LV U1 S m7B4	TWIT	TWB0	RW	TW	
9 V U1 S m7BN	5B6GHT	NNWNG	TW	T	T	TWIB	TWIB	9 V U1 S m7BR	7TW6R	7WvN	0W	5W	
								9 V U1 S m7B4	TWIB	TW6B	6W	5W	
								9 V U1 S m7GT	TWIB	TW6G	6W	5W	
9 V U1 S m7GT	5B6GHT	NNW5	TW	T	T	TWIB	TWIB	9 V U1 S m7BN	7TWIB	7WGT	RW	RW	
								LV U1 S m7GT	TWIT	TWB0	RW	TW	
* PO2	654WTT	NGWTT	TW	TWR5	TWIB	T	T	4Nm68	TWR5	TWIB	6W	6TTW	
9 Pm-5	65WTT	6T1W6N	TW	T	T	T	T	HV U1 S 9 Pm	TWIT	TWIT	TW	TW	
								& 4Nm6U					

* 2ndicates a voltage regulated bus (voltage controlled or swing ty3e j achine connected to it)
2ndicates a bus with a load j isj atch oM ore than TW9 V8

Project: WT OH T IWF

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: WT_OH

ETAP

N6.0.0C

Study Case: NPG NP1

Page: N

Date: N0-06-20N7

SW: T ESDT OOF P

Revision: 0% f EW

Config.: Wormal

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
IF	AV	% p ag.	Mng.	p T	p var	p T	p var	IF	p T	p var	Mm8	%P1	%Da8
931NM	45.B00	N00.025	0.0	0	0	0	0	p V UGS D-2B	0.052	0.245	5.0	N7.6	
								93DNU	-0.052	-0.245	5.0	N7.6	
9312M	45.B00	N00.025	0.0	0	0	0	0	JU-2/N	0.056	0.430	6.6	NN7	
								93DNU	-0.056	-0.430	6.6	NN7	
9314M	45.B00	N00.025	0.0	0	0	0	0	p V UGS D-24	0.056	0.N40	2.4	44.N	
								93DNU	-0.056	-0.N40	2.4	44.N	
9315M	45.B00	N00.025	0.0	0	0	0	0	p V UGS D-50	0.052	-0.32N	NB5	-5.B	
								93DNU	-0.052	0.32N	NB5	-5.B	
93DNM	N#9.000	N00.000	0.0	0	0	0	0	POI	-0.223	0.020	N0	-33.6	
								HV UGS p PD	0.223	-0.020	N0	-33.6	
93DNU	45.B00	N00.025	0.0	0	0	0	0	9315M	0.052	-0.32N	NB5	-5.B	
								9314M	0.056	0.N40	2.4	44.N	
								9312M	0.056	0.430	6.6	NN7	
								931NM	0.052	0.245	5.0	N7.6	
								p PD-4	-0.N7B	0.N67	5.N	-72.4	
								& HV UGS p PD					
HV UGS p PD	N#9.000	N00.000	0.0	0	0	0.0B5	0.N57	93DNM	-0.223	0.020	N0	-33.6	
								93DNU	0.N7B	-0.N67	N0	-72.4	
								& p PD-4					
JU-2/N	45.B00	N00.009	0.0	0	0	0	0	p V UGS D-N7	0.023	0.595	9.N	6.0	
								p V UGS D-22	0.0N7	0.426	BB	BN	
								9312M	-0.056	-0.9N0	N4.6	B6	
JU-5/N	45.B00	N00.0N0	0.0	0	0	0	0	p V UGS D-5N	0.005	0.N20	2.0	4.B	
								p V UGS D-52	0.0N7	0.4BB	B3	5.7	
								p V UGS D-54	0.005	0.N2N	2.0	4.5	
								p V UGS D-55	-0.02B	-0.B36	N0.0	5.2	
LV UGS D-0N	0.630	33.67B	0.0	0.000	-0.N5B	0	0	p V UGS D-0N	0.000	-0.N5B	N2N7	0.0	
LV UGS D-02	0.630	33.676	0.0	0.000	-0.N5B	0	0	p V UGS D-02	0.000	-0.N5B	N2N7	0.0	
LV UGS D-04	0.630	33.679	0.0	0.000	-0.N5B	0	0	p V UGS D-04	0.000	-0.N5B	N2N7	0.0	
LV UGS D-05	0.630	33.69N	0.0	0.000	-0.N5B	0	0	p V UGS D-05	0.000	-0.N5B	N2N7	0.0	
LV UGS D-0B	0.630	33.69B	0.0	0.000	-0.N5B	0	0	p V UGS D-0B	0.000	-0.N5B	N2N7	0.0	
LV UGS D-06	0.630	33.697	0.0	0.000	-0.N5B	0	0	p V UGS D-06	0.000	-0.N5B	N2N7	0.0	
LV UGS D-07	0.630	33.699	0.0	0.000	-0.N5B	0	0	p V UGS D-07	0.000	-0.N5B	N2N7	0.0	
LV UGS D-09	0.630	33.630	0.0	0.000	-0.N5B	0	0	p V UGS D-09	0.000	-0.N5B	N2N7	0.0	
LV UGS D-03	0.630	33.636	0.0	0.000	-0.N5B	0	0	p V UGS D-03	0.000	-0.N5B	N2N7	0.0	
LV UGS D-N0	0.630	33.70N	0.0	0.000	-0.N5B	0	0	p V UGS D-N0	0.000	-0.N5B	N2N7	0.0	

Project: WT OH T IWF

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: WT_OH

ETAP

N6.0.0C

Study Case: NPG NP1

Page: 2

File: N0-06-20N7

SW: T ESDT OOF P

Revision: 0% f EW

Config.: Wormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
IF	AV	% p ag.	Mng.	p T	p var	p T	p var	IF	p T	p var	Mm8	%P1	%Da8
LV UGS D-N4	0.630	33.697	0.0	0.000	-0.15B	0	0	p V UGS D-N4	0.000	-0.15B	N2N7	0.0	
LV UGS D-N5	0.630	33.699	0.0	0.000	-0.15B	0	0	p V UGS D-N5	0.000	-0.15B	N2N7	0.0	
LV UGS D-N6	0.630	33.632	0.0	0.000	-0.15B	0	0	p V UGS D-N6	0.000	-0.15B	N2N7	0.0	
LV UGS D-N6	0.630	33.697	0.0	0.000	-0.15B	0	0	p V UGS D-N6	0.000	-0.15B	N2N7	0.0	
LV UGS D-N7	0.630	33.70N	0.0	0.000	-0.15B	0	0	p V UGS D-N7	0.000	-0.15B	N2N7	0.0	
LV UGS D-20	0.630	33.639	0.0	0.000	-0.15B	0	0	p V UGS D-20	0.000	-0.15B	N2N7	0.0	
LV UGS D-2N	0.630	33.700	0.0	0.000	-0.15B	0	0	p V UGS D-2N	0.000	-0.15B	N2N7	0.0	
LV UGS D-22	0.630	33.70N	0.0	0.000	-0.15B	0	0	p V UGS D-22	0.000	-0.15B	N2N7	0.0	
LV UGS D-24	0.630	33.705	0.0	0.000	-0.15B	0	0	p V UGS D-24	0.000	-0.15B	N2N7	0.0	
LV UGS D-25	0.630	33.71B	0.0	0.000	-0.15B	0	0	p V UGS D-25	0.000	-0.15B	N2N7	0.0	
LV UGS D-2B	0.630	33.716	0.0	0.000	-0.15B	0	0	p V UGS D-2B	0.000	-0.15B	N2N7	0.0	
LV UGS D-26	0.630	33.635	0.0	0.000	-0.15B	0	0	p V UGS D-26	0.000	-0.15B	N2N7	0.0	
LV UGS D-27	0.630	33.63B	0.0	0.000	-0.15B	0	0	p V UGS D-27	0.000	-0.15B	N2N7	0.0	
LV UGS D-29	0.630	33.639	0.0	0.000	-0.15B	0	0	p V UGS D-29	0.000	-0.15B	N2N7	0.0	
LV UGS D-23	0.630	33.633	0.0	0.000	-0.15B	0	0	p V UGS D-23	0.000	-0.15B	N2N7	0.0	
LV UGS D-4N	0.630	33.694	0.0	0.000	-0.15B	0	0	p V UGS D-4N	0.000	-0.15B	N2N7	0.0	
LV UGS D-42	0.630	33.696	0.0	0.000	-0.15B	0	0	p V UGS D-42	0.000	-0.15B	N2N7	0.0	
LV UGS D-44	0.630	33.697	0.0	0.000	-0.15B	0	0	p V UGS D-44	0.000	-0.15B	N2N7	0.0	
LV UGS D-45	0.630	33.695	0.0	0.000	-0.15B	0	0	p V UGS D-45	0.000	-0.15B	N2N7	0.0	
LV UGS D-46	0.630	33.690	0.0	0.000	-0.15B	0	0	p V UGS D-46	0.000	-0.15B	N2N7	0.0	
LV UGS D-47	0.630	33.690	0.0	0.000	-0.15B	0	0	p V UGS D-47	0.000	-0.15B	N2N7	0.0	
LV UGS D-43	0.630	33.692	0.0	0.000	-0.15B	0	0	p V UGS D-43	0.000	-0.15B	N2N7	0.0	
LV UGS D-50	0.630	33.742	0.0	0.000	-0.15B	0	0	p V UGS D-50	0.000	-0.15B	N2N7	0.0	
LV UGS D-5N	0.630	33.707	0.0	0.000	-0.15B	0	0	p V UGS D-5N	0.000	-0.15B	N2N7	0.0	
LV UGS D-52	0.630	33.709	0.0	0.000	-0.15B	0	0	p V UGS D-52	0.000	-0.15B	N2N7	0.0	
LV UGS D-54	0.630	33.707	0.0	0.000	-0.15B	0	0	p V UGS D-54	0.000	-0.15B	N2N7	0.0	
LV UGS D-55	0.630	33.71B	0.0	0.000	-0.15B	0	0	p V UGS D-55	0.000	-0.15B	N2N7	0.0	
LV UGS D-5B	0.630	33.720	0.0	0.000	-0.15B	0	0	p V UGS D-5B	0.000	-0.15B	N2N7	0.0	
LV UGS D-56	0.630	33.727	0.0	0.000	-0.15B	0	0	p V UGS D-56	0.000	-0.15B	N2N7	0.0	
LV UGS D-59	0.630	33.633	0.0	0.000	-0.15B	0	0	p V UGS D-59	0.000	-0.15B	N2N7	0.0	
LV UGS D-53	0.630	33.700	0.0	0.000	-0.15B	0	0	p V UGS D-53	0.000	-0.15B	N2N7	0.0	
LV UGS D-B0	0.630	33.633	0.0	0.000	-0.15B	0	0	p V UGS D-B0	0.000	-0.15B	N2N7	0.0	
p V UGS D-0N	45.100	33.377	0.0	0	0	0.005	0.005	p V UGS D-02	-0.005	-0.153	2.B	2.9	
								LV UGS D-0N	0.000	0.15B	2.5	0.0	
p V UGS D-02	45.100	33.373	0.0	0	0	0.005	0.005	p V UGS D-0N	0.005	0.104	N7	5.0	
								p V UGS D-04	-0.009	-0.212	5.2	4.4	
								LV UGS D-02	0.000	0.15B	2.5	0.0	
p V UGS D-04	45.100	33.39N	0.0	0	0	0.005	0.005	p V UGS D-02	0.009	0.212	4.6	4.3	
								p V UGS D-05	-0.012	-0.46N	6.0	4.5	

Project: WT OH T IWF

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: WT_OH

ETAP

N6.0.0C

Study Case: NPG NP1

Page: 4

File: N0-06-20N7

SW: T ESDT OOF P

Revision: 0% f EW

Config.: Wormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
IF	AV	% p ag.	Mng.	p T	p var	p T	p var	IF	p T	p var	Mm8	%P1	%Da8
p V UGS D-05	45.B00	33.394	0.0	0	0	0.005	0.005	LV UGS D-04	0.000	0.N5B	2.5	0.0	
								p V UGS D-04	0.0N2	0.4NB	B4	5.0	
								p V UGS D-0B	-0.0N7	-0.565	7.9	4.6	
p V UGS D-0B	45.B00	33.397	0.0	0	0	0.005	0.005	LV UGS D-05	0.000	0.N5B	2.5	0.0	
								p V UGS D-05	0.0N7	0.5N2	6.3	5.0	
								p V UGS D-09	-0.02N	-0.B6N	3.5	4.7	
p V UGS D-06	45.B00	33.330	0.0	0	0	0.005	0.005	LV UGS D-0B	0.000	0.N5B	2.5	0.0	
								p V UGS D-07	-0.005	-0.N53	2.B	2.9	
								LV UGS D-06	0.000	0.N5B	2.5	0.0	
p V UGS D-07	45.B00	33.33N	0.0	0	0	0.005	0.005	p V UGS D-06	0.005	0.N20	2.0	4.B	
								p V UGS D-N6	0.005	0.095	N5	5.3	
								p V UGS D-NB	-0.0N2	-0.4B4	B3	4.B	
p V UGS D-09	45.B00	33.332	0.0	0	0	0.005	0.005	LV UGS D-07	0.000	0.N5B	2.5	0.0	
								p V UGS D-0B	0.02N	0.565	7.9	5.B	
								p V UGS D-03	-0.02B	-0.6N4	N0.4	5.N	
p V UGS D-03	45.B00	33.333	0.0	0	0	0.005	0.005	LV UGS D-09	0.000	0.N5B	2.5	0.0	
								p V UGS D-09	0.02B	0.534	9.4	BN	
								p V UGS D-N0	-0.023	-0.652	N0.9	5.B	
p V UGS D-N0	45.B00	N00.004	0.0	0	0	0.005	0.005	LV UGS D-03	0.000	0.N5B	2.5	0.0	
								p V UGS D-03	0.023	0.BBN	3.2	B4	
								p V UGS D-2B	-0.044	-0.700	NN7	5.9	
p V UGS D-N4	45.B00	33.393	0.0	0	0	0.005	0.005	LV UGS D-N0	0.000	0.N5B	2.5	0.0	
								p V UGS D-N6	-0.005	-0.N53	2.B	2.9	
								LV UGS D-N4	0.000	0.N5B	2.5	0.0	
p V UGS D-N6	45.B00	33.330	0.0	0	0	0.005	0.005	p V UGS D-N4	0.005	0.NN7	2.0	4.B	
								p V UGS D-NB	-0.009	-0.266	5.B	4.N	
								LV UGS D-N6	0.000	0.N5B	2.5	0.0	
p V UGS D-NB	45.B00	33.335	0.0	0	0	0.005	0.005	p V UGS D-07	0.0N2	0.290	5.7	5.5	
								p V UGS D-N6	0.009	0.N97	4.N	5.B	
								p V UGS D-N7	-0.02B	-0.6N6	N0.4	5.0	
p V UGS D-N6	45.B00	33.393	0.0	0	0	0.005	0.005	LV UGS D-NB	0.000	0.N5B	2.5	0.0	
								p V UGS D-07	-0.005	-0.N53	2.B	2.9	
								LV UGS D-N6	0.000	0.N5B	2.5	0.0	
p V UGS D-N7	45.B00	N00.004	0.0	0	0	0.005	0.005	JU-2/N	-0.023	-0.B33	N0.0	5.3	
								p V UGS D-NB	0.02B	0.5B0	7.B	BB	
								LV UGS D-N7	0.000	0.N5B	2.5	0.0	
p V UGS D-20	45.B00	N00.000	0.0	0	0	0.005	0.005	p V UGS D-2N	-0.005	-0.N53	2.B	2.9	
								LV UGS D-20	0.000	0.N5B	2.5	0.0	
								p V UGS D-20	0.005	0.075	N2	B6	

Project: WT OH T IWF

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: WT_OH

ETAP

N6.0.0C

Study Case: NPG NP1

Page: 5

Date: N0-06-20N7

SW: T ESDT OOF P

Revision: 0% f EW

Config.: Wormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
IF	AV	% p ag.	Mng.	p T	p var	p T	p var	IF	p T	p var	Mm8	%P1	%Da8
p V UGS D-22	45.B00	N00.005	0.0	0	0	0.005	0.005	p V UGS D-22	-0.009	-0.224	4.7	4.7	
								LV UGS D-2N	0.000	0.N5B	2.5	0.0	
								JU-2/N	-0.0N7	-0.505	6.9	5.N	
								p V UGS D-2N	0.009	0.N85	4.2	5.4	
								p V UGS D-23	0.005	0.06N	N0	6.9	
p V UGS D-24	45.B00	N00.006	0.0	0	0	0.005	0.005	LV UGS D-22	0.000	0.N5B	2.5	0.0	
								9314M	-0.056	-0.769	N2.3	6.0	
								p V UGS D-29	0.052	0.6N8	N0.5	6.7	
p V UGS D-25	45.B00	N00.0N7	0.0	0	0	0.005	0.005	LV UGS D-24	0.000	0.N5B	2.5	0.0	
								p V UGS D-2B	-0.005	-0.N53	2.B	2.9	
p V UGS D-2B	45.B00	N00.0N9	0.0	0	0	0.005	0.005	LV UGS D-25	0.000	0.N5B	2.5	0.0	
								931NM	-0.052	-0.574	7.3	9.9	
								p V UGS D-N0	0.044	0.2N9	4.7	NB2	
								p V UGS D-25	0.005	0.N06	N9	4.3	
								LV UGS D-2B	0.000	0.N5B	2.5	0.0	
p V UGS D-26	45.B00	33.337	0.0	0	0	0.005	0.005	p V UGS D-27	-0.005	-0.N53	2.B	2.9	
								LV UGS D-26	0.000	0.N5B	2.5	0.0	
								p V UGS D-26	0.005	0.NN2	N3	4.7	
p V UGS D-27	45.B00	33.339	0.0	0	0	0.005	0.005	p V UGS D-29	-0.009	-0.26N	5.5	4.2	
								LV UGS D-27	0.000	0.N5B	2.5	0.0	
								p V UGS D-24	-0.052	-0.772	N2.3	B5	
								p V UGS D-27	0.009	0.22B	4.9	4.7	
								p V UGS D-44	0.023	0.439	6.7	7.4	
p V UGS D-23	45.B00	N00.00N	0.0	0	0	0.005	0.005	LV UGS D-29	0.000	0.N5B	2.5	0.0	
								p V UGS D-22	-0.005	-0.N53	2.B	2.9	
								LV UGS D-23	0.000	0.N5B	2.5	0.0	
								p V UGS D-42	-0.005	-0.N53	2.B	2.9	
								LV UGS D-4N	0.000	0.N5B	2.5	0.0	
p V UGS D-42	45.B00	33.399	0.0	0	0	0.005	0.005	p V UGS D-4N	0.005	0.043	0.7	N0.B	
								p V UGS D-44	-0.009	-0.N93	4.2	5.5	
								LV UGS D-42	0.000	0.N5B	2.5	0.0	
p V UGS D-44	45.B00	33.393	0.0	0	0	0.005	0.005	p V UGS D-29	-0.023	-0.656	N0.9	5.B	
								p V UGS D-42	0.009	0.N6N	2.7	B2	
								p V UGS D-45	0.0N7	0.446	B6	B0	
								LV UGS D-44	0.000	0.N5B	2.5	0.0	
								p V UGS D-44	-0.0N7	-0.490	6.5	5.5	
p V UGS D-45	45.B00	33.397	0.0	0	0	0.005	0.005	p V UGS D-46	0.009	0.20N	4.5	5.N	
								p V UGS D-43	0.005	0.023	0.B	N5.0	
								LV UGS D-45	0.000	0.N5B	2.5	0.0	

Project: WT OH T IWF

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: WT_OH

ETAP

N6.0.0C

Study Case: NPG NP1

Page: B

Date: N0-06-20N7

SW: T ESDT OOF P

Revision: 0% f EW

Config.: Wormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
IF	AV	% p ag.	Mng.	p T	p var	p T	p var	IF	p T	p var	Mm8	%P1	%Da8
p V UGS D-46	45.B00	33.394	0.0	0	0	0.005	0.005	p V UGS D-45	-0.009	-0.27N	5.B	4.N	
								p V UGS D-47	0.005	0.N22	2.0	4.5	
								LV UGS D-46	0.000	0.N5B	2.5	0.0	
p V UGS D-47	45.B00	33.392	0.0	0	0	0.005	0.005	p V UGS D-46	-0.005	-0.N53	2.B	2.9	
								LV UGS D-47	0.000	0.N5B	2.5	0.0	
p V UGS D-43	45.B00	33.395	0.0	0	0	0.005	0.005	p V UGS D-45	-0.005	-0.N53	2.B	2.9	
								LV UGS D-43	0.000	0.N5B	2.5	0.0	
p V UGS D-50	45.B00	N00.045	0.0	0	0	0.005	0.005	9315M	-0.052	-0.642	N0.6	6.6	
								p V UGS D-56	0.049	0.594	9.N	7.9	
								LV UGS D-50	0.000	0.N5B	2.5	0.0	
p V UGS D-5N	45.B00	N00.003	0.0	0	0	0.005	0.005	JU-5/N	-0.005	-0.N53	2.B	2.9	
								LV UGS D-5N	0.000	0.N5B	2.5	0.0	
p V UGS D-52	45.B00	N00.0N0	0.0	0	0	0.005	0.005	JU-5/N	-0.0N7	-0.4B6	6.0	5.7	
								p V UGS D-53	0.0N4	0.207	4.B	6.0	
								LV UGS D-52	0.000	0.N5B	2.5	0.0	
p V UGS D-54	45.B00	N00.003	0.0	0	0	0.005	0.005	JU-5/N	-0.005	-0.N53	2.B	2.9	
								LV UGS D-54	0.000	0.N5B	2.5	0.0	
p V UGS D-55	45.B00	N00.0N7	0.0	0	0	0.005	0.005	JU-5/N	0.02B	0.563	7.3	B4	
								p V UGS D-5B	-0.023	-0.6N9	N0.5	5.7	
								LV UGS D-55	0.000	0.N5B	2.5	0.0	
p V UGS D-5B	45.B00	N00.024	0.0	0	0	0.005	0.005	p V UGS D-55	0.023	0.536	9.4	B3	
								p V UGS D-56	-0.044	-0.65B	N0.9	B2	
								LV UGS D-5B	0.000	0.N5B	2.5	0.0	
p V UGS D-56	45.B00	N00.040	0.0	0	0	0.005	0.005	p V UGS D-50	-0.047	-0.60B	N0.N	6.2	
								p V UGS D-5B	0.044	0.5B6	7.6	7.4	
								LV UGS D-56	0.000	0.N5B	2.5	0.0	
p V UGS D-59	45.B00	N00.00N	0.0	0	0	0.005	0.005	p V UGS D-53	-0.005	-0.N53	2.B	2.9	
								LV UGS D-59	0.000	0.N5B	2.5	0.0	
p V UGS D-53	45.B00	N00.002	0.0	0	0	0.005	0.005	p V UGS D-52	-0.0N2	-0.476	6.4	4.4	
								p V UGS D-59	0.005	0.NN4	N3	4.7	
								p V UGS D-B0	0.005	0.NN5	N3	4.6	
								LV UGS D-53	0.000	0.N5B	2.5	0.0	
p V UGS D-B0	45.B00	N00.00N	0.0	0	0	0.005	0.005	p V UGS D-53	-0.005	-0.N53	2.B	2.9	
								LV UGS D-B0	0.000	0.N5B	2.5	0.0	
* POI	N49.000	N00.000	0.0	0.223	-0.026	0	0	93DNM	0.223	-0.026	N0	-33.5	
p PD-4	N4.900	N00.026	0.0	0	0	0	0	HV UGS p PD	0.000	0.000	0.0	0.0	
								& 93DNU					

* Indicates a voltage regulated bus (voltage controlled or swing type machine connected to it)

Indicates a bus with a load mismatch ok more than 0.Np VM

Project: TD OH D -Tm
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File Name: TDj OH

ETAP
NOV 2020

Study Case: NGLP6 NP.

Page: N
Date: 11/20/2020
Sheet: DESFD 00mP
Version: 01.k ET
Conc: T or al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
Bus	MVA	V (kV)	W (%)	D (%)	W (%)	D (%)	W (%)	Bus	D (%)	W (%)	P (W)	P (W)	Fa9	
34. Np	5BAMCG	NGM7/B	GM	C	G	C	C	8 V U6 S F271	GM7	GM5B	BM	NRW		
								34FNU	2GM7	2GM5B	BM	NRW		
34. 7p	5BAMCG	NGM7/B	GM	C	G	C	C	JU27/N	GM80	GM54G	0W	NNR		
								34FNU	2GM80	2GM54G	0W	NNR		
34. 5p	5BAMCG	NGM7/B	GM	C	G	C	C	8 V U6 S F275	GM80	GM5G	7W	55W		
								34FNU	2GM80	2GM5G	7W	55W		
34. Bp	5BAMCG	NGM7/B	GM	C	G	C	C	8 V U6 S F2B3	GM7	GM7N	NIW	2BW		
								34FNU	2GM7	GM7N	NIW	2BW		
34FNp	N53MCG	NGLMCG	GM	C	G	C	C	PO-	2GM5B	GMGI	GW	2NCGM		
								HV U6 S 8 PF	GM5B	2GMGI	GW	2NCGM		
34FNU	5BAMCG	NGM7/B	GM	C	G	C	C	34. Bp	GM7	GM7N	NIW	2BW		
								34. 5p	GM80	GM5G	7W	55W		
								34. 7p	GM80	GM54G	0W	NNR		
								34. Np	GM7	GM5B	BM	NRW		
								8 PF~5	2GMN1	GMNR	BM	2R7W		
								& HV U6 S 8 PF						
HV U6 S 8 PF	N53MCG	NGLMCG	GM	C	G	GM4	GM07	34FNp	2GM5B	GMGI	GW	2NCGM		
								34FNU	GMN1	2GMNR	NM	2R7W	1MCG	
								& 8 PF~5						
JU27/N	5BAMCG	NGM7/B	GM	C	G	C	C	8 V U6 S F2NR	GM74	GM3B	3W	0M		
								8 V U6 S F277	GMNR	GM70	1W	1W		
								34. 7p	2GM80	2GMNG	N5W	1W		
JU27N	5BAMCG	NGM7/B	GM	C	G	C	C	8 V U6 S F2BN	GMCB	GM7G	7M	5W		
								8 V U6 S F2B7	GMNR	GM11	1W	BM		
								8 V U6 S F2B5	GMCB	GM7N	7M	5W		
								8 V U6 S F2BB	2GM71	2GM40	NMG	BM		
LV U6 S F2GN	GM4G	44WR1	GM	GMCG	2GMN1	C	C	8 V U6 S F2GN	GMCG	2GMN1	N7NR	GM		
LV U6 S F2G7	GM4G	44WR0	GM	GMCG	2GMN1	C	C	8 V U6 S F2G7	GMCG	2GMN1	N7NR	GM		
LV U6 S F2G5	GM4G	44WR3	GM	GMCG	2GMN1	C	C	8 V U6 S F2G5	GMCG	2GMN1	N7NR	GM		
LV U6 S F2GB	GM4G	44W3N	GM	GMCG	2GMN1	C	C	8 V U6 S F2GB	GMCG	2GMN1	N7NR	GM		
LV U6 S F2G1	GM4G	44W31	GM	GMCG	2GMN1	C	C	8 V U6 S F2G1	GMCG	2GMN1	N7NR	GM		
LV U6 S F2GD	GM4G	44W3R	GM	GMCG	2GMN1	C	C	8 V U6 S F2GD	GMCG	2GMN1	N7NR	GM		
LV U6 S F2GR	GM4G	44W33	GM	GMCG	2GMN1	C	C	8 V U6 S F2GR	GMCG	2GMN1	N7NR	GM		
LV U6 S F2G3	GM4G	44W4G	GM	GMCG	2GMN1	C	C	8 V U6 S F2G3	GMCG	2GMN1	N7NR	GM		
LV U6 S F2G4	GM4G	44W40	GM	GMCG	2GMN1	C	C	8 V U6 S F2G4	GMCG	2GMN1	N7NR	GM		
LV U6 S F2NG	GM4G	44WGN	GM	GMCG	2GMN1	C	C	8 V U6 S F2NG	GMCG	2GMN1	N7NR	GM		

Project: TD OH D -Tm
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: TDj OH

ETAP
NOTED
Study Case: NGLP6 NP.

Page: 7
Name: NGCDZ/CNR
ST: DESFD OOmP
Version: G k ET
ConAgW Tor_al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
-m	MV	f 8 agW	p ngW	8 D	8 %ar	8 D	8 %ar	-m	8 D	8 %ar	p _9	f P.	f Fa9
LV U6 S F2N5	G04G	44W3R	G06	G0CG	20NB1	C	C	8 V U6 S F2N5	G0CG	20NB1	N7NR	G06	
LV U6 S F2NB	G04G	44W33	G06	G0CG	20NB1	C	C	8 V U6 S F2NB	G0CG	20NB1	N7NR	G06	
LV U6 S F2N1	G04G	44W47	G06	G0CG	20NB1	C	C	8 V U6 S F2N1	G0CG	20NB1	N7NR	G06	
LV U6 S F2N0	G04G	44W3R	G06	G0CG	20NB1	C	C	8 V U6 S F2N0	G0CG	20NB1	N7NR	G06	
LV U6 S F2NR	G04G	44W0N	G06	G0CG	20NB1	C	C	8 V U6 S F2NR	G0CG	20NB1	N7NR	G06	
LV U6 S F27G	G04G	44W43	G06	G0CG	20NB1	C	C	8 V U6 S F27G	G0CG	20NB1	N7NR	G06	
LV U6 S F27N	G04G	44W0G	G06	G0CG	20NB1	C	C	8 V U6 S F27N	G0CG	20NB1	N7NR	G06	
LV U6 S F277	G04G	44W0N	G06	G0CG	20NB1	C	C	8 V U6 S F277	G0CG	20NB1	N7NR	G06	
LV U6 S F275	G04G	44W0CB	G06	G0CG	20NB1	C	C	8 V U6 S F275	G0CG	20NB1	N7NR	G06	
LV U6 S F27B	G04G	44W0N1	G06	G0CG	20NB1	C	C	8 V U6 S F27B	G0CG	20NB1	N7NR	G06	
LV U6 S F271	G04G	44W0N0	G06	G0CG	20NB1	C	C	8 V U6 S F271	G0CG	20NB1	N7NR	G06	
LV U6 S F270	G04G	44W4B	G06	G0CG	20NB1	C	C	8 V U6 S F270	G0CG	20NB1	N7NR	G06	
LV U6 S F27R	G04G	44W41	G06	G0CG	20NB1	C	C	8 V U6 S F27R	G0CG	20NB1	N7NR	G06	
LV U6 S F273	G04G	44W43	G06	G0CG	20NB1	C	C	8 V U6 S F273	G0CG	20NB1	N7NR	G06	
LV U6 S F274	G04G	44W44	G06	G0CG	20NB1	C	C	8 V U6 S F274	G0CG	20NB1	N7NR	G06	
LV U6 S F25N	G04G	44W35	G06	G0CG	20NB1	C	C	8 V U6 S F25N	G0CG	20NB1	N7NR	G06	
LV U6 S F257	G04G	44W30	G06	G0CG	20NB1	C	C	8 V U6 S F257	G0CG	20NB1	N7NR	G06	
LV U6 S F255	G04G	44W3R	G06	G0CG	20NB1	C	C	8 V U6 S F255	G0CG	20NB1	N7NR	G06	
LV U6 S F25B	G04G	44W3B	G06	G0CG	20NB1	C	C	8 V U6 S F25B	G0CG	20NB1	N7NR	G06	
LV U6 S F250	G04G	44W3G	G06	G0CG	20NB1	C	C	8 V U6 S F250	G0CG	20NB1	N7NR	G06	
LV U6 S F25R	G04G	44W3G	G06	G0CG	20NB1	C	C	8 V U6 S F25R	G0CG	20NB1	N7NR	G06	
LV U6 S F254	G04G	44W37	G06	G0CG	20NB1	C	C	8 V U6 S F254	G0CG	20NB1	N7NR	G06	
LV U6 S F2BG	G04G	44W57	G06	G0CG	20NB1	C	C	8 V U6 S F2BG	G0CG	20NB1	N7NR	G06	
LV U6 S F2BN	G04G	44W0CR	G06	G0CG	20NB1	C	C	8 V U6 S F2BN	G0CG	20NB1	N7NR	G06	
LV U6 S F2B7	G04G	44W0CB	G06	G0CG	20NB1	C	C	8 V U6 S F2B7	G0CG	20NB1	N7NR	G06	
LV U6 S F2B5	G04G	44W0CR	G06	G0CG	20NB1	C	C	8 V U6 S F2B5	G0CG	20NB1	N7NR	G06	
LV U6 S F2BB	G04G	44W0N1	G06	G0CG	20NB1	C	C	8 V U6 S F2BB	G0CG	20NB1	N7NR	G06	
LV U6 S F2B1	G04G	44W07G	G06	G0CG	20NB1	C	C	8 V U6 S F2B1	G0CG	20NB1	N7NR	G06	
LV U6 S F2B0	G04G	44W07R	G06	G0CG	20NB1	C	C	8 V U6 S F2B0	G0CG	20NB1	N7NR	G06	
LV U6 S F2B3	G04G	44W44	G06	G0CG	20NB1	C	C	8 V U6 S F2B3	G0CG	20NB1	N7NR	G06	
LV U6 S F2B4	G04G	44W0CG	G06	G0CG	20NB1	C	C	8 V U6 S F2B4	G0CG	20NB1	N7NR	G06	
LV U6 S F21G	G04G	44W44	G06	G0CG	20NB1	C	C	8 V U6 S F21G	G0CG	20NB1	N7NR	G06	
8 V U6 S F2CN	5B0CG	44W0RR	G06	C	G	G00CB	G00CB	8 V U6 S F2C7	2G00CB	20NB4	7W	7W	
								LV U6 S F2CN	G00CG	G0NB1	7W	G06	
								8 V U6 S F2CN	G00CB	G0NC5	NR	B06	
8 V U6 S F2C7	5B0CG	44W0R4	G06	C	G	G00CB	G00CB	8 V U6 S F2C5	2G00CB	20W17	BW	5W	
								LV U6 S F2C7	G00CG	G0NB1	7W	G06	
								8 V U6 S F2C7	G00CB	G0W07	5W	5W	
8 V U6 S F2C5	5B0CG	44W3N	G06	C	G	G00CB	G00CB	8 V U6 S F2CB	2G00N7	20X0N	0W	5W	

Project: TD OH D -Tm
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Silenace: TDj OH

ETAP
NOV06

Study Case: NGLP6 NP.

Page: 5
Date: 11/27/2017
ST: DESFD OOmP
Version: Gk ET
ConAgW Tor_al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
-m	M	f 8 agW	p ngW	8 D	8 %ar	8 D	8 %ar	-m	8 D	8 %ar	p _9	f P.	f Fa9
8 V U6 S F2CB	5BAMCG	44W35	G6	C	G	G6CB	G6CB	LV U6 S F2C5	G6CG	G6B1	7W	G6	
								8 V U6 S F2C5	G6N7	G6N1	1W	B6	
								8 V U6 S F2C1	2G6NR	2G6B0	RW	5W	
8 V U6 S F2C1	5BAMCG	44W3R	G6	C	G	G6CB	G6CB	LV U6 S F2CB	G6CG	G6B1	7W	G6	
								8 V U6 S F2CB	G6NR	G6N7	0W	B6	
								8 V U6 S F2C3	2G67N	2G6M0	4W	5W	
8 V U6 S F2C0	5BAMCG	44W4G	G6	C	G	G6CB	G6CB	LV U6 S F2C1	G6CG	G6B1	7W	G6	
								8 V U6 S F2CR	2G6CB	2G6B4	7W	7W	
								LV U6 S F2C0	G6CG	G6B1	7W	G6	
8 V U6 S F2CR	5BAMCG	44W4N	G6	C	G	G6CB	G6CB	8 V U6 S F2C0	G6CB	G67G	7W	5W	
								8 V U6 S F2N0	G6CB	G6B3	NW	BW	
								8 V U6 S F2N1	2G6N7	2G615	1W	5W	
8 V U6 S F2C3	5BAMCG	44W47	G6	C	G	G6CB	G6CB	LV U6 S F2CR	G6CG	G6B1	7W	G6	
								8 V U6 S F2C1	G67N	G6B0	RW	BW	
								8 V U6 S F2C4	2G671	2G6N5	NGW	BW	
8 V U6 S F2C4	5BAMCG	44W44	G6	C	G	G6CB	G6CB	LV U6 S F2C3	G6CG	G6B1	7W	G6	
								8 V U6 S F2C3	G671	G645	3W	1W	
								8 V U6 S F2NG	2G674	2G6B7	NGW	BW	
8 V U6 S F2NG	5BAMCG	NCG6C5	G6	C	G	G6CB	G6CB	LV U6 S F2C4	G6CG	G6B1	7W	G6	
								8 V U6 S F2C4	G674	G61N	4W	1W	
								8 V U6 S F271	2G6B5	2G6CG	NNW	BW	
8 V U6 S F2N5	5BAMCG	44W34	G6	C	G	G6CB	G6CB	LV U6 S F2NG	G6CG	G6B1	7W	G6	
								8 V U6 S F2NB	2G6CB	2G6B4	7W	7W	
								LV U6 S F2N5	G6CG	G6B1	7W	G6	
8 V U6 S F2NB	5BAMCG	44W4G	G6	C	G	G6CB	G6CB	8 V U6 S F2N5	G6CB	G6NR	7W	5W	
								8 V U6 S F2N1	2G6CB	2G600	BW	5W	
								LV U6 S F2NB	G6CG	G6B1	7W	G6	
8 V U6 S F2N1	5BAMCG	44W4B	G6	C	G	G6CB	G6CB	8 V U6 S F2CR	G6N7	G63G	BW	BW	
								8 V U6 S F2NB	G6CB	G6B3	5W	BW	
								8 V U6 S F2NR	2G671	2G6N0	NGW	BW	
8 V U6 S F2N0	5BAMCG	44W34	G6	C	G	G6CB	G6CB	LV U6 S F2N1	G6CG	G6B1	7W	G6	
								8 V U6 S F2CR	2G6CB	2G6B4	7W	7W	
								LV U6 S F2N0	G6CG	G6B1	7W	G6	
8 V U6 S F2NR	5BAMCG	NCG6C5	G6	C	G	G6CB	G6CB	JU27/N	2G674	2G644	NGW	BW	
								8 V U6 S F2N1	G671	G61G	RW	1W	
								LV U6 S F2NR	G6CG	G6B1	7W	G6	
8 V U6 S F27G	5BAMCG	NCG6CG	G6	C	G	G6CB	G6CB	8 V U6 S F27N	2G6CB	2G6B4	7W	7W	
								LV U6 S F27G	G6CG	G6B1	7W	G6	
								8 V U6 S F27G	G6CB	G6B3	NW	1W	

Project: TD OH D -Tm
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File Name: TDj OH

ETAP
NOV 2020
Study Case: NGLP6 NP.

Page: B
Date: 11/20/2020
Sheet: DESFD OOmP
Revision: 01 of 01
Conc: Toral

Bus		Voltage		Generation		Load		Load Flow				XFMR	
Bus	MVA	800V	400V	800V	400V	800V	400V	Bus	800V	400V	900V	Pf	Loss
8 V U6 S F277	50000	20000	10000	C	G	20000	10000	8 V U6 S F277	20000	10000	5000	5000	
								LV U6 S F27N	20000	10000	7000	10000	
								JU27/N	20000	10000	0000	0000	
								8 V U6 S F27N	20000	10000	5000	0000	
8 V U6 S F275	50000	20000	10000	C	G	20000	10000	8 V U6 S F274	20000	10000	1000	0000	
								LV U6 S F277	20000	10000	7000	10000	
								34. 5p	20000	10000	1000	0000	
								8 V U6 S F273	20000	10000	1000	0000	
8 V U6 S F27B	50000	20000	10000	C	G	20000	10000	LV U6 S F275	20000	10000	7000	10000	
								8 V U6 S F271	20000	10000	7000	7000	
								LV U6 S F27B	20000	10000	7000	10000	
								34. Np	20000	10000	1000	3000	
8 V U6 S F270	50000	20000	10000	C	G	20000	10000	8 V U6 S F270	20000	10000	5000	10000	
								8 V U6 S F27B	20000	10000	1000	5000	
								LV U6 S F271	20000	10000	7000	10000	
								8 V U6 S F27R	20000	10000	7000	7000	
8 V U6 S F27R	50000	20000	10000	C	G	20000	10000	LV U6 S F270	20000	10000	7000	10000	
								8 V U6 S F270	20000	10000	1000	5000	
								8 V U6 S F273	20000	10000	1000	5000	
								LV U6 S F27R	20000	10000	7000	10000	
8 V U6 S F273	50000	20000	10000	C	G	20000	10000	8 V U6 S F275	20000	10000	1000	1000	
								8 V U6 S F27R	20000	10000	5000	5000	
								8 V U6 S F255	20000	10000	0000	1000	
								LV U6 S F273	20000	10000	7000	10000	
8 V U6 S F274	50000	20000	10000	C	G	20000	10000	8 V U6 S F277	20000	10000	7000	7000	
								LV U6 S F274	20000	10000	7000	10000	
								8 V U6 S F257	20000	10000	7000	7000	
								LV U6 S F25N	20000	10000	7000	10000	
8 V U6 S F257	50000	20000	10000	C	G	20000	10000	8 V U6 S F25N	20000	10000	0000	1000	
								8 V U6 S F255	20000	10000	5000	0000	
								LV U6 S F257	20000	10000	7000	10000	
								8 V U6 S F273	20000	10000	1000	0000	
8 V U6 S F255	50000	20000	10000	C	G	20000	10000	8 V U6 S F257	20000	10000	7000	1000	
								8 V U6 S F25B	20000	10000	1000	1000	
								LV U6 S F255	20000	10000	7000	10000	
								8 V U6 S F255	20000	10000	0000	0000	
8 V U6 S F25B	50000	20000	10000	C	G	20000	10000	8 V U6 S F250	20000	10000	5000	0000	
								8 V U6 S F254	20000	10000	0000	1000	
								LV U6 S F25B	20000	10000	7000	10000	

Project: TD OH D-Tm
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File Name: TDj OH

ETAP
NOVEMBER

Study Case: NGIP6 NP.

Page: 1
Name: NGIP6 NP
ST: DESFD OOmP
Version: G k ET
ConAgW Tor_al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
Bus	MVA	800V	400V	800V	400V	800V	400V	Bus	800V	400V	900V	1000V	1500V
8 V U6 S F250	5BAMCG	44W35	GM	C	G	GMCB	GMCB	8 V U6 S F25B	2GMCB	2GMN	BAW	5W	
								8 V U6 S F25R	GMCB	GM77	7W	5W	
								LV U6 S F250	GMCG	GM81	7W	GM	
8 V U6 S F25R	5BAMCG	44W37	GM	C	G	GMCB	GMCB	8 V U6 S F250	2GMCB	2GM84	7W	7W	
								LV U6 S F25R	GMCG	GM81	7W	GM	
8 V U6 S F254	5BAMCG	44W3B	GM	C	G	GMCB	GMCB	8 V U6 S F25B	2GMCB	2GM84	7W	7W	
								LV U6 S F254	GMCG	GM81	7W	GM	
8 V U6 S F2BG	5BAMCG	NGOM5B	GM	C	G	GMCB	GMCB	34. Bp	2GM87	2GM57	NGW	0W	
								8 V U6 S F2B0	GM53	GM85	3W	RW	
								LV U6 S F2BG	GMCG	GM81	7W	GM	
8 V U6 S F2BN	5BAMCG	NGOMG4	GM	C	G	GMCB	GMCB	JU2BN	2GMCB	2GM84	7W	7W	
								LV U6 S F2BN	GMCG	GM81	7W	GM	
8 V U6 S F2B7	5BAMCG	NGOMNG	GM	C	G	GMCB	GMCB	JU2BN	2GMNR	2GM10	0W	BR	
								8 V U6 S F2B4	GMN5	GMCR	5W	0W	
								LV U6 S F2B7	GMCG	GM81	7W	GM	
8 V U6 S F2B5	5BAMCG	NGOMG4	GM	C	G	GMCB	GMCB	JU2BN	2GMCB	2GM84	7W	7W	
								LV U6 S F2B5	GMCG	GM81	7W	GM	
8 V U6 S F2BB	5BAMCG	NGOMNR	GM	C	G	GMCB	GMCB	JU2BN	GM71	GM04	RW	1W	
								8 V U6 S F2B1	2GM74	2GMN3	NGW	BR	
								LV U6 S F2BB	GMCG	GM81	7W	GM	
8 V U6 S F2B1	5BAMCG	NGOM75	GM	C	G	GMCB	GMCB	8 V U6 S F2BB	GM74	GM40	3W	1W	
								8 V U6 S F2B0	2GM55	2GM81	NGW	1W	
								LV U6 S F2B1	GMCG	GM81	7W	GM	
8 V U6 S F2B0	5BAMCG	NGOM5G	GM	C	G	GMCB	GMCB	8 V U6 S F2BG	2GM5R	2GMG1	NGW	0W	
								8 V U6 S F2B1	GM55	GM10	RW	RW	
								LV U6 S F2B0	GMCG	GM81	7W	GM	
8 V U6 S F2B3	5BAMCG	NGOMCN	GM	C	G	GMCB	GMCB	8 V U6 S F2B4	2GMCB	2GM84	7W	7W	
								LV U6 S F2B3	GMCG	GM81	7W	GM	
8 V U6 S F2B4	5BAMCG	NGOMG7	GM	C	G	GMCB	GMCB	8 V U6 S F2B7	2GMN7	2GMR0	0W	5W	
								8 V U6 S F2B3	GMCB	GMN5	NW	5W	
								8 V U6 S F21G	GMCB	GMNB	NW	5W	
								LV U6 S F2B4	GMCG	GM81	7W	GM	
8 V U6 S F21G	5BAMCG	NGOMCN	GM	C	G	GMCB	GMCB	8 V U6 S F2B4	2GMCB	2GM84	7W	7W	
								LV U6 S F21G	GMCG	GM81	7W	GM	
* PO-	N53MCG	NGIMCG	GM	GM5B	2GMNN	C	C	34FNp	GM5B	2GMNN	GW	244W	
8 PF~5	N5MCG	NGOM70	GM	C	G	C	C	HV U6 S 8 PF	GMCG	GMCG	GM	GM	
								& 34FNU					

* -indicates a %oltage regulated bus (%oltage controlled or swing ty9e _ achine connected to it)

-indicates a bus with a load _ is _ atch oA _ ore than GM8 Vp

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UNIT PY

Page: F
Date: F0-02-70FR
SU: WESI WOODP
version: 7G k EU
Config.: Uormal

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
ND	MV	f 8 ag.	p ng.	8 W	8 %ar	8 W	8 %ar	ND	8 W	8 %ar	p m9	f PY	f l a9	
34YFp	52.G00	F00.7G0	7.F	0	0	0	0	8 V B1 S 1 -7G	-6.F32	-F.F55	F02.4	43.2		
								34I FB	6.F32	F.F55	F02.4	43.2		
34Y7p	52.G00	F00.7G0	7.F	0	0	0	0	JB-7/F	-6.305	-F.FFG	FFGF	43.R		
								34I FB	6.305	F.FFG	FFGF	43.R		
34Y5p	52.G00	F00.7G0	7.F	0	0	0	0	8 V B1 S 1 -75	-6.300	-F.5R0	FFG3	43.0		
								34I FB	6.300	F.5R0	FFG3	43.0		
34Y2p	52.G00	F00.7G0	7.F	0	0	0	0	8 V B1 S 1 -20	-6.F63	-7.7R3	F04.3	45.3		
								34I FB	6.F63	7.7R3	F04.3	45.3		
34I Fp	F53.000	F00.007	0.0	0	0	0	0	PON	7G3R6	2.R5G	FF0.F	43.2		
								HV B1 S 8 PI	-7G3R6	-2.R5G	FF0.F	43.2		
34I FB	52.G00	F00.7G0	7.F	0	0	0	0	34Y2p	-6.F63	-7.7R3	F04.3	45.3		
								34Y5p	-6.300	-F.5R0	FFG3	43.0		
								34Y7p	-6.305	-F.FFG	FFGF	43.R		
								34YFp	-6.F32	-F.F55	F02.4	43.2		
								8 PI ~5	7G4C2	G34R	222.5	4RG		
HV B1 S 8 PI	F53.000	F00.007	0.0	0	0	0.0C2	0.F2R	& HV B1 S 8 PI						
								34I Fp	7G3R6	2.R5G	FF0.F	43.2		
								34I FB	-7G474	-2.337	FF0.2	43.5	0.67G	
JB-7/F	52.G00	F00.566	7.7	0	0	0	0	& 8 PI ~5						
								8 V B1 S 1 -FR	-2.555	-0.2R3	R7.R	44.2		
								8 V B1 S 1 -77	-7.2RR	-0.77G	2F.G	44.6		
JB-2/F	52.G00	F00.337	7.G	0	0	0	0	34Y7p	6.304	0.R05	FF2.F	44.G		
								8 V B1 S 1 -2F	-0.670	-0.0F3	F0.5	F00.0		
								8 V B1 S 1 -27	-7.2RR	-0.F43	2F.7	44.R		
								8 V B1 S 1 -25	-0.670	-0.0FR	F0.5	F00.0		
LV B1 S 1 -0F	0.640	F00.323	5.F	0.67G	0.000	0	0	8 V B1 S 1 -22	5.RFR	0.752	6F.3	44.3		
								8 V B1 S 1 -0F	0.67G	0.000	GF3.G	F00.0		
								8 V B1 S 1 -07	0.67G	0.000	GF3.6	F00.0		
								8 V B1 S 1 -05	0.67G	0.000	GF3.4	F00.0		
								8 V B1 S 1 -02	0.67G	0.000	GF4.0	F00.0		
								8 V B1 S 1 -0G	0.67G	0.000	GF4.5	F00.0		
								8 V B1 S 1 -06	0.67G	0.000	GF4.2	F00.0		
								8 V B1 S 1 -0R	0.67G	0.000	GF4.2	F00.0		
								8 V B1 S 1 -03	0.67G	0.000	GF4.G	F00.0		
								8 V B1 S 1 -04	0.67G	0.000	GF4.R	F00.0		
LV B1 S 1 -F0	0.640	F00.6R6	5.0	0.67G	0.000	0	0	8 V B1 S 1 -F0	0.67G	0.000	GF4.4	F00.0		

Project: UW OH WNUD

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: UW_OH

ETAP

F6.0.0C

Study Case: 1 UNIT PY

Page: 7

Date: F0-02-70FR

SU: WESI WOODP

Version: 7G k EU

Config.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
NO	MVA	From	to	P (MW)	Q (MVar)	P (MW)	Q (MVar)	From	P (MW)	Q (MVar)	PF	From	to
LV B1 S1 -F5	0.640	F00.R7R	5.0	0.67G	0.000	0	0	8 V B1 S1 -F5	0.67G	0.000	GF4.F	F00.0	
LV B1 S1 -F2	0.640	F00.R03	5.0	0.67G	0.000	0	0	8 V B1 S1 -F2	0.67G	0.000	GF4.7	F00.0	
LV B1 S1 -FG	0.640	F00.6F5	5.0	0.67G	0.000	0	0	8 V B1 S1 -FG	0.67G	0.000	GF4.R	F00.0	
LV B1 S1 -F6	0.640	F00.R07	5.0	0.67G	0.000	0	0	8 V B1 S1 -F6	0.67G	0.000	GF4.7	F00.0	
LV B1 S1 -FR	0.640	F00.C64	5.0	0.67G	0.000	0	0	8 V B1 S1 -FR	0.67G	0.000	G70.F	F00.0	
LV B1 S1 -70	0.640	F00.6C6	5.0	0.67G	0.000	0	0	8 V B1 S1 -70	0.67G	0.000	GF4.G	F00.0	
LV B1 S1 -7F	0.640	F00.603	5.0	0.67G	0.000	0	0	8 V B1 S1 -7F	0.67G	0.000	GF4.R	F00.0	
LV B1 S1 -77	0.640	F00.CR5	5.0	0.67G	0.000	0	0	8 V B1 S1 -77	0.67G	0.000	GF4.4	F00.0	
LV B1 S1 -75	0.640	F00.C66	5.0	0.67G	0.000	0	0	8 V B1 S1 -75	0.67G	0.000	GF4.4	F00.0	
LV B1 S1 -72	0.640	F00.2CR	7.4	0.67G	0.000	0	0	8 V B1 S1 -72	0.67G	0.000	G70.G	F00.0	
LV B1 S1 -7G	0.640	F00.223	7.4	0.67G	0.000	0	0	8 V B1 S1 -7G	0.67G	0.000	G70.6	F00.0	
LV B1 S1 -76	0.640	F00.664	5.0	0.67G	0.000	0	0	8 V B1 S1 -76	0.67G	0.000	GF4.2	F00.0	
LV B1 S1 -7R	0.640	F00.626	5.0	0.67G	0.000	0	0	8 V B1 S1 -7R	0.67G	0.000	GF4.G	F00.0	
LV B1 S1 -73	0.640	F00.602	5.0	0.67G	0.000	0	0	8 V B1 S1 -73	0.67G	0.000	GF4.3	F00.0	
LV B1 S1 -74	0.640	F00.67G	5.0	0.67G	0.000	0	0	8 V B1 S1 -74	0.67G	0.000	GF4.6	F00.0	
LV B1 S1 -5F	0.640	F00.R32	5.F	0.67G	0.000	0	0	8 V B1 S1 -5F	0.67G	0.000	GF3.3	F00.0	
LV B1 S1 -57	0.640	F00.RF3	5.F	0.67G	0.000	0	0	8 V B1 S1 -57	0.67G	0.000	GF4.7	F00.0	
LV B1 S1 -55	0.640	F00.63G	5.F	0.67G	0.000	0	0	8 V B1 S1 -55	0.67G	0.000	GF4.5	F00.0	
LV B1 S1 -52	0.640	F00.R7G	5.F	0.67G	0.000	0	0	8 V B1 S1 -52	0.67G	0.000	GF4.F	F00.0	
LV B1 S1 -56	0.640	F00.303	5.F	0.67G	0.000	0	0	8 V B1 S1 -56	0.67G	0.000	GF3.R	F00.0	
LV B1 S1 -5R	0.640	F00.372	5.F	0.67G	0.000	0	0	8 V B1 S1 -5R	0.67G	0.000	GF3.6	F00.0	
LV B1 S1 -54	0.640	F00.R4R	5.F	0.67G	0.000	0	0	8 V B1 S1 -54	0.67G	0.000	GF3.3	F00.0	
LV B1 S1 -20	0.640	F00.35G	5.F	0.67G	0.000	0	0	8 V B1 S1 -20	0.67G	0.000	GF3.6	F00.0	
LV B1 S1 -2F	0.640	F0F.052	5.7	0.67G	0.000	0	0	8 V B1 S1 -2F	0.67G	0.000	GF.RG	F00.0	
LV B1 S1 -27	0.640	F0F.0FR	5.7	0.67G	0.000	0	0	8 V B1 S1 -27	0.67G	0.000	GF.R6	F00.0	
LV B1 S1 -25	0.640	F0F.055	5.7	0.67G	0.000	0	0	8 V B1 S1 -25	0.67G	0.000	GF.RG	F00.0	
LV B1 S1 -22	0.640	F00.460	5.7	0.67G	0.000	0	0	8 V B1 S1 -22	0.67G	0.000	GF.R4	F00.0	
LV B1 S1 -2G	0.640	F00.470	5.7	0.67G	0.000	0	0	8 V B1 S1 -2G	0.67G	0.000	GF3.F	F00.0	
LV B1 S1 -26	0.640	F00.3RF	5.7	0.67G	0.000	0	0	8 V B1 S1 -26	0.67G	0.000	GF3.2	F00.0	
LV B1 S1 -23	0.640	F0F.FCG	5.5	0.67G	0.000	0	0	8 V B1 S1 -23	0.67G	0.000	GF6.4	F00.0	
LV B1 S1 -24	0.640	F0F.F55	5.5	0.67G	0.000	0	0	8 V B1 S1 -24	0.67G	0.000	GF.R0	F00.0	
LV B1 S1 -Ø	0.640	F0F.FC2	5.5	0.67G	0.000	0	0	8 V B1 S1 -Ø	0.67G	0.000	GF6.4	F00.0	
8 V B1 S1 -0F	52.000	F00.RF2	7.5	0	0	0.002	0.002	8 V B1 S1 -07	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S1 -0F	-0.672	0.003	F0.2	F00.0	
								8 V B1 S1 -0F	-0.670	-0.056	F0.5	44.3	
8 V B1 S1 -07	52.000	F00.636	7.5	0	0	0.002	0.002	8 V B1 S1 -05	F.720	0.072	70.6	F00.0	
								LV B1 S1 -07	-0.672	0.003	F0.2	F00.0	
								8 V B1 S1 -05	-F.754	-0.062	70.6	44.4	
8 V B1 S1 -05	52.000	F00.654	7.5	0	0	0.002	0.002	8 V B1 S1 -02	F.3G4	0.0G7	50.4	F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UNIT PY

Page: 5
Date: F0-02-70FR
SU: WESI WOODP
version: 7G k EU
ConAg.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	MV	f 8 ag.	p ng.	8 W	8 %ar	8 W	8 %ar	ND	8 W	8 %ar	p m9	f PY	f l a9
8 V B1 S I -02	52.G00	F00.603	7.5	0	0	0.002	0.002	LV B1 S I -05	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -05	-F.3GB	-0.044	5F.0	44.4	
								8 V B1 S I -0G	7.2R3	0.03R	2F.7	44.4	
8 V B1 S I -0G	52.G00	F00.G60	7.5	0	0	0.002	0.002	LV B1 S I -02	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -02	-7.2RR	-0.F20	2F.5	44.3	
								8 V B1 S I -03	5.04R	0.F73	GF.6	44.4	
8 V B1 S I -06	52.G00	F00.C26	7.5	0	0	0.002	0.002	LV B1 S I -0G	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -0R	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -06	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -0R	52.G00	F00.G74	7.5	0	0	0.002	0.002	8 V B1 S I -06	-0.670	-0.0F3	F0.5	F00.0	
								8 V B1 S I -F6	-0.670	-0.0C2	F0.2	44.6	
								8 V B1 S I -FG	F.3G4	0.060	5F.0	44.4	
8 V B1 S I -03	52.G00	F00.G72	7.5	0	0	0.002	0.002	LV B1 S I -0R	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -0G	-5.046	-0.77G	CF.R	44.R	
								8 V B1 S I -04	5.RF6	0.7F2	67.0	44.3	
8 V B1 S I -04	52.G00	F00.2RF	7.5	0	0	0.002	0.002	LV B1 S I -03	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -03	-5.RF2	-0.555	67.F	44.6	
								8 V B1 S I -F0	2.552	0.57F	R7.2	44.R	
8 V B1 S I -F0	52.G00	F00.22F	7.5	0	0	0.002	0.002	LV B1 S I -04	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -04	-2.555	-0.2F7	R7.G	44.6	
								8 V B1 S I -7G	2.4G7	0.200	37.3	44.R	
8 V B1 S I -F5	52.G00	F00.G45	7.5	0	0	0.002	0.002	LV B1 S I -F0	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -F2	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -F5	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -F2	52.G00	F00.GR2	7.5	0	0	0.002	0.002	8 V B1 S I -F5	-0.670	-0.07F	F0.5	44.4	
								8 V B1 S I -FG	F.720	0.004	70.6	F00.0	
								LV B1 S I -F2	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -FG	52.G00	F00.2R4	7.5	0	0	0.002	0.002	8 V B1 S I -0R	-F.3GB	-0.F55	5F.0	44.R	
								8 V B1 S I -F2	-F.753	-0.034	70.R	44.R	
								8 V B1 S I -FR	5.RFR	0.7F0	67.0	44.3	
8 V B1 S I -F6	52.G00	F00.C6R	7.5	0	0	0.002	0.002	LV B1 S I -FG	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -0R	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -F6	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -FR	52.G00	F00.202	7.7	0	0	0.002	0.002	JB-7/F	2.552	0.562	R7.G	44.6	
								8 V B1 S I -FG	-5.RF2	-0.5R6	67.7	44.G	
								LV B1 S I -FR	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -70	52.G00	F00.GF4	7.7	0	0	0.002	0.002	8 V B1 S I -7F	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -70	-0.672	0.003	F0.2	F00.0	
								8 V B1 S I -70	-0.670	-0.062	F0.2	44.G	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UNIT PY

Page: 2
Date: F0-02-70FR
SU: WESI WOODP
version: 7G k EU
ConAg.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
NO	MV	fflag	png	8W	8%	8W	8%	NO	8W	8%	pm9	fPY	fla9
8VB1S1-77	52.G00	F00.253	7.7	0	0	0.002	0.002	8VB1S1-77	F.720	0.0G7	70.R	44.4	
								LVB1S1-7F	-0.672	0.003	F0.2	F00.0	
								JB-7/F	7.2R4	0.F2R	2F.2	44.3	
								8VB1S1-7F	-F.754	-0.037	70.R	44.3	
								8VB1S1-74	-0.670	-0.0RR	F0.2	44.7	
8VB1S1-75	52.G00	F00.257	7.5	0	0	0.002	0.002	LVB1S1-77	-0.672	0.003	F0.2	F00.0	
								34Y5p	6.3F0	0.R2G	FF2.F	44.2	
								8VB1S1-73	-6.F40	-0.RCR	F05.4	44.5	
8VB1S1-72	52.G00	F00.577	7.7	0	0	0.002	0.002	LVB1S1-75	-0.672	0.003	F0.2	F00.0	
								8VB1S1-7G	0.670	-0.0F7	F0.5	-F00.0	
								LVB1S1-72	-0.672	0.003	F0.2	F00.0	
8VB1S1-7G	52.G00	F00.5F5	7.7	0	0	0.002	0.002	34YFp	6.F3R	0.343	F02.5	44.0	
								8VB1S1-F0	-2.42R	-0.3R3	35.3	43.G	
								8VB1S1-72	-0.670	-0.05F	F0.2	44.4	
8VB1S1-76	52.G00	F00.G52	7.5	0	0	0.002	0.002	LVB1S1-7G	-0.672	0.003	F0.2	F00.0	
								8VB1S1-7R	0.670	-0.0F7	F0.5	-F00.0	
								LVB1S1-76	-0.672	0.003	F0.2	F00.0	
8VB1S1-7R	52.G00	F00.GF7	7.5	0	0	0.002	0.002	8VB1S1-76	-0.670	-0.076	F0.5	44.4	
								8VB1S1-73	F.720	0.0F2	70.6	F00.0	
								LVB1S1-7R	-0.672	0.003	F0.2	F00.0	
8VB1S1-73	52.G00	F00.264	7.5	0	0	0.002	0.002	8VB1S1-75	6.F47	0.606	F05.6	44.G	
								8VB1S1-7R	-F.754	-0.0GF	70.R	44.4	
								8VB1S1-55	-2.555	-0.G6R	R7.3	44.7	
8VB1S1-74	52.G00	F00.24F	7.7	0	0	0.002	0.002	LVB1S1-73	-0.672	0.003	F0.2	F00.0	
								8VB1S1-77	0.670	-0.0F7	F0.5	-F00.0	
								LVB1S1-74	-0.672	0.003	F0.2	F00.0	
8VB1S1-5F	52.G00	F00.624	7.5	0	0	0.002	0.002	8VB1S1-57	0.670	-0.0F7	F0.5	-F00.0	
								LVB1S1-5F	-0.672	0.003	F0.2	F00.0	
								8VB1S1-57	-0.6F4	-0.044	F0.2	43.R	
8VB1S1-57	52.G00	F00.GB5	7.5	0	0	0.002	0.002	8VB1S1-55	F.754	0.033	70.R	44.3	
								LVB1S1-57	-0.672	0.003	F0.2	F00.0	
								8VB1S1-73	2.556	0.570	R7.2	44.R	
8VB1S1-55	52.G00	F00.GGD	7.5	0	0	0.002	0.002	8VB1S1-57	-F.754	-0.FFG	70.R	44.6	
								8VB1S1-52	-7.2RR	-0.7F6	2F.2	44.6	
								LVB1S1-55	-0.672	0.003	F0.2	F00.0	
8VB1S1-52	52.G00	F00.G40	7.5	0	0	0.002	0.002	8VB1S1-55	7.2R3	0.FR7	2F.5	44.3	
								8VB1S1-56	-F.754	-0.0RG	70.6	44.3	
								8VB1S1-54	-0.6F4	-0.F04	F0.G	43.G	
								LVB1S1-52	-0.672	0.003	F0.2	F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C
Study Case: 1 UN T PY

Page: G
Date: F0-02-70FR
SU: WESI WOODP
version: 7G k EU
ConAg.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	M	f 8 ag.	p ng.	8 W	8 %ar	8 W	8 %ar	ND	8 W	8 %ar	p m9	f PY	f l a9
8 V B1 S I -56	52.G00	F00.6R2	7.2	0	0	0.002	0.002	8 V B1 S I -52	F.720	0.002	70.6	F00.0	
								8 V B1 S I -5R	-0.670	-0.0F6	F0.5	F00.0	
								LV B1 S I -56	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -5R	52.G00	F00.640	7.2	0	0	0.002	0.002	8 V B1 S I -56	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -5R	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -54	52.G00	F00.667	7.2	0	0	0.002	0.002	8 V B1 S I -52	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -54	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -20	52.G00	F00.R00	7.2	0	0	0.002	0.002	34Y2p	6.F34	0.R2R	F05.6	44.5	
								8 V B1 S I -26	-G064	-0.RG4	45.2	44.F	
								LV B1 S I -20	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -2F	52.G00	F00.400	7.G	0	0	0.002	0.002	JB-2/F	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -2F	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -27	52.G00	F00.335	7.G	0	0	0.002	0.002	JB-2/F	7.2RR	0.F43	2F.7	44.R	
								8 V B1 S I -24	-F.3GR	-0.704	5F.0	44.2	
								LV B1 S I -27	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -25	52.G00	F00.344	7.G	0	0	0.002	0.002	JB-2/F	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -25	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -22	52.G00	F00.37G	7.G	0	0	0.002	0.002	JB-2/F	-5.RFG	-0.56F	6F.4	44.G	
								8 V B1 S I -2G	2.552	0.524	R7.7	44.R	
								LV B1 S I -22	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -2G	52.G00	F00.R36	7.G	0	0	0.002	0.002	8 V B1 S I -22	-2.555	-0.2RF	R7.2	44.2	
								8 V B1 S I -26	2.4G6	0.260	37.6	44.6	
								LV B1 S I -2G	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -26	52.G00	F00.R5R	7.2	0	0	0.002	0.002	8 V B1 S I -20	GGRF	0.65R	45.F	44.2	
								8 V B1 S I -2G	-2.4CF	-0.624	37.4	44.7	
								LV B1 S I -26	-0.672	0.003	F0.2	F00.0	
8 V B1 S I -23	52.G00	F0F.07F	7.G	0	0	0.002	0.002	8 V B1 S I -24	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -23	-0.672	0.003	F0.5	F00.0	
8 V B1 S I -24	52.G00	F00.444	7.G	0	0	0.002	0.002	8 V B1 S I -27	F.3G4	0.053	50.3	F00.0	
								8 V B1 S I -23	-0.670	-0.07G	F0.5	44.4	
								8 V B1 S I -G	-0.670	-0.072	F0.5	44.4	
								LV B1 S I -24	-0.672	0.003	F0.5	F00.0	
8 V B1 S I -G	52.G00	F0F.070	7.G	0	0	0.002	0.002	8 V B1 S I -24	0.670	-0.0F7	F0.5	-F00.0	
								LV B1 S I -G	-0.672	0.003	F0.5	F00.0	
* PON	F53.000	F00.000	0.0	-7G3RG	-2.R54	0	0	34I Fp	-7G3RG	-2.R54	FF0.F	43.2	
8 PI ~5	F5.300	F00.502	7.5	0	0	0	0	HV B1 S 8 PI	0.000	0.000	0.0	0.0	
								& 34I FB					

* Indicates a %oltage regulated bus (%oltage controlled or swing ty9e machine connected to it)
Indicates a bus with a load mismatch oAmore than 0.F 8 Vp

Project: Fm OH m EF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File name: Fm2OH

ETAP
NWDEC

Page: N
Date: NDDMfDNk
Sheet: mES_mOOj P
Revision: f6p 0 EF
Comments: For- al

Study Case: NPG 16L. 0

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	. - 4	p PI	p _a4
511N	B/6DD	NDDNIW	fTN	E	D	E	E	3 V UGS _vf6	WNSB	vfTDW	ND5B	1%4	
								51_NU	WNSB	fTDW	ND5B	1%4	
511f.	B/6DD	NDDNIW	fTN	E	D	E	E	JUvf/N	WSDf	vfTN6	NNTN	167%	
								51_NU	WSDf	fTN6	NNTN	167%	
511B	B/6DD	NDDNIW	fTN	E	D	E	E	3 V UGS _vfB	Wk15	vfTB1	NfD%	1%B	
								51_NU	Wk15	fTB1	NfD%	1%B	
511%	B/6DD	NDDNIW	fTN	E	D	E	E	3 V UGS _v%4	WNNW	vBfDB	NNWD	55K	
								51_NU	WNNW	BfDB	NNWD	55K	
51_N	N8TDD	NDDf	DD	E	D	E	E	POR	f6TBW	5TB5	NN4D	16D	
								HV UGS 3 P_	vf6TBW	v5TB5	NN4D	16D	
51_NU	B/6DD	NDDNIW	fTN	E	D	E	E	511%	WNNW	vBfDB	NNWD	55K	
								511B	Wk15	vfTB1	NfD%	1%B	
								511f.	WSDf	vfTN6	NNTN	167%	
								511N	WNSB	vfTDW	ND5B	1%4	
								3 P_~B	f6T%4	1K55	%WBT	1BW	
								& HV UGS 3 P_					
HV UGS 3 P_	N8TDD	NDDf	DD	E	D	DD6%	DN%k	51_N	f6TBW	5TB5	NN4D	16D	
								51_NU	vf6TfN	v5TBW	NN4%	1%B	Nf6D
								& 3 P_~B					
JUvf/N	B/6DD	NDDfB5	fT	E	D	E	E	3 V UGS _vNk	v%BBf	vNNf5	k%K	1W5	
								3 V UGS _vff	vfTkK	vD61W	%fB	1kT	
								511f.	WSDf	Nkf%	NNTN	1Wf	
JUv%N	B/6DD	NDDfBf	fB	E	D	E	E	3 V UGS _v%N	vDfWD	vDNN	ND%	157%	
								3 V UGS _v%4	vfTkK	vD6kD	%fTN	1kB	
								3 V UGS _v%B	vDfWD	vDND	ND%	157%	
								3 V UGS _v%4	BRNW	DR1N	vBD	1kB	
LV UGS _vDN	DfWD	NNND%	BD	DfW6	DDfB	E	E	3 V UGS _vDN	DfW6	DDfB	6fBT	15T	
LV UGS _vDf	DfWD	NNNDW	BD	DfW6	DDfB	E	E	3 V UGS _vDf	DfW6	DDfB	6fBB	15T	
LV UGS _vDB	DfWD	NDDfW	BD	DfW6	DDfB	E	E	3 V UGS _vDB	DfW6	DDfB	6fBW	15T	
LV UGS _vD%	DfWD	NDDfB%	BD	DfW6	DDfB	E	E	3 V UGS _vD%	DfW6	DDfB	6fB5	15T	
LV UGS _vD6	DfWD	ND65%	BD	DfW6	DDfB	E	E	3 V UGS _vD6	DfW6	DDfB	6f4D	15T	
LV UGS _vDW	DfWD	ND6W	BD	DfW6	DDfB	E	E	3 V UGS _vDW	DfW6	DDfB	6f4N	15T	
LV UGS _vDk	DfWD	ND6%	BD	DfW6	DDfB	E	E	3 V UGS _vDk	DfW6	DDfB	6f4f	15T	
LV UGS _vD5	DfWD	ND6%	BD	DfW6	DDfB	E	E	3 V UGS _vD5	DfW6	DDfB	6f4f	15T	
LV UGS _vDI	DfWD	ND65%	BD	DfW6	DDfB	E	E	3 V UGS _vDI	DfW6	DDfB	6f45	15T	
LV UGS _vND	DfWD	ND66D	BD	DfW6	DDfB	E	E	3 V UGS _vND	DfW6	DDfB	6f4K	15T	

Project: Fm OH m EF j

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16L_0

Page: f

Project name: NND%mfDNk

SF: mES_mOOj P

Assignment: f6p 0 EF

Configuration: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	. - 4	p PI	p _a4
LV UGS _vNB	DW6	NDD1D5	BD	DW6	DD1B	E	E	3 V UGS _vNB	DW6	DD1B	6fB11	1511	
LV UGS _vN%	DW6	NDD555	BD	DW6	DD1B	E	E	3 V UGS _vN%	DW6	DD1B	6f%4D	1511	
LV UGS _vN6	DW6	NDDK1N	BD	DW6	DD1B	E	E	3 V UGS _vN6	DW6	DD1B	6f%45	1511	
LV UGS _vNW	DW6	NDD55%	BD	DW6	DD1B	E	E	3 V UGS _vNW	DW6	DD1B	6f%4D	1511	
LV UGS _vNk	DW6	NDDK1k	BD	DW6	DD1B	E	E	3 V UGS _vNk	DW6	DD1B	6f%41	1511	
LV UGS _vfD	DW6	NDD5fB	BD	DW6	DD1B	E	E	3 V UGS _vfD	DW6	DD1B	6f%4B	1511	
LV UGS _vfN	DW6	NDDKkk	BD	DW6	DD1B	E	E	3 V UGS _vfN	DW6	DD1B	6f%4W	1511	
LV UGS _vff	DW6	NDDK%4D	BD	DW6	DD1B	E	E	3 V UGS _vff	DW6	DD1B	6f%45	1511	
LV UGS _vfB	DW6	NDDK%f	BD	DW6	DD1B	E	E	3 V UGS _vfB	DW6	DD1B	6f%45	1511	
LV UGS _vf%	DW6	NDDW41	f11	DW6	DD1B	E	E	3 V UGS _vf%	DW6	DD1B	6f67%	1511	
LV UGS _vf6	DW6	NDD611	f11	DW6	DD1B	E	E	3 V UGS _vf6	DW6	DD1B	6f675	1511	
LV UGS _vfW	DW6	NDD56%	BD	DW6	DD1B	E	E	3 V UGS _vfW	DW6	DD1B	6f%47	1511	
LV UGS _vfk	DW6	NDD5BN	BD	DW6	DD1B	E	E	3 V UGS _vfk	DW6	DD1B	6f%4B	1511	
LV UGS _vf5	DW6	NDDK5k	BD	DW6	DD1B	E	E	3 V UGS _vf5	DW6	DD1B	6f%45	1511	
LV UGS _vf1	DW6	NDDK1%	BD	DW6	DD1B	E	E	3 V UGS _vf1	DW6	DD1B	6f%45	1511	
LV UGS _vBN	DW6	NDD15f	BD	DW6	DD1B	E	E	3 V UGS _vBN	DW6	DD1B	6fB55	1511	
LV UGS _vBf	DW6	NDD1N6	BD	DW6	DD1B	E	E	3 V UGS _vBf	DW6	DD1B	6fB11	1511	
LV UGS _vBB	DW6	NDD5D	BD	DW6	DD1B	E	E	3 V UGS _vBB	DW6	DD1B	6f%4D	1511	
LV UGS _vB%	DW6	NDD1fB	BD	DW6	DD1B	E	E	3 V UGS _vB%	DW6	DD1B	6fB55	1511	
LV UGS _vBW	DW6	NNED1	BD	DW6	DD1B	E	E	3 V UGS _vBW	DW6	DD1B	6fB5%	1511	
LV UGS _vBk	DW6	NNED%6	BD	DW6	DD1B	E	E	3 V UGS _vBk	DW6	DD1B	6fB1B	1511	
LV UGS _vBl	DW6	NDD11k	BD	DW6	DD1B	E	E	3 V UGS _vBl	DW6	DD1B	6fB5%	1511	
LV UGS _v%4D	DW6	NNED66	BN	DW6	DD1B	E	E	3 V UGS _v%4D	DW6	DD1B	6fBN	1511	
LV UGS _v%8	DW6	NNF5f	BT	DW6	DD1B	E	E	3 V UGS _v%8	DW6	DD1B	6ff7D	1511	
LV UGS _v%4	DW6	NNF%W6	BT	DW6	DD1B	E	E	3 V UGS _v%4	DW6	DD1B	6ff7D	1511	
LV UGS _v%B	DW6	NNF5f	BT	DW6	DD1B	E	E	3 V UGS _v%B	DW6	DD1B	6ff7D	1511	
LV UGS _v%8%	DW6	NNF1DN	BT	DW6	DD1B	E	E	3 V UGS _v%8%	DW6	DD1B	6ff7%	1511	
LV UGS _v%6	DW6	NNN6W	BT	DW6	DD1B	E	E	3 V UGS _v%6	DW6	DD1B	6ff7W	1511	
LV UGS _v%8W	DW6	NNND15	BN	DW6	DD1B	E	E	3 V UGS _v%8W	DW6	DD1B	6ff71	1511	
LV UGS _v%5	DW6	NNN%4D	BT	DW6	DD1B	E	E	3 V UGS _v%5	DW6	DD1B	6fNB	1511	
LV UGS _v%4	DW6	NNN55	BT	DW6	DD1B	E	E	3 V UGS _v%4	DW6	DD1B	6fN5%	1511	
LV UGS _v6D	DW6	NNN%41	BT	DW6	DD1B	E	E	3 V UGS _v6D	DW6	DD1B	6fNB	1511	
3 V UGS _vDN	B%4DD	NDDK1N	f1B	E	D	DD%	DD%	3 V UGS _vDf	DW6	DD5N	ND%	111F	
								LV UGS _vDN	vDW%	vDE6	ND6	111N	
3 V UGS _vDf	B%4DD	NDDW1N	f1B	E	D	DD%	DD%	3 V UGS _vDN	vDW6	vDN%5	ND6	1k11	
								3 V UGS _vDB	NF%4D	DFND	fD11	151W	
								LV UGS _vDf	vDW%	vDE6	ND6	111N	
3 V UGS _vDB	B%4DD	NDDW%4	f1B	E	D	DD%	DD%	3 V UGS _vDf	vNFBI	vDF6D	fND	151D	
								3 V UGS _vD%	N561	DBBN	BN%	1515	

Project: Fm OH m Fj

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16L. 0

Page: B

Project: NND/mfDNk

SF: mES_mOOj P

Assignment: f6p 0 EF

Configuration: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	. - 4	p PI	p _a4
3 V UGS_vD%	B%6DD	NDD%65	f'B	E	D	DDD%	DDD%	LV UGS_vdB	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vdB	vN65	vDEk5	EN6	15TD	
								3 V UGS_vD6	fPk5	D661	%NI	15B	
3 V UGS_vD6	B%6DD	NDD%65	f'B	E	D	DDD%	DDD%	LV UGS_vD%	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vD%	vfPk5	vDENN	%TN	1kII	
								3 V UGS_vD6	BDIk	D61f	6f'6	15T	
3 V UGS_vDW	B%6DD	NDD%66	f'B	E	D	DDD%	DDD%	LV UGS_vD6	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vDk	DIWD	DE6N	ND6%	11T	
								LV UGS_vDW	vDIW%	vDI66	ND6	11TN	
3 V UGS_vDk	B%6DD	NDD%65	f'B	E	D	DDD%	DDD%	3 V UGS_vDW	vDIWD	vDNN	ND6	15T%	
								3 V UGS_vNW	vDIWD	vDN6W	NDW	1kTB	
								3 V UGS_vN6	N661	DE65	EN6	15T%	
3 V UGS_vD6	B%6DD	NDD%65	f'B	E	D	DDD%	DDD%	LV UGS_vDk	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vD6	vBDIW	vD661	6f'6	1kIW	
								3 V UGS_vDI	BRNW	DEkN	VBIF	1kII	
3 V UGS_vDI	B%6DD	NDD%65	f'B	E	D	DDD%	DDD%	LV UGS_vD6	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vD6	vBRN%	vDE1D	VBIF	1kT	
								3 V UGS_vND	%666	DIkN	k%6D	1kIW	
3 V UGS_vND	B%6DD	NDD%4%	f'B	E	D	DDD%	DDD%	LV UGS_vDI	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vDI	v%666	vNDW	k%6B	1kTN	
								3 V UGS_vf6	%66f	NN6B	5%6	1kT%	
3 V UGS_vNB	B%6DD	NDD%5f	f'B	E	D	DDD%	DDD%	LV UGS_vND	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vN6%	DIWD	DE6N	ND6%	11T	
								LV UGS_vNB	vDIW%	vDI66	ND6	11TN	
3 V UGS_vN6%	B%6DD	NDD%W	f'B	E	D	DDD%	DDD%	3 V UGS_vNB	vDIWD	vDNNB	ND6	15T%	
								3 V UGS_vN6	NI%6D	DN6	fDI	15T	
								LV UGS_vN6%	vDIW%	vDI66	ND6	11TN	
3 V UGS_vN6	B%6DD	NDD%W%	f'B	E	D	DDD%	DDD%	3 V UGS_vDk	vN665	vD6Nf	ENK	1kIW	
								3 V UGS_vN6%	vNFB5	vDf6k	fNN	1kIW	
								3 V UGS_vNk	BRNk	DEWk	VBIF	1kII	
3 V UGS_vNW	B%6DD	NDD%6k	f'B	E	D	DDD%	DDD%	LV UGS_vN6	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vDk	DIWD	DE6N	ND6%	11T	
								LV UGS_vNW	vDIW%	vDI66	ND6	11TN	
3 V UGS_vNk	B%6DD	NDD65N	f'T	E	D	DDD%	DDD%	JUwf/N	%666	NDN%	k%6f	1kT%	
								3 V UGS_vN6	vBRN%	vDI6B	VB5	1kD	
								LV UGS_vNk	vDIW%	vDI66	ND6	11TN	
3 V UGS_vfD	B%6DD	NDD%4k	f'T	E	D	DDD%	DDD%	3 V UGS_vfN	DIWD	DE6N	ND6%	11T	
								LV UGS_vfD	vDIW%	vDI66	ND6	11TN	
								3 V UGS_vfN	vDIWD	vDN6k	NDW	1kD	

Project: Fm OH m Fj
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I lлена- e: F m2OH

ETAP
NWDEC
Study Case: NPG 16L. 0

Page: %
j ate: NDD%fDNk
SF: mES_mOOj P
AeMsion: f6p 0 EF
Con&gT F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	. - 4	p PI	p_a4
3 V UGS_vf f	B%6DD	NDD%NB	f fT	E	D	DDD%	DDD%	3 V UGS_vf f	NfBI	DfB5	fND	15T	
								LV UGS_vfN	vDIW%	vDI56	ND6	11TN	
								JUvf/N	fPk5	D6N	%fT	1kII	
								3 V UGS_vfN	vNfBI	vDfW5	fNN	1kK	
3 V UGS_vfB	B%6DD	NDD%N6	f fB	E	D	DDD%	DDD%	3 V UGS_vf1	vDIW D	vDNkD	NDK	1W%	
								LV UGS_vf f	vDIW%	vDI56	ND6	11TN	
								511 B	W5DI	NkWW	Nk fT	1W5	
								3 V UGS_vf5	vW51	vNW56	NMI	1W5	
3 V UGS_vf%	B%6DD	NDD%f5f	f fT	E	D	DDD%	DDD%	LV UGS_vfB	vDIW%	vDI56	ND6	11TN	
								3 V UGS_vf6	DIW D	DI5N	ND%	11T	
								LV UGS_vf%	vDIW%	vDI56	ND6	11TN	
								511 N	W5W	N5f6	Nk fW	16II	
3 V UGS_vfW	B%6DD	NDD%f5	f fB	E	D	DDD%	DDD%	3 V UGS_vND	v%II%W	vNW D	5WII	16D	
								3 V UGS_vf%	vDIW D	vDN%	ND6	15TN	
								LV UGS_vf6	vDIW%	vDI56	ND6	11TN	
								3 V UGS_vfk	DIW D	DI5N	ND%	11T	
3 V UGS_vfk	B%6DD	NDD%6	f fB	E	D	DDD%	DDD%	LV UGS_vfW	vDIW%	vDI56	ND6	11TN	
								3 V UGS_vfW	vDIW D	vDN	ND6	15T	
								3 V UGS_vf5	Nf% D	DfDD	fDI	15K	
								LV UGS_vfk	vDIW%	vDI56	ND6	11TN	
3 V UGS_vf5	B%6DD	NDD%W	f fB	E	D	DDD%	DDD%	3 V UGS_vfB	WN	N5B%	NMB	1kTN	
								3 V UGS_vfk	vNfBI	vDfBW	fND	15T	
								3 V UGS_vBB	v%BBf	vNfNk	k6D	1WB	
								LV UGS_vf5	vDIW%	vDI56	ND6	11TN	
3 V UGS_vf1	B%6DD	NDD%W5	f fT	E	D	DDD%	DDD%	3 V UGS_vf f	DIW D	DI5N	ND%	11T	
								LV UGS_vf1	vDIW%	vDI56	ND6	11TN	
								3 V UGS_vBf	DIW D	DI5N	ND%	11T	
								LV UGS_vBN	vDIW%	vDI56	ND6	11TN	
3 V UGS_vBf	B%6DD	NDD%51	f fB	E	D	DDD%	DDD%	3 V UGS_vBN	vDIWN	vDN f	ND5	16B5	
								3 V UGS_vBB	NfBI	DfkB	fNN	1kK	
								LV UGS_vBf	vDIW%	vDI56	ND6	11TN	
								3 V UGS_vf5	%BBW	DI kD	kBI	1k fW	
3 V UGS_vBB	B%6DD	NDD%6%	f fB	E	D	DDD%	DDD%	3 V UGS_vBf	vNfBI	vDBN	fNf	1k fT	
								3 V UGS_vB%	v fPk k	vD55	%fP%	1kB	
								LV UGS_vBB	vDIW%	vDI56	ND6	11TN	
								3 V UGS_vBB	fPk5	D5%	%fT	1kK	
3 V UGS_vB%	B%6DD	NDD%1k	f fB	E	D	DDD%	DDD%	3 V UGS_vBW	vNfBI	vDfWN	fNN	1kII	
								3 V UGS_vBI	vDIWN	vDfD'	ND5	16TN	
								LV UGS_vB%	vDIW%	vDI56	ND6	11TN	

Project: Fm OH m Ffj
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File name: Fm2OH

ETAP
NEW

Page: 6
Date: 11/11/2020
Sheet: mES_m00j P
Revision: f6p 0 EF
Comment: For - al

Study Case: NPG 16L. 0

Bus		Voltage		Generation		Load		Load Flow						XFMR
B	9V	p_3 agT	. ngT	3_m	3_Mr	3_m	3_Mr	B	3_m	3_Mr	. - 4	p PI	p_a4	
3_V UGS_vBW	B/6ID	NDW6B	fTB	L	D	DDD%	DDD%	3_V UGS_vB%	ND%	DNID	fD6	15B		
								3_V UGS_vBk	vDIWD	vDNDI	ND6	15B		
								LV UGS_vBW	vDIW%	vDE6	ND6	11TN		
3_V UGS_vBk	B/6ID	NDKID	fTB	L	D	DDD%	DDD%	3_V UGS_vBW	DIWD	DE6N	ND%	11T		
								LV UGS_vBk	vDIW%	vDE6	ND6	11TN		
3_V UGS_vBI	B/6ID	NDW6N	fTB	L	D	DDD%	DDD%	3_V UGS_vB%	DIWD	DE6N	ND%	11T		
								LV UGS_vBI	vDIW%	vDE6	ND6	11TN		
3_V UGS_vD	B/6ID	NDKf1	fT%	L	D	DDD%	DDD%	511%	W65	NW6W	ND6	1W6		
								3_V UGS_vW	v6B6	vN616	1W6	1WN		
								LV UGS_vD	vDIW%	vDE6	ND6	11TN		
3_V UGS_vN	B/6ID	NDI6k	fTB	L	D	DDD%	DDD%	JUvN	DIWD	DE6N	ND%	11T		
								LV UGS_vN	vDIW%	vDE6	ND%	11TN		
3_V UGS_v4	B/6ID	NDI%	fTB	L	D	DDD%	DDD%	JUvN	fP6k	D6W	%6TN	1k6		
								3_V UGS_v4	vN66k	vD65	EN6	1W6		
								LV UGS_v4	vDIW%	vDE6	ND%	11TN		
3_V UGS_vB	B/6ID	NDI6k	fTB	L	D	DDD%	DDD%	JUvN	DIWD	DE6N	ND%	11T		
								LV UGS_vB	vDIW%	vDE6	ND%	11TN		
3_V UGS_v%	B/6ID	ND6kW	fTB	L	D	DDD%	DDD%	JUvN	vB6N%	vDI6	W66	1kTN		
								3_V UGS_v6	%66%	DI11	k66	1kT%		
								LV UGS_v%	vDIW%	vDE6	ND%	11TN		
3_V UGS_v6	B/6ID	ND6BD	fT%	L	D	DDD%	DDD%	3_V UGS_v%	v666	vN6f	k66	1W6		
								3_V UGS_vW	%66f	N6DB	5%6W	1kT		
								LV UGS_v6	vDIW%	vDE6	ND6	11TN		
3_V UGS_vW	B/6ID	NDKkf	fT%	L	D	DDD%	DDD%	3_V UGS_vD	66kD	N6kB	16T	1W6		
								3_V UGS_v6	v666D	vN6f	56T%	1WB		
								LV UGS_vW	vDIW%	vDE6	ND6	11TN		
3_V UGS_v5	B/6ID	NN66	fTB	L	D	DDD%	DDD%	3_V UGS_v4	DIWD	DE6N	ND6	11T		
								LV UGS_v5	vDIW%	vDE6	ND%	11TN		
3_V UGS_v4	B/6ID	NN6WB	fTB	L	D	DDD%	DDD%	3_V UGS_v6	N661	DE6W	EN6	15TW		
								3_V UGS_v5	vDIWD	vDN6	ND%	15T		
								3_V UGS_v6D	vDIWD	vDN6	ND%	15B		
								LV UGS_v4	vDIW%	vDE6	ND%	11TN		
3_V UGS_v6D	B/6ID	NN66	fTB	L	D	DDD%	DDD%	3_V UGS_v4	DIWD	DE6N	ND6	11T		
								LV UGS_v6D	vDIW%	vDE6	ND%	11TN		
* POR	N66ID	ND6ID	DD	v666W	v66%	L	L	51_N	v666W	v66%	NN6D	16D		
3_P_~B	N66ID	ND6ID%	fT%	L	D	L	L	HV UGS 3_P_	DDD	DDD	DD	DD		
& 51_NU														

* Indicates a Voltage regulated bus (Voltage controlled or swing ty4e - achine connected to it)
Indicates a bus with a load - is- atch o8- ore than DN3 V.

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: 0
j ate: 0D9CP%DDk
SF : m ES_m OOj l
AeMsion: fQp . EF
Con8gT F or2 al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4	
5N_06	1BICDD	0DDDI f	f TD	E	D	E	E	3 V U1 S _%G	%WDSI	%TDG	0DSTN	NBN		
								5N_0U	WDSI	f TDG	0DSTN	NBN		
5N_f6	1BICDD	0DDDI f	f TD	E	D	E	E	JU%0	%WSDf	%D1I	00ND	NGB		
								5N_0U	WSDf	f D1I	00ND	NGB		
5N_16	1BICDD	0DDDI f	f TD	E	D	E	E	3 V U1 S _%I	%WRN5	%T5k	0f DB	NBB		
								5N_0U	WRN5	f T5k	0f DB	NBB		
5N_B6	1BICDD	0DDDI f	f TD	E	D	E	E	3 V U1 S _%B	%WDVV	%TDD	00WD	55B		
								5N_0U	WDVV	1 TDD	00WD	55B		
5N_06	0I5TDD	NGDDf	DD	E	D	E	E	POv	fG5kl	5TGH	0fDD	NGD		
								HV U1 S 3 P_	%G5kl	%TGH	0fDD	NGD		
5N_0U	1BICDD	0DDDI f	f TD	E	D	E	E	5N_B6	%WDVV	%TDD	00WD	55B		
								5N_16	%WRN5	%T5k	0f DB	NBB		
								5N_f6	%WSDf	%D1I	00ND	NGB		
								5N_06	%WDSI	%TDG	0DSTN	NBN		
								3 P_~I	fGNBN	NkkN	BWTB	N TW		
								& HV U1 S 3 P_						
HV U1 S 3 P_	0I5TDD	NGDDf	DD	E	D	DDBS	DD1I	5N_06	fG5kl	5TGH	0fDD	NGD		
								5N_0U	%GNf0	%TWVW	0fDB	NBS	%TKD	
								& 3 P_~I						
JU%0	1BICDD	0DDfkl	f TF	E	D	E	E	3 V U1 S _%k	%BT1f	%Dfk	kBK	NW5		
								3 V U1 S _%f	%Bkk	%DGNW	BfTG	NkT		
								5N_f6	WSDN	0kfI	00kT	NWN		
JU%B0	1BICDD	0DD5kG	f TG	E	D	E	E	3 V U1 S _%B	%DWFD	%DD00	0DB	N5B		
								3 V U1 S _%Bf	%Bkk	%DCKD	BfT	NkTG		
								3 V U1 S _%Bf	%DWFD	%DD0D	0DB	N5TG		
								3 V U1 S _%BB	1TROW	DRN	WfD	Nk5		
LV U1 S _%B	DDWD	0DDN50	1 TD	DDWG	DEN	E	E	3 V U1 S _%B	DDWG	DEN	Gf1TG	N5TN		
LV U1 S _%Bf	DDWD	0DDNf	1 TD	DDWG	DEN	E	E	3 V U1 S _%Bf	DDWG	DEN	Gf1T	N5TN		
LV U1 S _%Bf	DDWD	0DDNB	1 TD	DDWG	DEN	E	E	3 V U1 S _%Bf	DDWG	DEN	Gf1TN	N5TN		
LV U1 S _%BB	DDWD	0DD5kD	1 TD	DDWG	DEN	E	E	3 V U1 S _%BB	DDWG	DEN	GfBD	N5TN		
LV U1 S _%BG	DDWD	0DD5fD	1 TD	DDWG	DEN	E	E	3 V U1 S _%BG	DDWG	DEN	GfBT	N5TN		
LV U1 S _%BW	DDWD	0DDRN5	1 TD	DDWG	DEN	E	E	3 V U1 S _%BW	DDWG	DEN	GfBTG	N5TN		
LV U1 S _%Bk	DDWD	0DDR5D	1 TD	DDWG	DEN	E	E	3 V U1 S _%Bk	DDWG	DEN	GfBW	N5TN		
LV U1 S _%B5	DDWD	0DDR5D	1 TD	DDWG	DEN	E	E	3 V U1 S _%B5	DDWG	DEN	GfBW	N5TN		
LV U1 S _%BN	DDWD	0DDkfD	1 TD	DDWG	DEN	E	E	3 V U1 S _%BN	DDWG	DEN	GfBN	N5TN		
LV U1 S _%BD	DDWD	0DDW5W	1 TD	DDWG	DEN	E	E	3 V U1 S _%BD	DDWG	DEN	GfGD	N5TN		

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: f
j ate: 0D%CP%DDk
SF: m ES_m OOj l
AeMsion: fQp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
LV U1 S_ %I	DIWD	0DDfBB	1TD	DIWG	DIEI	E	E	3 V U1 S_ %I	DIWG	DIEI	GfBI	NfN	
LV U1 S_ %B	DIWD	0DDfG	1TD	DIWG	DIEI	E	E	3 V U1 S_ %B	DIWG	DIEI	GfBI	NfN	
LV U1 S_ %G	DIWD	0DDkf k	1TD	DIWG	DIEI	E	E	3 V U1 S_ %G	DIWG	DIEI	GfBf	NfN	
LV U1 S_ %W	DIWD	0DDfD	1TD	DIWG	DIEI	E	E	3 V U1 S_ %W	DIWG	DIEI	GfBB	NfN	
LV U1 S_ %k	DIWD	0DDfH	1TD	DIWG	DIEI	E	E	3 V U1 S_ %k	DIWG	DIEI	GfGI	NfN	
LV U1 S_ %D	DIWD	0DDkGN	1TD	DIWG	DIEI	E	E	3 V U1 S_ %D	DIWG	DIEI	GfBk	NfN	
LV U1 S_ %0	DIWD	0DDk0I	1TD	DIWG	DIEI	E	E	3 V U1 S_ %0	DIWG	DIEI	GfBN	NfN	
LV U1 S_ %f	DIWD	0DDfW	1TD	DIWG	DIEI	E	E	3 V U1 S_ %f	DIWG	DIEI	GfGD	NfN	
LV U1 S_ %I	DIWD	0DDfW5	1TD	DIWG	DIEI	E	E	3 V U1 S_ %I	DIWG	DIEI	GfGD	NfN	
LV U1 S_ %B	DIWD	0DDfBG	fTN	DIWG	DIEI	E	E	3 V U1 S_ %B	DIWG	DIEI	GfGf	NfN	
LV U1 S_ %G	DIWD	0DDfG	fTN	DIWG	DIEI	E	E	3 V U1 S_ %G	DIWG	DIEI	GfGf	NfN	
LV U1 S_ %W	DIWD	0DDfND	1TD	DIWG	DIEI	E	E	3 V U1 S_ %W	DIWG	DIEI	GfBG	NfN	
LV U1 S_ %k	DIWD	0DDfWk	1TD	DIWG	DIEI	E	E	3 V U1 S_ %k	DIWG	DIEI	GfBW	NfN	
LV U1 S_ %5	DIWD	0DDkfI	1TD	DIWG	DIEI	E	E	3 V U1 S_ %5	DIWG	DIEI	GfBN	NfN	
LV U1 S_ %N	DIWD	0DDfID	1TD	DIWG	DIEI	E	E	3 V U1 S_ %N	DIWG	DIEI	GfBf	NfN	
LV U1 S_ %0	DIWD	0DDfN5	1TD	DIWG	DIEI	E	E	3 V U1 S_ %0	DIWG	DIEI	GfI f	NfN	
LV U1 S_ %f	DIWD	0DDfGD	1TD	DIWG	DIEI	E	E	3 V U1 S_ %f	DIWG	DIEI	GfBI	NfN	
LV U1 S_ %I	DIWD	0DDfOW	1TD	DIWG	DIEI	E	E	3 V U1 S_ %I	DIWG	DIEI	GfBB	NfN	
LV U1 S_ %B	DIWD	0DDfGN	1TD	DIWG	DIEI	E	E	3 V U1 S_ %B	DIWG	DIEI	GfBD	NfN	
LV U1 S_ %W	DIWD	0DDfBG	1TD	DIWG	DIEI	E	E	3 V U1 S_ %W	DIWG	DIEI	GfI k	NfN	
LV U1 S_ %k	DIWD	0DDfW0	1TD	DIWG	DIEI	E	E	3 V U1 S_ %k	DIWG	DIEI	GfI W	NfN	
LV U1 S_ %N	DIWD	0DDfNI	1TD	DIWG	DIEI	E	E	3 V U1 S_ %N	DIWG	DIEI	GfI f	NfN	
LV U1 S_ %D	DIWD	0DDfNO	1TD	DIWG	DIEI	E	E	3 V U1 S_ %D	DIWG	DIEI	GfI G	NfN	
LV U1 S_ %0	DIWD	0DDfO5	1TD	DIWG	DIEI	E	E	3 V U1 S_ %0	DIWG	DIEI	GfI I	NfN	
LV U1 S_ %f	DIWD	0DDfID	1TD	DIWG	DIEI	E	E	3 V U1 S_ %f	DIWG	DIEI	GfI B	NfN	
LV U1 S_ %I	DIWD	0DDfO5	1TD	DIWG	DIEI	E	E	3 V U1 S_ %I	DIWG	DIEI	GfI I	NfN	
LV U1 S_ %B	DIWD	0DDfIk	1TD	DIWG	DIEI	E	E	3 V U1 S_ %B	DIWG	DIEI	GfI k	NfN	
LV U1 S_ %G	DIWD	0DDfEN	1TD	DIWG	DIEI	E	E	3 V U1 S_ %G	DIWG	DIEI	GfI N	NfN	
LV U1 S_ %W	DIWD	0DDfIB	1TD	DIWG	DIEI	E	E	3 V U1 S_ %W	DIWG	DIEI	GfI f	NfN	
LV U1 S_ %5	DIWD	0DDfBW	1TD	DIWG	DIEI	E	E	3 V U1 S_ %5	DIWG	DIEI	GfO W	NfN	
LV U1 S_ %N	DIWD	0DDfIFB	1TD	DIWG	DIEI	E	E	3 V U1 S_ %N	DIWG	DIEI	GfO k	NfN	
LV U1 S_ %D	DIWD	0DDfIBG	1TD	DIWG	DIEI	E	E	3 V U1 S_ %D	DIWG	DIEI	GfO W	NfN	
3 V U1 S_ %0	IBIGD	0DDfWG	fTI	E	D	DDDB	DDDB	3 V U1 S_ %0	DIWD	DDfO	ODfB	NNf	
3 V U1 S_ %f	IBIGD	0DDfWk	fTI	E	D	DDDB	DDDB	LV U1 S_ %0	%DIWB	%DDfG	ODfG	NND	
								3 V U1 S_ %0	%DIWD	%DDf5	ODfG	NkN	
								3 V U1 S_ %I	OTfBD	DDfDN	fDN	NfW	
3 V U1 S_ %I	IBIGD	0DDfG5	fTI	E	D	DDDB	DDDB	LV U1 S_ %f	%DIWB	%DDfG	ODfG	NND	
								3 V U1 S_ %B	OTfGN	DDfIO	IOfB	NfG	

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1_NGL6.

Page: I
j ate: 0D%CP%DDk
SF: m ES_m OOj I
AeMsion: fQp . EF
Con8gT: F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S_%B	1BICD 0DDKBB	fT	E	D	DDDB	DDDB	3 V U1 S_%I	LV U1 S_%I	%DWB	%D5G	0DG	NND	
								3 V U1 S_%I	%F5G	%DIkk	10TW	N5D	
								3 V U1 S_%G	fTk5	DEG	B0TN	N5T	
3 V U1 S_%G	1BICD 0DDENB	fT	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%DWB	%D5G	0DG	NND	
								3 V U1 S_%B	%Tk5	%D00	BTD	NkN	
								3 V U1 S_%D	1TNk	DGN	GTG	N5T	
3 V U1 S_%W	1BICD 0DDKk0	fT	E	D	DDDB	DDDB	3 V U1 S_%k	LV U1 S_%G	%DWB	%D5G	0DG	NND	
								3 V U1 S_%k	DWD	DE0	0DB	NNF	
								LV U1 S_%W	%DWB	%D5G	0DG	NND	
3 V U1 S_%k	1BICD 0DDBG	fT	E	D	DDDB	DDDB	3 V U1 S_%W	3 V U1 S_%W	%DWB	%D5G	0DG	N5B	
								3 V U1 S_%W	%DWB	%D00	0DG	N5B	
								3 V U1 S_%G	%DWB	%D5G	0DG	N5B	
3 V U1 S_%D	1BICD 0DDKCB	fT	E	D	DDDB	DDDB	3 V U1 S_%G	LV U1 S_%k	%DWB	%D5G	0DG	NND	
								3 V U1 S_%G	%DNW	%DN5N	GT5	NkTW	
								3 V U1 S_%N	1T0W	DkkD	WT	NkN	
3 V U1 S_%N	1BICD 0DDINB	fT	E	D	DDDB	DDDB	3 V U1 S_%D	LV U1 S_%D	%DWB	%D5G	0DG	NND	
								3 V U1 S_%D	%R0B	%D5N	WTk	NkT	
								3 V U1 S_%D	BT11	DNkD	kBD	NkTW	
3 V U1 S_%D	1BICD 0DDIWD	fT	E	D	DDDB	DDDB	3 V U1 S_%N	LV U1 S_%N	%DWB	%D5G	0DG	NND	
								3 V U1 S_%N	%BT1f	%D00	kBB	NkD	
								3 V U1 S_%G	BNG	0DB	5BK	NkTB	
3 V U1 S_%I	1BICD 0DDK05	fT	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%D	%DWB	%D5G	0DG	NND	
								3 V U1 S_%B	DWD	DE0	0DB	NNF	
								LV U1 S_%I	%DWB	%D5G	0DG	NND	
3 V U1 S_%B	1BICD 0DDEN5	fT	E	D	DDDB	DDDB	3 V U1 S_%I	3 V U1 S_%I	%DWB	%D5G	0DG	N5B	
								3 V U1 S_%I	%DWB	%D00	0DG	N5B	
								3 V U1 S_%G	0TBD	DDNG	fDN	N55	
3 V U1 S_%G	1BICD 0DDKED	fT	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%DWB	%D5G	0DG	NND	
								3 V U1 S_%B	%F5G	%D00	10Tk	NkTW	
								3 V U1 S_%B	%T15	%FkB	f0D	NkTW	
3 V U1 S_%W	1BICD 0DDEN	fT	E	D	DDDB	DDDB	3 V U1 S_%k	3 V U1 S_%k	1T0k	DKW	WT	NkN	
								LV U1 S_%G	%DWB	%D5G	0DG	NND	
								3 V U1 S_%k	DWD	DE0	0DB	NNF	
3 V U1 S_%k	1BICD 0DDI0k	fT	E	D	DDDB	DDDB	3 V U1 S_%D	LV U1 S_%W	%DWB	%D5G	0DG	NND	
								3 V U1 S_%D	BT1B	0D0I	kBT	NkTB	
								3 V U1 S_%G	%R0B	%DN f	WTN	NkD	
3 V U1 S_%D	1BICD 0DDI1f	fT	E	D	DDDB	DDDB	3 V U1 S_%0	LV U1 S_%k	%DWB	%D5G	0DG	NND	
								3 V U1 S_%0	DWD	DE0	0DB	NNF	
								LV U1 S_%D	%DWB	%D5G	0DG	NND	
3 V U1 S_%0	1BICD 0DDI5W	fT	E	D	DDDB	DDDB	3 V U1 S_%D	3 V U1 S_%D	%DWB	%D5G	0DG	NkD	

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: B
j ate: 0D%CP%DDk
SF : m ES_m OOj l
AeMsion: fQp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S _%f	1BQDD	0DDIBN	fT	E	D	DDB	DDB	3 V U1 S _%f	0T1N	DF15	f0D	N5T	
								LV U1 S _%0	%DWB	%D5G	0DG	NND	
								JU%/0	fEk5	D05	BfT	NkN	
								3 V U1 S _%0	%T1N	%DFW	f0D	NkK	
3 V U1 S _%I	1BQDD	0DDIG0	fT	E	D	DDB	DDB	3 V U1 S _%N	%DWD	%DkD	0DK	NWG	
								LV U1 S _%f	%DWB	%D5G	0DG	NND	
								5N16	W5DN	0KVG	00kT	NW5	
								3 V U1 S _%5	%W5N	%W5B	0DKD	NWG	
3 V U1 S _%B	1BQDD	0DDF05	fT	E	D	DDB	DDB	LV U1 S _%I	%DWB	%D5G	0DG	NND	
								3 V U1 S _%G	DWfD	DE50	0DB	NNf	
								LV U1 S _%B	%DWB	%D5G	0DG	NND	
								5N06	W55W	05fB	0DKK	NGN	
3 V U1 S _%W	1BQDD	0DDEWB	fT	E	D	DDB	DDB	3 V U1 S _%D	%BNBW	%W0N	5WN	NGD	
								3 V U1 S _%B	%DWfD	%DfB	0DW	N5D	
								LV U1 S _%G	%DWB	%D5G	0DG	NND	
								3 V U1 S _%k	DWfD	DE50	0DB	NNf	
3 V U1 S _%k	1BQDD	0DDEB0	fT	E	D	DDB	DDB	LV U1 S _%W	%DWB	%D5G	0DG	NND	
								3 V U1 S _%W	%DWfD	%D0N	0DG	N5T	
								3 V U1 S _%5	0TFD	DFDD	fDN	N5K	
								LV U1 S _%k	%DWB	%D5G	0DG	NND	
3 V U1 S _%5	1BQDD	0DDfNk	fT	E	D	DDB	DDB	3 V U1 S _%I	W0N0	0GH1	0DMf	NkD	
								3 V U1 S _%k	%T1N	%DF1W	f0D	N5T	
								3 V U1 S _%I	%Bf1f	%T0W	kGD	NMf	
								LV U1 S _%5	%DWB	%D5G	0DG	NND	
3 V U1 S _%N	1BQDD	0DDEB5	fT	E	D	DDB	DDB	3 V U1 S _%f	DWfD	DE50	0DB	NNf	
								LV U1 S _%N	%DWB	%D5G	0DG	NND	
								3 V U1 S _%0	DWfD	DE50	0DB	NNf	
								LV U1 S _%0	%DWB	%D5G	0DG	NND	
3 V U1 S _%f	1BQDD	0DDGfB	fT	E	D	DDB	DDB	3 V U1 S _%0	%W0N	%D0Nf	0D5	NGG	
								3 V U1 S _%I	0T1N	DFkI	f0D	NkK	
								LV U1 S _%f	%DWB	%D5G	0DG	NND	
								3 V U1 S _%5	Bf1W	DNkD	kBD	NkW	
3 V U1 S _%I	1BQDD	0DDEND	fT	E	D	DDB	DDB	3 V U1 S _%f	%T1N	%DfD	f0T	NkT	
								3 V U1 S _%B	%Ek5	%D5k	BfB	NkT	
								LV U1 S _%I	%DWB	%D5G	0DG	NND	
								3 V U1 S _%I	fEk5	DCEB	BfT	NkK	
3 V U1 S _%B	1BQDD	0DDG1	fT	E	D	DDB	DDB	3 V U1 S _%W	%T1N	%DFVD	f0D	NkN	
								3 V U1 S _%N	%W0N	%DFDf	0D5	NGD	
								LV U1 S _%B	%DWB	%D5G	0DG	NND	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: G
j ate: 0D%CP%DDk
SF : m ES_m OOj l
AeMsion: fQp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S _%W	1BICDD	0DDW0N	fT	E	D	DDCB	DDCB	3 V U1 S _%B	0TFBD	DDND	fDN	N5B	
								3 V U1 S _%k	%DWFD	%DDDN	0DIG	N5TG	
								LV U1 S _%W	%DWFB	%DES6	0DIG	NND	
3 V U1 S _%k	1BICDD	0DDW6G	fT	E	D	DDCB	DDCB	3 V U1 S _%W	DWFD	DES0	0DB	NNF	
								LV U1 S _%k	%DWFB	%DES6	0DIG	NND	
3 V U1 S _%N	1BICDD	0DDW6k	fT	E	D	DDCB	DDCB	3 V U1 S _%B	DWFD	DES0	0DB	NNF	
								LV U1 S _%N	%DWFB	%DES6	0DIG	NND	
3 V U1 S _%BD	1BICDD	0DDW6G	fB	E	D	DDCB	DDCB	5N B6	WD55	0TKG	0DMW	NMG	
								3 V U1 S _%BW	%GCG6	%TGNB	NMF	NMD	
								LV U1 S _%BD	%DWFB	%DES6	0DIG	NND	
3 V U1 S _%B0	1BICDD	0DD6N	fTG	E	D	DDCB	DDCB	JU%B0	DWFD	DES0	0DB	NNF	
								LV U1 S _%B0	%DWFB	%DES6	0DB	NND	
3 V U1 S _%Bf	1BICDD	0DD6kW	fTG	E	D	DDCB	DDCB	JU%B0	fBkk	DGWN	BfT	NkTG	
								3 V U1 S _%BN	%B5Gk	%DB55	10TN	NMK	
								LV U1 S _%Bf	%DWFB	%DES6	0DB	NND	
3 V U1 S _%Bf	1BICDD	0DD6N	fTG	E	D	DDCB	DDCB	JU%B0	DWFD	DES0	0DB	NNF	
								LV U1 S _%Bf	%DWFB	%DES6	0DB	NND	
3 V U1 S _%BB	1BICDD	0DD60f	fTG	E	D	DDCB	DDCB	JU%B0	%k0B	%DN05	WTG	NkD	
								3 V U1 S _%BG	BfTB	DNN	klTB	NkB	
								LV U1 S _%BB	%DWFB	%DES6	0DIG	NND	
3 V U1 S _%BG	1BICDD	0DDKWW	fB	E	D	DDCB	DDCB	3 V U1 S _%BB	%BfTB	%Df0	kBf	NM6	
								3 V U1 S _%BW	BNGT	0TFD	5BW	NkT	
								LV U1 S _%BG	%DWFB	%DES6	0DIG	NND	
3 V U1 S _%BW	1BICDD	0DDKDS	fB	E	D	DDCB	DDCB	3 V U1 S _%BD	GCKD	0Bkf	NGK	NMK	
								3 V U1 S _%BG	%BNGD	%TND	5GB	NMF	
								LV U1 S _%BW	%DWFB	%DES6	0DIG	NND	
3 V U1 S _%B5	1BICDD	0DDf0	fTG	E	D	DDCB	DDCB	3 V U1 S _%BN	DWFD	DES0	0DB	NNF	
								LV U1 S _%B5	%DWFB	%DES6	0DB	NND	
3 V U1 S _%BN	1BICDD	0DDNN	fTG	E	D	DDCB	DDCB	3 V U1 S _%Bf	0BGN	Df0W	10fT	N5fW	
								3 V U1 S _%B5	%DWFD	%D05	0DIG	N5T	
								3 V U1 S _%GD	%DWFD	%D0k	0DB	N5T	
								LV U1 S _%BN	%DWFB	%DES6	0DB	NND	
3 V U1 S _%GD	1BICDD	0DDf0	fTG	E	D	DDCB	DDCB	3 V U1 S _%BN	DWFD	DES0	0DB	NNF	
								LV U1 S _%GD	%DWFB	%DES6	0DB	NND	
* POv	0f5TDD	NGDD	DD	%G6kl	%T6W	E	E	5N_06	%G6kl	%T6W	0fDD	NGD	
3 P_~I	0f5DD	0DDf1N	fB	E	D	E	E	HV U1 S 3 P_	DDDD	DDDD	DD	DD	
								& 5N_0U					

* indicates a Moltage regulated bus (Moltage controlled or swing ty4e 2 achine connected to it)
indicates a bus with a load 2 is2 atch o82 ore than DD 3 V6

Project: Fm OH m 7F0
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: Fm -OH

ETAP
NWDEC

Study Case: NPG 16LE. 0

Page: N
Date: NDR/RAN
SF: mES_mOO0P
Revision: %M p EF
Con8gT: Forl al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	70	3 m	3 Aar	. I 4	MPj	M_a4
51j N	B/6DD	NDDP6W	%N	E	D	E	E	3 V UGS _R6	RWN1	%DNB	N6T6	R6TN	
								51_NU	WN1	R4DNB	N6T6	R6TN	
51j %	B/6DD	NDDP6W	%N	E	D	E	E	JUR6N	RWF15	%6Bv6	N6DN	RvT6	
								51_NU	WF15	R6Bv6	N6DN	RvT6	
51j B	B/6DD	NDDP6W	%N	E	D	E	E	3 V UGS _RB	RWF16	%DIB	N6T	R6TW	
								51_NU	WF16	R6DIB	N6T	R6TW	
51j v.	B/6DD	NDDP6W	%N	E	D	E	E	3 V UGS _RD	RWNW	DEff	N6BII	R1D	
								51_NU	WNW	RDEff	N6BII	R1D	
51_N	N6TDD	11T11	DD	E	D	E	E	PO7	%6T6W	R6TNW	N6BII	R6D	
								HV UGS 3 P_	R6T6W	5TNW	N6BII	R6D	
51_NU	B/6DD	NDDP6W	%N	E	D	E	E	51j v.	RWNW	DEff	N6BII	R1D	
								51j B	RWF16	%DIB	N6T	R6TW	
								51j %	RWF15	%6Bv6	N6DN	RvT6	
								51j N	RWN1	%DNB	N6T6	R6TN	
								3 P_~B	%6TIBW	R6T6	v6DD	RvW6	
								& HV UGS 3 P_					
HV UGS 3 P_	N6TDD	11T11	DD	E	D	DD6B	DNwf	51_N	%6T6W	R6TNW	N6BII	R6D	
								51_NU	R6TIND	5BW	N6BII	R6T6	RN6D
								& 3 P_~B					
JUR6N	B/6DD	NDDP6W	%6	E	D	E	E	3 V UGS _RN	R6T6D	N6T6B	ffT6	R6AI	
								3 V UGS _R6	R6wf6	NDEB	vvT6	R6AB	
								51j %	W6D6	R6f66	N6B6	R6AT	
JUR6N	B/6DD	NDDP6B	%6V	E	D	E	E	3 V UGS _RN	R6W6D	DP4W	NN6	R6D6	
								3 V UGS _R6	R6wfW	NDDW	vvTII	R6NII	
								3 V UGS _RB	R6W6D	DP4f	NN6	R6D6	
								3 V UGS _Rv	R6TN6	R6W6v	WT	R6N6	
LV UGS _RN	D6WD	11T55	B6	D6W6	R6EN6	E	E	3 V UGS _RN	D6W6	R6EN6	65vT6	R6T6	
LV UGS _R6	D6WD	11T6B	B6	D6W6	R6EN6	E	E	3 V UGS _R6	D6W6	R6EN6	65vT	R6T6	
LV UGS _RB	D6WD	11T6N	B6	D6W6	R6EN6	E	E	3 V UGS _RB	D6W6	R6EN6	65vTII	R6T6	
LV UGS _Rv	D6WD	11T6W	B6	D6W6	R6EN6	E	E	3 V UGS _Rv	D6W6	R6EN6	656TN	R6T6	
LV UGS _R6	D6WD	11T65	B6	D6W6	R6EN6	E	E	3 V UGS _R6	D6W6	R6EN6	656B	R6T6	
LV UGS _RW	D6WD	11T6B	B6N	D6W6	R6EN6	E	E	3 V UGS _RW	D6W6	R6EN6	656T6	R6T6	
LV UGS _Rf	D6WD	11T65	B6N	D6W6	R6EN6	E	E	3 V UGS _Rf	D6W6	R6EN6	656B	R6T6	
LV UGS _R6	D6WD	11T6W	B6N	D6W6	R6EN6	E	E	3 V UGS _R6	D6W6	R6EN6	656T	R6T6	
LV UGS _RDI	D6WD	11T6v	B6N	D6W6	R6EN6	E	E	3 V UGS _RDI	D6W6	R6EN6	656TW	R6T6	
LV UGS _RD	D6WD	11T61	B6N	D6W6	R6EN6	E	E	3 V UGS _RD	D6W6	R6EN6	656T	R6T6	

Project: Fm OH m 70

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File Name: Fm - OH

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: %

Date: NDR/R4N

SF: m ES_m 000 P

Revision: %M p EF

Configuration: For al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	9V	M 3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	70	3 m	3 Aar	. I 4	MPj	M_a4
LV UGS _RB	DWD	11T%0	BN	DW6	RDEN%	E	E	3 V UGS _RB	DW6	RDEN%	65vII	R51B	
LV UGS _Rv	DWD	11TIDB	BN	DW6	RDEN%	E	E	3 V UGS _Rv	DW6	RDEN%	656ID	R51B	
LV UGS _R6	DWD	11T5N5	BN	DW6	RDEN%	E	E	3 V UGS _R6	DW6	RDEN%	656TB	R51B	
LV UGS _RW	DWD	11Tf1%	BN	DW6	RDEN%	E	E	3 V UGS _RW	DW6	RDEN%	656TN	R51B	
LV UGS _Rf	DWD	11Tf1%	BN	DW6	RDEN%	E	E	3 V UGS _Rf	DW6	RDEN%	656TB	R51B	
LV UGS _RD	DWD	11T5B	BN	DW6	RDEN%	E	E	3 V UGS _RD	DW6	RDEN%	656TN	R51B	
LV UGS _RN	DWD	11TvB	BN	DW6	RDEN%	E	E	3 V UGS _RN	DW6	RDEN%	656TV	R51B	
LV UGS _R%	DWD	11T5N	BN	DW6	RDEN%	E	E	3 V UGS _R%	DW6	RDEN%	656TB	R51B	
LV UGS _RB	DWD	11TfW	BN	DW6	RDEN%	E	E	3 V UGS _RB	DW6	RDEN%	656TF	R51B	
LV UGS _Rv	DWD	11Tv5	BD	DW6	RDEN%	E	E	3 V UGS _Rv	DW6	RDEN%	656TI	R51B	
LV UGS _R6	DWD	11TvD	BD	DW6	RDEN%	E	E	3 V UGS _R6	DW6	RDEN%	65WD	R51B	
LV UGS _RW	DWD	11Tv6	BN	DW6	RDEN%	E	E	3 V UGS _RW	DW6	RDEN%	656TB	R51B	
LV UGS _Rf	DWD	11T%6	BN	DW6	RDEN%	E	E	3 V UGS _Rf	DW6	RDEN%	656TB	R51B	
LV UGS _R5	DWD	11T5W	BN	DW6	RDEN%	E	E	3 V UGS _R5	DW6	RDEN%	656TF	R51B	
LV UGS _R4	DWD	11T65	BN	DW6	RDEN%	E	E	3 V UGS _R4	DW6	RDEN%	656TB	R51B	
LV UGS _REN	DWD	11TIN6	BP%	DW6	RDEN%	E	E	3 V UGS _REN	DW6	RDEN%	65vTI	R51B	
LV UGS _R5%	DWD	11T6W	BP%	DW6	RDEN%	E	E	3 V UGS _R5%	DW6	RDEN%	656TB	R51B	
LV UGS _RB	DWD	11T%4W	BP%	DW6	RDEN%	E	E	3 V UGS _RB	DW6	RDEN%	656TB	R51B	
LV UGS _Rv	DWD	11T65	BP%	DW6	RDEN%	E	E	3 V UGS _Rv	DW6	RDEN%	656TB	R51B	
LV UGS _RW	DWD	11TIBB	BP%	DW6	RDEN%	E	E	3 V UGS _RW	DW6	RDEN%	65vTB	R51B	
LV UGS _Rf	DWD	11Tv5	BP%	DW6	RDEN%	E	E	3 V UGS _Rf	DW6	RDEN%	65vTF	R51B	
LV UGS _Rl	DWD	11T%B	BP%	DW6	RDEN%	E	E	3 V UGS _Rl	DW6	RDEN%	65vTI	R51B	
LV UGS _RD	DWD	11T5B	BB	DW6	RDEN%	E	E	3 V UGS _RD	DW6	RDEN%	656TN	R51B	
LV UGS _RN	DWD	11Tlv	BB	DW6	RDEN%	E	E	3 V UGS _RN	DW6	RDEN%	65vTB	R51B	
LV UGS _R%	DWD	11Tf1	BB	DW6	RDEN%	E	E	3 V UGS _R%	DW6	RDEN%	65vTW	R51B	
LV UGS _RB	DWD	11Tlv	BB	DW6	RDEN%	E	E	3 V UGS _RB	DW6	RDEN%	65vTB	R51B	
LV UGS _Rv	DWD	11Tvv	BB	DW6	RDEN%	E	E	3 V UGS _Rv	DW6	RDEN%	65vTB	R51B	
LV UGS _R6	DWD	11T%6	BB	DW6	RDEN%	E	E	3 V UGS _R6	DW6	RDEN%	65vTI	R51B	
LV UGS _RW	DWD	11TIDf	BB	DW6	RDEN%	E	E	3 V UGS _RW	DW6	RDEN%	656ID	R51B	
LV UGS _R5	DWD	NDDI%	BB	DW6	RDEN%	E	E	3 V UGS _R5	DW6	RDEN%	65BII	R51B	
LV UGS _R1	DWD	NDDfB	BB	DW6	RDEN%	E	E	3 V UGS _R1	DW6	RDEN%	65vTD	R51B	
LV UGS _RD	DWD	NDDIN	BB	DW6	RDEN%	E	E	3 V UGS _RD	DW6	RDEN%	65BII	R51B	
3 V UGS _RN	Bv5DD	NDD6D%	%6	E	D	DDv	DDv	3 V UGS _RD%	DWD	RD5W	NNf	R55B	
								LV UGS _RN	RDWv	DB5%	NNf	R55II	
3 V UGS _RD%	Bv5DD	NDDvff	%6	E	D	DDv	DDv	3 V UGS _RN	RDWN	DBf1	NNB	RNN%	
								3 V UGS _RB	NPB1	RDW6	%BD	R51II	
								LV UGS _RD%	RDWv	DB5%	NNf	R55II	
3 V UGS _RB	Bv5DD	NDDWB6	%6	E	D	DDv	DDv	3 V UGS _RD%	RDW45	DBW6	%4f	RND	
								3 V UGS _RDv	N565	RD5IN	BvTB	RDP%	

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	9V	M 3 agT	ingT	3 m	3 Aar	3 m	3 Aar	70	3 m	3 Aar	1 4	MPj	M_a4
3 V UGS_Rv	Bv 6DD	NDB6ND	%v	E	D	DDBv	DDBv	LV UGS_RB	RDBv	DB%0	NNf	R5Tl	
								3 V UGS_RB	RN56f	DBvv	BvD	RND	
								3 V UGS_R6	%vff	RNN'D	v6T	RDBv	
3 V UGS_R6	Bv 6DD	NDB6f%	%v	E	D	DDBv	DDBv	LV UGS_Rv	RDBv	DB%0	NNf	R5Tl	
								3 V UGS_Rv	RvffW	NN5	v6B	RNN	
								3 V UGS_R6	BDL6	RNvv	6Wl	RDBv	
3 V UGS_RW	Bv 6DD	NDB65	%v	E	D	DDBv	DDBv	LV UGS_R6	RDBv	DB%0	NNf	R5T5	
								3 V UGS_Rf	DBvD	RDBvW	NNf	R5T5	
								LV UGS_RW	RDBv	DB%0	NNf	R5T5	
3 V UGS_Rf	Bv 6DD	NDB6f%	%B	E	D	DDBv	DDBv	3 V UGS_RW	RDBvD	DBvW	NN5	RDB%	
								3 V UGS_RW	RDBvN	DBvW	NN5	Rv%	
								3 V UGS_R6	N56l	RDB5B	BvB	RDB	
3 V UGS_R6	Bv 6DD	NDB6N	%v	E	D	DDBv	DDBv	LV UGS_Rf	RDBv	DB%0	NNf	R5T5	
								3 V UGS_R6	RBDlv	NBvf	6WB	RNNf	
								3 V UGS_Rl	BfNv	RNNvB	Wtl	RNN%	
3 V UGS_Rl	Bv 6DD	NDB6Nl	%B	E	D	DDBv	DDBv	LV UGS_R6	RDBv	DB%0	NNf	R5T5	
								3 V UGS_R6	RfN	N66v	WtN	Rv%	
								3 V UGS_RD	vBBN	RN5D	f5T5	RNNf	
3 V UGS_RD	Bv 6DD	NDB66	%B	E	D	DDBv	DDBv	LV UGS_Rl	RDBv	DB%0	NNf	R5T5	
								3 V UGS_Rl	RvBB	Nf5l	f5T5	Rv%	
								3 V UGS_R6	vllv1	RvNN6	5lT5	Rv%	
3 V UGS_RB	Bv 6DD	NDB6v	%v	E	D	DDBv	DDBv	LV UGS_RD	RDBv	DB%0	NNf	R5T5	
								3 V UGS_Rv	DBvD	RDBvW	NNf	R5T5	
								LV UGS_RB	RDBv	DB%0	NNf	R5Tl	
3 V UGS_Rv	Bv 6DD	NDB6Nf	%v	E	D	DDBv	DDBv	3 V UGS_RB	RDBvD	DBv	NN5	RDBv	
								3 V UGS_R6	NvB1	RDBvD	%Bv	R5lT5	
								LV UGS_Rv	RDBv	DB%0	NNf	R5Tl	
3 V UGS_R6	Bv 6DD	NDB6B%	%B	E	D	DDBv	DDBv	3 V UGS_Rf	RN56f	DBND	BB5	RNNf	
								3 V UGS_Rv	RNvB5	DBvD	%v	RNNf	
								3 V UGS_Rf	BfN6	RNNvW	W5D	RNN%	
3 V UGS_RW	Bv 6DD	NDB6Df	%v	E	D	DDBv	DDBv	LV UGS_R6	RDBv	DB%0	NNf	R5T5	
								3 V UGS_Rf	DBvD	RDBvW	NNf	R5T5	
								LV UGS_RW	RDBv	DB%0	NNf	R5Tl	
3 V UGS_Rf	Bv 6DD	NDB6ff	%B	E	D	DDBv	DDBv	JURvN	vBBN	RN5Bf	f5T5	Rv%	
								3 V UGS_R6	RfN%	N6NN	Wtl	Rv%	
								LV UGS_Rf	RDBv	DB%0	NNf	R5T5	
3 V UGS_RD	Bv 6DD	NDB6l5	%B	E	D	DDBv	DDBv	3 V UGS_RN	DBvD	RDBvW	NNf	R5T5	
								LV UGS_RD	RDBv	DB%0	NNf	R5Tl	
								3 V UGS_RN	RDBvN	DBvN	NNN	Rv%	

Project: Fm OH m 7F0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project: Fm - OH

ETAP

NWDEC

Study Case: NPG 16LE_0

Page: v

Date: 10/10/2023

Sheet: mES_m000P

Description: 16M p EF

Configuration: For all

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	9V	M 3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	70	3 m	3 Aar	. I 4	MPj	M_a4
3 V UGS_R0%	Bv75DD	NDEB4W	%B	E	D	DDEv	DDEv	3 V UGS_R0%	NP4B1	DE6fW	%B	RDI	
								LV UGS_R0%	RDW4v	DEB%0	NNI	R55B	
								JUR4N	%4ff	RNN	v6B	RNB	
								3 V UGS_R0%	RNP4S	DE6vW	%4W	RNB	
3 V UGS_R0B	Bv75DD	NDEB4%	%B	E	D	DDEv	DDEv	3 V UGS_R0	RDWNI	DE4f	NNN	RBB	
								LV UGS_R0%	RDW4v	DEB%0	NNI	R55B	
								51j B	W5DW	DEfN6	N%4B	R%4I	
								3 V UGS_R0	RW5W	%B51	NNI	RBB	
3 V UGS_R0v	Bv75DD	NDEB4B	%B	E	D	DDEv	DDEv	LV UGS_R0B	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0	DW4D	DEB4W	NNI	R55B	
								LV UGS_R0v	RDW4v	DEB%0	NNI	R55B	
								51j N	W5B	DE4%5	NDI	RvD	
3 V UGS_R0W	Bv75DD	NDEB61	%B	E	D	DDEv	DDEv	3 V UGS_RD	RvIvB	NW4D	5WII	RvII	
								3 V UGS_R0v	RDW4D	DEB	NNv	RND	
								LV UGS_R0	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0	DW4D	DEB4W	NNI	R55B	
3 V UGS_R0f	Bv75DD	NDEB6I	%B	E	D	DDEv	DDEv	LV UGS_R0W	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0	RDW4v	DEB%0	NNI	R55B	
								LV UGS_R0W	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0	NP4B1	RDW4v	%4N	R1W	
3 V UGS_R0	Bv75DD	NDEB6N	%B	E	D	DDEv	DDEv	LV UGS_R0f	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0B	W55	DEB1	NNW	R%4B	
								3 V UGS_R0	NP4B1	DEf5	%B	RDIW	
								3 V UGS_R0B	RvBBD	NW6	ffT%	RBB	
3 V UGS_R0	Bv75DD	NDEBfB	%B	E	D	DDEv	DDEv	LV UGS_R0	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0%	DW4D	DEB4W	NNI	R55B	
								LV UGS_R0	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0%	DW4D	DEB4W	NNI	R55B	
3 V UGS_R0N	Bv75DD	NDEBBD	%B	E	D	DDEv	DDEv	LV UGS_R0N	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0N	RDW4v	DEB%0	NNI	R55B	
								LV UGS_R0N	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0N	RDW4v	DEB%0	NNI	R55B	
3 V UGS_R0%	Bv75DD	NDEBfN	%B	E	D	DDEv	DDEv	3 V UGS_R0B	NP4B1	DE6vN	%B	RNIW	
								LV UGS_R0%	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0	vBBv	R55N	f5B	RNI	
								3 V UGS_R0%	NP4S	DENv	%4	R%4	
3 V UGS_R0v	Bv75DD	NDEBfB	%B	E	D	DDEv	DDEv	3 V UGS_R0v	DEfW	NDe%	vvB	R%4%	
								LV UGS_R0B	RDW4v	DEB%0	NNI	R55B	
								3 V UGS_R0B	%4ff	RDE6	v6TN	RNIW	
								3 V UGS_R0W	NP4S	DE6v	%4W	RNB	
3 V UGS_R0	Bv75DD	NDEBfB	%B	E	D	DDEv	DDEv	3 V UGS_R0I	RDW4v	DE46	NDI	RvII	
								LV UGS_R0v	RDW4v	DEB%0	NNI	R55B	

Project: Fm OH m 70

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project: Fm - OH

ETAP

Model

Study Case: NPG 16LE_0

Page: 6

Date: 10/14/2020

Sheet: mES_m000P

Description: 6M p EF

Configuration: For all

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	9V	M 3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	70	3 m	3 Aar	. I 4	MPj	M_a4
3 V UGS _RBW	B/75D	NDDvfv	%4	E	D	DDEv	DDEv	3 V UGS _RBv	NP41	RDW4	%4N	R51B	
								3 V UGS _RBf	RDW4	DE45	NN6	R4DN	
								LV UGS _RBW	RDW4	DE8%	NNf	R55II	
3 V UGS _RBf	B/75D	NDDW%	%4	E	D	DDEv	DDEv	3 V UGS _RBW	DIW4	DEB4W	NNf	R55B	
								LV UGS _RBf	RDW4	DE8%	NNf	R55II	
3 V UGS _RBI	B/75D	NDDWBI	%4	E	D	DDEv	DDEv	3 V UGS _RBv	DIW4	DEB4W	NNf	R55B	
								LV UGS _RBI	RDW4	DE8%	NNf	R55II	
3 V UGS _RD	B/75D	NDDWf	%4	E	D	DDEv	DDEv	51j v.	W56	R4D%	NDDW	R4B%	
								3 V UGS _RW	R56W	%4f	11D	R4Bf	
								LV UGS _RD	RDW4	DE8%	NNf	R55II	
3 V UGS _RN	B/75D	NDD6D	%4W	E	D	DDEv	DDEv	JUR/N	DIW4	DEB4W	NNf	R55B	
								LV UGS _RN	RDW4	DE8%	NNf	R55II	
3 V UGS _R%	B/75D	NDDW1B	%4W	E	D	DDEv	DDEv	JUR/N	%4fW	R4DN	vvII	R4NI	
								3 V UGS _R1	R56W	DEB6	BB%	R4BD	
								LV UGS _R%	RDW4	DE8%	NNf	R55II	
3 V UGS _RB	B/75D	NDD6D	%4W	E	D	DDEv	DDEv	JUR/N	DIW4	DEB4W	NNf	R55B	
								LV UGS _RB	RDW4	DE8%	NNf	R55II	
3 V UGS _Rv	B/75D	NDDW65	%4W	E	D	DDEv	DDEv	JUR/N	R4fN%	N6%	WII	R4%	
								3 V UGS _R6	vBB%	R56v	f5B	R4NI	
								LV UGS _Rv	RDW4	DE8%	NNf	R55II	
3 V UGS _R6	B/75D	NDDWBI	%4W	E	D	DDEv	DDEv	3 V UGS _Rv	R4BB	NfBB	ffT	R4%	
								3 V UGS _RW	vII6D	R4D1	51B	R4%	
								LV UGS _R6	RDW4	DE8%	NNf	R55II	
3 V UGS _RW	B/75D	NDDW%	%4	E	D	DDEv	DDEv	3 V UGS _RD	66W	R4Nf	11T	R4BD	
								3 V UGS _R6	R4v5	N5fN	55N	R4B	
								LV UGS _RW	RDW4	DE8%	NNf	R55II	
3 V UGS _R5	B/75D	NDDW6	%4f	E	D	DDEv	DDEv	3 V UGS _R1	DIW4	DEB4W	NNW	R55B	
								LV UGS _R5	RDW4	DE8%	NNf	R55II	
3 V UGS _R1	B/75D	NDDW5W	%4f	E	D	DDEv	DDEv	3 V UGS _R%	N561	R4IIW	BvT	R51II	
								3 V UGS _R5	RDW4	DE81	NNW	R4DW	
								3 V UGS _R6D	RDW4	DE4D	NNW	R4D	
								LV UGS _R1	RDW4	DE8%	NNf	R55II	
								3 V UGS _R1	DIW4	DEB4W	NNW	R55B	
3 V UGS _R6D	B/75D	NDDW6	%4f	E	D	DDEv	DDEv	LV UGS _R6D	RDW4	DE8%	NNf	R55II	
								51_N	R466W	56N%	NNII	R46D	
* PO7	NB5TD	NDDDD	DD	R466W	56N%	E	E	HV UGS 3 P_	DDDD	DDDD	DD	R4%	
3 P_~B	NB5D	NDDND	%4B	E	D	E	E	& 51_NU					

* 7 indicates a Aoltage regulated bus (Aoltage controlled or swing ty4e I achine connected to it)

7 indicates a bus with a load I isI atch o81 ore than DN3 V.

Project: Fm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I lilena- e: F m 2OH

ETAP
N1010C
Study Case: NGIP6 . 1LE0 W

Page: N
Wate: NGGI v/GN
SF : m ES_m OOWj
keAision: %d M p EF
Con&gD F or- al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4
5. I N0	j BDCG	NGGDFj	%dN	C	G	C	C	3 V U6 S _v%4	vIDNf.	%d0Nl	NC&Df	v. l DN	
								5. _NU	TDNf.	v%40Nl	NC&Df	v. l DN	
5. I %0	j BDCG	NGGDFj	%dN	C	G	C	C	JUV%&N	vIDB. 5	%d0Bf	NC&DN	v. BD	
								5. _NU	TDB. 5	v%40Bf	NC&DN	v. BD	
5. I j 0	j BDCG	NGGDFj	%dN	C	G	C	C	3 V U6 S _v%4	vIDB. 1	%d0i 1	NN&B	v. l Df	
								5. _NU	TDB. 1	v%40i 1	NN&B	v. l Df	
5. I B0	j BDCG	NGGDFj	%dN	C	G	C	C	3 V U6 S _vBG	vIDNTB	G&B5G	NC&B0	v. . l0i	
								5. _NU	TDNTB	vG&B5G	NC&B0	v. . l0i	
5. _N0	Nj 5l0CG	NC&BD. .	G0i	C	G	C	C	POR	%4B1N	v&DBN	NC&D	v. l l0i	
								HV U6 S 3 P_	v%4B1N	5DBN	NC&D	v. l l0i	
5. _NU	j BDCG	NGGDFj	%dN	C	G	C	C	5. I B0	vIDNTB	G&B5G	NC&B0	v. . l0i	
								5. I j 0	vIDB. 1	%d0i 1	NN&B	v. l Df	
								5. I %0	vIDB. 5	%d0Bf	NC&DN	v. BD	
								5. I N0	vIDNf.	%d0Nl	NC&Df	v. l DN	
								3 P_~j	%4Dj T	vfDj f	BlCp	v. TD%	
								& HV U6 S 3 P_					
HV U6 S 3 P_	Nj 5l0CG	NC&BD. .	G0i	C	G	G0i.	G0Nf%	5. _N0	%4B1N	v&DBN	NC&D	v. l l0i	
								5. _NU	v%4DNG	5Dpf.	NC&D	v. l DN	j B1G
								& 3 P_~j					
JUV%&N	j BDCG	NC&GDF	%D%	C	G	C	C	3 V U6 S _vNf	v&Dj G	NB%&B	fffB	v. %D	
								3 V U6 S _v%%	v%4Bf 1	N0i j	BB&B	v. %d	
								5. I %0	TBGI	v%401f	N0&Df	v. %d	
JUV&N	j BDCG	NC&G&G	%d	C	G	C	C	3 V U6 S _vBN	vG0f%G	G&B%T	NN&B	v. G&B%	
								3 V U6 S _vB%	v%4Bf T	N0&fN	BB&D	v. ND	
								3 V U6 S _v&j	vG0f%G	G&B% f	NN&B	v. G&B%	
								3 V U6 S _vBB	j BfNl	v&Df1B	TfB	v. NlB	
LV U6 S _vGN	G0f. G	. . D%4	j B%	G0f%4	vG0fN%	C	C	3 V U6 S _vGN	G0f%4	vG0fN%	15BD	v&. D	
LV U6 S _vC%	G0f. G	. . DCG	j B%	G0f%4	vG0fN%	C	C	3 V U6 S _vC%	G0f%4	vG0fN%	151l0i	v&. D	
LV U6 S _v&j	G0f. G	. . B15	j B%	G0f%4	vG0fN%	C	C	3 V U6 S _v&j	G0f%4	vG0fN%	151D	v&. D	
LV U6 S _vCB	G0f. G	. . Bfj %	j B%	G0f%4	vG0fN%	C	C	3 V U6 S _vCB	G0f%4	vG0fN%	151lB	v&. D	
LV U6 S _vGI	G0f. G	. . Bf. B	j B%	G0f%4	vG0fN%	C	C	3 V U6 S _vGI	G0f%4	vG0fN%	151Df	v&. D	
LV U6 S _vGf	G0f. G	. . BNG	j DN	G0f%4	vG0fN%	C	C	3 V U6 S _vGf	G0f%4	vG0fN%	151Df	v&. D	
LV U6 S _vGf	G0f. G	. . Bf. B	j DN	G0f%4	vG0fN%	C	C	3 V U6 S _vGf	G0f%4	vG0fN%	151Df	v&. D	
LV U6 S _vG&	G0f. G	. . Bf f j	j DN	G0f%4	vG0fN%	C	C	3 V U6 S _vG&	G0f%4	vG0fN%	151B	v&. D	
LV U6 S _vG	G0f. G	. . BfBG	j DN	G0f%4	vG0fN%	C	C	3 V U6 S _vG	G0f%4	vG0fN%	151l0i	v&. D	
LV U6 S _vNG	G0f. G	. . Bf%T	j DN	G0f%4	vG0fN%	C	C	3 V U6 S _vNG	G0f%4	vG0fN%	151l0i	v&. D	

Project: F m OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I l ena- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: %
Wate: NGL vGNF
SF : m ES_m OOWj
k eAision: 94 M p EF
Con8gD For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4
LV U6 S _vJ	GD. G	.. B1T	j DN	GD%4	vGDN%	C	C	3 V U6 S _vJ	GD%4	vGDN%	151D	v5. D	
LV U6 S _vNB	GD. G	.. B1j .	j DN	GD%4	vGDN%	C	C	3 V U6 S _vNB	GD%4	vGDN%	151B	v5. D	
LV U6 S _vNI	GD. G	.. B1B	j DN	GD%4	vGDN%	C	C	3 V U6 S _vNI	GD%4	vGDN%	151D	v5. D	
LV U6 S _vNT	GD. G	.. B%	j DN	GD%4	vGDN%	C	C	3 V U6 S _vNT	GD%4	vGDN%	151B	v5. D	
LV U6 S _vNf	GD. G	.. BfG	j DN	GD%4	vGDN%	C	C	3 V U6 S _vNf	GD%4	vGDN%	151D	v5. D	
LV U6 S _v%G	GD. G	.. B%G	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%G	GD%4	vGDN%	151D	v5. D	
LV U6 S _v%N	GD. G	.. B5G	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%N	GD%4	vGDN%	151B	v5. D	
LV U6 S _v%%	GD. G	.. B5B	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%%	GD%4	vGDN%	151D	v5. D	
LV U6 S _v%j	GD. G	.. BfN	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%j	GD%4	vGDN%	151D	v5. D	
LV U6 S _v%B	GD. G	.. B51	j Df	GD%4	vGDN%	C	C	3 V U6 S _v%B	GD%4	vGDN%	151B	v5. D	
LV U6 S _v%4	GD. G	.. Bf f	j Df	GD%4	vGDN%	C	C	3 V U6 S _v%4	GD%4	vGDN%	151B	v5. D	
LV U6 S _v%4	GD. G	.. B5N	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%4	GD%4	vGDN%	151B	v5. D	
LV U6 S _v%f	GD. G	.. BfTN	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%f	GD%4	vGDN%	151B	v5. D	
LV U6 S _v%5	GD. G	.. B%j	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%5	GD%4	vGDN%	151D	v5. D	
LV U6 S _v%	GD. G	.. Bf. 1	j DN	GD%4	vGDN%	C	C	3 V U6 S _v%	GD%4	vGDN%	151D	v5. D	
LV U6 S _vj N	GD. G	.. B1%	j D%	GD%4	vGDN%	C	C	3 V U6 S _vj N	GD%4	vGDN%	151B	v5. D	
LV U6 S _vj %	GD. G	.. Bf. j	j D%	GD%4	vGDN%	C	C	3 V U6 S _vj %	GD%4	vGDN%	151B	v5. D	
LV U6 S _vj j	GD. G	.. BfTj	j D%	GD%4	vGDN%	C	C	3 V U6 S _vj j	GD%4	vGDN%	151B	v5. D	
LV U6 S _vj B	GD. G	.. Bf. 1	j D%	GD%4	vGDN%	C	C	3 V U6 S _vj B	GD%4	vGDN%	151D	v5. D	
LV U6 S _vj T	GD. G	.. Bf fG	j D%	GD%4	vGDN%	C	C	3 V U6 S _vj T	GD%4	vGDN%	151D%	v5. D	
LV U6 S _vj f	GD. G	.. B5B	j D%	GD%4	vGDN%	C	C	3 V U6 S _vj f	GD%4	vGDN%	151D	v5. D	
LV U6 S _vj .	GD. G	.. BfTG	j D%	GD%4	vGDN%	C	C	3 V U6 S _vj .	GD%4	vGDN%	151B	v5. D	
LV U6 S _vBG	GD. G	.. B%	j D	GD%4	vGDN%	C	C	3 V U6 S _vBG	GD%4	vGDN%	151B	v5. D	
LV U6 S _vBN	GD. G	.. Dj N	j DB	GD%4	vGDN%	C	C	3 V U6 S _vBN	GD%4	vGDN%	15B5	v5. D	
LV U6 S _vB%	GD. G	.. DNT	j DB	GD%4	vGDN%	C	C	3 V U6 S _vB%	GD%4	vGDN%	15BD	v5. D	
LV U6 S _vBj	GD. G	.. Dj G	j DB	GD%4	vGDN%	C	C	3 V U6 S _vBj	GD%4	vGDN%	15B5	v5. D	
LV U6 S _vBB	GD. G	.. B5N	j DB	GD%4	vGDN%	C	C	3 V U6 S _vBB	GD%4	vGDN%	151D	v5. D	
LV U6 S _vBI	GD. G	.. BfT%	j D	GD%4	vGDN%	C	C	3 V U6 S _vBI	GD%4	vGDN%	151D%	v5. D	
LV U6 S _vBT	GD. G	.. BfBj	j D	GD%4	vGDN%	C	C	3 V U6 S _vBT	GD%4	vGDN%	151B	v5. D	
LV U6 S _vB5	GD. G	NCGD%	j D	GD%4	vGDN%	C	C	3 V U6 S _vB5	GD%4	vGDN%	15BQ	v5. D	
LV U6 S _vB	GD. G	NCGD%	j D	GD%4	vGDN%	C	C	3 V U6 S _vB	GD%4	vGDN%	15BDB	v5. D	
LV U6 S _vLG	GD. G	NCGD%	j D	GD%4	vGDN%	C	C	3 V U6 S _vLG	GD%4	vGDN%	15BQ	v5. D	
3 V U6 S _vGN	j BDG	NCGDj .	%D	C	G	GDGB	GDGB	3 V U6 S _vGN	GD%G	vGD%4	NN	v55D	
3 V U6 S _vG%	j BDG	NCGDNI	%DB	C	G	GDGB	GDGB	LV U6 S _vGN	vGD%B	GD%	NN	v55D	
								3 V U6 S _vGN	vGDN	GDf.	NN	v. ND%	
								3 V U6 S _vGj	NDj .	vGDG	%j Df	v5. D	
3 V U6 S _vGj	j BDG	NCGDf%	%DB	C	G	GDGB	GDGB	LV U6 S _vG%	vGD%B	GD%	NN	v55D	
								3 V U6 S _vG%	vNDj 5	GDf	%DB	v. ND%	
								3 V U6 S _vGB	NDf5	vGD. N	j BDB	v. GD%	

Project: F m OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I l ena- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: j
Wate: NGL vGN
SF : m ES_m OOWj
keAision: 94 M p EF
Con8gd F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4
3 V U6 S _vGB	j BD CG	NCGPBF	%4B	C	G	G00CB	G00CB	LV U6 S _vGj	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vGj	vNB1f	GBBB	j BB	v NB	
								3 V U6 S _vGl	%4Bf	vNDfG	BlB	v GB	
3 V U6 S _vGl	j BD CG	NCGPG	%4B	C	G	G00CB	G00CB	LV U6 S _vGB	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vGB	v4BfT	NDN5	BlB	v ND	
								3 V U6 S _vG5	j B1	vNBEB	lfB	v GB	
3 V U6 S _vGf	j BD CG	NCGP4	%4B	C	G	G00CB	G00CB	LV U6 S _vGl	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vGf	GNfG	vGPfT	NNB	v55D	
								LV U6 S _vGf	vGN%B	GP%%	NNB	v55B	
3 V U6 S _vGf	j BD CG	NCGPG	%4D	C	G	G00CB	G00CB	3 V U6 S _vGf	vGNfG	GP%T	NND	v GP%	
								3 V U6 S _vNf	vGN	GPfN	NNB%	v %4B%	
								3 V U6 S _vNl	NB1.	vGB5j	j BB	v GP	
3 V U6 S _vG5	j BD CG	NCGP55	%4B	C	G	G00CB	G00CB	LV U6 S _vGf	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vGl	vj B1B	NpBf	lTB	v NB	
								3 V U6 S _vG	j BNB	vNfj	T5B	v NB%	
3 V U6 S _vG	j BD CG	NCGP4T	%4D	C	G	G00CB	G00CB	LV U6 S _vG5	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vG5	vj BNN	ND11	TfB%	v %4B%	
								3 V U6 S _vNG	BBj N	vNB5N	f5B	v NB	
3 V U6 S _vNG	j BD CG	NCGP5%	%4D	C	G	G00CB	G00CB	LV U6 S _vG	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vG	vBBj G	NB. G	f5B%	v %4B	
								3 V U6 S _v4	BBB	vBNf	5. D	v ND	
3 V U6 S _vNj	j BD CG	NCGPfN	%4B	C	G	G00CB	G00CB	LV U6 S _vNG	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vNB	GNfG	vGPfT	NNB	v55D	
								LV U6 S _vNj	vGN%B	GP%%	NNB	v55B	
3 V U6 S _vNB	j BD CG	NCGP1B	%4B	C	G	G00CB	G00CB	3 V U6 S _vNj	vGNfG	GP%B	NNB	v GB	
								3 V U6 S _vNl	NBj.	vGNfG	%fB	v f. B	
								LV U6 S _vNB	vGN%B	GP%%	NNB	v55B	
3 V U6 S _vNl	j BD CG	NCGPfG	%4D	C	G	G00CB	G00CB	3 V U6 S _vGf	vNB1f	GBNG	j j B	v NB	
								3 V U6 S _vNB	vNBj5	GBBG	%4D	v NB	
								3 V U6 S _vNf	j BNB	vNfT	T5B	v NB%	
3 V U6 S _vNf	j BD CG	NCGPB	%4B	C	G	G00CB	G00CB	LV U6 S _vNl	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vGf	GNfG	vGPfT	NNB	v55D	
								LV U6 S _vNf	vGN%B	GP%%	NNB	v55B	
3 V U6 S _vNf	j BD CG	NCGP%1	%4D	C	G	G00CB	G00CB	3 V U6 S _vNf	vGNfG	GP%T	NNB	v55D	
								LV U6 S _vNf	vGN%B	GP%%	NNB	v55B	
								3 V U6 S _vNf	vGNfG	GP%T	NNB	v55D	

Project: Fm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I l ena- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: B
Wate: NGL vGN
SF : m ES_m OOWj
keAision: 14 M p EF
Con8gD F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4
3 V U6 S _v%	j BDCG	NCGDj	%D	C	G	G0CB	G0CB	3 V U6 S _v%	NDj .	vCDff	%B	v. CD	
								LV U6 S _vN	vCD%B	CD%	NNB	v55B	
								JUVN	%Bff	vNDNG	BlD	v. ND	
								3 V U6 S _vN	vNDj 5	CDBf	%D	v. ND	
								3 V U6 S _v%	vCDN	CDj 5	NNN	v. j DB	
3 V U6 S _v%	j BDCG	NCGD%	%D	C	G	G0CB	G0CB	LV U6 S _v%	vCD%B	CD%	NNB	v55B	
								5. I j 0	TBGT	vDNT	NBj	v. %D	
								3 V U6 S _v%	vTDST	%D. N	NCD	v. j D	
3 V U6 S _vB	j BDCG	NCGDG	%B	C	G	G0CB	G0CB	LV U6 S _v%	vCD%B	CD%	NNB	v55B	
								3 V U6 S _v4	CD%G	vCD%T	NNB	v55D	
3 V U6 S _v4	j BDCG	NCDNj	%B	C	G	G0CB	G0CB	LV U6 S _vB	vCD%B	CD%	NNB	v55B	
								5. I ND	TDSj	vD4G	NG D	v. BD	
3 V U6 S _vT	j BDCG	NCGDT	%B	C	G	G0CB	G0CB	3 V U6 S _vNG	vBDj	NDEN	5fDB	v. BD	
								3 V U6 S _vB	vCD%G	CDj	NNB	v. ND	
								LV U6 S _v4	vCD%B	CD%	NNB	v55B	
								3 V U6 S _v%	CD%G	vCD%T	NNB	v55D	
3 V U6 S _v%	j BDCG	NCGDf	%B	C	G	G0CB	G0CB	LV U6 S _vT	vCD%B	CD%	NNB	v55B	
								3 V U6 S _vT	vCDN	CD%5	NNB	v. CD	
								3 V U6 S _v%	NDj .	vCDNB	%D	v5. D	
3 V U6 S _v%	j BDCG	NCGj 5	%D	C	G	G0CB	G0CB	LV U6 S _v%	vCD%B	CD%	NNB	v55B	
								3 V U6 S _v%	TDS5	vDDBG	NNNB	v. %D	
								3 V U6 S _v%	vNDj .	CDf 5	%B	v. CD	
								3 V U6 S _vj j	vBDj G	NDj T	ffD	v. j D	
3 V U6 S _v%	j BDCG	NCGNG	%D	C	G	G0CB	G0CB	LV U6 S _v%	vCD%B	CD%	NNB	v55B	
								3 V U6 S _v%	CD%G	vCD%T	NNB	v55D	
								LV U6 S _v%	vCD%B	CD%	NNB	v55B	
3 V U6 S _vj N	j BDCG	NCDTf	%B	C	G	G0CB	G0CB	3 V U6 S _vj %	CD%G	vCD%T	NNB	v55D	
								LV U6 S _vj N	vCD%B	CD%	NNB	v55B	
								3 V U6 S _vj N	vCDN	CDNT	NGD	v. BDB	
3 V U6 S _vj j	j BDCG	NCDf 5	%B	C	G	G0CB	G0CB	3 V U6 S _vj j	NDj .	vCDEN	%D	v. ND	
								LV U6 S _vj %	vCD%B	CD%	NNB	v55B	
								3 V U6 S _v%	BDj B	vB5N	f5B	v. NB	
								3 V U6 S _vj %	vNDj 5	CDNB	%B	v. %B	
3 V U6 S _vj B	j BDCG	NCGNG	%B	C	G	G0CB	G0CB	3 V U6 S _vj B	vBf T	NDB%	BBB	v. %B	
								LV U6 S _vj j	vCD%B	CD%	NNB	v55B	
								3 V U6 S _vj j	%Bff	vND51	BlDN	v. ND	
								3 V U6 S _vj T	vNDj 5	CD1B	%D	v. ND	
								3 V U6 S _vj .	vCDN	CDG	NGD	v. BD	
								LV U6 S _vj B	vCD%B	CD%	NNB	v55B	

Project: Fm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I ilena- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: 1
Wate: NGL vGN
SF : m ES_m OOWj
keAision: 4M p EF
Con8gd F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RV	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RV	3 m	3 Aar	0 - 4	MPI	M_a4
3 V U6 S _vj T	j BDCG	NCGp5B	%D	C	G	GDCB	GDCB	3 V U6 S _vj B	NDj .	vCP%B	%D	v5. D	
								3 V U6 S _vj f	vCP%G	CB% 5	NND	v. GD	
								LV U6 S _vj T	vCP%B	CP%%	NND	v55B	
3 V U6 S _vj f	j BDCG	NCGp. .	%D	C	G	GDCB	GDCB	3 V U6 S _vj T	CP%G	vCP%T	NND	v55D	
								LV U6 S _vj f	vCP%B	CP%%	NND	v55D	
3 V U6 S _vj .	j BDCG	NCGpf1	%B	C	G	GDCB	GDCB	3 V U6 S _vj B	CP%G	vCP%T	NND	v55D	
								LV U6 S _vj .	vCP%B	CP%%	NND	v55B	
3 V U6 S _vBG	j BDCG	NCGpBB	%D	C	G	GDCB	GDCB	5. I B0	TDS1	vDCB	NND	v. j D%	
								3 V U6 S _vBT	vIDT1	%DT5	. . DN	v. j D	
								LV U6 S _vBG	vCP%B	CP%%	NND	v55B	
3 V U6 S _vBN	j BDCG	NCGBBI	%D	C	G	GDCB	GDCB	JUvBN	CP%G	vCP%T	NND	v55D	
								LV U6 S _vBN	vCP%B	CP%%	NND	v55D	
3 V U6 S _vB%	j BDCG	NCGBj G	%D	C	G	GDCB	GDCB	JUvBN	%BT	vNDIN	BBD	v. ND	
								3 V U6 S _vB	vDS1T	CBj T	j j D	v. j D%	
								LV U6 S _vB%	vCP%B	CP%%	NND	v55D	
3 V U6 S _vBj	j BDCG	NCGBBI	%D	C	G	GDCB	GDCB	JUvBN	CP%G	vCP%T	NND	v55D	
								LV U6 S _vBj	vCP%B	CP%%	NND	v55D	
3 V U6 S _vBB	j BDCG	NCGp. 1	%D	C	G	GDCB	GDCB	JUvBN	vj D%N	ND%	TID	v. %D	
								3 V U6 S _vBI	Bpj %	vDS11	f5D	v. ND	
								LV U6 S _vBB	vCP%B	CP%%	NND	v55D	
3 V U6 S _vBI	j BDCG	NCGpfT	%D	C	G	GDCB	GDCB	3 V U6 S _vBB	vBpj G	NBj B	ffB	v. %B	
								3 V U6 S _vBT	BD1G	vDGI.	5. D	v. %D	
								LV U6 S _vBI	vCP%B	CP%%	NND	v55B	
3 V U6 S _vBT	j BDCG	NCGp15	%D	C	G	GDCB	GDCB	3 V U6 S _vBG	1DTT	vDN 5	. . B	v. j D%	
								3 V U6 S _vBI	vBDB5	NBf%	55D%	v. j D	
								LV U6 S _vBT	vCP%B	CP%%	NND	v55B	
3 V U6 S _vB5	j BDCG	NCGDB%	%D	C	G	GDCB	GDCB	3 V U6 S _vB	CP%G	vCP%T	NND	v55D	
								LV U6 S _vB5	vCP%B	CP%%	NND	v55D	
3 V U6 S _vB	j BDCG	NCGD%	%D	C	G	GDCB	GDCB	3 V U6 S _vB%	NB1.	vDGT	j BB	v5. D	
								3 V U6 S _vB5	vCPN	CB5.	NND	v. CD	
								3 V U6 S _vLG	vCPN	CB%N	NND	v. CD	
								LV U6 S _vB	vCP%B	CP%%	NND	v55D	
3 V U6 S _vLG	j BDCG	NCGDB%	%D	C	G	GDCB	GDCB	3 V U6 S _vB	CP%G	vCP%T	NND	v55D	
								LV U6 S _vLG	vCP%B	CP%%	NND	v55D	
* POR	N 5DCG	NGLDCG	CB5	v4B1N	5Dj T	C	C	5. _ND	v4B1N	5Dj T	NCD	v. 1D%	
3 P _~j	N 5CG	NCGBT	%D	C	G	C	C	HV U6 S 3 P _	GDCG	GDCG	CB5	CB5	
								& 5. _NU					

* Bdicates a Aoltage regulated bus (Aoltage controlled or swing ty4e- achine connected to it)
Bdicates a bus with a load - is- atch o8- ore than CND3 V0

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UN T PY

Page: F
Date: F0-02-70FR
SU: WESI WOODP
version: 00f k EU
Config.: Uormal

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR
ND	MV	f 8 ag.	p ng.	8 W	8 %ar	8 W	8 %ar	ND	8 W	8 %ar	p m9	f PY	f l a9
34YFp	52.000	44.364	2.R	0	0	0	0	8 V B1 S 1 -7G	-F5.522	-0.0R0	772.0	44.3	
								34I FB	F5.522	0.0R0	772.0	44.3	
34Y7p	52.000	44.364	2.R	0	0	0	0	JB-7/F	-F2.63F	-0.0R76	726.5	44.4	
								34I FB	F2.63F	0.0R76	726.5	44.4	
34Y5p	52.000	44.364	2.R	0	0	0	0	8 V B1 S 1 -75	-F2.66R	-0.4CF	726.5	44.3	
								34I FB	F2.66R	0.4CF	726.5	44.3	
34Y2p	52.000	44.364	2.R	0	0	0	0	8 V B1 S 1 -20	-F5.7R6	-F.37G	772.6	44.F	
								34I FB	F5.7R6	F.37G	772.6	44.F	
34I Fp	F53.000	F00.00F	0.0	0	0	0	0	PON	CG307	-0.270	755.G	F00.0	
								HV B1 S 8 PI	-CG307	0.270	755.G	F00.0	
34I FB	52.000	44.364	2.R	0	0	0	0	34Y2p	-F5.7R6	-F.37G	772.6	44.F	
								34Y5p	-F2.66R	-0.4CF	726.5	44.3	
								34Y7p	-F2.63F	-0.0R76	726.5	44.4	
								34YFp	-F5.522	-0.0R0	772.0	44.3	
								8 PI ~5	CG463	2.7R7	420.6	44.R	
								& HV B1 S 8 PI					
HV B1 S 8 PI	F53.000	F00.00F	0.0	0	0	0.0C2	0.0F2R	34I Fp	CG307	-0.270	755.G	F00.0	
								34I FB	-CG3C6	0.7R5	755.R	F00.0	0.67G
								& 8 PI ~5					
JB-7/F	52.000	F00.03R	2.3	0	0	0	0	8 V B1 S 1 -FR	-4.5G4	-0.7GG	FC6.G	F00.0	
								8 V B1 S 1 -77	-G5C6	-0.F05	34.G	F00.0	
								34Y7p	F2.0FF	0.5C6	726.F	F00.0	
JB-2/F	52.000	F0F.0F5	GG	0	0	0	0	8 V B1 S 1 -2F	-F.52F	0.0FF	77.7	F00.0	
								8 V B1 S 1 -27	-G5CG	-0.03F	33.R	F00.0	
								8 V B1 S 1 -25	-F.52F	0.0F7	77.7	F00.0	
								8 V B1 S 1 -22	3.056	0.0C6	F55.F	F00.0	
LV B1 S 1 -0F	0.640	F0F.0R7	6.R	F.5C0	0.000	0	0	8 V B1 S 1 -0F	F.5C0	0.000	FFF.R5	F00.0	
LV B1 S 1 -07	0.640	F0F.0F5	6.R	F.5C0	0.000	0	0	8 V B1 S 1 -07	F.5C0	0.000	FFF.3.0	F00.0	
LV B1 S 1 -05	0.640	F00.4F7	6.R	F.5C0	0.000	0	0	8 V B1 S 1 -05	F.5C0	0.000	FFF.4.F	F00.0	
LV B1 S 1 -02	0.640	F00.322	6.R	F.5C0	0.000	0	0	8 V B1 S 1 -02	F.5C0	0.000	FFF.4.3	F00.0	
LV B1 S 1 -0G	0.640	F00.R22	6.R	F.5C0	0.000	0	0	8 V B1 S 1 -0G	F.5C0	0.000	FF7F.0	F00.0	
LV B1 S 1 -06	0.640	F00.R74	6.6	F.5C0	0.000	0	0	8 V B1 S 1 -06	F.5C0	0.000	FF7F.F	F00.0	
LV B1 S 1 -0R	0.640	F00.647	6.6	F.5C0	0.000	0	0	8 V B1 S 1 -0R	F.5C0	0.000	FF7F.G	F00.0	
LV B1 S 1 -03	0.640	F00.6R0	6.6	F.5C0	0.000	0	0	8 V B1 S 1 -03	F.5C0	0.000	FF7F.3	F00.0	
LV B1 S 1 -04	0.640	F00.C60	6.6	F.5C0	0.000	0	0	8 V B1 S 1 -04	F.5C0	0.000	FF75.0	F00.0	
LV B1 S 1 -F0	0.640	F00.C00	6.G	F.5C0	0.000	0	0	8 V B1 S 1 -F0	F.5C0	0.000	FF75.R	F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UNIT PY

Page: 7
Date: F0-02-70FR
SU: WESI WOODP
version: 00f k EU
ConAg.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	M	f 8 ag.	p ng.	8 W	8 %ar	8 W	8 %ar	ND	8 W	8 %ar	p m9	f PY	f l a9
LV B1 S I -F5	0.640	F00.350	6.6	F.5C0	0.000	0	0	8 V B1 S I -F5	F.5C0	0.000	FF70.0	F00.0	
LV B1 S I -F2	0.640	F00.R34	6.6	F.5C0	0.000	0	0	8 V B1 S I -F2	F.5C0	0.000	FF70.G	F00.0	
LV B1 S I -FG	0.640	F00.CB6	6.6	F.5C0	0.000	0	0	8 V B1 S I -FG	F.5C0	0.000	FF77.R	F00.0	
LV B1 S I -F6	0.640	F00.RRG	6.6	F.5C0	0.000	0	0	8 V B1 S I -F6	F.5C0	0.000	FF70.6	F00.0	
LV B1 S I -FR	0.640	F00.257	6.G	F.5C0	0.000	0	0	8 V B1 S I -FR	F.5C0	0.000	FF72.2	F00.0	
LV B1 S I -70	0.640	F00.63F	6.G	F.5C0	0.000	0	0	8 V B1 S I -70	F.5C0	0.000	FF7F.R	F00.0	
LV B1 S I -7F	0.640	F00.CBG	6.G	F.5C0	0.000	0	0	8 V B1 S I -7F	F.5C0	0.000	FF77.R	F00.0	
LV B1 S I -77	0.640	F00.C04	6.G	F.5C0	0.000	0	0	8 V B1 S I -77	F.5C0	0.000	FF75.6	F00.0	
LV B1 S I -75	0.640	F00.2R2	6.G	F.5C0	0.000	0	0	8 V B1 S I -75	F.5C0	0.000	FF72.0	F00.0	
LV B1 S I -72	0.640	F00.7R6	6.2	F.5C0	0.000	0	0	8 V B1 S I -72	F.5C0	0.000	FF76.7	F00.0	
LV B1 S I -7G	0.640	F00.7CG	6.2	F.5C0	0.000	0	0	8 V B1 S I -7G	F.5C0	0.000	FF76.2	F00.0	
LV B1 S I -76	0.640	F00.632	6.6	F.5C0	0.000	0	0	8 V B1 S I -76	F.5C0	0.000	FF7F.6	F00.0	
LV B1 S I -7R	0.640	F00.65R	6.6	F.5C0	0.000	0	0	8 V B1 S I -7R	F.5C0	0.000	FF77.7	F00.0	
LV B1 S I -73	0.640	F00.C2G	6.6	F.5C0	0.000	0	0	8 V B1 S I -73	F.5C0	0.000	FF75.7	F00.0	
LV B1 S I -74	0.640	F00.67F	6.G	F.5C0	0.000	0	0	8 V B1 S I -74	F.5C0	0.000	FF77.5	F00.0	
LV B1 S I -5F	0.640	F00.4F3	6.R	F.5C0	0.000	0	0	8 V B1 S I -5F	F.5C0	0.000	FFF4.0	F00.0	
LV B1 S I -57	0.640	F00.RRR	6.R	F.5C0	0.000	0	0	8 V B1 S I -57	F.5C0	0.000	FF70.6	F00.0	
LV B1 S I -55	0.640	F00.R06	6.R	F.5C0	0.000	0	0	8 V B1 S I -55	F.5C0	0.000	FF7F.2	F00.0	
LV B1 S I -52	0.640	F00.R4F	6.R	F.5C0	0.000	0	0	8 V B1 S I -52	F.5C0	0.000	FF70.2	F00.0	
LV B1 S I -56	0.640	F00.464	6.R	F.5C0	0.000	0	0	8 V B1 S I -56	F.5C0	0.000	FFF3.G	F00.0	
LV B1 S I -5R	0.640	F0F.002	6.R	F.5C0	0.000	0	0	8 V B1 S I -5R	F.5C0	0.000	FFF3.F	F00.0	
LV B1 S I -54	0.640	F00.42G	6.R	F.5C0	0.000	0	0	8 V B1 S I -54	F.5C0	0.000	FFF3.R	F00.0	
LV B1 S I -20	0.640	F00.477	6.4	F.5C0	0.000	0	0	8 V B1 S I -20	F.5C0	0.000	FFF4.0	F00.0	
LV B1 S I -2F	0.640	F0F.5F4	RF	F.5C0	0.000	0	0	8 V B1 S I -2F	F.5C0	0.000	FFF2.6	F00.0	
LV B1 S I -27	0.640	F0F.732	RF	F.5C0	0.000	0	0	8 V B1 S I -27	F.5C0	0.000	FFFG0	F00.0	
LV B1 S I -25	0.640	F0F.5F3	RF	F.5C0	0.000	0	0	8 V B1 S I -25	F.5C0	0.000	FFF2.6	F00.0	
LV B1 S I -22	0.640	F0F.F66	R0	F.5C0	0.000	0	0	8 V B1 S I -22	F.5C0	0.000	FFF6.5	F00.0	
LV B1 S I -2G	0.640	F0F.03R	R0	F.5C0	0.000	0	0	8 V B1 S I -2G	F.5C0	0.000	FFFR7	F00.0	
LV B1 S I -26	0.640	F00.447	6.4	F.5C0	0.000	0	0	8 V B1 S I -26	F.5C0	0.000	FFF3.7	F00.0	
LV B1 S I -23	0.640	F0F.QR2	RF	F.5C0	0.000	0	0	8 V B1 S I -23	F.5C0	0.000	FFFF.3	F00.0	
LV B1 S I -24	0.640	F0F.C73	RF	F.5C0	0.000	0	0	8 V B1 S I -24	F.5C0	0.000	FFF7.5	F00.0	
LV B1 S I -C0	0.640	F0F.QR7	RF	F.5C0	0.000	0	0	8 V B1 S I -C0	F.5C0	0.000	FFFF.3	F00.0	
8 V B1 S I -0F	52.C00	F00.305	GF	0	0	0.002	0.002	8 V B1 S I -07	F.52F	-0.02F	77.5	-F00.0	
								LV B1 S I -0F	-F.526	0.05R	77.5	-F00.0	
8 V B1 S I -07	52.C00	F00.R25	GF	0	0	0.002	0.002	8 V B1 S I -0F	-F.52F	-0.006	77.5	F00.0	
								8 V B1 S I -05	7.637	-0.052	22.6	F00.0	
								LV B1 S I -07	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -05	52.C00	F00.627	GF	0	0	0.002	0.002	8 V B1 S I -07	-7.6R4	-0.00G	22.6	F00.0	
								8 V B1 S I -02	2.07F	-0.056	66.4	F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UNIT PY

Page: 5
Date: F0-02-70FR
SU: WESI WOODP
version: 00f k EU
ConAg.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	M	f 8 ag.	p ng.	8 W	8 %ar	8 W	8 %ar	ND	8 W	8 %ar	p m9	f PY	f l a9
8 V B1 S I -02	52.G00	F00.GRG	GF	0	0	0.002	0.002	LV B1 S I -05	-F.526	0.05R	77.2	-F00.0	
								8 V B1 S I -05	-2.0F3	-0.0F0	66.4	F00.0	
								8 V B1 S I -0G	G5G#	-0.05F	34.7	F00.0	
								LV B1 S I -02	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -0G	52.G00	F00.2R2	GF	0	0	0.002	0.002	8 V B1 S I -02	-G5G2	-0.070	34.7	F00.0	
								8 V B1 S I -03	6.64G	-0.07F	FF.FG	F00.0	
								LV B1 S I -0G	-F.526	0.05R	77.2	-F00.0	
								8 V B1 S I -0R	F.52F	-0.02F	77.2	-F00.0	
8 V B1 S I -0R	52.G00	F00.277	G0	0	0	0.002	0.002	LV B1 S I -06	-F.526	0.05R	77.2	-F00.0	
								8 V B1 S I -06	-F.52F	0.0F7	77.5	F00.0	
								8 V B1 S I -F6	-F.520	-0.072	77.5	F00.0	
								8 V B1 S I -FG	2.075	-0.074	6R0	F00.0	
8 V B1 S I -03	52.G00	F00.200	G0	0	0	0.002	0.002	LV B1 S I -0R	-F.526	0.05R	77.2	-F00.0	
								8 V B1 S I -0G	-6.640	-0.0R5	FF.FG	F00.0	
								8 V B1 S I -04	3.057	0.057	F55.4	F00.0	
								LV B1 S I -03	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -04	52.G00	F00.734	G0	0	0	0.002	0.002	8 V B1 S I -03	-3.075	-0.F2G	F55.4	F00.0	
								8 V B1 S I -F0	4.562	0.F02	FC6.5	F00.0	
								LV B1 S I -04	-F.526	0.05R	77.G	-F00.0	
								8 V B1 S I -04	-4.5G4	-0.F40	FC6.5	F00.0	
8 V B1 S I -F0	52.G00	F00.750	2.4	0	0	0.002	0.002	8 V B1 S I -7G	F0.R00	0.F24	FR3.R	F00.0	
								LV B1 S I -F0	-F.526	0.05R	77.G	-F00.0	
								8 V B1 S I -F2	F.52F	-0.02F	77.5	-F00.0	
								LV B1 S I -F5	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -F2	52.G00	F00.G70	G0	0	0	0.002	0.002	8 V B1 S I -F5	-F.52F	0.004	77.5	F00.0	
								8 V B1 S I -FG	7.637	-0.0C0	22.R	-F00.0	
								LV B1 S I -F2	-F.526	0.05R	77.2	-F00.0	
								8 V B1 S I -0R	-2.0F3	-0.025	6R0	F00.0	
8 V B1 S I -FG	52.G00	F00.5F6	G0	0	0	0.002	0.002	8 V B1 S I -F2	-7.6RR	-0.074	22.R	F00.0	
								8 V B1 S I -FR	3.056	0.05F	F52.F	F00.0	
								LV B1 S I -FG	-F.526	0.05R	77.G	-F00.0	
								8 V B1 S I -0R	F.52F	-0.02F	77.5	-F00.0	
8 V B1 S I -F6	52.G00	F00.C0G	G0	0	0	0.002	0.002	LV B1 S I -F6	-F.526	0.05R	77.2	-F00.0	
								JB-7/F	4.566	0.F2R	FC6.G	F00.0	
								8 V B1 S I -FG	-3.072	-0.F33	F52.F	F00.0	
								LV B1 S I -FR	-F.52G	0.053	77.G	-F00.0	
8 V B1 S I -70	52.G00	F00.2FF	2.4	0	0	0.002	0.002	8 V B1 S I -7F	F.52F	-0.02F	77.2	-F00.0	
								LV B1 S I -70	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -7F	52.G00	F00.5FG	2.4	0	0	0.002	0.002	8 V B1 S I -70	-F.520	-0.052	77.2	F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C
Study Case: 1 UNIT PY

Page: 2
Date: F0-02-70FR
SU: WESI WOODP
version: 00f k EU
ConAg.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
NO	MV	Phase	Angle	PW	Var	PW	Var	NO	PW	Var	PM9	FPY	Flow
8 V B1 S I -77	52.000	F00.753	2.4	0	0	0.002	0.002	8 V B1 S I -77	7.63F	-0.00R	22.R	F00.0	
								LV B1 S I -7F	-F.526	0.05R	77.G	-F00.0	
								JB-7/F	G56F	0.073	34.G	F00.0	
								8 V B1 S I -7F	-7.6R4	-0.075	22.R	F00.0	
								8 V B1 S I -74	-F.520	-0.02R	77.2	44.4	
8 V B1 S I -75	52.000	F00.702	2.4	0	0	0.002	0.002	LV B1 S I -77	-F.526	0.05R	77.G	-F00.0	
								34Y5p	F2.RF5	0.547	72G3	F00.0	
								8 V B1 S I -73	-F5.5RF	-0.255	775.2	44.4	
8 V B1 S I -72	52.000	F00.00G	2.3	0	0	0.002	0.002	LV B1 S I -75	-F.52G	0.05R	77.G	-F00.0	
								8 V B1 S I -7G	F.52F	-0.02F	77.G	-F00.0	
8 V B1 S I -7G	52.000	44.432	2.3	0	0	0.002	0.002	LV B1 S I -72	-F.52G	0.053	77.G	-F00.0	
								34YFp	F5.5GB	0.0GG	775.3	44.4	
								8 V B1 S I -F0	-F0.6RG	-0.04G	FR4.0	44.3	
8 V B1 S I -76	52.000	F00.2FG	G0	0	0	0.002	0.002	8 V B1 S I -72	-F.52F	-0.00F	77.2	F00.0	
								LV B1 S I -7G	-F.52G	0.053	77.G	-F00.0	
								8 V B1 S I -7R	F.52F	-0.02F	77.2	-F00.0	
								LV B1 S I -76	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -7R	52.000	F00.56R	G0	0	0	0.002	0.002	8 V B1 S I -76	-F.52F	0.005	77.2	F00.0	
								8 V B1 S I -73	7.637	-0.022	22.R	-F00.0	
								LV B1 S I -7R	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -73	52.000	F00.7RG	G0	0	0	0.002	0.002	8 V B1 S I -75	F5.530	0.74G	775.2	F00.0	
								8 V B1 S I -7R	-7.630	0.004	22.R	F00.0	
								8 V B1 S I -55	-4.5G4	-0.52G	FC6.5	44.4	
								LV B1 S I -73	-F.526	0.05R	77.G	-F00.0	
8 V B1 S I -74	52.000	F00.5CF	2.4	0	0	0.002	0.002	8 V B1 S I -77	F.52F	-0.02F	77.2	-F00.0	
								LV B1 S I -74	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -5F	52.000	F00.623	GF	0	0	0.002	0.002	8 V B1 S I -57	F.52F	-0.02F	77.5	-F00.0	
								LV B1 S I -5F	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -57	52.000	F00.003	GF	0	0	0.002	0.002	8 V B1 S I -5F	-F.520	-0.0R0	77.5	44.4	
								8 V B1 S I -55	7.63F	0.074	22.6	F00.0	
								LV B1 S I -57	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -55	52.000	F00.25R	GF	0	0	0.002	0.002	8 V B1 S I -73	4.5R2	0.FF7	FC6.7	F00.0	
								8 V B1 S I -57	-7.6R4	-0.0G6	22.6	F00.0	
								8 V B1 S I -52	-G5G2	-0.04R	34.7	F00.0	
								LV B1 S I -55	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -52	52.000	F00.077	GF	0	0	0.002	0.002	8 V B1 S I -55	G5GB	0.0G2	34.7	F00.0	
								8 V B1 S I -56	-7.6R3	-0.0F6	22.6	F00.0	
								8 V B1 S I -54	-F.554	-0.030	77.5	44.3	
								LV B1 S I -52	-F.526	0.05R	77.2	-F00.0	

Bus		Voltage		Generation		Load		Load Flow				XFMR	
NO	MVA	Phase	Angle	W	Var	W	Var	NO	W	Var	PMU	PF	Ratio
8 V B1 S I -56	52.000	F00.R00	G7	0	0	0.002	0.002	8 V B1 S I -52	7.637	-0.002	22.6	-F00.0	
								8 V B1 S I -5R	-F.52F	0.0F5	77.5	F00.0	
								LV B1 S I -56	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -5R	52.000	F00.R5G	G7	0	0	0.002	0.002	8 V B1 S I -56	F.52F	-0.02F	77.5	-F00.0	
								LV B1 S I -5R	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -54	52.000	F00.6RG	G7	0	0	0.002	0.002	8 V B1 S I -52	F.52F	-0.02F	77.5	-F00.0	
								LV B1 S I -54	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -20	52.000	F00.6C0	G5	0	0	0.002	0.002	34Y2p	F5.563	0.275	777.2	44.4	
								8 V B1 S I -26	-F7.076	-0.262	700.F	44.4	
								LV B1 S I -20	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -2F	52.000	F0F.0C0	GG	0	0	0.002	0.002	JB-2/F	F.52F	-0.02F	77.7	-F00.0	
								LV B1 S I -2F	-F.526	0.05R	77.5	-F00.0	
8 V B1 S I -27	52.000	F0F.0FG	GG	0	0	0.002	0.002	JB-2/F	G5CG	0.030	33.R	F00.0	
								8 V B1 S I -24	-2.0F5	-0.F7F	66.G	F00.0	
								LV B1 S I -27	-F.526	0.05R	77.5	-F00.0	
8 V B1 S I -25	52.000	F0F.024	GG	0	0	0.002	0.002	JB-2/F	F.52F	-0.02F	77.7	-F00.0	
								LV B1 S I -25	-F.526	0.05R	77.5	-F00.0	
8 V B1 S I -22	52.000	F00.34R	GG	0	0	0.002	0.002	JB-2/F	-3.07R	-0.FR4	F55.7	F00.0	
								8 V B1 S I -2G	4.564	0.F54	FCG2	F00.0	
								LV B1 S I -22	-F.526	0.05R	77.5	-F00.0	
8 V B1 S I -2G	52.000	F00.3F3	G2	0	0	0.002	0.002	8 V B1 S I -22	-4.56F	-0.7CG	FCG2	F00.0	
								8 V B1 S I -26	F0.R05	0.7F2	FRRR	F00.0	
								LV B1 S I -2G	-F.526	0.05R	77.5	-F00.0	
8 V B1 S I -26	52.000	F00.R75	G5	0	0	0.002	0.002	8 V B1 S I -20	F7.052	0.5C7	700.0	F00.0	
								8 V B1 S I -2G	-F0.645	-0.547	FRR3	44.4	
								LV B1 S I -26	-F.526	0.05R	77.2	-F00.0	
8 V B1 S I -23	52.000	F0F.506	G6	0	0	0.002	0.002	8 V B1 S I -24	F.52F	-0.020	77.7	-F00.0	
								LV B1 S I -23	-F.526	0.05R	77.7	-F00.0	
8 V B1 S I -24	52.000	F0F.760	G6	0	0	0.002	0.002	8 V B1 S I -27	2.075	-0.024	66.G	F00.0	
								8 V B1 S I -23	-F.52F	0.005	77.7	F00.0	
								8 V B1 S I -C0	-F.52F	0.00G	77.7	F00.0	
								LV B1 S I -24	-F.526	0.05R	77.7	-F00.0	
8 V B1 S I -C0	52.000	F0F.502	G6	0	0	0.002	0.002	8 V B1 S I -24	F.52F	-0.020	77.7	-F00.0	
								LV B1 S I -C0	-F.526	0.05R	77.7	-F00.0	
* PON	F53.000	F00.000	0.0	-CG307	0.270	0	0	34I Fp	-CG307	0.270	755.G	F00.0	
8 PI ~5	F5.300	44.3R7	GF	0	0	0	0	HV B1 S 8 PI	0.000	0.000	0.0	0.0	
& 34I FB													

* Indicates a voltage regulated bus (voltage controlled or swing type machine connected to it)

Indicates a bus with a load mismatch oAmore than 0.F 8 Vp

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: N
j ate: ND66%DNk
SF: m ES_m OOj l
AeMsion: 6Dp 0 EF
Con8gT: F or2 al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
51- N	1B6DD	NDDF65	BK	E	D	E	E	3 V UGS _%66	%T I N	%END	fBDN	1f'R	
								51_NU	N T I N	6END	fBDN	1f'R	
51- f.	1B6DD	NDDF65	BK	E	D	E	E	JU%N	%BW6	%61 D	f'W'6	1f'TI	
								51_NU	NBW6	661 D	f'W'6	1f'TI	
51- I.	1B6DD	NDDF65	BK	E	D	E	E	3 V UGS _%6I	%BW6N	%WD66	f'VBW	1f'B	
								51_NU	NBW6N	WD66	f'VBW	1f'B	
51- B	1B6DD	NDDF65	BK	E	D	E	E	3 V UGS _%6D	%N T 6f	%WB6	f'BWN	51TI	
								51_NU	N T 6f	WB6	f'BWN	51TI	
51_N	N 5IDD	NDDD6	DD	E	D	E	E	POv	66kN5	N5T1B	fB6'B	16'D	
								HV UGS 3 P_	%66kN5	%N5T1B	fB6'B	16'D	
51_NU	1B6DD	NDDF65	BK	E	D	E	E	51- B	%N T 6f	%WB6	f'BWN	51TI	
								51- I.	%BW6N	%WD66	f'VBW	1f'B	
								51- f.	%BW6	%61 D	f'W'6	1f'TI	
								51- N	%T I N	%END	fBDN	1f'R	
								3 P_~I	66TIDf	fI k'W	NN TI	1f'D	
								& HV UGS 3 P_					
HV UGS 3 P_	N 5IDD	NDDD6	DD	E	D	DD6B	DNk	51_N	66kN5	N5T1B	fB6'B	16'D	
								51_NU	%66kN5	%N5B5f	fB6'B	1BII	1T'6
								& 3 P_~I					
JU%N	1B6DD	NDDF61k	BII	E	D	E	E	3 V UGS _%6k	%T 6f	%6D6	NNWN	1I TW	
								3 V UGS _%6f	%T 6D	%NIVD	1B5	1I TI	
								51- f.	NBkDf	6BW6	f'VDII	1I k	
JU%N	1B6DD	NNIIB6	6'B	E	D	E	E	3 V UGS _%6N	%NIBD	%DB6B	fI T'	1BR	
								3 V UGS _%6f	%T 6f	%NIBN	1I '6	1BD	
								3 V UGS _%6I	%NIBD	%DB6I	fI T'	1BR	
								3 V UGS _%6B	5TDI	f'6B5	N I TI	1BT	
LV UGS _%6N	DWD	ND'TWN	W6	NI 6D	DEWk	E	E	3 V UGS _%6N	NI 6D	DEWk	NNW'k	1B6	
LV UGS _%6f	DWD	ND'TW5	W6	NI 6D	DEWk	E	E	3 V UGS _%6f	NI 6D	DEWk	NNW6B	1B6	
LV UGS _%6I	DWD	ND'T6fN	W6	NI 6D	DEWk	E	E	3 V UGS _%6I	NI 6D	DEWk	NNW6W	1B6	
LV UGS _%6B	DWD	ND'T6BW	W6	NI 6D	DEWk	E	E	3 V UGS _%6B	NI 6D	DEWk	NNW66	1B6	
LV UGS _%66	DWD	ND'TI I	W6	NI 6D	DEWk	E	E	3 V UGS _%66	NI 6D	DEWk	NNW'6	1B6	
LV UGS _%6W	DWD	ND'Tk'W	WB	NI 6D	DEWk	E	E	3 V UGS _%6W	NI 6D	DEWk	NNW6'B	1B6	
LV UGS _%6k	DWD	ND'TI k	WB	NI 6D	DEWk	E	E	3 V UGS _%6k	NI 6D	DEWk	NNW6TI	1B6	
LV UGS _%66	DWD	ND'TI I	W6	NI 6D	DEWk	E	E	3 V UGS _%66	NI 6D	DEWk	NNW6'6	1B6	
LV UGS _%6I	DWD	ND'TDI I	WB	NI 6D	DEWk	E	E	3 V UGS _%6I	NI 6D	DEWk	Nk'DB	1B6	
LV UGS _%6D	DWD	ND'TDN5	WB	NI 6D	DEWk	E	E	3 V UGS _%6D	NI 6D	DEWk	Nk'NB	1B6	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: f
j ate: ND%6%Dk
SF: m ES_m OOj l
AeMsion: 6Dp 0 EF
Con8gT: F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
LV UGS_ %M	DW D	ND T k6	WB	NI 6D	DEBK	L	L	3 V UGS_ %M	NI 6D	DEBK	NNKT	1B6	
LV UGS_ %B	DW D	ND T l f	WB	NI 6D	DEBK	L	L	3 V UGS_ %B	NI 6D	DEBK	NNKf	1B6	
LV UGS_ %6	DW D	ND TNk	WB	NI 6D	DEBK	L	L	3 V UGS_ %6	NI 6D	DEBK	NkDT	1B6	
LV UGS_ %W	DW D	ND T f B	WB	NI 6D	DEBK	L	L	3 V UGS_ %W	NI 6D	DEBK	NNKl	1B6	
LV UGS_ %k	DW D	ND N l f l	WB	NI 6D	DEBK	L	L	3 V UGS_ %k	NI 6D	DEBK	Nkf f	1B6	
LV UGS_ %D	DW D	ND T k l	WB	NI 6D	DEBK	L	L	3 V UGS_ %D	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %N	DW D	ND T k f	WB	NI 6D	DEBK	L	L	3 V UGS_ %N	NI 6D	DEBK	NkDk	1B6	
LV UGS_ %f	DW D	ND N l l N	WB	NI 6D	DEBK	L	L	3 V UGS_ %f	NI 6D	DEBK	NkNk	1B6	
LV UGS_ %l	DW D	ND N l 5	WB	NI 6D	DEBK	L	L	3 V UGS_ %l	NI 6D	DEBK	NkNl	1B6	
LV UGS_ %B	DW D	ND N W B	WB	NI 6D	DEBK	L	L	3 V UGS_ %B	NI 6D	DEBK	Nk6T	1B6	
LV UGS_ %6	DW D	ND N W W	WB	NI 6D	DEBK	L	L	3 V UGS_ %6	NI 6D	DEBK	Nk6f	1B6	
LV UGS_ %W	DW D	ND T 66	WB	NI 6D	DEBK	L	L	3 V UGS_ %W	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %k	DW D	ND T l B	WB	NI 6D	DEBK	L	L	3 V UGS_ %k	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %5	DW D	ND TNk	WB	NI 6D	DEBK	L	L	3 V UGS_ %5	NI 6D	DEBK	NkDT	1B6	
LV UGS_ %l	DW D	ND TN D	WB	NI 6D	DEBK	L	L	3 V UGS_ %l	NI 6D	DEBK	NkDT	1B6	
LV UGS_ %N	DW D	ND T 6 D	WB	NI 6D	DEBK	L	L	3 V UGS_ %N	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %f	DW D	ND T 6 f	WB	NI 6D	DEBK	L	L	3 V UGS_ %f	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %l	DW D	ND T f k	WB	NI 6D	DEBK	L	L	3 V UGS_ %l	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %B	DW D	ND T f f	WB	NI 6D	DEBK	L	L	3 V UGS_ %B	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %W	DW D	ND TN D	WB	NI 6D	DEBK	L	L	3 V UGS_ %W	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %k	DW D	ND TN k	WB	NI 6D	DEBK	L	L	3 V UGS_ %k	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %l	DW D	ND T 5 B	WB	NI 6D	DEBK	L	L	3 V UGS_ %l	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %D	DW D	ND TN D	WB	NI 6D	DEBK	L	L	3 V UGS_ %D	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %N	DW D	ND TN f	WB	NI 6D	DEBK	L	L	3 V UGS_ %N	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %f	DW D	ND T 66	WB	NI 6D	DEBK	L	L	3 V UGS_ %f	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %l	DW D	ND TN N	WB	NI 6D	DEBK	L	L	3 V UGS_ %l	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %B	DW D	ND T 6 W	WB	NI 6D	DEBK	L	L	3 V UGS_ %B	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %6	DW D	ND T 5 l	WB	NI 6D	DEBK	L	L	3 V UGS_ %6	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %W	DW D	ND TN W	WB	NI 6D	DEBK	L	L	3 V UGS_ %W	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %5	DW D	ND T k 5	WB	NI 6D	DEBK	L	L	3 V UGS_ %5	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %l	DW D	ND T f l	WB	NI 6D	DEBK	L	L	3 V UGS_ %l	NI 6D	DEBK	NNW T	1B6	
LV UGS_ %D	DW D	ND T k W	WB	NI 6D	DEBK	L	L	3 V UGS_ %D	NI 6D	DEBK	NNW T	1B6	
3 V UGS_ %N	1B6D	ND N k k	6D	L	D	DDDB	DDDB	3 V UGS_ %N	NI 6D	DEBK	NNW T	1B6	
3 V UGS_ %f	1B6D	ND N 6 B	6D	L	D	DDDB	DDDB	3 V UGS_ %f	NI 6D	DEBK	NNW T	1B6	
3 V UGS_ %l	1B6D	ND N l W	6D	L	D	DDDB	DDDB	3 V UGS_ %l	NI 6D	DEBK	NNW T	1B6	
3 V UGS_ %B	1B6D	ND N l W	6D	L	D	DDDB	DDDB	3 V UGS_ %B	NI 6D	DEBK	NNW T	1B6	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: 1
j ate: ND66%DNk
SF: m ES_m OOj 1
AeMsion: 6Dp 0 EF
Con8gT: F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
3 V UGS_%B	1B6DD	NNf1	6D	E	D	DDDB	DDDB	LV UGS_%A	%IB6	%DBfk	f1T	16T	
								3 V UGS_%A	%BDNW	%NBDI	kDI	1BB	
								3 V UGS_%B	6T6k	N5fW	11TW	1BR	
3 V UGS_%B	1B6DD	NNNN6	6D	E	D	DDDB	DDDB	LV UGS_%B	%IB6	%DBfk	f1T	16T	
								3 V UGS_%B	%T6N	%B5kk	11TI	1BB	
								3 V UGS_%B	WWf	fTDD	NkTN	1BW	
3 V UGS_%W	1B6DD	NNND65	BII	E	D	DDDB	DDDB	LV UGS_%B	%IB6	%DBfk	f1B	16T	
								3 V UGS_%k	NIEN	DBfI	f1T	16B	
								LV UGS_%W	%IB6	%DBfW	f1B	16T	
3 V UGS_%k	1B6DD	NNND5	BII	E	D	DDDB	DDDB	3 V UGS_%W	%IBD	%B6f	f1B	1BR	
								3 V UGS_%W	%IBD	%B51	f1TW	11TI	
								3 V UGS_%B	BDFN	NIWB	kDI	1BR	
3 V UGS_%B	1B6DD	NNND'D	6D	E	D	DDDB	DDDB	LV UGS_%k	%IB6	%DBfW	f1B	16T	
								3 V UGS_%B	%W5k	%T16	NkTK	1BN	
								3 V UGS_%A	5Df5	fBNk	NBDI	1BB	
3 V UGS_%A	1B6DD	NDf6k1	BII	E	D	DDDB	DDDB	LV UGS_%B	%IB6	%DBfW	f1B	16T	
								3 V UGS_%B	%DN5	%TI1N	NBNW	11TI	
								3 V UGS_%D	1T61	1T6B	NW5I	1BN	
3 V UGS_%D	1B6DD	NDK1k	BII	E	D	DDDB	DDDB	LV UGS_%A	%IB6	%DBfW	f1B	16T	
								3 V UGS_%A	%T61	%BBD	NW5B	11TI	
								3 V UGS_%6	NDWB	1fW	N5f5	1BN	
3 V UGS_%A	1B6DD	NNNN65	BII	E	D	DDDB	DDDB	LV UGS_%D	%IB6	%DBfW	f1B	16T	
								3 V UGS_%B	NIEN	DBfI	f1T	16B	
								LV UGS_%A	%IB6	%DBfk	f1T	16T	
3 V UGS_%B	1B6DD	NNNNB	BII	E	D	DDDB	DDDB	3 V UGS_%A	%IBD	%B66	f1B	1BR	
								3 V UGS_%B	fTW5N	D5k5	BWk	16D	
								LV UGS_%B	%IB6	%DBfk	f1B	16T	
3 V UGS_%B	1B6DD	NDf51k	BII	E	D	DDDB	DDDB	3 V UGS_%k	%BDNW	%BfW	kDK	1BT	
								3 V UGS_%B	%TK6	%D165	BkTN	1BN	
								3 V UGS_%k	5DI1	fBNk	NBNf	1BB	
3 V UGS_%W	1B6DD	NNNDW	BII	E	D	DDDB	DDDB	LV UGS_%B	%IB6	%DBfW	f1B	16T	
								3 V UGS_%k	NIEN	DBfI	f1T	16B	
								LV UGS_%W	%IB6	%DBfk	f1B	16T	
3 V UGS_%k	1B6DD	NDKDD	BII	E	D	DDDB	DDDB	JU%/N	1TVD	1T1k	NW55	1BD	
								3 V UGS_%B	%DN1	%TIkB	NBfTN	11f5	
								LV UGS_%k	%IB6	%DBfW	f1B	16T	
3 V UGS_%D	1B6DD	NDI16B	B5	E	D	DDDB	DDDB	3 V UGS_%N	NIEN	DBfI	f1T	16B	
								LV UGS_%D	%IB6	%DBfW	f1B	16T	
								3 V UGS_%D	%IBD	%B11	f1TK	11TK	

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: B
j ate: ND66%DNk
SF: m ES_m OOj l
AeMsion: 6Dp 0 EF
Con8gT: F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
3 V UGS_%f	1B6DD	NDKkW	BII	E	D	DDB	DDB	3 V UGS_%f	fTW6N	DII fN	EKTD	1BW	
								LV UGS_%N	%NIB6	%DBfW	fIIB	16T	
								JU%/N	6TI61	NE56	1BT	1BT	
								3 V UGS_%N	%TK5	%DI6N	EKT	1BT	
3 V UGS_%I	1B6DD	NDKkW	BII	E	D	DDB	DDB	3 V UGS_%I	%NII1	%DBNf	fIIB	11B	
								LV UGS_%f	%NIB6	%DBfW	fIIB	16T	
								51- I.	NBRDI	6TDN	fVDR	11R	
								3 V UGS_%5	%NTW	%DK5	fIkB	11B	
3 V UGS_%B	1B6DD	NDI61	B5	E	D	DDB	DDB	LV UGS_%I	%NIB6	%DBfW	fIIB	16T	
								3 V UGS_%6	NIBN	DBfI	fIIB	16B	
								LV UGS_%B	%NIB6	%DBfW	fIIB	16T	
								51- N	N TIRk	6TIRk	fI5R	11T	
3 V UGS_%6	1B6DD	NDI6W	B5	E	D	DDB	DDB	3 V UGS_%D	%DIW6	%BTDI	NIRK	1fR	
								3 V UGS_%B	%NIBN	%DBW6	fIIR	1B6	
								LV UGS_%6	%NIB6	%DBfW	fIIB	16T	
								3 V UGS_%k	NIBN	DBfI	fIIT	16B	
3 V UGS_%W	1B6DD	NNI6W	6D	E	D	DDB	DDB	LV UGS_%W	%NIB6	%DBfW	fIIB	16T	
								3 V UGS_%k	%NIBD	%DBWN	fIIB	1BW	
								3 V UGS_%5	fTW6N	DE5B	BW6	16D	
								LV UGS_%k	%NIB6	%DBfW	fIIB	16T	
3 V UGS_%5	1B6DD	NDI5k	6D	E	D	DDB	DDB	3 V UGS_%I	N Tki	BIBD	fIIR	11B	
								3 V UGS_%k	%TKI	%DIIN	EKTD	1BW	
								3 V UGS_%I	%TI61	%TI5	NWIR	11T	
								LV UGS_%5	%NIB6	%DBfW	fIIB	16T	
3 V UGS_%I	1B6DD	NDI6D	BII	E	D	DDB	DDB	3 V UGS_%f	NIBN	DBfI	fIIT	16B	
								LV UGS_%I	%NIB6	%DBfW	fIIB	16T	
								3 V UGS_%f	NIBN	DBfI	fIIT	16B	
								LV UGS_%N	%NIB6	%DBfk	fIIT	16T	
3 V UGS_%f	1B6DD	NNI56	6D	E	D	DDB	DDB	3 V UGS_%N	%NII1	%DI61	fIIB	1fII	
								3 V UGS_%I	fTW6D	DII65	EKTN	1BT	
								LV UGS_%f	%NIB6	%DBfk	fIIT	16T	
								3 V UGS_%5	ITkD	ITWB	NW65	1BN	
3 V UGS_%I	1B6DD	NNI6D	6N	E	D	DDB	DDB	3 V UGS_%f	%TK5	%DI5W	EKT	11B	
								3 V UGS_%B	%TI6N	%NII66	1BT	11II	
								LV UGS_%I	%NIB6	%DBfk	fIIB	16T	
								3 V UGS_%I	6TI6W	NIIIN	1BD	1BT	
3 V UGS_%B	1B6DD	NNI6W	6N	E	D	DDB	DDB	3 V UGS_%W	%TKW	%DIIB6	BWII	1BT	
								3 V UGS_%I	%NII1	%DI66	fIIT	1fTW	
								LV UGS_%B	%NIB6	%DBfk	fIIT	16T	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ile na2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: 6
j ate: ND66%DNk
SF: m ES_m OOj l
AeMsion: 6Dp 0 EF
Con8gT F or2 al

Bus		Voltage			Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4	
3 V UGS _%W	1B6DD	NDN11W	6D	E	D	DDDB	DDDB	3 V UGS _%B	fTW6N	DEk6B	BW6	16TN		
								3 V UGS _%k	%NIBD	%DB6N	f11T	1B6		
								LV UGS _%W	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%k	1B6DD	NDN11I	6D	E	D	DDDB	DDDB	3 V UGS _%W	NIBN	DBf1	f11T	16B		
								LV UGS _%k	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%1	1B6DD	NDN1kD	6D	E	D	DDDB	DDDB	3 V UGS _%B	NIBN	DBf1	f11T	16B		
								LV UGS _%1	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%BD	1B6DD	NDNBBW	6T	E	D	DDDB	DDDB	51- B	N T61	6Tk1	f16K	116		
								3 V UGS _%BW	%NTDN5	%BTW6D	fNTW	11T		
								LV UGS _%BD	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%BN	1B6DD	NDN15B	6B	E	D	DDDB	DDDB	JU%BN	NIBN	DBf1	f11TN	16B		
								LV UGS _%BN	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%Bf	1B6DD	NDN1BW	6B	E	D	DDDB	DDDB	JU%BN	6T6f	NIBD	11TB	1BD		
								3 V UGS _%B1	%BDNN	%B6Nk	kDB	116		
								LV UGS _%Bf	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%B1	1B6DD	NDN151	6B	E	D	DDDB	DDDB	JU%BN	NIBN	DBf1	f11TN	16B		
								LV UGS _%B1	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%BB	1B6DD	NDNK1W	6T	E	D	DDDB	DDDB	JU%BN	%DT1	%TtkD	NBDW	116		
								3 V UGS _%B6	1TVB	1T1B	NWTK	1BD		
								LV UGS _%BB	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%B6	1B6DD	NDN165	6T	E	D	DDDB	DDDB	3 V UGS _%BB	%T6W	%T6NN	NWB6	11TW		
								3 V UGS _%BW	NBWk	1T1B	N6kTW	11T		
								LV UGS _%B6	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%BW	1B6DD	NDN6B5	6T	E	D	DDDB	DDDB	3 V UGS _%BD	N Tfk	B61k	fNN6	11TW		
								3 V UGS _%B6	%NDW6W	%BNNB	N5TK	11T		
								LV UGS _%BW	%NIB6	%DBf6k	f11T	16T		
3 V UGS _%B5	1B6DD	ND Tfk1	6B	E	D	DDDB	DDDB	3 V UGS _%B1	NIBN	DBfB	f11D	16B		
								LV UGS _%B5	%NIB6	%DBf6k	f11TN	16T		
3 V UGS _%B1	1B6DD	ND TtfB	6B	E	D	DDDB	DDDB	3 V UGS _%Bf	BDf6f	NIB6	WB	1B6		
								3 V UGS _%B5	%NIBD	%BWN	f11T	1BW		
								3 V UGS _%D	%NIBD	%BWD	f11T	1BW		
								LV UGS _%B1	%NIB6	%DBf6k	f11TN	16T		
3 V UGS _%D	1B6DD	ND TfkN	6B	E	D	DDDB	DDDB	3 V UGS _%B1	NIBN	DBfB	f11D	16B		
								LV UGS _%D	%NIB6	%DBf6k	f11TN	16T		
* POv	N 5TDD	ND DDD	DD	%66KNk	%5T11		E	51_N	%66KNk	%5T11	fB6B	16D		
3 P_~I	N 5DD	ND Bfk	6TN	E	D	E	E	HV UGS 3 P_	DDDD	DDDD	DD	DD		
								& 51_NU						

* indicates a Moltage regulated bus (Moltage controlled or swing ty4e 2 achine connected to it)
indicates a bus with a load 2 is2 atch o82 ore than DN3 V.

Project: Fm OH m EF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I lilena- e: F m 2OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: 0
j ate: 0DD%wfDDk
SF : m ES_m OOj P
AeMsion: Qp . EF
Con&gT F or- al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
Bj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	Bj	3 m	3 Mr	6 - 4	p PI	p_a4	
5N 06	B%GDD	0DDDD%	%K	E	D	E	E	3 V U1 S _vfG	v0BBB0	vGP4DG	f%DIG	N`R		
								5N_0U	0BBB0	GP4DG	f%DIG	N`R		
5N f6	B%GDD	0DDDD%	%K	E	D	E	E	JUvf/0	v0%AWW5	vG5fG	f%VB5	N`TN		
								5N_0U	0%AWW5	G5fG	f%VB5	N`TN		
5N B6	B%GDD	0DDDD%	%K	E	D	E	E	3 V U1 S _vfB	v0%AVD	vWDN	f%VGD	N`T%		
								5N_0U	0%AVD	WDN	f%VGD	N`T%		
5N %6	B%GDD	0DDDD%	%K	E	D	E	E	3 V U1 S _v%0	v0BFGf	vW%GN	f%W%	5NN		
								5N_0U	0BFGf	W%GN	f%W%	5NN		
5N_06	0B5TDD	NGEDG	DD	E	D	E	E	POR	CGKff	05TBD5	fG5TB	NGD		
								HV U1 S 3 P_	vCGKff	v05TBD5	fG5TB	NGD		
5N_0U	B%GDD	0DDDD%	%K	E	D	E	E	5N %6	v0BFGf	vW%GN	f%W%	5NN		
								5N B6	v0%AVD	vWDN	f%VGD	N`T%		
								5N f6	v0%AWW5	vG5fG	f%VB5	N`TN		
								5N 06	v0BBB0	vGP4DG	f%DIG	N`R		
								3 P_~B	CGND	fBRBk	0DGB	N`D		
								& HV U1 S 3 P_						
HV U1 S 3 P_	0B5TDD	NGEDG	DD	E	D	DD%	DDBB	5N_06	CGKff	05TBD5	fG5TB	NGD		
								5N_0U	vCGKkd	v05T04	fG5T	N`N	v0TkG	
								& 3 P_~B						
JUvf/0	B%GDD	0DDP8%	%N	E	D	E	E	3 V U1 S _v0k	vNBGf	vBTGf	0VW%	NBIV		
								3 V U1 S _vff	vGBGD	v0TGN	N`GN	NBN		
								5N f6	0%KdF	GPW0	f%WB	NBR		
JUv%0	B%GDD	0DDTKNB	GP%	E	D	E	E	3 V U1 S _v%0	v0TB%D	vDP4GB	fBB	N`K		
								3 V U1 S _v%4	vGBGf	v0TN%D	NBIV	N`D		
								3 V U1 S _v%B	v0TB%D	vDP4GB	fBB	N`K		
								3 V U1 S _v%8	5TBB	fT5%W	0%DD	N`B		
LV U1 S _vD	DMND	0DfT0D	WG	0TBGD	DPW%	E	E	3 V U1 S _vD0	0TBGD	DPW%	00VG%	N`G		
LV U1 S _vDf	DMND	0DfTpk5	WG	0TBGD	DPW%	E	E	3 V U1 S _vDf	0TBGD	DPW%	00VWD	N`G		
LV U1 S _vDB	DMND	0DfTBk0	WG	0TBGD	DPW%	E	E	3 V U1 S _vDB	0TBGD	DPW%	00VKB	N`G		
LV U1 S _vD%	DMND	0DfTFNG	WG	0TBGD	DPW%	E	E	3 V U1 S _vD%	0TBGD	DPW%	00V8T	N`G		
LV U1 S _vDG	DMND	0DfTD5f	WG	0TBGD	DPW%	E	E	3 V U1 S _vDG	0TBGD	DPW%	00VNG	N`G		
LV U1 S _vDW	DMND	0DfTdfG	W%	0TBGD	DPW%	E	E	3 V U1 S _vDW	0TBGD	DPW%	00kDD	N`G		
LV U1 S _vDk	DMND	0DfTD5W	WG	0TBGD	DPW%	E	E	3 V U1 S _vDk	0TBGD	DPW%	00kDW	N`G		
LV U1 S _vD5	DMND	0DfTD5	WG	0TBGD	DPW%	E	E	3 V U1 S _vD5	0TBGD	DPW%	00kDW	N`G		
LV U1 S _vDN	DMND	0DfT05	WG	0TBGD	DPW%	E	E	3 V U1 S _vDN	0TBGD	DPW%	00kfT	N`G		
LV U1 S _v0D	DMND	0DfT5W%	W%	0TBGD	DPW%	E	E	3 V U1 S _v0D	0TBGD	DPW%	00kBD	N`G		

Project: Fm OH m EF j

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

0WDEC

Study Case: NGP1_NGL6.

Page: f

Project: 0DD%afDDk

SF: mES_mOOj P

Assignment: Qp . EF

Configuration: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	6 - 4	p PI	p _a4
LV U1 S _vOB	DIWND	0DfTf%	WE%	0fBGD	DEP%	E	E	3 V U1 S _vOB	0fBGD	DEP%	00VND	N%G	
LV U1 S _v0%	DIWND	0DfTD50	WE%	0fBGD	DEP%	E	E	3 V U1 S _v0%	0fBGD	DEP%	00VNG	N%G	
LV U1 S _v0G	DIWND	0DDfNW	WE%	0fBGD	DEP%	E	E	3 V U1 S _v0G	0fBGD	DEP%	00kfTD	N%G	
LV U1 S _v0W	DIWND	0DfTDkB	WE%	0fBGD	DEP%	E	E	3 V U1 S _v0W	0fBGD	DEP%	00VNW	N%G	
LV U1 S _v0k	DIWND	0DDfTk0	WE%	0fBGD	DEP%	E	E	3 V U1 S _v0k	0fBGD	DEP%	00k%af	N%G	
LV U1 S _vfD	DIWND	0DfTDf	WE%	0fBGD	DEP%	E	E	3 V U1 S _vfD	0fBGD	DEP%	00k0fB	N%G	
LV U1 S _vf0	DIWND	0DDfNf0	WE%	0fBGD	DEP%	E	E	3 V U1 S _vf0	0fBGD	DEP%	00kfTG	N%G	
LV U1 S _vff	DIWND	0DDfBN	WE%	0fBGD	DEP%	E	E	3 V U1 S _vff	0fBGD	DEP%	00kBP%	N%G	
LV U1 S _vfB	DIWND	0DDfB%W	WG	0fBGD	DEP%	E	E	3 V U1 S _vfB	0fBGD	DEP%	00kBB	N%G	
LV U1 S _vf%	DIWND	0DDfCB	WB	0fBGD	DEP%	E	E	3 V U1 S _vf%	0fBGD	DEP%	00kkTD	N%G	
LV U1 S _vfG	DIWND	0DDfGN	WB	0fBGD	DEP%	E	E	3 V U1 S _vfG	0fBGD	DEP%	00kkT	N%G	
LV U1 S _vfW	DIWND	0DfTD%	WG	0fBGD	DEP%	E	E	3 V U1 S _vfW	0fBGD	DEP%	00kDP%	N%G	
LV U1 S _vfk	DIWND	0DfTDB	WG	0fBGD	DEP%	E	E	3 V U1 S _vfk	0fBGD	DEP%	00k0TD	N%G	
LV U1 S _vf5	DIWND	0DDfNGW	WG	0fBGD	DEP%	E	E	3 V U1 S _vf5	0fBGD	DEP%	00kfTD	N%G	
LV U1 S _vfN	DIWND	0DDfGN	WE%	0fBGD	DEP%	E	E	3 V U1 S _vfN	0fBGD	DEP%	00kfTD	N%G	
LV U1 S _vB0	DIWND	0DfTBD	WG	0fBGD	DEP%	E	E	3 V U1 S _vB0	0fBGD	DEP%	00VBD	N%G	
LV U1 S _vBf	DIWND	0DfTGD	VWV	0fBGD	DEP%	E	E	3 V U1 S _vBf	0fBGD	DEP%	00VBR	N%G	
LV U1 S _vBB	DIWND	0DfTDkW	VWV	0fBGD	DEP%	E	E	3 V U1 S _vBB	0fBGD	DEP%	00VNW	N%G	
LV U1 S _vB%	DIWND	0DfTk0	VWV	0fBGD	DEP%	E	E	3 V U1 S _vB%	0fBGD	DEP%	00VBTG	N%G	
LV U1 S _vBW	DIWND	0DfTBW	VWV	0fBGD	DEP%	E	E	3 V U1 S _vBW	0fBGD	DEP%	00VWB	N%G	
LV U1 S _vBk	DIWND	0DfTBk	WG	0fBGD	DEP%	E	E	3 V U1 S _vBk	0fBGD	DEP%	00VGN	N%G	
LV U1 S _vBN	DIWND	0DfTB%	VWV	0fBGD	DEP%	E	E	3 V U1 S _vBN	0fBGD	DEP%	00VNW	N%G	
LV U1 S _vBD	DIWND	0DfTGN	VK	0fBGD	DEP%	E	E	3 V U1 S _vBD	0fBGD	DEP%	00VGR	N%G	
LV U1 S _vB0	DIWND	0DBDf	VS	0fBGD	DEP%	E	E	3 V U1 S _vB0	0fBGD	DEP%	00GNK	N%G	
LV U1 S _vBf	DIWND	0DBDfG	VS	0fBGD	DEP%	E	E	3 V U1 S _vBf	0fBGD	DEP%	00VDD	N%G	
LV U1 S _vBB	DIWND	0DBDf0	VS	0fBGD	DEP%	E	E	3 V U1 S _vBB	0fBGD	DEP%	00GNK	N%G	
LV U1 S _vB%	DIWND	0DfTBGW	VS	0fBGD	DEP%	E	E	3 V U1 S _vB%	0fBGD	DEP%	00VBT	N%G	
LV U1 S _vBG	DIWND	0DfTB%N	VS	0fBGD	DEP%	E	E	3 V U1 S _vBG	0fBGD	DEP%	00VBD	N%G	
LV U1 S _vBW	DIWND	0DfTBW	VK	0fBGD	DEP%	E	E	3 V U1 S _vBW	0fBGD	DEP%	00VWV	N%G	
LV U1 S _vB5	DIWND	0DBBf5	VS	0fBGD	DEP%	E	E	3 V U1 S _vB5	0fBGD	DEP%	00GAG	N%G	
LV U1 S _vBN	DIWND	0DBBf5D	VS	0fBGD	DEP%	E	E	3 V U1 S _vBN	0fBGD	DEP%	00CKD	N%G	
LV U1 S _vBD	DIWND	0DBBfW	VS	0fBGD	DEP%	E	E	3 V U1 S _vBD	0fBGD	DEP%	00GAG	N%G	
3 V U1 S _vD0	BfAGD	0DDfBG	GD	E	D	DDD%	DDD%	3 V U1 S _vDf	0fBf0	DEfB	fBf	NGE%	
3 V U1 S _vDf	BfAGD	0DDfW	GD	E	D	DDD%	DDD%	LV U1 S _vD0	v0fBfG	vDEfBk	fBB	NGB	
								3 V U1 S _vD0	v0fBfD	vDEk0	fBG	NGE%	
								3 V U1 S _vDB	fTBf0	DEfNB	%MK	NGN	
3 V U1 S _vDB	BfAGD	0DDfD%	GD	E	D	DDD%	DDD%	LV U1 S _vDf	v0fBfG	vDEfBk	fBB	NGB	
								3 V U1 S _vD%	vfTBk5	vDfNB	%MN	NGE%	
								3 V U1 S _vD%	%DDN	0fBGW	kDf	NfB	

Project: Fm OH m EF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File name: Fm2OH

ETAP
0WDEC

Study Case: NGP1_NGL6.

Page: B
j ate: 0DD%afDDk
SF: mES_mOOj P
AeMsion: Qp . EF
Con&gT F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	6 - 4	p PI	p_a4
3 V U1 S_vD%	B%GDD	0DDTEkk	GD	E	D	DDD%	DDD%	LV U1 S_vDB	vDB%G	vDB%k	fBB	NGB	
								3 V U1 S_vDB	v%DDW	vDB%F	kDB%	NB%	
								3 V U1 S_vDG	GBGk	DBfG	NBk	NB%	
3 V U1 S_vDG	B%GDD	0DDNWB	GD	E	D	DDD%	DDD%	LV U1 S_vD%	vDB%G	vDB%W	fBB%	NGB	
								3 V U1 S_vD%	vGBG	vBkW	NB	NB%	
								3 V U1 S_vD\$	WWN	fTN	00kB	NB%	
3 V U1 S_vDW	B%GDD	0DDNDG	%N	E	D	DDD%	DDD%	LV U1 S_vDG	vDB%G	vDB%W	fBB%	NGB	
								3 V U1 S_vDk	DB%0	DB%B	fBB	NG%	
								LV U1 S_vDW	vDB%G	vDB%W	fBB%	NGB	
3 V U1 S_vDk	B%GDD	0DD\$VG	%N	E	D	DDD%	DDD%	3 V U1 S_vDW	vDB%D	vDB%G	fBG	NB%	
								3 V U1 S_v0W	vDB%D	vDB%5	fBk	NB%	
								3 V U1 S_v0G	%DF0	DBWB	kDB%	NB%	
3 V U1 S_vD\$	B%GDD	0DD\$Wk	GD	E	D	DDD%	DDD%	LV U1 S_vDk	vDB%G	vDB%W	fBB%	NGB	
								3 V U1 S_vDG	vWB%k	vTNB	00k5	NB%	
								3 V U1 S_vDN	5DF5	fB0W	0%0D	NB%	
3 V U1 S_vDN	B%GDD	0DDkFW	GD	E	D	DDD%	DDD%	LV U1 S_vD\$	vDB%G	vDB%W	fBB%	NGB	
								3 V U1 S_vD\$	v5D05	vTN	0%05	NBN	
								3 V U1 S_v0D	NBGN	BBG	0VGF	NB%	
3 V U1 S_v0D	B%GDD	0DDW%	%N	E	D	DDD%	DDD%	LV U1 S_vDN	vDB%G	vDB%W	fBB%	NGB	
								3 V U1 S_vDN	vNBG	vB%B5	0VGR	NBN	
								3 V U1 S_vfG	0DWN%	B5WD	05ND	NB%	
3 V U1 S_v0B	B%GDD	0DDTDW	%N	E	D	DDD%	DDD%	LV U1 S_v0D	vDB%G	vDB%W	fBG	NGB	
								3 V U1 S_v0%	DB%0	DB%B	fBB	NG%	
								LV U1 S_v0B	vDB%G	vDB%W	fBB%	NGB	
3 V U1 S_v0%	B%GDD	0DDN%	%N	E	D	DDD%	DDD%	3 V U1 S_v0B	vDB%D	vDB%G	fBG	NB%	
								3 V U1 S_v0G	fWB0	DBk5	%WB	NGD	
								LV U1 S_v0%	vDB%G	vDB%W	fBB%	NGB	
3 V U1 S_v0G	B%GDD	0DDk%	%N	E	D	DDD%	DDD%	3 V U1 S_vDk	v%DDW	vDB%G	kDN	NB%	
								3 V U1 S_v0%	vTNkG	vDNGk	%kT	NB%	
								3 V U1 S_v0k	5DBB	fB0G	0%0%	NB%	
3 V U1 S_v0W	B%GDD	0DDNG%	%N	E	D	DDD%	DDD%	LV U1 S_v0G	vDB%G	vDB%W	fBB%	NGB	
								3 V U1 S_vDk	DB%0	DB%B	fBB	NG%	
								LV U1 S_v0W	vDB%G	vDB%W	fBB%	NGB	
3 V U1 S_v0k	B%GDD	0DDG%k	%N	E	D	DDD%	DDD%	JUvf0	NBWD	BENG	0VGR	NB%	
								3 V U1 S_v0G	v5D0N	vTNkf	0%TB	NB%	
								LV U1 S_v0k	vDB%G	vDB%W	fBG	NGB	
3 V U1 S_vfD	B%GDD	0DD\$D	%N	E	D	DDD%	DDD%	3 V U1 S_vf0	DB%0	DB%B	fBB	NG%	
								LV U1 S_vfD	vDB%G	vDB%W	fBB%	NGB	
								3 V U1 S_vfD	vDB%D	vDB%5	fB5	NBk	

Project: Fm OH m Fj
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I l ena- e: F m2OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: %
j ate: 0DD%afDDk
SF : m ES_m OOj P
AeMsion: Qp . EF
Con&gT F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	6 - 4	p PI	p _a4
3 V U1 S _vf f	B/4GD	0DDW0W	%N	E	D	DDD%	DDD%	3 V U1 S _vf f	fTW0	DN0	%kD	N04W	
								LV U1 S _vf0	v0B4G	vD44W	fB4%	NGB	
								JUvf/0	GBGN	0B5%	N04G	N04B	
								3 V U1 S _vf0	vfTW5	vDNGD	%kTB	N04F	
3 V U1 S _vfB	B/4GD	0DDWB	GD	E	D	DDD%	DDD%	3 V U1 S _vfN	v0BBN	vDC00	fB5	NB4%	
								LV U1 S _vf f	v0B4G	vD44W	fB4G	NGB	
								5N B6	044B	GP4k	fW0D	NB4	
								3 V U1 S _vf5	v0BBW	vG4k%	fB4K	NB4	
3 V U1 S _vf%	B/4GD	0DDBW	%B	E	D	DDD%	DDD%	LV U1 S _vfB	v0B4G	vD44W	fB4G	NGB	
								3 V U1 S _vfG	0B40	D44f	fB4G	NG4%	
								LV U1 S _vf%	v0B4G	vD44W	fB4G	NGB	
								5N 06	0BB4k	GDNB	fBND	NB4	
3 V U1 S _vfW	B/4GD	0DD5%	GD	E	D	DDD%	DDD%	3 V U1 S _v0D	v0DWG	v4BDG	0N0N	N4K	
								3 V U1 S _vf%	v0B40	vD44G	fB4	N04G	
								LV U1 S _vfG	v0B4G	vD44W	fB4G	NGB	
								3 V U1 S _vfk	0B40	D44B	fBB	NG4%	
3 V U1 S _vf k	B/4GD	0DDB4f	GD	E	D	DDD%	DDD%	LV U1 S _vfW	v0B4G	vD44W	fB4%	NGB	
								3 V U1 S _vfW	v0B4D	vD44W	fB4G	N04W	
								3 V U1 S _vf5	fTW0	D55B	%4N	NGD	
								LV U1 S _vf k	v0B4G	vD44W	fB4%	NGB	
3 V U1 S _vf5	B/4GD	0DDK4%	GD	E	D	DDD%	DDD%	3 V U1 S _vfB	0BB4B	%4Bk	fB45	NB5	
								3 V U1 S _vf k	vfTWK	vDN0N	%kD	N04W	
								3 V U1 S _vBB	vNBGB	vB4NG	0W4G	NBB	
								LV U1 S _vf5	v0B4G	vD44W	fB4%	NGB	
3 V U1 S _vfN	B/4GD	0DDK4k	%N	E	D	DDD%	DDD%	3 V U1 S _vf f	0B40	D44B	fB4%	NG4%	
								LV U1 S _vfN	v0B4G	vD44W	fB4%	NGB	
								3 V U1 S _vBf	0B40	D44B	fBB	NG4%	
								LV U1 S _vB0	v0B4G	vD44k	fBB	NGB	
3 V U1 S _vBf	B/4GD	0DD4Bf	GD	E	D	DDD%	DDD%	3 V U1 S _vB0	v0BBN	vDC4%	fBN	N4N	
								3 V U1 S _vBB	fTW5D	D4k	%kD	N04F	
								LV U1 S _vBf	v0B4G	vD44W	fB4%	NGB	
								3 V U1 S _v5	NB4D	BBW	0VGD	N04D	
3 V U1 S _vBB	B/4GD	0DDNGW	GD	E	D	DDD%	DDD%	3 V U1 S _vBf	vfTW5	vDN5G	%kTB	NBN	
								3 V U1 S _vB%	vGBD	v0NG%	N04%	NBN	
								LV U1 S _vBB	v0B4G	vD44W	fB4%	NGB	
								3 V U1 S _vBB	GBGW	0N00	N04F	N04F	
3 V U1 S _vB%	B/4GD	0DD4CB	GD	E	D	DDD%	DDD%	3 V U1 S _vBW	vfTWW	vDN4%	%kD	N04B	
								3 V U1 S _vBN	v0BBN	vDC4G	fBN	N4W	
								LV U1 S _vB%	v0B4G	vD44W	fB4%	NGB	

Project: Fm OH m Fj
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File name: Fm2OH

ETAP
0WDEC

Page: G
Date: 0DD%afDDk
Sheet: mES_mOOj P
Revision: Qp . EF
Comment: For- al

Study Case: NGP1 NGL6 .

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	B	3 m	3 Mr	6 - 4	p PI	p _a4
3 V U1 S _vBW	B%GDD	0DDTF%	GD	E	D	DDD%	DDD%	3 V U1 S _vB%	fTW%0	D%k%	%MW	NGD	
								3 V U1 S _vBk	vTB%4D	vD%4D	fB%0	N%5	
								LV U1 S _vBW	vTB%G	vD%4k	fBB	NGB	
3 V U1 S _vBk	B%GDD	0DDTF50	GD	E	D	DDD%	DDD%	3 V U1 S _vBW	0TB%0	D%4B	fBT	NG%	
								LV U1 S _vBk	vTB%G	vD%4k	fBB	NGB	
3 V U1 S _vBN	B%GDD	0DDTF0k	GD	E	D	DDD%	DDD%	3 V U1 S _vB%	0TB%0	D%4B	fBT	NG%	
								LV U1 S _vBN	vTB%G	vD%4k	fBB	NGB	
3 V U1 S _v%0	B%GDD	0DDTFN%	GT	E	D	DDD%	DDD%	5N %	0B%05	GDW	fB%0	NBG	
								3 V U1 S _v%W	v%TD%5	v%W%W	f%TD%	NBB	
								LV U1 S _v%0	vTB%G	vD%4k	fBB	NGB	
3 V U1 S _v%0	B%GDD	0DDTFBB	GP%	E	D	DDD%	DDD%	JUv%0	0TB%0	D%4B	fBD	NG%	
								LV U1 S _v%0	vTB%G	vD%4k	fBT	NGB	
3 V U1 S _v%4	B%GDD	0DDTKNG	GP%	E	D	DDD%	DDD%	JUv%0	GB%0	0T%N	N%W	N%4D	
								3 V U1 S _v%N	v%TD%0	v%TD%W	kDG	NBG	
								LV U1 S _v%4	vTB%G	vD%4k	fBT	NGB	
3 V U1 S _v%B	B%GDD	0DDTFB0	GP%	E	D	DDD%	DDD%	JUv%0	0TB%0	D%4B	fBD	NG%	
								LV U1 S _v%B	vTB%G	vD%4k	fBT	NGB	
3 V U1 S _v%%	B%GDD	0DDTW%	GB	E	D	DDD%	DDD%	JUv%0	v%TD%f	v%TW%	0%45	NB5	
								3 V U1 S _v%G	N%W	B%N	0W%4D	N%4D	
								LV U1 S _v%%	vTB%G	vD%4k	fBT	NGB	
3 V U1 S _v%G	B%GDD	0DDTKBW	GB	E	D	DDD%	DDD%	3 V U1 S _v%%	vNB%G	vB%DN	0W%4k	N%W	
								3 V U1 S _v%W	0D%W	B%N	05k%5	NBN	
								LV U1 S _v%G	vTB%G	vD%4k	fBB	NGB	
3 V U1 S _v%W	B%GDD	0DDTENW	GB	E	D	DDD%	DDD%	3 V U1 S _v%0	0f%TD%W	%4B%	f%TD%	N%W	
								3 V U1 S _v%G	v%TD%W	v%4D%0	05ND	NBB	
								LV U1 S _v%W	vTB%G	vD%4k	fBB	NGB	
3 V U1 S _v%5	B%GDD	0DDTdf0	GP%	E	D	DDD%	DDD%	3 V U1 S _v%N	0TB%0	D%4B	fBD	NG%	
								LV U1 S _v%5	vTB%G	vD%4k	fBD	NGB	
3 V U1 S _v%N	B%GDD	0DDTKkB	GP%	E	D	DDD%	DDD%	3 V U1 S _v%4	%4D%f	0TB%0	WNG	N%5	
								3 V U1 S _v%5	vTB%0	vD%4W	fBT	N%4W	
								3 V U1 S _vGD	vTB%0	vD%4W	fBT	N%4W	
								LV U1 S _v%N	vTB%G	vD%4k	fBD	NGB	
3 V U1 S _vGD	B%GDD	0DDTdfD	GP%	E	D	DDD%	DDD%	3 V U1 S _v%N	0TB%0	D%4B	fBD	NG%	
								LV U1 S _vGD	vTB%G	vD%4k	fBD	NGB	
* POR	0B%TD	NGDD	DD	vGGkf0	v%5BDW	E	E	5N_06	vGGkf0	v%5BDW	f%5B	NGD	
3 P_~B	0B%TD	0DD%kB	GT	E	D	E	E	HV U1 S 3 P_	DDDD	DDDD	DD	DD	
								& 5N_0U					

* Indicates a Voltage regulated bus (Voltage controlled or swing ty4e - achine connected to it)
Indicates a bus with a load - is- atch o8- ore than DD 3 V6

Project: Fm OH m EF 0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: N

Date: NND6v9DN

SF: mES_mOO0j

Revision: 6DM p EF

Configuration: For- al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4	
511N	jB5DD	11T6B	BTW	E	D	E	E	3 V UGS_v%6	vN Tjj	j Tj B	% Df	vW5		
								51_NU	N Tjj	vj Tj B	% Df	vW5		
511%	jB5DD	11T6B	BTW	E	D	E	E	JUV%N	vBWD	j T1f	%BB	vWV		
								51_NU	NWD	vj T1f	%BB	vWV		
511j.	jB5DD	11T6B	BTW	E	D	E	E	3 V UGS_v%4	vB%6	j TWf	%j %	vlfD		
								51_NU	NB%6	vj TWf	%j %	vlfD		
511B	jB5DD	11T6B	BTW	E	D	E	E	3 V UGS_vBD	vN P%Y	%4 1f	%6T	v5B		
								51_NU	N P%Y	v%4 1f	%6T	v5B		
51_N	N5IDD	11T15	DD	E	D	E	E	POR	66TBl	vN5T%B	%B6T	v6D		
								HV UGS 3 P_	v66TBl	N5T%B	%B6T	v6D		
51_NU	jB5DD	11T6B	BTW	E	D	E	E	511B	vN P%Y	%4 1f	%6T	v5B		
								511j.	vB%6	j TWf	%j %	vlfD		
								511%	vBWD	j T1f	%BB	vWV		
								511N	vN Tjj	j Tj B	% Df	vW5		
								3 P_~j	66T%D	vN TDW	1VjT	vlfT%		
								& HV UGS 3 P_						
HV UGS 3 P_	N5IDD	11T15	DD	E	D	DD6j	DNB	51_N	66TBl	vN5T%B	%B6T	v6D		
								51_NU	v66TD%	N5Tf	%B6T	v6TN	vN5f6	
								& 3 P_~j						
JUV%N	jB5DD	11TWN	BT	E	D	E	E	3 V UGS_vNf	vTj6j	%B%6	NW%l	vWN		
								3 V UGS_v%%	v6T6D	N6fW	lj B	v6T		
								511%	NBTD%	vBP%N	%6Vj	vWD		
JUV%N	jB5DD	NDBI W	6TW	E	D	E	E	3 V UGS_vBN	vNj BD	DEj N	% B	v6T%		
								3 V UGS_vB%	v6T6%	NW%N	lj D	v6T		
								3 V UGS_vBj	vNj BD	DEj %	% B	v6T%		
								3 V UGS_vBB	5Tj %	v%BWj	Nj 1T	v6TW		
LV UGS_vDN	DWD	11T%4	Wl	Nj 6D	vDEN6	E	E	3 V UGS_vDN	Nj 6D	vDEN6	N5%4j	v6TW		
LV UGS_vD%	DWD	11Tfj	W5	Nj 6D	vDEN6	E	E	3 V UGS_vD%	Nj 6D	vDEN6	N5j D	v6TW		
LV UGS_vDj	DWD	11Tf5	W5	Nj 6D	vDEN6	E	E	3 V UGS_vDj	Nj 6D	vDEN6	N5BN	v6TW		
LV UGS_vDB	DWD	11TfNl	W5	Nj 6D	vDEN6	E	E	3 V UGS_vDB	Nj 6D	vDEN6	N5B5	v6TW		
LV UGS_vD6	DWD	11TfjN	W5	Nj 6D	vDEN6	E	E	3 V UGS_vD6	Nj 6D	vDEN6	N56T	v6TW		
LV UGS_vDW	DWD	11TW66	Wf	Nj 6D	vDEN6	E	E	3 V UGS_vDW	Nj 6D	vDEN6	N56TW	v6TW		
LV UGS_vDf	DWD	11TW4D	Wf	Nj 6D	vDEN6	E	E	3 V UGS_vDf	Nj 6D	vDEN6	N5WD	v6TW		
LV UGS_vD5	DWD	11Tf6	Wf	Nj 6D	vDEN6	E	E	3 V UGS_vD5	Nj 6D	vDEN6	N5W5	v6TW		
LV UGS_vDI	DWD	11TBlj	WV	Nj 6D	vDEN6	E	E	3 V UGS_vDI	Nj 6D	vDEN6	N5fT5	v6TW		
LV UGS_vND	DWD	11T6B	WV	Nj 6D	vDEN6	E	E	3 V UGS_vND	Nj 6D	vDEN6	N5TD	v6TW		

Project: F m OH m EF 0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: F m 2OH

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: %

Date: NND6v9DN

SF: m ES_m OO0 j

Revision: 6DM p EF

Configuration: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M 3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4
LV UGS_vNj	DWDD	11Tf6f	VF	Nfj 6D	vDEN6	E	E	3 V UGS_vNj	Nfj 6D	vDEN6	N5BB	v6TW	
LV UGS_vNB	DWDD	11TN5	VF	Nfj 6D	vDEN6	E	E	3 V UGS_vNB	Nfj 6D	vDEN6	N5B5	v6TW	
LV UGS_vN6	DWDD	11T54	VW	Nfj 6D	vDEN6	E	E	3 V UGS_vN6	Nfj 6D	vDEN6	N5fTN	v6TW	
LV UGS_vNW	DWDD	11TW5	VF	Nfj 6D	vDEN6	E	E	3 V UGS_vNW	Nfj 6D	vDEN6	N56TN	v6TW	
LV UGS_vNf	DWDD	11TN%	V5	Nfj 6D	vDEN6	E	E	3 V UGS_vNf	Nfj 6D	vDEN6	N5fT5	v6TW	
LV UGS_v9D	DWDD	11TW5	VW	Nfj 6D	vDEN6	E	E	3 V UGS_v9D	Nfj 6D	vDEN6	N56T5	v6TW	
LV UGS_v9N	DWDD	11TW	VW	Nfj 6D	vDEN6	E	E	3 V UGS_v9N	Nfj 6D	vDEN6	N5WV	v6TW	
LV UGS_v9%	DWDD	11B16	V5	Nfj 6D	vDEN6	E	E	3 V UGS_v9%	Nfj 6D	vDEN6	N5fT5	v6TW	
LV UGS_v9j	DWDD	11T5%	VW	Nfj 6D	vDEN6	E	E	3 V UGS_v9j	Nfj 6D	vDEN6	N55TB	v6TW	
LV UGS_v9B	DWDD	11TjN	V5	Nfj 6D	vDEN6	E	E	3 V UGS_v9B	Nfj 6D	vDEN6	N51TB	v6TW	
LV UGS_v96	DWDD	11TjN	V5	Nfj 6D	vDEN6	E	E	3 V UGS_v96	Nfj 6D	vDEN6	N51T	v6TW	
LV UGS_v9W	DWDD	11T55	VF	Nfj 6D	vDEN6	E	E	3 V UGS_v9W	Nfj 6D	vDEN6	N5WB	v6TW	
LV UGS_v9f	DWDD	11T5j	VF	Nfj 6D	vDEN6	E	E	3 V UGS_v9f	Nfj 6D	vDEN6	N5W	v6TW	
LV UGS_v95	DWDD	11T5f	VF	Nfj 6D	vDEN6	E	E	3 V UGS_v95	Nfj 6D	vDEN6	N5fT	v6TW	
LV UGS_v94	DWDD	11TWN	VW	Nfj 6D	vDEN6	E	E	3 V UGS_v94	Nfj 6D	vDEN6	N5W%	v6TW	
LV UGS_vjN	DWDD	11TWj	W	Nfj 6D	vDEN6	E	E	3 V UGS_vjN	Nfj 6D	vDEN6	N5Bj	v6TW	
LV UGS_vj%	DWDD	11TjN	V5	Nfj 6D	vDEN6	E	E	3 V UGS_vj%	Nfj 6D	vDEN6	N56T	v6TW	
LV UGS_vjj	DWDD	11T5B	V5	Nfj 6D	vDEN6	E	E	3 V UGS_vjj	Nfj 6D	vDEN6	N5Wf	v6TW	
LV UGS_vjB	DWDD	11Tj1	V5	Nfj 6D	vDEN6	E	E	3 V UGS_vjB	Nfj 6D	vDEN6	N56T5	v6TW	
LV UGS_vjW	DWDD	11T5W	W	Nfj 6D	vDEN6	E	E	3 V UGS_vjW	Nfj 6D	vDEN6	N5jT5	v6TW	
LV UGS_vjf	DWDD	11T5j1	W	Nfj 6D	vDEN6	E	E	3 V UGS_vjf	Nfj 6D	vDEN6	N5jTB	v6TW	
LV UGS_vj1	DWDD	11T5j	W	Nfj 6D	vDEN6	E	E	3 V UGS_vj1	Nfj 6D	vDEN6	N5BN	v6TW	
LV UGS_vBD	DWDD	11TW5	fTD	Nfj 6D	vDEN6	E	E	3 V UGS_vBD	Nfj 6D	vDEN6	N56TB	v6TW	
LV UGS_vBN	DWDD	11Tj f	fTj	Nfj 6D	vDEN6	E	E	3 V UGS_vBN	Nfj 6D	vDEN6	N5%T%	v6TW	
LV UGS_vB%	DWDD	11Tj	fTj	Nfj 6D	vDEN6	E	E	3 V UGS_vB%	Nfj 6D	vDEN6	N5%W	v6TW	
LV UGS_vBj	DWDD	11Tj W	fTj	Nfj 6D	vDEN6	E	E	3 V UGS_vBj	Nfj 6D	vDEN6	N5%T%	v6TW	
LV UGS_vBB	DWDD	11TN6	fT%	Nfj 6D	vDEN6	E	E	3 V UGS_vBB	Nfj 6D	vDEN6	N5jT	v6TW	
LV UGS_vB6	DWDD	11TW%	fT%	Nfj 6D	vDEN6	E	E	3 V UGS_vB6	Nfj 6D	vDEN6	N5Bj	v6TW	
LV UGS_vBW	DWDD	11Tf5	fTN	Nfj 6D	vDEN6	E	E	3 V UGS_vBW	Nfj 6D	vDEN6	N5B	v6TW	
LV UGS_vB5	DWDD	NDDN%	fTB	Nfj 6D	vDEN6	E	E	3 V UGS_vB5	Nfj 6D	vDEN6	NN1TW	v6TW	
LV UGS_vBI	DWDD	NDDN	fTB	Nfj 6D	vDEN6	E	E	3 V UGS_vBI	Nfj 6D	vDEN6	N5DN	v6TW	
LV UGS_v6D	DWDD	NDDN%	fTB	Nfj 6D	vDEN6	E	E	3 V UGS_v6D	Nfj 6D	vDEN6	NN1TW	v6TW	
3 V UGS_vDN	jB5DD	NDE5%	6T%	E	D	DDDB	DDDB	3 V UGS_vD%	Nfj BN	vDBW	%TW	v6TW	
								LV UGS_vDN	vNfj B6	DB6W	%TW	v6TW	
3 V UGS_vD%	jB5DD	NDEW5	6T%	E	D	DDDB	DDDB	3 V UGS_vDN	vNfj BD	DEj	%TB	v6TW	
								3 V UGS_vDj	%W5N	vDBfB	BfTD	v6TN	
								LV UGS_vD%	vNfj B6	DB6f	%T	v6TW	
3 V UGS_vDj	jB5DD	NDDfj	6T%	E	D	DDDB	DDDB	3 V UGS_vD%	v9W5	DEjB	BW5	v6TB	
								3 V UGS_vDB	BEN	vNP46	fDB	v6T%	

Project: Fm OH m F0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16LE_0

Page: j

Date: 11/16/2017

Sheet: mES_m000j

Revision: 6DM p EF

Comment: For - al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Ar	3 m	3 Ar	R0	3 m	3 Ar	. - 4	MPI	M_a4
3 V UGS_vdB	j B6DD	NDDfN6	6TN	E	D	DDB	DDB	LV UGS_vdJ	vNf B6	DB6f	% T	v1BT	
								3 V UGS_vdJ	vBDNW	NP4B1	fD8%	v16B	
								3 V UGS_vd6	6Tj 6f	vNFDI	1j B	v16T	
3 V UGS_vd6	j B6DD	NDDf%4	6TN	E	D	DDB	DDB	LV UGS_vdB	vNf B6	DB6f	% T	v1BT	
								3 V UGS_vdB	v6Tj 6N	NW61	1j B	v16B	
								3 V UGS_vd5	WW%	v4N4D	NN7%	v16T	
3 V UGS_vdW	j B6DD	NDDf6N	6D	E	D	DDB	DDB	LV UGS_vd6	vNf B6	DB6f	% T	v1BT	
								3 V UGS_vdI	Nf BN	vDBWD	% T	v1BW	
								LV UGS_vdW	vNf B6	DB6f	% T	v1BT	
3 V UGS_vdI	j B6DD	NDDfN	6D	E	D	DDB	DDB	3 V UGS_vdW	vNf BD	DBj N	% B	v16B	
								3 V UGS_vdNW	vNf BD	Dfj 1W	% T	v16T	
								3 V UGS_vd6	BDfN	vNf6f	fD6	v16B	
3 V UGS_vd5	j B6DD	NDDfN%	6D	E	D	DDB	DDB	LV UGS_vdI	vNf B6	DB6f	% T	v1BT	
								3 V UGS_vd6	vWW6W	%D4	NNM	v16T	
								3 V UGS_vdI	5D4	v4B5f	NBDB	v16B	
3 V UGS_vdI	j B6DD	NDDID	6D	E	D	DDB	DDB	LV UGS_vd5	vNf B6	DB6f	% T	v1BT	
								3 V UGS_vd5	v5DN5	%f f6	Nj 1B	v16T	
								3 V UGS_vdD	1Tj 61	v45j W	NWj B	v16T	
3 V UGS_vdD	j B6DD	NDD6N	BII	E	D	DDB	DDB	LV UGS_vdI	vNf B6	DB6f	% B	v1BT	
								3 V UGS_vdI	v1Tj 6j	%f 6N	NWj N	v16T	
								3 V UGS_v46	NDRWB	vj P4N	N5W5	v16B	
3 V UGS_vdJ	j B6DD	NDDf6%	6D	E	D	DDB	DDB	LV UGS_vdD	vNf B6	DB6f	% B	v1BT	
								3 V UGS_vdB	Nf BN	vDBWD	% TW	v1BW	
								LV UGS_vdJ	vNf B6	DB6f	% T	v1BT	
3 V UGS_vdB	j B6DD	NDDfNB	6D	E	D	DDB	DDB	3 V UGS_vdJ	vNf BD	DBf6	% B	v16T	
								3 V UGS_vd6	%4W5N	vD51	BTN	v1BII	
								LV UGS_vdB	vNf B6	DB6f	% T	v1BT	
3 V UGS_vd6	j B6DD	NDDfNB	6D	E	D	DDB	DDB	3 V UGS_vdI	vBDNW	NP4NW	fDN	v16T	
								3 V UGS_vdB	v4W6	DBND	BWf	v16T	
								3 V UGS_vdN	5Tj %	v4B5f	NBDB	v16B	
3 V UGS_vdW	j B6DD	NDDf4B	6D	E	D	DDB	DDB	LV UGS_vd6	vNf B6	DB6f	% T	v1BT	
								3 V UGS_vdI	Nf BN	vDBWD	% T	v1BW	
								LV UGS_vdW	vNf B6	DB6f	% T	v1BT	
3 V UGS_vdN	j B6DD	NDDEND	BII	E	D	DDB	DDB	JUv4N	1Tj WD	v4f 1%	NWj B	v16B	
								3 V UGS_vd6	v5DN1	%fj N	Nj 1T	v1WD	
								LV UGS_vdN	vNf B6	DB6f	% B	v1BT	
3 V UGS_v4D	j B6DD	NDDf6B	BII	E	D	DDB	DDB	3 V UGS_v4N	Nf BN	vDBWD	% T	v1BW	
								LV UGS_v4D	vNf B6	DB6f	% T	v1BT	
								3 V UGS_v4D	vNfj 1	Dfj 5W	% T	v1WN	

Project: Fm OH m EF0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: B

Date: 10/16/2019

SF: mES_m000j

Revision: 6DM p EF

Conductor: For-al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4
3 V UGS_v0%	jB6DD	NDD1%	BII	E	D	DDB	DDB	3 V UGS_v0%	%WSD	vDBBW	BTD	v6B	
								LV UGS_v0%	vNF B6	DB6f	%T	vBT	
								JUVN	6T65	vNW6D	ljT	v6TW	
								3 V UGS_v0%	%W5	DBN	BW5	v6T	
3 V UGS_v%	jB6DD	NDD4D	BII	E	D	DDB	DDB	3 V UGS_v4	vNF j1	DJfj	%T%	vWf	
								LV UGS_v0%	vNF B6	DB6f	%T	vBT	
								511j.	NBTLB	vB704	%WD	vWN	
								3 V UGS_v%	vJTW	jTW	%T	vW%	
3 V UGS_vB	jB6DD	11T4	BT	E	D	DDB	DDB	LV UGS_v%	vNF B6	DB6f	%T	vBT	
								3 V UGS_v%	NfBN	vDBWN	%T	vBW	
								LV UGS_vB	vNF B6	DB6f	%T	vBT	
								511N	NJTB5	vJTWB	%NB5	vW5	
3 V UGS_v%	jB6DD	11TNN	BT	E	D	DDB	DDB	3 V UGS_vND	vNDWV	%TV5	N5BW	vW5	
								3 V UGS_vB	vNF BN	DBN5	%T5	v6T5	
								LV UGS_v%	vNF B6	DB6f	%T5	vBT	
								3 V UGS_v%	NfBN	vDBW	%T	vBW	
3 V UGS_vW	jB6DD	NDD56	6D	E	D	DDB	DDB	LV UGS_vW	vNF B6	DB6f	%T	vBT	
								3 V UGS_vW	vNF BD	DB%	%T5	v6B	
								3 V UGS_v%	%W5N	vDB5j	BTD%	v6D	
								LV UGS_v%	vNF B6	DB6f	%T	vBT	
3 V UGS_v%	jB6DD	NDD6B	6D	E	D	DDB	DDB	3 V UGS_v%	NJfj	vJTD6	%jTD	vWD	
								3 V UGS_v%	%W5	DBB5	BTD	v6Tj	
								3 V UGS_vjj	vTj6j	%61W	NWB	vWB	
								LV UGS_v%	vNF B6	DB6f	%T5	vBT	
3 V UGS_v4	jB6DD	NDDN5	BII	E	D	DDB	DDB	3 V UGS_v0%	NfBN	vDBW	%T	vBW	
								LV UGS_v4	vNF B6	DB6f	%T	vBT	
								3 V UGS_vj%	NfBN	vDBW	%TW	vBW	
								LV UGS_vjN	vNF B6	DB6f	%T	vBT	
3 V UGS_vj%	jB6DD	NDD%	6T%	E	D	DDB	DDB	3 V UGS_vjN	vNF j1	DJ6D	%TN	vWf	
								3 V UGS_vjj	%WSD	vDBNN	BWf	v6T	
								LV UGS_vj%	vNF B6	DB6f	%T	vBT	
								3 V UGS_v%	ljTW	%54	NW5T	v6T	
3 V UGS_vjj	jB6DD	NDDND	6N	E	D	DDB	DDB	3 V UGS_vj%	%W5	DT5B	BWV	vWD	
								3 V UGS_vjB	v6T6N	NB5j	ljT%	v6Tl	
								LV UGS_vjj	vNF B6	DB6f	%T	vBT	
								3 V UGS_vjj	6T6W	vNW6	ljTB	v6T	
3 V UGS_vjB	jB6DD	NDD%	6T%	E	D	DDB	DDB	3 V UGS_vjW	%WV	DB%B	BWf	v6TW	
								3 V UGS_vj1	vNF j1	DJBD	%TN	vWl	
								LV UGS_vjB	vNF B6	DB6f	%T	vBT	

Project: Fm OH m EF 0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm20H

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: 6

Date: NND6v4NF

SF: mES_mOO0j

Revision: 6DM p EF

Configuration: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4
3 V UGS _vj W	j B6DD	NDDEN	6%	E	D	DDB	DDB	3 V UGS _vj B	%6N	vD61j	BfN	vBII	
								3 V UGS _vj f	vNf BD	DEj j	%f B	v6T%	
								LV UGS _vj W	vNf B6	DE6f	%f T	vBT	
3 V UGS _vj f	j B6DD	NDDj B	6%	E	D	DDB	DDB	3 V UGS _vj W	Nf BN	vDBW	%f W	vBW	
								LV UGS _vj f	vNf B6	DE6f	%f T	vBT	
3 V UGS _vj l	j B6DD	NDDf f5	6%	E	D	DDB	DDB	3 V UGS _vj B	Nf BN	vDBW	%f W	vBW	
								LV UGS _vj l	vNf B6	DE6f	%f T	vBT	
3 V UGS _vBD	j B6DD	NDDMB	6f	E	D	DDB	DDB	511 B	Nf f6l	vj f56	%f NF	vW%	
								3 V UGS _vBW	v%4DN5	j f %	%4f N	vWB	
								LV UGS _vBD	vNf B6	DE6f	%f T	vBT	
3 V UGS _vBN	j B6DD	NDDj N	6W	E	D	DDB	DDB	JUvBN	Nf BN	vDBW	%f W	vBW	
								LV UGS _vBN	vNf B6	DE6W	%f W	vBT	
3 V UGS _vB%	j B6DD	NDDB15	6W	E	D	DDB	DDB	JUvBN	6f 6%	vNWN	lj D	v6f	
								3 V UGS _vBl	vBDNN	NNBN	Wf B	vW%	
								LV UGS _vB%	vNf B6	DE6f	%f T	vBT	
3 V UGS _vBj	j B6DD	NDDj D	6W	E	D	DDB	DDB	JUvBN	Nf BN	vDBW	%f W	vBW	
								LV UGS _vBj	vNf B6	DE6W	%f W	vBT	
3 V UGS _vBB	j B6DD	NDDEND	6W	E	D	DDB	DDB	JUvBN	v5D%0	%4f BB	Nf l f	vWD	
								3 V UGS _vB6	l f vj	v%4f B	NW4l	v6f	
								LV UGS _vBB	vNf B6	DE6f	%f T	vBT	
3 V UGS _vB6	j B6DD	NDDf 65	6f	E	D	DDB	DDB	3 V UGS _vBB	v f f66	%4f D	NW4f	vWN	
								3 V UGS _vBW	NBW W	vj fN6D	N6fI	v6fI	
								LV UGS _vB6	vNf B6	DE6f	%f T	vBT	
3 V UGS _vBW	j B6DD	NDDf DB	6f	E	D	DDB	DDB	3 V UGS _vBD	N%4f4f	vj fBj 6	%4f T	vW%	
								3 V UGS _vB6	vNDf6W	%4f f6	N6fN	vWf	
								LV UGS _vBW	vNf B6	DE6f	%f T	vBT	
3 V UGS _vB5	j B6DD	NDDf66	6f	E	D	DDB	DDB	3 V UGS _vBl	Nf BN	vDBW	%f B	vBW	
								LV UGS _vB5	vNf B6	DE6W	%f W	vBT	
3 V UGS _vBl	j B6DD	NDDfN%	6f	E	D	DDB	DDB	3 V UGS _vB%	BDfN	vNf D5	fDf	v6fN	
								3 V UGS _vB5	vNf BD	DE6f	%f B	v6fB	
								3 V UGS _v6D	vNf BD	DE6%	%f B	v6fJ	
								LV UGS _vBl	vNf B6	DE6W	%f W	vBT	
								3 V UGS _vBl	Nf BN	vDBW	%f B	vBW	
3 V UGS _v6D	j B6DD	NDDf6B	6f	E	D	DDB	DDB	LV UGS _v6D	vNf B6	DE6W	%f W	vBT	
								51_N	v66TB5	N5f %	%B6f	v6fD	
* POR	N5TDD	NDDDD	DD	v66TB5	N5f %	E	E	51_N					
3 P_~j	Nf BID	l1TWB	6D	E	D	E	E	HV UGS 3 P_	DDDD	DDDD	DD	DD	
								& 51_NU					

* Indicates a Aoltage regulated bus (Aoltage controlled or swing ty4e - achine connected to it)

Indicates a bus with a load - is- atch o8- ore than DN3 V.

Project: Fm OH m FW
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: Fm -OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: N
Wate: NRGTR/CN%
SF : mES_m OOWP
f ekision: 1GA MEF
ConpigD Forl al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
4. j N0	5BDGG	.. D4T	BD	C	G	C	C	9 V U6 S _R1	R5B55	5DB4	v5N0	R TD	
								4. _NU	N5B55	R5DB4	v5N0	R TD	
4. j v0	5BDGG	.. D4T	BD	C	G	C	C	JUR/N	RBDT.	5DCG	v1BD	R TD	
								4. _NU	NBDT.	R5DCG	v1BD	R TD	
4. j 50	5BDGG	.. D4T	BD	C	G	C	C	9 V U6 S _R5	RBD11	5D4N	v15D	R %40	
								4. _NU	NBD11	R5D4N	v15D	R %40	
4. j B0	5BDGG	.. D4T	BD	C	G	C	C	9 V U6 S _RBG	R5B15	vDB5	vvTDN	R 4DB	
								4. _NU	N5B15	RvDB5	vvTDN	R 4DB	
4. _N0	N54BGG	NGBD. 4	G0	C	G	C	C	PO7	11DBv	R4B1TT	v55D	R 1B0	
								HV U6 S 9 P_	R1DBv	N4B1TT	v55D	R 1B0	
4. _NU	5BDGG	.. D4T	BD	C	G	C	C	4. j B0	R5B15	vDB5	vvTDN	R 4DB	
								4. j 50	RBD11	5D4N	v15D	R %40	
								4. j v0	RBDT.	5DCG	v1BD	R TD	
								4. j N0	R5B55	5DB4	v5N0	R TD	
								9 P_~5	11DN	R5DBvv	. TD0	R %40	
								& HV U6 S 9 P_					
HV U6 S 9 P_	N54BGG	NGBD. 4	G0	C	G	G01.	G01v	4. _N0	11DBv	R4B1TT	v55D	R 1B0	
								4. _NU	R1BGN	N4DB	v55D	R 1DN	5DB1
								& 9 P_~5					
JUR/N	5BDGG	.. B15	B0	C	G	C	C	9 V U6 S _R0%	R B1v	vD4%	N15DN	R TDN	
								9 V U6 S _Rv	R B1B	N0%	. 5D	R 1D	
								4. j v0	NBDv	RBD15	v1TD	R TD0	
JUR/N	5BDGG	NGB. .	1D	C	G	C	C	9 V U6 S _REN	R5B1G	GDB5N	v5D	R 1D	
								9 V U6 S _RBv	R B1v	N1GN	. 5DN	R 1B	
								9 V U6 S _RB5	R5B1G	GDB5v	v5D	R 1D	
								9 V U6 S _RBB	4DB5v	RvDBTB	NB00	R 1D	
LV U6 S _RGN	GD. G	.. B5N	TD	N51G	RDBNI	C	C	9 V U6 S _RGN	N51G	RDBNI	NN45D	R 1D	
LV U6 S _RGv	GD. G	.. D04	TD	N51G	RDBNI	C	C	9 V U6 S _RGv	N51G	RDBNI	NN4BDN	R 1D	
LV U6 S _RG5	GD. G	.. D4G	TD	N51G	RDBNI	C	C	9 V U6 S _RG5	N51G	RDBNI	NN41B	R 1D	
LV U6 S _RDB	GD. G	.. DvN	TD	N51G	RDBNI	C	C	9 V U6 S _RDB	N51G	RDBNI	NN4TD0	R 1D	
LV U6 S _RGI	GD. G	.. D55	TD	N51G	RDBNI	C	C	9 V U6 S _RGI	N51G	RDBNI	NN4%40	R 1D	
LV U6 S _RGT	GD. G	.. D14	TD%	N51G	RDBNI	C	C	9 V U6 S _RGT	N51G	RDBNI	NN4TD%	R 1D	
LV U6 S _R0%	GD. G	.. Dvv	TD%	N51G	RDBNI	C	C	9 V U6 S _R0%	N51G	RDBNI	NN4%40	R 1D	
LV U6 S _RG4	GD. G	.. DB0%	TD%	N51G	RDBNI	C	C	9 V U6 S _RG4	N51G	RDBNI	NN4%40	R 1D	
LV U6 S _RG	GD. G	.. B. 1	TD	N51G	RDBNI	C	C	9 V U6 S _RG	N51G	RDBNI	NN44B%	R 1D	
LV U6 S _RNG	GD. G	.. B1T	TD	N51G	RDBNI	C	C	9 V U6 S _RNG	N51G	RDBNI	NN4. DN	R 1D	

Project: Fm OH m FW
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: Fm -OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: v
Wate: NRGTR/GN%
SF: mES_mOOW
fekision: 1GA MEF
ConpigD Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
LV U6 S _R5	CD. G	.. DT.	TB%	N51G	RGBNI	C	C	9 V U6 S _R5	N51G	RGBNI	NN41D	R 1D	
LV U6 S _RB	CD. G	.. DvN	TB%	N51G	RGBNI	C	C	9 V U6 S _RB	N51G	RGBNI	NN41D5	R 1D	
LV U6 S _RNI	CD. G	.. DBv.	TD	N51G	RGBNI	C	C	9 V U6 S _RNI	N51G	RGBNI	NN44B	R 1D	
LV U6 S _RNT	CD. G	.. DCG	TB%	N51G	RGBNI	C	C	9 V U6 S _RNT	N51G	RGBNI	NN4TD	R 1D	
LV U6 S _R%	CD. G	.. BNB	TD	N51G	RGBNI	C	C	9 V U6 S _R%	N51G	RGBNI	NN4.D	R 1D	
LV U6 S _RG	CD. G	.. DTG	TD	N51G	RGBNI	C	C	9 V U6 S _RG	N51G	RGBNI	NN4TD%	R 1D	
LV U6 S _RN	CD. G	.. DBI.	TD	N51G	RGBNI	C	C	9 V U6 S _RN	N51G	RGBNI	NN4%4	R 1D	
LV U6 S _Rv	CD. G	.. B. %	TD	N51G	RGBNI	C	C	9 V U6 S _Rv	N51G	RGBNI	NN44D%	R 1D	
LV U6 S _R5	CD. G	.. BvB	TD	N51G	RGBNI	C	C	9 V U6 S _R5	N51G	RGBNI	NN4.D	R 1D	
LV U6 S _RB	CD. G	.. D55	TDB	N51G	RGBNI	C	C	9 V U6 S _RB	N51G	RGBNI	NN CD	R 1D	
LV U6 S _R1	CD. G	.. BNI	TDB	N51G	RGBNI	C	C	9 V U6 S _R1	N51G	RGBNI	NN CD	R 1D	
LV U6 S _RT	CD. G	.. DB. G	TB%	N51G	RGBNI	C	C	9 V U6 S _RT	N51G	RGBNI	NN4%4	R 1D	
LV U6 S _R%	CD. G	.. DBI	TB%	N51G	RGBNI	C	C	9 V U6 S _R%	N51G	RGBNI	NN44D	R 1D	
LV U6 S _R4	CD. G	.. B1.	TB%	N51G	RGBNI	C	C	9 V U6 S _R4	N51G	RGBNI	NN4.D	R 1D	
LV U6 S _Rv	CD. G	.. DGB	TD	N51G	RGBNI	C	C	9 V U6 S _Rv	N51G	RGBNI	NN4%4B	R 1D	
LV U6 S _RSN	CD. G	.. DT1	TD	N51G	RGBNI	C	C	9 V U6 S _RSN	N51G	RGBNI	NN41D	R 1D	
LV U6 S _Rv	CD. G	.. D55	TB	N51G	RGBNI	C	C	9 V U6 S _Rv	N51G	RGBNI	NN4%4B	R 1D	
LV U6 S _R5	CD. G	.. DBIT	TB	N51G	RGBNI	C	C	9 V U6 S _R5	N51G	RGBNI	NN4%4	R 1D	
LV U6 S _RB	CD. G	.. DBN	TB	N51G	RGBNI	C	C	9 V U6 S _RB	N51G	RGBNI	NN4TD	R 1D	
LV U6 S _RT	CD. G	.. DG	TD	N51G	RGBNI	C	C	9 V U6 S _RT	N51G	RGBNI	NN4ED	R 1D	
LV U6 S _R5%	CD. G	.. DBN	TD	N51G	RGBNI	C	C	9 V U6 S _R5%	N51G	RGBNI	NN4ED	R 1D	
LV U6 S _R5.	CD. G	.. D41	TD	N51G	RGBNI	C	C	9 V U6 S _R5.	N51G	RGBNI	NN41D	R 1D	
LV U6 S _REG	CD. G	.. D%G	%4B	N51G	RGBNI	C	C	9 V U6 S _REG	N51G	RGBNI	NN4TD	R 1D	
LV U6 S _REN	CD. G	.. B5.	%4B	N51G	RGBNI	C	C	9 V U6 S _REN	N51G	RGBNI	NN45DB	R 1D	
LV U6 S _Rv	CD. G	.. BGI	%4B	N51G	RGBNI	C	C	9 V U6 S _Rv	N51G	RGBNI	NN45D	R 1D	
LV U6 S _R5	CD. G	.. B54	%4B	N51G	RGBNI	C	C	9 V U6 S _R5	N51G	RGBNI	NN45DB	R 1D	
LV U6 S _RBB	CD. G	.. DB%	%4D	N51G	RGBNI	C	C	9 V U6 S _RBB	N51G	RGBNI	NN4B4	R 1D	
LV U6 S _RBI	CD. G	.. DTB	%4D	N51G	RGBNI	C	C	9 V U6 S _RBI	N51G	RGBNI	NN41D	R 1D	
LV U6 S _RBT	CD. G	.. DNG	%4D	N51G	RGBNI	C	C	9 V U6 S _RBT	N51G	RGBNI	NN4TD	R 1D	
LV U6 S _R4	CD. G	NCGD1	%4B	N51G	RGBNI	C	C	9 V U6 S _R4	N51G	RGBNI	NN4CB	R 1D	
LV U6 S _RB	CD. G	NCGDvN	%4B	N51G	RGBNI	C	C	9 V U6 S _RB	N51G	RGBNI	NN4ND	R 1D	
LV U6 S _RG	CD. G	NCGD15	%4B	N51G	RGBNI	C	C	9 V U6 S _RG	N51G	RGBNI	NN4CB	R 1D	
9 V U6 S _RN	5BD CG	NCGDvT	1D	C	G	GDCB	GDCB	9 V U6 S _Rv	N51B	RGBTG	v5D	R BD	
								LV U6 S _RN	RN5BI	GB1%	v5D%	R BD%	
9 V U6 S _Rv	5BD CG	NCGB%N	1D	C	G	GDCB	GDCB	9 V U6 S _RN	RN5BG	GBN5	v5DB	R 1D	
								9 V U6 S _R5	vD4N	RGB%B	B%4B	R 1D	
								LV U6 S _Rv	RN5BI	GB1%	v5D%	R BD%	
9 V U6 S _R5	5BD CG	NCGD%T	1D	C	G	GDCB	GDCB	9 V U6 S _Rv	RvD%4	GB51	BT4	R 1D	
								9 V U6 S _RB	BDN	RND. 1	%CD	R 1D	

Project: Fm OH m FW
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: Fm - OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: 5
Wate: NRGTR/CN%
SF : mES_m OOWP
f ekision: 1GA MEF
ConpigD Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
9 V U6 S _RG	5BDGG	NCGDN%	1DN	C	G	G00CB	G00CB	LV U6 S _R5	RN3BI	GB1%	v5D%	R B%	
								9 V U6 S _R5	R00NT	N0B	%C0	R 1D	
								9 V U6 S _RG	1B1%	RN0NG	. 5D	R 1B	
9 V U6 S _RG	5BDGG	NCGDN%	1DN	C	G	G00CB	G00CB	LV U6 S _RB	RN3BI	GB1%	v5D%	R B%	
								9 V U6 S _RB	R131N	NTTG	. 5D	R 1D	
								9 V U6 S _RG	TD. v	R/DwN	N04B	R 1B	
9 V U6 S _RG	5BDGG	NCGDN%	1DN	C	G	G00CB	G00CB	LV U6 S _RG	RN3BI	GB1%	v5D%	R B%	
								9 V U6 S _R%	N3BN	R0BTG	v5D%	R B%	
								LV U6 S _RG	RN3BI	GB1%	v5D%	R B%	
9 V U6 S _R%	5BDGG	NCGDN	1DN	C	G	G00CB	G00CB	9 V U6 S _RG	RN3BG	GB5N	v5D	R 1D	
								9 V U6 S _RT	RN3BG	GB. T	v5B	R 1D	
								9 V U6 S _RN	B0wN	RN044	%C0	R 1D	
9 V U6 S _RG	5BDGG	NCGDN%	1DN	C	G	G00CB	G00CB	LV U6 S _R%	RN3BI	GB1%	v5D%	R B%	
								9 V U6 S _RG	R1D4T	vD0v4	NN1B	R 1D%	
								9 V U6 S _RG	4D0v%	R/D44	NB0D	R 1D	
9 V U6 S _RG	5BDGG	. . D. v	1DN	C	G	G00CB	G00CB	LV U6 S _RG	RN3BI	GB1%	v5D	R B%	
								9 V U6 S _RG	R10N4	vB3T	NB0D	R 1D	
								9 V U6 S _RG	. B1.	R/B5%	NB5D%	R 1D%	
9 V U6 S _RG	5BDGG	. . D1B	BD	C	G	G00CB	G00CB	LV U6 S _RG	RN3BI	GB1%	v5D	R B%	
								9 V U6 S _RG	R B15	vD4v	NB5D	R 1D	
								9 V U6 S _R1	N0T. B	B5D5	N4TD	R 1B	
9 V U6 S _R5	5BDGG	NCGD11	1DN	C	G	G00CB	G00CB	LV U6 S _RG	RN3BI	GB1%	v5D	R B%	
								9 V U6 S _RB	N3BN	R0BTG	v5D%	R B%	
								LV U6 S _R5	RN3BI	GB1%	v5D%	R B%	
9 V U6 S _RB	5BDGG	NCGDN%	1DN	C	G	G00CB	G00CB	9 V U6 S _R5	RN3BG	GBw4	v5D	R 1B	
								9 V U6 S _RN	vD4N	R04.	B%0	R B%	
								LV U6 S _RB	RN3BI	GB1%	v5D%	R B%	
9 V U6 S _RN	5BDGG	NCGDw%	1DN	C	G	G00CB	G00CB	9 V U6 S _R%	R00NT	N0NT	%C0	R 1D%	
								9 V U6 S _RB	R/D%4	GBNN	B1B	R 1D%	
								9 V U6 S _R%	4D0v	R/D44	NB0D%	R 1D	
9 V U6 S _RT	5BDGG	NCGDN%	1DN	C	G	G00CB	G00CB	LV U6 S _RN	RN3BI	GB1%	v5D	R B%	
								9 V U6 S _R%	N3BN	R0BTG	v5D%	R B%	
								LV U6 S _RT	RN3BI	GB1%	v5D%	R B%	
9 V U6 S _R%	5BDGG	. . DNv	BD	C	G	G00CB	G00CB	JURwN	. BTG	R/D% 5	NB5D	R 1B	
								9 V U6 S _RN	R10N	vB55	N5. D	R 1D%	
								LV U6 S _R%	RN3BI	GB1%	v5D	R B%	
9 V U6 S _RG	5BDGG	NCGDNT	BD	C	G	G00CB	G00CB	9 V U6 S _RN	N3BN	R0BTG	v5D%	R B%	
								LV U6 S _RG	RN3BI	GB1%	v5D%	R B%	
								9 V U6 S _RG	RN35.	GB4T	v5B	R 1D	

Project: F m OH m 7F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: F m - OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: B
Wate: NRGIR/CN%
SF : m ES_m OOWP
f ekision: 1GA MEF
ConpigD Forl al

Bus		Voltage		Generation		Load		Load Flow					XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3	
9 V U6 S _Rv	5BD CG	. . D. 1	BD	C	G	G0CB	G0CB	9 V U6 S _Rv	vD4G	R0BT	B40	R 1B		
								LV U6 S _RN	RN3B1	GB1%	v5D	R B0%		
								JUR/N	1B14	RN1N	. 5D	R 1D		
								9 V U6 S _RN	R/D%4	GBN%	BITD	R 1D		
9 V U6 S _R5	5BD CG	. . Dvv	BD	C	G	G0CB	G0CB	9 V U6 S _R.	RN35.	GB%6	v5B	R TB		
								LV U6 S _Rv	RN3B1	GB1%	v5D	R B0%		
								4. j 50	NB0CB	RB05v	v1TD	R TDN		
								9 V U6 S _R4	R5D15	5D0N	v5vD	R TD		
9 V U6 S _RB	5BD CG	. . B5v	B0%	C	G	G0CB	G0CB	LV U6 S _R5	RN3B1	GB1%	v5D	R B0%		
								9 V U6 S _R1	N3BN	R0BTN	v5D	R B0		
								LV U6 S _RB	RN3B1	GB1%	v5D	R B0%		
								4. j N0	N5B4	BD1G	v5vD0	R TD		
9 V U6 S _RT	5BD CG	. . BNB	B0%	C	G	G0CB	G0CB	9 V U6 S _RG	R0D1T	vD0N	N4B	R TB		
								9 V U6 S _RB	RN3BN	GBN4	v5D	R 1D		
								LV U6 S _R1	RN3B1	GB1%	v5D	R B0%		
								9 V U6 S _R%	N3BN	R0BTN	v5D0	R B0		
9 V U6 S _R%	5BD CG	N0GB4%	1D	C	G	G0CB	G0CB	LV U6 S _RT	RN3B1	GB1%	v5D	R B0%		
								9 V U6 S _RT	RN3BG	GBv5	v5D	R 1B		
								9 V U6 S _R4	vD4N	R04B	B40	R 1B0		
								LV U6 S _R%	RN3B1	GB1%	v5D	R B0%		
9 V U6 S _R4	5BD CG	. . D1%	1B0	C	G	G0CB	G0CB	9 V U6 S _R5	N5B%6	BD0%	v5D0	R TB0		
								9 V U6 S _R%	R/D%4	GB4	B40	R 1B		
								9 V U6 S _R5	R B15	vD. 4	N1vD	R TB		
								LV U6 S _R4	RN3B1	GB1%	v5D	R B0%		
9 V U6 S _R.	5BD CG	N0GBN	BD	C	G	G0CB	G0CB	9 V U6 S _Rv	N3BN	R0BTN	v5D0	R B0		
								LV U6 S _R.	RN3B1	GB1%	v5D0	R B0%		
								9 V U6 S _R5v	N3BN	R0BTG	v5D0	R B0		
								LV U6 S _RN	RN3B1	GB1%	v5D0	R B0%		
9 V U6 S _R5v	5BD CG	N0GB5G	1D	C	G	G0CB	G0CB	9 V U6 S _RN	RN35.	GB1N	v5DN	R TB0%		
								9 V U6 S _R5	vD4G	R0NN	BT0	R 1D0		
								LV U6 S _Rv	RN3B1	GB1%	v5D0	R B0%		
								9 V U6 S _R4	. BT.	R0v4	N5D0	R 1D0		
9 V U6 S _R5	5BD CG	N0GB15	1D	C	G	G0CB	G0CB	9 V U6 S _R5v	R/D%4	GB4B	BT0%	R TB0		
								9 V U6 S _RB	R B1N	N04B	. 5B	R 1D		
								LV U6 S _R5	RN3B1	GB1%	v5D	R B0%		
								9 V U6 S _R5	1B1T	RN1v1	. 5D	R 1D0		
9 V U6 S _RB	5BD CG	N0GB5%	1D	C	G	G0CB	G0CB	9 V U6 S _RT	R/D%4	GBvB	BT0	R 1D		
								9 V U6 S _R.	RN35.	GBBN	v5DN	R TD		
								LV U6 S _RB	RN3B1	GB1%	v5D0	R B0%		

Project: F m OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: F m - OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: 1
Wate: NRGTR/GN%
SF : m ES_m OOWP
f ekision: 1GA MEF
Conpigd Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
9 V U6 S _RST	5BDGG	NCG3CB	1D	C	G	G0CB	G0CB	9 V U6 S _R5B	vD4N	R3. 5	B9D	R BD	
								9 V U6 S _R5%	RN3BG	GB55	v5D	R 1D	
								LV U6 S _RST	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5%	5BDGG	NCG35%	1D	C	G	G0CB	G0CB	9 V U6 S _RST	N3BN	R3BTG	v5D	R BD	
								LV U6 S _R5%	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5.	5BDGG	NCG4N	1D	C	G	G0CB	G0CB	9 V U6 S _R5B	N3BN	R3BTG	v5D%	R BD	
								LV U6 S _R5.	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5G	5BDGG	NCGN1%	1B	C	G	G0CB	G0CB	4. j B0	N5D1.	R5D44	v5v10	R TD	
								9 V U6 S _RBT	Rv10N4	5Bv%	vG4B	R TTB	
								LV U6 S _R5G	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5N	5BDGG	NCG5B	1D%	C	G	G0CB	G0CB	JURBN	N3BN	R3BTG	v5D	R BD	
								LV U6 S _R5N	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5v	5BDGG	NCGBCG	1D	C	G	G0CB	G0CB	JURBN	1D1v	RDTGv	. 5D	R 1D	
								9 V U6 S _R5	R30NN	NDBv	T. D	R TD	
								LV U6 S _R5v	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5	5BDGG	NCG55	1D%	C	G	G0CB	G0CB	JURBN	N3BN	R3BTG	v5D	R BD	
								LV U6 S _R5	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5B	5BDGG	NCG5Nv	1D	C	G	G0CB	G0CB	JURBN	R40v	v5BI	N5. B	R TTD	
								9 V U6 S _R5I	. B75	RvBG	N75D	R 1D	
								LV U6 S _R5B	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R5I	5BDGG	NCGBTG	1D	C	G	G0CB	G0CB	9 V U6 S _R5B	R B711	vD. N	N7vD	R TTD	
								9 V U6 S _RBT	NCE. T	R5D1v	N7TD	R 1D	
								LV U6 S _R5I	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _RBT	5BDGG	NCGDT	1DB	C	G	G0CB	G0CB	9 V U6 S _R5G	Nv10vT	R5B5%	vG4D	R TTD	
								9 V U6 S _R5I	RCE4T	vD%%	N41D	R TB	
								LV U6 S _RBT	RN3BI	GB1%	v5D%	R BD%	
9 V U6 S _R54	5BDGG	NCGT14	1D	C	G	G0CB	G0CB	9 V U6 S _R5	N3BN	R3BTG	v5D	R BD	
								LV U6 S _R54	RN3BI	GB1T	v5D	R BD%	
9 V U6 S _R5	5BDGG	NCGTNI	1D%	C	G	G0CB	G0CB	9 V U6 S _R5v	R0vN	R5G	%CB	R 1D	
								9 V U6 S _R54	RN3BG	GBvB	v5DB	R 1DB	
								9 V U6 S _R5G	RN3BG	GBv1	v5DB	R 1B	
9 V U6 S _R5G	5BDGG	NCGT1T	1D	C	G	G0CB	G0CB	LV U6 S _R5	RN3BI	GB1T	v5D	R BD%	
								9 V U6 S _R5	N3BN	R3BTG	v5D	R BD	
								LV U6 S _R5G	RN3BI	GB1T	v5D	R BD%	
* PO7	N540CG	NGL0CG	G0	R 1D5N	N4BTT	C	C	4. _ND	R 1D5N	N4BTT	v55D	R 1D	
9 P_~5	N50CG	. . DNT	1D	C	G	C	C	HV U6 S 9 P_	G0CG	G0CG	G0	G0	
								& 4. _NU					

* 7ndicates a koltage regulated bus (koltage controlled or swing ty3e I achine connected to it)
7ndicates a bus with a load I isI atch op1 ore than GDN9 V0

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Yilena_e: UWj OH

ETAP
F6.0.0C
Study Case: 1 UN T PY

Page: F
Date: F02072R0Fv
SU: WESI WOODm
%eGision: v7f k EU
ConAg.: Uor_al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	MV	f 8 ag.	p ng.	8 W	8 Gr	8 W	8 Gr	ND	8 W	8 Gr	p _9	f PY	f l a9
34YFp	m5.700	F00.006	6.5	0	0	0	0	8 V B1 S I 2R7	2F3.540	20.m60	m04.7	F00.0	
								34I FB	F3.540	0.m60	m04.7	F00.0	
34YRp	m5.700	F00.006	6.5	0	0	0	0	JB2R/F	2R0.m56	20.R37	m50.7	F00.0	
								34I FB	R0.m56	0.R37	m50.7	F00.0	
34Ymp	m5.700	F00.006	6.5	0	0	0	0	8 V B1 S I 2Rm	2R0.mF4	20.5v4	m50.F	F00.0	
								34I FB	R0.mF4	0.5v4	m50.F	F00.0	
34YSp	m5.700	F00.006	6.5	0	0	0	0	8 V B1 S I 2S0	2F3.m65	2F.mRR	m03.F	44.v	
								34I FB	F3.m65	F.mRR	m03.F	44.v	
34I Fp	Fm5.000	F00.00F	0.0	0	0	0	0	PON	vv.R7F	26.m77	mR5.m	244.v	
								HV B1 S 8 PI	2vv.R7F	6.m77	mR5.m	244.v	
34I FB	m5.700	F00.006	6.5	0	0	0	0	34YSp	2F3.m65	2F.mRR	m03.F	44.v	
								34Ymp	2R0.mF4	20.5v4	m50.F	F00.0	
								34YRp	2R0.m56	20.R37	m50.7	F00.0	
								34YFp	2F3.540	20.m60	m04.7	F00.0	
								8 PI ~m	vv.7F4	R.556	FR4v.3	F00.0	
HV B1 S 8 PI	Fm5.000	F00.00F	0.0	0	0	0.075	0.F5v	& HV B1 S 8 PI					
								34I Fp	vv.R7F	26.m77	mR5.m	244.v	
								34I FB	2vv.m07	6.R0v	mR5.7	244.v	
								& 8 PI ~m					
								JB2R/F	2FR4v3	0.000	RF6.6	F00.0	
JB2R/F	m5.700	F00.R4m	6.v	0	0	0	0	8 V B1 S I 2Fv	2v.5R7	0.0mv	FRm4	F00.0	
								8 V B1 S I 2RR	R0.50m	20.0mv	m50.5	F00.0	
								34YRp					
JB2S/F	m5.700	F0F.547	v.6	0	0	0	0	8 V B1 S I 2SF	2F.36R	0.055	m0.v	2F00.0	
								8 V B1 S I 2SR	2v.5R4	0.075	FRR7	F00.0	
								8 V B1 S I 2Sm	2F.36R	0.057	m0.v	2F00.0	
								8 V B1 S I 2S5	FF.F7R	20.F5m	F3m4	F00.0	
LV B1 S I 20F	0.640	F0F.6Fv	4.R	F.3v7	0.000	0	0	8 V B1 S I 20F	F.3v7	0.000	F75m7	F00.0	
LV B1 S I 20R	0.640	F0F.7m7	4.R	F.3v7	0.000	0	0	8 V B1 S I 20R	F.3v7	0.000	F755.3	F00.0	
LV B1 S I 20m	0.640	F0F.m4v	4.R	F.3v7	0.000	0	0	8 V B1 S I 20m	F.3v7	0.000	F756.4	F00.0	
LV B1 S I 205	0.640	F0F.m05	4.R	F.3v7	0.000	0	0	8 V B1 S I 205	F.3v7	0.000	F753.m	F00.0	
LV B1 S I 207	0.640	F0F.F66	4.R	F.3v7	0.000	0	0	8 V B1 S I 207	F.3v7	0.000	F770.5	F00.0	
LV B1 S I 206	0.640	F0F.F7m	4.F	F.3v7	0.000	0	0	8 V B1 S I 206	F.3v7	0.000	F770.6	F00.0	
LV B1 S I 20v	0.640	F0F.F0R	4.F	F.3v7	0.000	0	0	8 V B1 S I 20v	F.3v7	0.000	F77F.5	F00.0	
LV B1 S I 203	0.640	F0F.067	4.F	F.3v7	0.000	0	0	8 V B1 S I 203	F.3v7	0.000	F77R0	F00.0	
LV B1 S I 204	0.640	F00.4F6	4.F	F.3v7	0.000	0	0	8 V B1 S I 204	F.3v7	0.000	F775.m	F00.0	
LV B1 S I 2F0	0.640	F00.3m6	4.0	F.3v7	0.000	0	0	8 V B1 S I 2F0	F.3v7	0.000	F777.7	F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Yilena_e: UWj OH

ETAP
F6.0.0C
Study Case: 1 UN T PY

Page: R
Date: F02072R0Fv
SU: WESI WOODm
%eGSION: v7f k EU
ConAg.: Uor_al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	M	f 8 ag.	p ng.	8 W	8 Gr	8 W	8 Gr	ND	8 W	8 Gr	p _9	f PY	f l a9
LV B1 S I 2fm	0.640	F0F.R4R	4.F	F.3v7	0.000	0	0	8 V B1 S I 2fm	F.3v7	0.000	F753.7	F00.0	
LV B1 S I 2F5	0.640	F0F.Rn6	4.F	F.3v7	0.000	0	0	8 V B1 S I 2F5	F.3v7	0.000	F754.5	F00.0	
LV B1 S I 2F7	0.640	F00.476	4.F	F.3v7	0.000	0	0	8 V B1 S I 2F7	F.3v7	0.000	F77m6	F00.0	
LV B1 S I 2F6	0.640	F0F.RF7	4.F	F.3v7	0.000	0	0	8 V B1 S I 2F6	F.3v7	0.000	F754.v	F00.0	
LV B1 S I 2Fv	0.640	F00.v5v	4.0	F.3v7	0.000	0	0	8 V B1 S I 2Fv	F.3v7	0.000	F776.4	F00.0	
LV B1 S I 2R0	0.640	F0F.04F	4.0	F.3v7	0.000	0	0	8 V B1 S I 2R0	F.3v7	0.000	F77F.6	F00.0	
LV B1 S I 2RF	0.640	F00.474	3.4	F.3v7	0.000	0	0	8 V B1 S I 2RF	F.3v7	0.000	F77m6	F00.0	
LV B1 S I 2RR	0.640	F00.375	3.4	F.3v7	0.000	0	0	8 V B1 S I 2RR	F.3v7	0.000	F777.R	F00.0	
LV B1 S I 2Rm	0.640	F00.v43	4.0	F.3v7	0.000	0	0	8 V B1 S I 2Rm	F.3v7	0.000	F776.F	F00.0	
LV B1 S I 2R5	0.640	F00.7m4	3.3	F.3v7	0.000	0	0	8 V B1 S I 2R5	F.3v7	0.000	F760.F	F00.0	
LV B1 S I 2R7	0.640	F00.7FF	3.3	F.3v7	0.000	0	0	8 V B1 S I 2R7	F.3v7	0.000	F760.7	F00.0	
LV B1 S I 2R6	0.640	F0F.035	4.F	F.3v7	0.000	0	0	8 V B1 S I 2R6	F.3v7	0.000	F77F.v	F00.0	
LV B1 S I 2Rv	0.640	F0F.0F3	4.F	F.3v7	0.000	0	0	8 V B1 S I 2Rv	F.3v7	0.000	F77R.v	F00.0	
LV B1 S I 2R3	0.640	F00.34F	4.F	F.3v7	0.000	0	0	8 V B1 S I 2R3	F.3v7	0.000	F775.v	F00.0	
LV B1 S I 2R4	0.640	F0F.004	4.0	F.3v7	0.000	0	0	8 V B1 S I 2R4	F.3v7	0.000	F77R3	F00.0	
LV B1 S I 2nF	0.640	F0F.m44	4.m	F.3v7	0.000	0	0	8 V B1 S I 2nF	F.3v7	0.000	F756.4	F00.0	
LV B1 S I 2nR	0.640	F0F.R06	4.m	F.3v7	0.000	0	0	8 V B1 S I 2nR	F.3v7	0.000	F754.3	F00.0	
LV B1 S I 2nm	0.640	F0F.F03	4.m	F.3v7	0.000	0	0	8 V B1 S I 2nm	F.3v7	0.000	F77F.m	F00.0	
LV B1 S I 2n5	0.640	F0F.RR7	4.m	F.3v7	0.000	0	0	8 V B1 S I 2n5	F.3v7	0.000	F754.7	F00.0	
LV B1 S I 2n6	0.640	F0F.5v0	4.m	F.3v7	0.000	0	0	8 V B1 S I 2n6	F.3v7	0.000	F757.3	F00.0	
LV B1 S I 2nv	0.640	F0F.7F3	4.m	F.3v7	0.000	0	0	8 V B1 S I 2nv	F.3v7	0.000	F757.F	F00.0	
LV B1 S I 2n4	0.640	F0F.5n6	4.m	F.3v7	0.000	0	0	8 V B1 S I 2n4	F.3v7	0.000	F756.m	F00.0	
LV B1 S I 250	0.640	F0F.m67	4.7	F.3v7	0.000	0	0	8 V B1 S I 250	F.3v7	0.000	F75v.5	F00.0	
LV B1 S I 25F	0.640	F0F.343	4.3	F.3v7	0.000	0	0	8 V B1 S I 25F	F.3v7	0.000	F7m4.m	F00.0	
LV B1 S I 25R	0.640	F0F.354	4.3	F.3v7	0.000	0	0	8 V B1 S I 25R	F.3v7	0.000	F750.0	F00.0	
LV B1 S I 25m	0.640	F0F.346	4.3	F.3v7	0.000	0	0	8 V B1 S I 25m	F.3v7	0.000	F7m4.m	F00.0	
LV B1 S I 255	0.640	F0F.634	4.v	F.3v7	0.000	0	0	8 V B1 S I 255	F.3v7	0.000	F75R5	F00.0	
LV B1 S I 257	0.640	F0F.73m	4.v	F.3v7	0.000	0	0	8 V B1 S I 257	F.3v7	0.000	F755.F	F00.0	
LV B1 S I 256	0.640	F0F.57v	4.6	F.3v7	0.000	0	0	8 V B1 S I 256	F.3v7	0.000	F756.0	F00.0	
LV B1 S I 253	0.640	F0RR5v	4.4	F.3v7	0.000	0	0	8 V B1 S I 253	F.3v7	0.000	F7m5.0	F00.0	
LV B1 S I 254	0.640	F0RF35	4.4	F.3v7	0.000	0	0	8 V B1 S I 254	F.3v7	0.000	F7n7.0	F00.0	
LV B1 S I 270	0.640	F0RR57	4.4	F.3v7	0.000	0	0	8 V B1 S I 270	F.3v7	0.000	F7m5.F	F00.0	
8 V B1 S I 20F	m5.700	F0F.R67	v.F	0	0	0.005	0.005	8 V B1 S I 20R	F.36m	20.0v5	m0.3	244.4	
								LV B1 S I 20F	2F.36v	0.0vF	m0.4	244.4	
								8 V B1 S I 20F	2F.36F	0.0Rv	m0.3	2F00.0	
8 V B1 S I 20R	m5.700	F0F.F3m	v.F	0	0	0.005	0.005	8 V B1 S I 20m	mvRm	20.F0R	6F.6	2F00.0	
								LV B1 S I 20R	2F.36v	0.0vF	m0.4	244.4	
								8 V B1 S I 20R	2mvF3	0.06R	6F.6	2F00.0	
8 V B1 S I 20m	m5.700	F0F.055	v.0	0	0	0.005	0.005	8 V B1 S I 205	7.73F	20.Fmv	4R7	2F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Yilena_e: UWj OH

ETAP
F6.0.0C
Study Case: 1 UN T PY

Page: m
Date: F02072R0Fv
SU: WESI WOODm
%eGision: v7f k EU
ConAg.: Uor_al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	M	f 8 ag.	p ng.	8 W	8 Gr	8 W	8 Gr	ND	8 W	8 Gr	p_9	f PY	f l a9
8 V B1 S I 205	m5.700	F00.47R	v.0	0	0	0.005	0.005	LV B1 S I 20m	2F.36v	0.0vF	m0.4	244.4	
								8 V B1 S I 20m	27.7v6	0.04R	4R5	2F00.0	
								8 V B1 S I 207	v.5m8	20.F6v	FRmm	2F00.0	
8 V B1 S I 207	m5.700	F00.3F5	v.0	0	0	0.005	0.005	LV B1 S I 205	2F.36v	0.0vF	mF.0	244.4	
								8 V B1 S I 205	2v.5R3	0.FF3	FRmm	2F00.0	
								8 V B1 S I 203	4.R40	20.F4m	F75.m	2F00.0	
8 V B1 S I 206	m5.700	F00.300	6.4	0	0	0.005	0.005	LV B1 S I 207	2F.36v	0.0vF	mF.0	244.4	
								8 V B1 S I 20v	F.36R	20.0v7	m0.4	244.4	
								LV B1 S I 206	2F.36v	0.0vF	mF.0	244.4	
8 V B1 S I 20v	m5.700	F00.v54	6.4	0	0	0.005	0.005	8 V B1 S I 206	2F.36R	0.056	m0.4	2F00.0	
								8 V B1 S I 2F6	2F.360	0.0F0	m0.4	F00.0	
								8 V B1 S I 2F7	7.735	20.FnF	4R3	2F00.0	
8 V B1 S I 203	m5.700	F00.vFR	6.4	0	0	0.005	0.005	LV B1 S I 20v	2F.36v	0.0vF	mF.0	244.4	
								8 V B1 S I 207	24.R3F	0.F0R	F75.R	F00.0	
								8 V B1 S I 204	FF.F5m	20.Fvv	F37.R	2F00.0	
8 V B1 S I 204	m5.700	F00.76R	6.4	0	0	0.005	0.005	LV B1 S I 203	2F.36v	0.0vF	mF.0	244.4	
								8 V B1 S I 203	2F.FRv	0.0v0	F37.R	F00.0	
								8 V B1 S I 2F0	FR434	20.F57	RF6.R	F00.0	
8 V B1 S I 2F0	m5.700	F00.53m	6.3	0	0	0.005	0.005	LV B1 S I 204	2F.36v	0.0vR	mF.F	244.4	
								8 V B1 S I 204	2FR4v4	0.067	RF6.R	F00.0	
								8 V B1 S I 2R7	F5.35F	20.F50	R5v.R	F00.0	
8 V B1 S I 2Fm	m5.700	F00.4m4	6.4	0	0	0.005	0.005	LV B1 S I 2F0	2F.36v	0.0vR	mF.F	244.4	
								8 V B1 S I 2F5	F.36R	20.0v7	m0.4	244.4	
								LV B1 S I 2Fm	2F.36v	0.0vF	mF.0	244.4	
8 V B1 S I 2F5	m5.700	F00.33m	6.4	0	0	0.005	0.005	8 V B1 S I 2Fm	2F.36F	0.05m	m0.4	2F00.0	
								8 V B1 S I 2F7	mvR5	20.FF3	6F.3	2F00.0	
								LV B1 S I 2F5	2F.36v	0.0vF	mF.0	244.4	
8 V B1 S I 2F7	m5.700	F00.60m	6.4	0	0	0.005	0.005	8 V B1 S I 20v	27.7v6	0.060	4R3	F00.0	
								8 V B1 S I 2F5	2mvF5	0.0m4	6F.3	F00.0	
								8 V B1 S I 2Fv	FF.F7R	20.Fv5	F37.7	2F00.0	
8 V B1 S I 2F6	m5.700	F00.36m	6.4	0	0	0.005	0.005	LV B1 S I 2F7	2F.36v	0.0vR	mF.F	244.4	
								8 V B1 S I 20v	F.36R	20.0v7	m0.4	244.4	
								LV B1 S I 2F6	2F.36v	0.0vF	mF.0	244.4	
8 V B1 S I 2Fv	m5.700	F00.m45	6.3	0	0	0.005	0.005	JB2RF	FR44F	20.F0R	RF6.6	F00.0	
								8 V B1 S I 2F7	2FF.FR4	0.0R6	F37.7	F00.0	
								LV B1 S I 2Fv	2F.36v	0.0vR	mF.F	244.4	
8 V B1 S I 2R0	m5.700	F00.vn8	6.3	0	0	0.005	0.005	8 V B1 S I 2RF	F.36R	20.0v7	mF.0	244.4	
								LV B1 S I 2R0	2F.36v	0.0vF	mF.0	244.4	
								8 V B1 S I 2R0	2F.360	0.000	m0.4	F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Yilena_e: UWj OH

ETAP
F6.0.0C

Study Case: 1 UN T PY

Page: 5
Date: F02072R0Fv
SU: WESI WOODm
%eGision: v7f k EU
ConÁg.: Uor_ al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	M	f 8 ag.	p ng.	8 W	8 Gr	8 W	8 Gr	ND	8 W	8 Gr	p _9	f PY	f l a9
8 V B1 S I 2R	m5.700	F00.700	6.v	0	0	0.005	0.005	8 V B1 S I 2RR	mvRR	20.0v7	6F.4	2F00.0	
								LV B1 S I 2RF	2F.36v	0.0vR	nF.F	244.4	
								JB2RF	v.55F	20.F03	FRm4	2F00.0	
								8 V B1 S I 2RF	2mvF4	0.056	6F.4	F00.0	
								8 V B1 S I 2R4	2F.360	20.0Fm	nF.0	F00.0	
8 V B1 S I 2Rm	m5.700	F00.555	6.3	0	0	0.005	0.005	LV B1 S I 2RR	2F.36v	0.0vR	nF.F	244.4	
								34Ymp	R0.506	20.0FF	m0.0	F00.0	
								8 V B1 S I 2R3	2F3.755	20.067	m04.0	F00.0	
8 V B1 S I 2R5	m5.700	F00.F37	6.6	0	0	0.005	0.005	LV B1 S I 2Rm	2F.36v	0.0vR	nF.F	244.4	
								8 V B1 S I 2R7	F.36R	20.0v6	nF.F	244.4	
8 V B1 S I 2R7	m5.700	F00.F76	6.6	0	0	0.005	0.005	LV B1 S I 2R5	2F.36v	0.0vR	nF.R	244.4	
								34YFp	F3.7F3	0.F6v	m04.5	F00.0	
8 V B1 S I 2R6	m5.700	F00.vnF	6.4	0	0	0.005	0.005	8 V B1 S I 2F0	2F5.v4m	20.Rv6	R5v.R	F00.0	
								8 V B1 S I 2R5	2F.36R	0.0mm	nF.F	2F00.0	
								LV B1 S I 2R7	2F.36v	0.0vR	nF.R	244.4	
								8 V B1 S I 2Rv	F.36R	20.0v7	nF.0	244.4	
8 V B1 S I 2Rv	m5.700	F00.665	6.4	0	0	0.005	0.005	LV B1 S I 2R6	2F.36v	0.0vF	nF.0	244.4	
								8 V B1 S I 2R6	2F.36F	0.0mv	m04.0	2F00.0	
8 V B1 S I 2R3	m5.700	F00.7m3	6.4	0	0	0.005	0.005	8 V B1 S I 2R3	mvR5	20.FFm	6F.4	2F00.0	
								LV B1 S I 2Rv	2F.36v	0.0vR	nF.F	244.4	
								8 V B1 S I 2Rm	F3.76F	20.060	m04.0	F00.0	
								8 V B1 S I 2Rv	2mvF4	0.0vv	6F.4	2F00.0	
8 V B1 S I 2R4	m5.700	F00.676	6.3	0	0	0.005	0.005	8 V B1 S I 2mm	2FR430	20.04m	RF6.F	F00.0	
								LV B1 S I 2R3	2F.36v	0.0vR	nF.F	244.4	
								8 V B1 S I 2RR	F.36R	20.0v7	nF.0	244.4	
8 V B1 S I 2nF	m5.700	F0F.05v	v.F	0	0	0.005	0.005	LV B1 S I 2R4	2F.36v	0.0vR	nF.F	244.4	
								8 V B1 S I 2nR	F.36R	20.0v7	m04.0	244.4	
8 V B1 S I 2nR	m5.700	F00.37m	v.F	0	0	0.005	0.005	LV B1 S I 2nF	2F.36v	0.0vF	m04.0	244.4	
								8 V B1 S I 2nF	2F.374	20.0m6	m04.0	F00.0	
8 V B1 S I 2mm	m5.700	F00.v77	v.F	0	0	0.005	0.005	8 V B1 S I 2mm	mvRF	20.0m4	6F.3	F00.0	
								LV B1 S I 2nR	2F.36v	0.0vF	nF.0	244.4	
								8 V B1 S I 2R3	Fm003	20.FR6	RF6.F	F00.0	
								8 V B1 S I 2nR	2mvF3	0.0FF	6F.3	F00.0	
8 V B1 S I 2n5	m5.700	F00.3vR	v.F	0	0	0.005	0.005	8 V B1 S I 2m5	2v.5Rv	0.050	FRm5	F00.0	
								LV B1 S I 2mm	2F.36v	0.0vF	nF.0	244.4	
								8 V B1 S I 2mm	v.5m6	20.03F	FRm5	F00.0	
								8 V B1 S I 2n6	2mvF7	0.07R	6F.6	F00.0	
								8 V B1 S I 2n4	2F.374	20.056	m0.3	F00.0	
								LV B1 S I 2n5	2F.36v	0.0vF	nF.0	244.4	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Yilena_e: UWj OH

ETAP
F6.0.0C

Study Case: 1 UN T PY

Page: 7
Date: F02072R0Fv
SU: WESI WOODm
%eGision: v7f k EU
ConAg.: Uor_al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	M	f 8 ag.	p ng.	8 W	8 Gr	8 W	8 Gr	ND	8 W	8 Gr	p _9	f PY	f l a9
8 V B1 S I 2n6	n5.700	F0F.FFv	v.F	0	0	0.005	0.005	8 V B1 S I 2n5	mvR5	20.FRf	6F.v	244.4	
								8 V B1 S I 2nv	2F.36R	0.05v	n0.3	2F00.0	
								LV B1 S I 2n6	2F.36v	0.0vF	n0.4	244.4	
8 V B1 S I 2nv	n5.700	F0F.F66	v.F	0	0	0.005	0.005	8 V B1 S I 2n6	F.36R	20.0v7	n0.3	244.4	
								LV B1 S I 2nv	2F.36v	0.0vF	n0.4	244.4	
8 V B1 S I 2n4	n5.700	F0F.03m	v.F	0	0	0.005	0.005	8 V B1 S I 2n5	F.36R	20.0v7	n0.4	244.4	
								LV B1 S I 2n4	2F.36v	0.0vF	n0.4	244.4	
8 V B1 S I 250	n5.700	F0F.0FR	v.m	0	0	0.005	0.005	34Y5p	F3.7n5	0.075	n0v.F	F00.0	
								8 V B1 S I 256	2F6.6v7	20.FR4	Rv6.m	F00.0	
								LV B1 S I 250	2F.36v	0.0vF	n0.4	244.4	
8 V B1 S I 25F	n5.700	F0F.756	v.6	0	0	0.005	0.005	JB25/F	F.36m	20.0v5	n0.v	244.4	
								LV B1 S I 25F	2F.36v	0.0v0	n0.3	244.4	
8 V B1 S I 25R	n5.700	F0F.54v	v.6	0	0	0.005	0.005	JB25/F	v.5R4	20.075	FRR7	F00.0	
								8 V B1 S I 254	27.76v	20.0R0	4F.3	F00.0	
								LV B1 S I 25R	2F.36v	0.0v0	n0.3	244.4	
8 V B1 S I 25m	n5.700	F0F.757	v.6	0	0	0.005	0.005	JB25/F	F.36m	20.0v5	n0.v	244.4	
								LV B1 S I 25m	2F.36v	0.0v0	n0.3	244.4	
8 V B1 S I 255	n5.700	F0F.nmv	v.6	0	0	0.005	0.005	JB25/F	2F.Fn7	0.0Rv	F3m4	F00.0	
								8 V B1 S I 257	FR44v	20.F0R	RF5.6	F00.0	
								LV B1 S I 255	2F.36v	0.0vF	n0.3	244.4	
8 V B1 S I 257	n5.700	F0F.RnF	v.7	0	0	0.005	0.005	8 V B1 S I 255	2FR435	20.003	RF5.6	F00.0	
								8 V B1 S I 256	F5.356	20.066	RS7.5	F00.0	
								LV B1 S I 257	2F.36v	0.0vF	n0.4	244.4	
8 V B1 S I 256	n5.700	F0F.F07	v.5	0	0	0.005	0.005	8 V B1 S I 250	F6.640	0.0R6	Rv6.m	F00.0	
								8 V B1 S I 257	2F5.3R3	20.F0F	RS7.5	F00.0	
								LV B1 S I 256	2F.36v	0.0vF	n0.4	244.4	
8 V B1 S I 253	n5.700	F0F.346	v.v	0	0	0.005	0.005	8 V B1 S I 254	F.36m	20.0v5	n0.6	244.4	
								LV B1 S I 253	2F.36v	0.0v0	n0.v	244.4	
8 V B1 S I 254	n5.700	F0F.3nm	v.v	0	0	0.005	0.005	8 V B1 S I 25R	7.737	20.F53	4F.3	2F00.0	
								8 V B1 S I 253	2F.36F	0.0n6	n0.6	2F00.0	
								8 V B1 S I 270	2F.36F	0.0n5	n0.6	2F00.0	
								LV B1 S I 254	2F.36v	0.0v0	n0.v	244.4	
8 V B1 S I 270	n5.700	F0F.345	v.v	0	0	0.005	0.005	8 V B1 S I 254	F.36m	20.0v5	n0.6	244.4	
								LV B1 S I 270	2F.36v	0.0v0	n0.v	244.4	
* PON	Fm2.000	F00.000	0.0	2vv.R70	6.n60	0	0	34I Fp	2vv.R70	6.n60	nR5.m	244.v	
8 PI ~m	Fm300	44.465	v.0	0	0	0	0	HV B1 S 8 PI	0.000	0.000	0.0	0.0	
								& 34I FB					

* Indicates a Voltage regulated bus (Voltage controlled or swing ty9e _ achine connected to it)
Indicates a bus with a load _ is _ atch oA_ ore than 0.F 8 Vp

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: N
j ate: ND%6%DNk
SF: m ES_m OOj I
AeMsion: k6p 0 EF
Con8gT: F or2 al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
51- N	1B6DD	NDDE6N	VW	E	D	E	E	3 V UGS _%6	%6B6W	%T15	115R	1NN	
								51_NU	N6B6W	5T15	115R	1NN	
51- f.	1B6DD	NDDE6N	VW	E	D	E	E	JU%6/N	%DI1D5	%DWB	1kfTD	1NI	
								51_NU	fDI1D5	1DWB	1kfTD	1NI	
51- I.	1B6DD	NDDE6N	VW	E	D	E	E	3 V UGS _%6I	%DFkk	%T6N	1kfT5	1ND	
								51_NU	fDFkk	1T6N	1kfT5	1ND	
51- B	1B6DD	NDDE6N	VW	E	D	E	E	3 V UGS _%6D	%6T1I	%T51	1BTI	51T	
								51_NU	N6T1I	1T51	1BTI	51T	
51_N	N 5TDD	NDDEk	DD	E	D	E	E	POv	kkTDI f	f6T116	111TF	16D	
								HV UGS 3 P_	%kTDI f	%6T116	111TF	16D	
51_NU	1B6DD	NDDE6N	VW	E	D	E	E	51- B	%6T1I	%T51	1BTI	51T	
								51- I.	%DFkk	%T6N	1kfT5	1ND	
								51- f.	%DI1D5	%DWB	1kfTD	1NI	
								51- N	%6B6W	%T15	115R	1NN	
								3 P_~I	kkTBB	16T1W	N6W5	1DR	
								& HV UGS 3 P_					
HV UGS 3 P_	N 5TDD	NDDEk	DD	E	D	DD6B	DNk	51_N	kkTDI f	f6T116	111TF	16D	
								51_NU	%kTD56	%6B5f	111TW	1BII	6TDD
								& 3 P_~I					
JU%6/N	1B6DD	NDDE6B5	W5	E	D	E	E	3 V UGS _%6k	%T1WD	%61W	f16D	1N5	
								3 V UGS _%6f	%6NW	%TNW	NBTI	1fTD	
								51- f.	fDIkk	5R61	1WTN	1NI	
JU%6/N	1B6DD	NDTEkW	kT5	E	D	E	E	3 V UGS _%6N	%65WD	%DR6k	1fT5	1fTW	
								3 V UGS _%6f	%6Tf f	%T6B	NNRk	1fTD	
								3 V UGS _%6I	%65WD	%DR6W	1fT5	1fTW	
								3 V UGS _%6B	NNNI	BTW5	NlkTI	1fT	
LV UGS _%6N	DWD	NDTR5N	1D	N5k6	DEND	E	E	3 V UGS _%6N	N5k6	DEND	N6WB	1N5	
LV UGS _%6f	DWD	NDTWB	1D	N5k6	DEND	E	E	3 V UGS _%6f	N5k6	DEND	N6K5	1N5	
LV UGS _%6I	DWD	NDTB6	1D	N5k6	DEND	E	E	3 V UGS _%6I	N5k6	DEND	N6DI	1N5	
LV UGS _%6B	DWD	NDTE15	1D	N5k6	DEND	E	E	3 V UGS _%6B	N5k6	DEND	N6NI	1N5	
LV UGS _%65	DWD	NDTk1	1TN	N5k6	DEND	E	E	3 V UGS _%65	N5k6	DEND	N6BB	1N5	
LV UGS _%6W	DWD	NDTNB	1D	N5k6	DEND	E	E	3 V UGS _%6W	N5k6	DEND	N665	1N5	
LV UGS _%6k	DWD	NDTN1	1D	N5k6	DEND	E	E	3 V UGS _%6k	N5k6	DEND	N6WR	1N5	
LV UGS _%65	DWD	NDTNB	1D	N5k6	DEND	E	E	3 V UGS _%65	N5k6	DEND	N6WW	1N5	
LV UGS _%6I	DWD	NDTIB6	1D	N5k6	DEND	E	E	3 V UGS _%6I	N5k6	DEND	N615	1N5	
LV UGS _%6D	DWD	NDTf1	1D	N5k6	DEND	E	E	3 V UGS _%6D	N5k6	DEND	N6NR	1N5	

Project: Fm OH m vF j

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File Name: F m 7OH

ETAP

Model

Study Case: NPG 16L. 0

Page: f

Project Name: ND66%DNk

SF: m ES_m OOj 1

Assignment: k6p 0 EF

Configuration: F or2 al

Bus	Voltage			Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
LV UGS_ %M	DWDD	NDITID	5II	N5k6	DEND	L	L	3 V UGS_ %M	N5k6	DEND	N61 IV	1N5	
LV UGS_ %B	DWDD	NDITkD	5II	N5k6	DEND	L	L	3 V UGS_ %B	N5k6	DEND	N6BIV	1N5	
LV UGS_ %6	DWDD	NDITkN	1D	N5k6	DEND	L	L	3 V UGS_ %6	N5k6	DEND	N61 B	1N5	
LV UGS_ %MW	DWDD	NDITWN	1D	N5k6	DEND	L	L	3 V UGS_ %MW	N5k6	DEND	N6Bk	1N5	
LV UGS_ %k	DWDD	NDITWf	5II	N5k6	DEND	L	L	3 V UGS_ %k	N5k6	DEND	NWIT	1N5	
LV UGS_ %D	DWDD	NDITl	5II	N5k6	DEND	L	L	3 V UGS_ %D	N5k6	DEND	N65T	1N5	
LV UGS_ %N	DWDD	NDIT515	5II	N5k6	DEND	L	L	3 V UGS_ %N	N5k6	DEND	NWDIW	1N5	
LV UGS_ %f	DWDD	NDITK56	5II	N5k6	DEND	L	L	3 V UGS_ %f	N5k6	DEND	NWITB	1N5	
LV UGS_ %I	DWDD	NDITk11	1D	N5k6	DEND	L	L	3 V UGS_ %I	N5k6	DEND	NWITN	1N5	
LV UGS_ %B	DWDD	NDITB6	5B	N5k6	DEND	L	L	3 V UGS_ %B	N5k6	DEND	NWIT5	1N5	
LV UGS_ %6	DWDD	NDITNf	5B	N5k6	DEND	L	L	3 V UGS_ %6	N5k6	DEND	NKDN	1N5	
LV UGS_ %W	DWDD	NDITN6	1D	N5k6	DEND	L	L	3 V UGS_ %W	N5k6	DEND	N6Wf	1N5	
LV UGS_ %k	DWDD	NDITD6	1D	N5k6	DEND	L	L	3 V UGS_ %k	N5k6	DEND	N6k B	1N5	
LV UGS_ %5	DWDD	NDITl61	1N	N5k6	DEND	L	L	3 V UGS_ %5	N5k6	DEND	N61 IV	1N5	
LV UGS_ %1	DWDD	NDITl6N	5II	N5k6	DEND	L	L	3 V UGS_ %1	N5k6	DEND	N61 R	1N5	
LV UGS_ %N	DWDD	NDIT5W	1N	N5k6	DEND	L	L	3 V UGS_ %N	N5k6	DEND	NB1 B	1N5	
LV UGS_ %f	DWDD	NDITk1	1N	N5k6	DEND	L	L	3 V UGS_ %f	N5k6	DEND	N6f B	1N5	
LV UGS_ %I	DWDD	NDITk6	1N	N5k6	DEND	L	L	3 V UGS_ %I	N5k6	DEND	N6B5	1N5	
LV UGS_ %B	DWDD	NDITDI	1N	N5k6	DEND	L	L	3 V UGS_ %B	N5k6	DEND	N6f T	1N5	
LV UGS_ %W	DWDD	NDITWN	1N	N5k6	DEND	L	L	3 V UGS_ %W	N5k6	DEND	NB5T	1N5	
LV UGS_ %k	DWDD	NDITkf1	1N	N5k6	DEND	L	L	3 V UGS_ %k	N5k6	DEND	NBk T	1N5	
LV UGS_ %1	DWDD	NDITW6	1N	N5k6	DEND	L	L	3 V UGS_ %1	N5k6	DEND	NB5 R	1N5	
LV UGS_ %D	DWDD	NDITk1N	1T	N5k6	DEND	L	L	3 V UGS_ %D	N5k6	DEND	NBk T	1N5	
LV UGS_ %N	DWDD	NDBB1B	1B	N5k6	DEND	L	L	3 V UGS_ %N	N5k6	DEND	NW6T	1N5	
LV UGS_ %f	DWDD	NDBBHf	1B	N5k6	DEND	L	L	3 V UGS_ %f	N5k6	DEND	NWVD	1N5	
LV UGS_ %I	DWDD	NDBB1I	1B	N5k6	DEND	L	L	3 V UGS_ %I	N5k6	DEND	NW6T	1N5	
LV UGS_ %B	DWDD	NDBf1D	1B	N5k6	DEND	L	L	3 V UGS_ %B	N5k6	DEND	NW1T	1N5	
LV UGS_ %6	DWDD	NDBBk	1B	N5k6	DEND	L	L	3 V UGS_ %6	N5k6	DEND	NBENk	1N5	
LV UGS_ %BW	DWDD	NDITk	1B	N5k6	DEND	L	L	3 V UGS_ %BW	N5k6	DEND	NBBI	1N5	
LV UGS_ %5	DWDD	NDB51B	1B	N5k6	DEND	L	L	3 V UGS_ %5	N5k6	DEND	NW1D	1N5	
LV UGS_ %1	DWDD	NDB5fk	1B	N5k6	DEND	L	L	3 V UGS_ %1	N5k6	DEND	NWDD	1N5	
LV UGS_ %D	DWDD	NDB51f	1B	N5k6	DEND	L	L	3 V UGS_ %D	N5k6	DEND	NW1D	1N5	
3 V UGS_ %N	1B5DD	NDN5DW	kD	L	D	DDB	DDB	3 V UGS_ %f	N5WV	DkfW	1fB	11T	
								LV UGS_ %N	%5WV	%Bk1D	1fB	11N	
3 V UGS_ %f	1B5DD	NDNkNk	kD	L	D	DDB	DDB	3 V UGS_ %N	%5WD	%Bk6B	11N	1fT	
								3 V UGS_ %I	1RfN	NB11	WVD	1fB	
								LV UGS_ %f	%5WV	%Bkf1	11D	11N	
3 V UGS_ %I	1B5DD	NDN5WV	kD	L	D	DDB	DDB	3 V UGS_ %f	%kN6	%B11	WVf	1fB	
								3 V UGS_ %B	6BkW	fTVB	11T	1fR	

Project: Fm OH m vF j

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File Name: Fm 70H

ETAP

NWDEC

Study Case: NPG 16L. 0

Page: 1

Project Name: ND66DN

SF: mES_mOOj 1

Assignment: k6p 0 EF

Configuration: For2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
3 V UGS_%B	1B6DD	NN6k	kD	E	D	DDB	DDB	LV UGS_%A	%5WW	%Rf1	11D	11N	
								3 V UGS_%A	%6kN	%TND	11B	1fB	
								3 V UGS_%B	kBf	1D6	NfB	1fW	
3 V UGS_%B	1B6DD	NN16	kD	E	D	DDB	DDB	LV UGS_%B	%5WW	%Rf1	11D	11N	
								3 V UGS_%B	%BfD	%D5B	NfR	1fT	
								3 V UGS_%B	1T5N	1B1	N6R	1fB	
3 V UGS_%B	1B6DD	NN1D	kD	E	D	DDB	DDB	LV UGS_%B	%5WW	%Rf1	11N	11N	
								3 V UGS_%B	N5W	Dkf6	11D	11T	
								LV UGS_%B	%5WW	%Rf1	11N	11N	
3 V UGS_%B	1B6DD	NN6f	kD	E	D	DDB	DDB	3 V UGS_%B	%5WD	%R66	11T	1fR	
								3 V UGS_%B	%561	%R1N	11B	1fD	
								3 V UGS_%B	6B5D	fTkD	11R	1fW	
3 V UGS_%B	1B6DD	NN65	kD	E	D	DDB	DDB	LV UGS_%B	%5WW	%Rf1	11N	11N	
								3 V UGS_%B	%TkD	%B11	NWB	1fT	
								3 V UGS_%B	NNf	BWB	N1B	1fT	
3 V UGS_%B	1B6DD	ND166	kD	E	D	DDB	DDB	LV UGS_%B	%5WW	%Rf1	11N	11N	
								3 V UGS_%B	%NNN	%R1D	fDDf	1fD	
								3 V UGS_%B	N1TkB	6B6B	f11T	1fT	
3 V UGS_%B	1B6DD	ND1k	kD	E	D	DDB	DDB	LV UGS_%B	%5W6	%Rf5	11T	11T	
								3 V UGS_%B	%N1W	%B1B	f11T	1fD	
								3 V UGS_%B	NBf1	Wf65	fVkd	1fN	
3 V UGS_%B	1B6DD	NN1Bk	kD	E	D	DDB	DDB	LV UGS_%B	%5W6	%Rf5	11T	11T	
								3 V UGS_%B	N5W	Dkf6	11D	11T	
								LV UGS_%B	%5WW	%Rf1	11N	11N	
3 V UGS_%B	1B6DD	NN15W	kD	E	D	DDB	DDB	3 V UGS_%B	%5WD	%R65	11T	1fW	
								3 V UGS_%B	1RfN	NB51	WWf	1fT	
								LV UGS_%B	%5WW	%Rf1	11N	11N	
3 V UGS_%B	1B6DD	ND15N	kD	E	D	DDB	DDB	3 V UGS_%B	%6kN	%TBN	NDN	1fT	
								3 V UGS_%B	%RDI	%5W	WWk	1fT	
								3 V UGS_%B	NNBf	BWfW	N1T	1fB	
3 V UGS_%B	1B6DD	NN1kW	kD	E	D	DDB	DDB	LV UGS_%B	%5W6	%Rf5	11T	11T	
								3 V UGS_%B	N5W	Dkf6	11D	11T	
								LV UGS_%B	%5WW	%Rf1	11N	11N	
3 V UGS_%B	1B6DD	ND1W5	kD	E	D	DDB	DDB	3 V UGS_%B	N1TkW	6B1k	f1Bf	1fN	
								3 V UGS_%B	%NNN6	%Bk1	fDND	1N1	
								LV UGS_%B	%5W6	%Rf5	11T	11T	
3 V UGS_%B	1B6DD	NN16N	kD	E	D	DDB	DDB	3 V UGS_%B	N5W	Dkf6	11N	11T	
								LV UGS_%B	%5WW	%Rf5	11T	11T	
								3 V UGS_%B	%565	%BDD	11W	1NB	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ile na2 e: F m 7OH

ETAP
NWDEC
Study Case: NPG 16L. 0

Page: B
j ate: ND66%DNk
SF: m ES_m OOj I
AeMsion: k6p 0 EF
Con8gT: F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
yj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	yj	3 m	3 Mr	. 2 4	p P-	p _a4
3 V UGS_%f	1B6DD	NDK1f	W6	E	D	DDB	DDB	3 V UGS_%f	1KfD	N6f6	WWK	1fT6	
								LV UGS_%N	%N6W6	%Dkf5	11T	11T	
								JU%/N	kH B	1Df	N1K	1fT	
								3 V UGS_%N	%KN6	%N66B	WW	1fT	
3 V UGS_%I	1B6DD	ND6Lk	W	E	D	DDB	DDB	3 V UGS_%I	%N65	%D6N	11K	1NW	
								LV UGS_%f	%N6W6	%Dkf5	11T	11T	
								51-1.	fDf5D	5K5k	1W6B	1N6	
								3 V UGS_%5	%56N	%DW	116T	1NK	
3 V UGS_%B	1B6DD	NDHBB	WK	E	D	DDB	DDB	LV UGS_%I	%N6W6	%Dkf5	11T	11T	
								3 V UGS_%6	N6WN	DkfB	11T	11T	
3 V UGS_%6	1B6DD	NDHND	WK	E	D	DDB	DDB	LV UGS_%B	%N6W6	%Dkf6	11B	11T	
								51- N	N6B5	5N6B	11kN	1N6	
								3 V UGS_%D	%BRWW	%WWB	fkdT	1NN	
								3 V UGS_%B	%N6WN	%DkWW	11TW	1fT6	
3 V UGS_%W	1B6DD	NNNK1	kD	E	D	DDB	DDB	LV UGS_%6	%N6W6	%Dkf6	11B	11T	
								3 V UGS_%k	N6WN	Dkf6	11D	11T	
								LV UGS_%W	%N6WW	%Dkf1	11N	11N	
								3 V UGS_%W	%N6WD	%DkW	11T	1fT6	
3 V UGS_%5	1B6DD	NDH1W	kD	E	D	DDB	DDB	3 V UGS_%5	1KfN	N655	WW	1fT	
								LV UGS_%k	%N6WW	%Dkf5	11N	11N	
								3 V UGS_%I	N6B11	kTBf	11BT	1N	
								3 V UGS_%k	%KNW	%N6f1	WWW	1fT6	
3 V UGS_%I	1B6DD	NDH1W	kD	E	D	DDB	DDB	3 V UGS_%I	%N1W	%TW6	f1BK	1NW	
								LV UGS_%5	%N6W6	%Dkf5	11T	11T	
								3 V UGS_%f	N6WN	DkfB	11N	11T	
								LV UGS_%I	%N6W6	%Dkf5	11T	11T	
3 V UGS_%N	1B6DD	NNW6	kN	E	D	DDB	DDB	3 V UGS_%f	N6WN	Dkf6	1fT	11T	
								LV UGS_%N	%N6WW	%Dkf1	11D	11N	
	1B6DD	NNf1k	kN	E	D	DDB	DDB	3 V UGS_%N	%N66k	%D615	11TW	1Nf	
								3 V UGS_%I	1KN	N6W	WWW	1fT	
3 V UGS_%I	1B6DD	NNf1N	kN	E	D	DDB	DDB	LV UGS_%f	%N6WW	%Dkf1	11N	11N	
								3 V UGS_%5	Nf116	6K5	f11D	1fN	
								3 V UGS_%f	%KNB	%61D	WW6	1N	
								3 V UGS_%B	%N	%NW	N1T	1fD	
3 V UGS_%B	1B6DD	NN6f5	kN	E	D	DDB	DDB	LV UGS_%I	%N6WW	%Dkf1	11N	11N	
								3 V UGS_%I	kBf1	1Nf	N1D	1fT	
								3 V UGS_%W	%KN	%N6B	WWB	1fT	
								3 V UGS_%I	%N66k	%D6B5	11K	1ND	
								LV UGS_%B	%N6WW	%Dkf1	11D	11N	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ile na2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: 6
j ate: ND66%DNk
SF: m ES_m OOj I
AeMsion: k6p 0 EF
Con8gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
3 V UGS _%W	1B6DD	NDNW6k	kTN	E	D	DDB	DDB	3 V UGS _%B	1Tff	NEk1	V6II	1fII	
								3 V UGS _%k	%N6WD	%DR6B	11ID	1fTR	
								LV UGS _%W	%N6WW	%DRf1	11ID	11TN	
3 V UGS _%k	1B6DD	NDN6k	kTN	E	D	DDB	DDB	3 V UGS _%W	N6WN	DRfW	1fII	11T	
								LV UGS _%k	%N6WW	%DRf1	1fII	11TN	
3 V UGS _%1	1B6DD	NDN6k	kTN	E	D	DDB	DDB	3 V UGS _%B	N6WN	DRfW	1fII	11T	
								LV UGS _%1	%N6WW	%DRf1	11ID	11TN	
3 V UGS _%BD	1B6DD	NDN66	kT	E	D	DDB	DDB	51- B	N6BN	5DWB	11fTN	1NR	
								3 V UGS _%BW	%N6WN	%T11	f11T	1NB	
								LV UGS _%BD	%N6WW	%DRf1	1fII	11TN	
3 V UGS _%BN	1B6DD	NDT61f	kT6	E	D	DDB	DDB	JU%BN	N6WN	DRfk	1fTW	11T	
								LV UGS _%BN	%N6WW	%DR1N	1fTR	11TN	
3 V UGS _%Bf	1B6DD	NDT6k1	kT6	E	D	DDB	DDB	JU%BN	kTff	1T6I	NNR	1fID	
								3 V UGS _%B1	%T6WN	%BTk	11TN	1NR	
								LV UGS _%Bf	%N6WW	%DR1N	1fTR	11TN	
3 V UGS _%B1	1B6DD	NDT61D	kT6	E	D	DDB	DDB	JU%BN	N6WN	DRfk	1fTW	11T	
								LV UGS _%B1	%N6WW	%DR1N	1fTR	11TN	
3 V UGS _%BB	1B6DD	NDT6TW	kT6	E	D	DDB	DDB	JU%BN	%NNTf	%BR5I	N15TN	1NI	
								3 V UGS _%B6	N6T5B	6TND	f1D6	1fTN	
								LV UGS _%BB	%N6WW	%DR1D	1fT6	11TN	
3 V UGS _%B6	1B6DD	NDT6Nk	kTB	E	D	DDB	DDB	3 V UGS _%BB	%N6TW6	%N6N	f1NW	1NB	
								3 V UGS _%BW	N6Tf1	W6BW	fV6B	1NI	
								LV UGS _%B6	%N6WW	%DR1D	1fT6	11TN	
3 V UGS _%BW	1B6DD	NDN11	kTB	E	D	DDB	DDB	3 V UGS _%BD	N6WW	kT1k	f15TB	1NR	
								3 V UGS _%B6	%N6TD6	%W6NN	fV6TW	1NB	
								LV UGS _%BW	%N6WW	%DR1D	1fII	11TN	
3 V UGS _%B5	1B6DD	NDT115	kT6	E	D	DDB	DDB	3 V UGS _%B1	N6WN	DRfk	1fT6	11TN	
								LV UGS _%B5	%N6WW	%DR1N	1fTW	11TN	
3 V UGS _%B1	1B6DD	NDT6kD	kT6	E	D	DDB	DDB	3 V UGS _%Bf	6T5f	fT6k	1kII	1fTR	
								3 V UGS _%B5	%N6WD	%DRV6	1fTR	1fT6	
								3 V UGS _%D	%N6WD	%DRVB	1fTR	1fT6	
								LV UGS _%B1	%N6WW	%DR1N	1fTW	11TN	
								3 V UGS _%B1	N6WN	DRfk	1fT6	11TN	
3 V UGS _%D	1B6DD	NDT11W	kT6	E	D	DDB	DDB	LV UGS _%D	%N6WW	%DR1N	1fTW	11TN	
								51_N	%kT1D	%6Tf5	111T	16D	
* POv	N 5TDD	NDDD	DD	%kT1D	%6Tf5	E	E	HV UGS 3 P_	DDDD	DDDD	DD	DD	
3 P_~I	N 5TDD	NDDBW	kT	E	D	E	E	& 51_NU					

* indicates a Voltage regulated bus (Voltage controlled or swing ty4e 2 achine connected to it)
indicates a bus with a load 2 is2 atch o82 ore than DN3 V.

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: 0
j ate: 0D%CP%DDk
SF : m ES_m OOj l
AeMsion: kQp . EF
Con8gT F or2 al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
5N 06	1BICDD	NN50G	VK	E	D	E	E	3 V U1 S _%G	%5BGG	%Tf5	11NG	N0D	
								5N_0U	05BGG	5Tf5	11NG	N0D	
5N f6	1BICDD	NN50G	VK	E	D	E	E	JU%0	%DIDk	%DGB	1kf5	N0T	
								5N_0U	fDIDk	NDGB	1kf5	N0T	
5N 16	1BICDD	NN50G	VK	E	D	E	E	3 V U1 S _%I	%Dfkg	%F1N	1klTW	N0D	
								5N_0U	fDfkg	NF1N	1klTW	N0D	
5N B6	1BICDD	NN50G	VK	E	D	E	E	3 V U1 S _%BD	%5TIDf	%FVW	1B1N	5NT	
								5N_0U	05TIDf	NFVW	1B1N	5NT	
5N_06	015TDD	NGIDk	DD	E	D	E	E	POv	kkDI0	fGFkG	1GkD	NGD	
								HV U1 S 3 P_	%kDI0	%GFkG	1GkD	NGD	
5N_0U	1BICDD	NN50G	VK	E	D	E	E	5N B6	%5TIDf	%FVW	1B1N	5NT	
								5N 16	%Dfkg	%F1N	1klTW	N0D	
								5N f6	%DIDk	%DGB	1kf5	N0T	
								5N 06	%5BGG	%Tf5	11NG	N0D	
								3 P_~I	kkTBD	1G5k	0BfNG	NDK	
HV U1 S 3 P_	015TDD	NGIDk	DD	E	D	DDf5	DDH	& HV U1 S 3 P_					
								5N_06	kkDI0	fGFkG	1GkD	NGD	
								5N_0U	%kT5D	%GIND	1GkB	NGD	
JU%0	1BICDD	0DDI0I	VN	E	D	E	E	& 3 P_~I					
								3 V U1 S _%k	%fTND	%IGN	f1GG	N05	
								3 V U1 S _%f	%B0W	%DWD	01BG	NTD	
JU%B0	1BICDD	0DfTBB	kTG	E	D	E	E	5N f6	fDIDkW	5KG	1kDD	N0N	
								3 V U1 S _%BD	%5VD	%RkG	1fTN	NTW	
								3 V U1 S _%Bf	%Bff	%DGf	01fTD	NTD	
								3 V U1 S _%BI	%5VD	%RGW	1fTN	NTW	
LV U1 S _%BD	DDND	0DfTGGf	ND	05kG	D50D	E	E	3 V U1 S _%BB	00DBf	BfWB	0NkR	NfT	
								3 V U1 S _%BD	05kG	D50D	0WDD	N05	
								3 V U1 S _%Df	05kG	D50D	0WDTG	N05	
LV U1 S _%BI	DDND	0DfT0W	ND	05kG	D50D	E	E	3 V U1 S _%DI	05kG	D50D	0WQf5	N05	
LV U1 S _%BB	DDND	0DfT1N	ND	05kG	D50D	E	E	3 V U1 S _%DB	05kG	D50D	0WCGG	N05	
LV U1 S _%BG	DDND	0DfTBN	ND	05kG	D50D	E	E	3 V U1 S _%DG	05kG	D50D	0W5TD	N05	
LV U1 S _%BW	DDND	0DfTNB	ND	05kG	D50D	E	E	3 V U1 S _%DW	05kG	D50D	0WNGG	N05	
LV U1 S _%Bk	DDND	0DfTNN	ND	05kG	D50D	E	E	3 V U1 S _%Ek	05kG	D50D	0WDB	N05	
LV U1 S _%BS	DDND	0DfT0G	ND	05kG	D50D	E	E	3 V U1 S _%ES	05kG	D50D	0WDDf	N05	
LV U1 S _%BN	DDND	0DfT0B	ND	05kG	D50D	E	E	3 V U1 S _%EN	05kG	D50D	0WWTG	N05	
LV U1 S _%BD	DDND	0DfTGN5	ND	05kG	D50D	E	E	3 V U1 S _%GD	05kG	D50D	0WGB	N05	

Project: Fm OH m vF j

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File Name: F m 7OH

ETAP

0WDEEC

Study Case: NGP1 NGL6 .

Page: f

Project Name: 0D98CP6DDk

SF: mES_m OOj 1

Assignment: kQp . EF

Configuration: F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
LV U1 S_ %I	DWND 0DI TDD	ND	0FkG	DE0D				3 V U1 S_ %I	0FkG	DE0D	0WkT	N0F	
LV U1 S_ %B	DWND 0DI TEB	ND	0FkG	DE0D				3 V U1 S_ %B	0FkG	DE0D	0WkT	N0F	
LV U1 S_ %G	DWND 0DI TRD	ND	0FkG	DE0D				3 V U1 S_ %G	0FkG	DE0D	0WWT	N0F	
LV U1 S_ %W	DWND 0DI TDI	ND	0FkG	DE0D				3 V U1 S_ %W	0FkG	DE0D	0WkTB	N0F	
LV U1 S_ %k	DWND 0DI TEW	ND	0FkG	DE0D				3 V U1 S_ %k	0FkG	DE0D	0WkTW	N0F	
LV U1 S_ %D	DWND 0DI TELN	5TN	0FkG	DE0D				3 V U1 S_ %D	0FkG	DE0D	0WWT	N0F	
LV U1 S_ %0	DWND 0DI TWW	5TN	0FkG	DE0D				3 V U1 S_ %0	0FkG	DE0D	0WWT	N0F	
LV U1 S_ %f	DWND 0DI TCB	5TN	0FkG	DE0D				3 V U1 S_ %f	0FkG	DE0D	0WWW	N0F	
LV U1 S_ %I	DWND 0DI TGN	ND	0FkG	DE0D				3 V U1 S_ %I	0FkG	DE0D	0WGN	N0F	
LV U1 S_ %B	DWND 0DI TDI	5TN	0FkG	DE0D				3 V U1 S_ %B	0FkG	DE0D	0WkT	N0F	
LV U1 S_ %G	DWND 0DI TED	5TN	0FkG	DE0D				3 V U1 S_ %G	0FkG	DE0D	0WkTN	N0F	
LV U1 S_ %W	DWND 0DI TNG	ND	0FkG	DE0D				3 V U1 S_ %W	0FkG	DE0D	0WGN	N0F	
LV U1 S_ %k	DWND 0DI TEW	ND	0FkG	DE0D				3 V U1 S_ %k	0FkG	DE0D	0WWT	N0F	
LV U1 S_ %5	DWND 0DI Tfn	ND	0FkG	DE0D				3 V U1 S_ %5	0FkG	DE0D	0WWT	N0F	
LV U1 S_ %N	DWND 0DI Tfo	5TN	0FkG	DE0D				3 V U1 S_ %N	0FkG	DE0D	0WWT	N0F	
LV U1 S_ %0	DWND 0DI Tfk	ND	0FkG	DE0D				3 V U1 S_ %0	0FkG	DE0D	0WkT	N0F	
LV U1 S_ %f	DWND 0DI TGD	NF	0FkG	DE0D				3 V U1 S_ %f	0FkG	DE0D	0WVG	N0F	
LV U1 S_ %I	DWND 0DI TEG	NF	0FkG	DE0D				3 V U1 S_ %I	0FkG	DE0D	0WkT	N0F	
LV U1 S_ %B	DWND 0DI TSD	NF	0FkG	DE0D				3 V U1 S_ %B	0FkG	DE0D	0WGD	N0F	
LV U1 S_ %W	DWND 0DI TEH	ND	0FkG	DE0D				3 V U1 S_ %W	0FkG	DE0D	0WkTB	N0F	
LV U1 S_ %k	DWND 0DI TEN	ND	0FkG	DE0D				3 V U1 S_ %k	0FkG	DE0D	0WkTD	N0F	
LV U1 S_ %N	DWND 0DI TEW	ND	0FkG	DE0D				3 V U1 S_ %N	0FkG	DE0D	0WkTB	N0F	
LV U1 S_ %D	DWND 0DI TGD	NB	0FkG	DE0D				3 V U1 S_ %D	0FkG	DE0D	0WkDN	N0F	
LV U1 S_ %0	DWND 0DBFW	NG	0FkG	DE0D				3 V U1 S_ %0	0FkG	DE0D	0WST	N0F	
LV U1 S_ %f	DWND 0DBF0B	NG	0FkG	DE0D				3 V U1 S_ %f	0FkG	DE0D	0WNW	N0F	
LV U1 S_ %I	DWND 0DBFVG	NG	0FkG	DE0D				3 V U1 S_ %I	0FkG	DE0D	0WST	N0F	
LV U1 S_ %B	DWND 0DBED	NG	0FkG	DE0D				3 V U1 S_ %B	0FkG	DE0D	0WkTN	N0F	
LV U1 S_ %G	DWND 0DI TBS	NG	0FkG	DE0D				3 V U1 S_ %G	0FkG	DE0D	0WGB	N0F	
LV U1 S_ %W	DWND 0DI TWS	NB	0FkG	DE0D				3 V U1 S_ %W	0FkG	DE0D	0WSTG	N0F	
LV U1 S_ %5	DWND 0DBWW	NG	0FkG	DE0D				3 V U1 S_ %5	0FkG	DE0D	0WfTG	N0F	
LV U1 S_ %N	DWND 0DBWDD	NG	0FkG	DE0D				3 V U1 S_ %N	0FkG	DE0D	0WfTG	N0F	
LV U1 S_ %D	DWND 0DBWVG	NG	0FkG	DE0D				3 V U1 S_ %D	0FkG	DE0D	0WfTG	N0F	
3 V U1 S_ %0	1BICDD 0D0Tki	kTD		D	D	DDB	DDB	3 V U1 S_ %f	0FkG	DrfG	1fTN	N0F	
								LV U1 S_ %0	0FkG	DrfN	1fTD	N0D	
								3 V U1 S_ %0	0FkG	Drki	1fTF	N0F	
3 V U1 S_ %f	1BICDD 0D0Tki	kTD		D	D	DDB	DDB	3 V U1 S_ %I	1FkG	0FkG	WWD	N0F	
								LV U1 S_ %f	0FkG	DrfN	1fTD	N0D	
								3 V U1 S_ %B	0FkG	DrfN	1fTD	N0D	
3 V U1 S_ %I	1BICDD 0D0Tki	kTD		D	D	DDB	DDB	3 V U1 S_ %f	0FkG	DrfN	1fTD	N0D	
								3 V U1 S_ %B	0FkG	DrfN	1fTD	N0D	

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1_NGL6.

Page: I
j ate: 0D%CP%DDk
SF: mES_mOOj I
AeMsion: kQp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow					XFMR
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S_%B	1BICDD	0DDTfB	kD	E	D	DDB	DDB	LV U1 S_%I	%FVW	%RfN	11D	N D	
								3 V U1 S_%I	%GkD	%TD5	NNR	N B	
								3 V U1 S_%G	kH f	1DI1	0Ifk	N TW	
3 V U1 S_%G	1BICDD	0DDTW	kD	E	D	DDB	DDB	LV U1 S_%B	%FVW	%RfN	11D	N D	
								3 V U1 S_%B	%TFD	%D50	011D	N B	
								3 V U1 S_%5	NF50	1TDW	0VWD	N TG	
3 V U1 S_%W	1BICDD	0DDNkG	kD	E	D	DDB	DDB	LV U1 S_%G	%FVW	%Rf5	11T	N T	
								3 V U1 S_%k	0FW	DkfG	11D	N T	
								LV U1 S_%W	%FWG	%Rf5	11T	N T	
3 V U1 S_%k	1BICDD	0DDN05	kD	E	D	DDB	DDB	3 V U1 S_%W	%FWD	%RkG	11T	N R	
								3 V U1 S_%W	%FCN	%RND	11TG	N TD	
								3 V U1 S_%G	Gk5D	fTW	NNN	N TW	
3 V U1 S_%5	1BICDD	0DDN B	kD	E	D	DDB	DDB	LV U1 S_%k	%FWG	%Rf5	11T	N T	
								3 V U1 S_%G	%TkD	%BNW	0VWk	N T	
								3 V U1 S_%N	00D10	BIWD	0NN5	N B	
3 V U1 S_%N	1BICDD	0DDkfD	kD	E	D	DDB	DDB	LV U1 S_%5	%FWG	%Rf5	11T	N T	
								3 V U1 S_%5	%0D0f	%RfW	fDDW	N TD	
								3 V U1 S_%D	0fTkI	GBGD	f115	N T	
3 V U1 S_%D	1BICDD	0DDWf	kD	E	D	DDB	DDB	LV U1 S_%N	%FWG	%Rf5	11T	N T	
								3 V U1 S_%N	%fTN0	%GFN	f1BB	N TD	
								3 V U1 S_%G	0B5ff	WfG	fVKTW	N TD	
3 V U1 S_%I	1BICDD	0DD0B	WN	E	D	DDB	DDB	LV U1 S_%D	%FWG	%Rf5	11T	N T	
								3 V U1 S_%B	0FW	DkfG	11D	N T	
								LV U1 S_%I	%FVW	%Rf5	11D	N D	
3 V U1 S_%B	1BICDD	0DDQf	WN	E	D	DDB	DDB	3 V U1 S_%I	%FWD	%RkG	11T	N TW	
								3 V U1 S_%G	1Rf0	0B5f	VWf	N TN	
								LV U1 S_%B	%FVW	%Rf5	11T	N T	
3 V U1 S_%G	1BICDD	0DDRk	kD	E	D	DDB	DDB	3 V U1 S_%k	%Gk0	%T1N	0DDB	N T	
								3 V U1 S_%B	%kDN	%TWD	VW5	N T	
								3 V U1 S_%k	00DBf	BIW1	fDDB	N B	
3 V U1 S_%W	1BICDD	0DDTH	kD	E	D	DDB	DDB	LV U1 S_%G	%FWG	%Rf5	11T	N T	
								3 V U1 S_%k	0FW	DkfG	11D	N T	
								LV U1 S_%W	%FWG	%Rf5	11T	N T	
3 V U1 S_%k	1BICDD	0DDBW	WN	E	D	DDB	DDB	JU%0	0fTkG	GENf	f1BK	N TD	
								3 V U1 S_%G	%0D0B	%BRW	fD0TG	N0N	
								LV U1 S_%k	%FWG	%Rfk	11B	N T	
3 V U1 S_%D	1BICDD	0DD50k	WN	E	D	DDB	DDB	3 V U1 S_%0	0FW	DkfB	11T	N T	
								LV U1 S_%D	%FWG	%Rf5	11T	N T	
								3 V U1 S_%D	%5G5	%5DD	11TW	N0N	

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: B
j ate: 0D0CP%DDk
SF : m ES_m OOj l
AeMsion: kQp . EF
Con8gT F or2 al

Bus		Voltage		Generation		Load		Load Flow					XFMR	
yj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	yj	3 m	3 Mr	6 2 4	p P-	p _a4	
3 V U1 S _%f	1BICDD 0DDGk	WN	E	D	DDDB	DDDB	JU%/0	3 V U1 S _%f	1RfD	0TfB	VW5	N TG		
								LV U1 S _%0	%5WG	%8rf5	11 T	N T		
								3 V U1 S _%0	kH B	1T5N	01BD	N T		
								3 V U1 S _%N	%K0G	%TGG	VKD	N T		
3 V U1 S _%I	1BICDD 0DDKkf	kD	E	D	DDDB	DDDB	5N 16	LV U1 S _%f	%5WG	%8rf5	11 T	N T		
								3 V U1 S _%5	fDT5D	5KkN	1VWf	N0B		
								LV U1 S _%I	%5WG	%8rf5	11 T	N T		
								3 V U1 S _%B	%5TD5	%5DGG	11WD	N0R		
3 V U1 S _%B	1BICDD 0DD0D5	W5	E	D	DDDB	DDDB	3 V U1 S _%G	LV U1 S _%I	05W	Dkf1	11 B	N T		
								LV U1 S _%B	%5WG	%8rfk	11 TG	N T		
								3 V U1 S _%G	1BICDD 0DDkG	W5	E	D	DDDB DDDB	
								5N 06	05Bsk	5DBG	11k5	N0G		
3 V U1 S _%W	1BICDD 0DDNG	kD	E	D	DDDB	DDDB	3 V U1 S _%k	3 V U1 S _%0D	%5WG	%8rf5	11 T	N T		
								LV U1 S _%W	%5WG	%8rfk	11 TG	N T		
								3 V U1 S _%k	05W	DkfB	11 D	N T		
								LV U1 S _%W	%5WG	%8rf5	11 T	N T		
3 V U1 S _%k	1BICDD 0DD5kI	kD	E	D	DDDB	DDDB	3 V U1 S _%W	3 V U1 S _%5	1Rf0	0Bsk	VWG	N TN		
								LV U1 S _%k	%5WG	%8rf5	11 T	N T		
								3 V U1 S _%I	05GN	kNG	11GD	N0N		
								3 V U1 S _%k	%R0W	%TGF	VWR	N TG		
3 V U1 S _%5	1BICDD 0DDK1G	kD	E	D	DDDB	DDDB	3 V U1 S _%I	3 V U1 S _%I	%fTNW	%GW5N	f1GF	N0TW		
								LV U1 S _%5	%5WG	%8rf5	11 T	N T		
								3 V U1 S _%N	05W	DkfB	11 T	N T		
								LV U1 S _%N	%5WG	%8rf5	11 T	N T		
3 V U1 S _%N	1BICDD 0DDkfk	WN	E	D	DDDB	DDDB	3 V U1 S _%f	3 V U1 S _%0	05W	DkfG	11 D	N T		
								LV U1 S _%N	%5WW	%8rfN	11 D	N D		
								3 V U1 S _%f	1BICDD 0DDTW5	kD	E	D	DDDB DDDB	
								3 V U1 S _%0	%5Gk	%51k	11 R	N0T		
3 V U1 S _%f	1BICDD 0DDTW5	kD	E	D	DDDB	DDDB	3 V U1 S _%I	3 V U1 S _%I	1K05	0TGW	VWR	N T		
								LV U1 S _%f	%5WW	%8rfN	11 D	N D		
								3 V U1 S _%5	0fTNG	GEkB	f11TG	N T		
								3 V U1 S _%f	%R0B	%T5N	VWN	N0N		
3 V U1 S _%I	1BICDD 0DDTgk	kD	E	D	DDDB	DDDB	3 V U1 S _%B	3 V U1 S _%B	%B0N	%DWD	011TG	N D		
								LV U1 S _%I	%5WW	%8rf5	11 T	N T		
								3 V U1 S _%I	kBfN	1DfD	011T	N T		
								3 V U1 S _%W	%R00	%T55	VWG	N T		
3 V U1 S _%B	1BICDD 0DDTNB	kD	E	D	DDDB	DDDB	3 V U1 S _%N	LV U1 S _%B	%5Gk	%5Bk	11 B	N0D		
								3 V U1 S _%B	%5WW	%8rfN	11 D	N D		

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: G
j ate: 0D%CP%DDk
SF: m ES_m OOj l
AeMsion: kQp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S _%W	1BICDD	0D%DWB	kD	E	D	DDB	DDB	3 V U1 S _%B	1Rff	0EkN	VWD	N TN	
								3 V U1 S _%k	%FWD	%RGI	11 D	N TR	
								LV U1 S _%W	%FVW	%RfN	11 D	N D	
3 V U1 S _%k	1BICDD	0D%DDB	kD	E	D	DDB	DDB	3 V U1 S _%W	0FW	DkfG	1f TN	N T	
								LV U1 S _%k	%FVW	%RfN	11 D	N D	
3 V U1 S _%N	1BICDD	0D%DfB	kD	E	D	DDB	DDB	3 V U1 S _%B	0FW	DkfG	11 D	N T	
								LV U1 S _%N	%FVW	%RfN	11 D	N D	
3 V U1 S _%D	1BICDD	0D%Df0	kT	E	D	DDB	DDB	5N B6	05Df	5DGW	11f B	N0K	
								3 V U1 S _%BW	%VWGD	%T10	fNNN	N0TG	
								LV U1 S _%D	%FVW	%RfN	11 D	N D	
3 V U1 S _%D	1BICDD	0D%DID	kTG	E	D	DDB	DDB	JU%B0	0FW	DkfW	1f R	N T	
								LV U1 S _%D	%FVW	%R1D	1f B	N D	
3 V U1 S _%f	1BICDD	0D%DfBk	kTG	E	D	DDB	DDB	JU%B0	kBff	1DGD	01f D	N TD	
								3 V U1 S _%BN	%GWD	%BfB	NNI	N0K	
								LV U1 S _%f	%FVW	%R1D	1f B	N D	
3 V U1 S _%B	1BICDD	0D%DfN5	kTG	E	D	DDB	DDB	JU%B0	0FW	DkfW	1f R	N T	
								LV U1 S _%B	%FVW	%R1D	1f B	N D	
3 V U1 S _%B	1BICDD	0D%D10	kTG	E	D	DDB	DDB	JU%B0	%0Df	%BkN	0N5TW	N0N	
								3 V U1 S _%BG	0fT5I	GCIG	f10T	N TD	
								LV U1 S _%B	%FVW	%R1D	1f TN	N D	
3 V U1 S _%BG	1BICDD	0D%D5kB	kTG	E	D	DDB	DDB	3 V U1 S _%B	%fTN5	%N0B	f1f D	N0B	
								3 V U1 S _%BW	0B5fN	VfBD	fVBN	N0N	
								LV U1 S _%BG	%FVW	%R1D	1f TN	N D	
3 V U1 S _%BW	1BICDD	0D%DfKD	kTB	E	D	DDB	DDB	3 V U1 S _%D	0VWVN	kT10	fNND	N0K	
								3 V U1 S _%BG	%B5Dk	%WGDG	fVWF	N0TW	
								LV U1 S _%BW	%FVW	%RfN	11 D	N D	
3 V U1 S _%B5	1BICDD	0D%DfKk	kTG	E	D	DDB	DDB	3 V U1 S _%BN	0FW	DkfK	1f TW	N D	
								LV U1 S _%B5	%FVW	%R10	1f TW	N D	
3 V U1 S _%BN	1BICDD	0D%DfWN	kTG	E	D	DDB	DDB	3 V U1 S _%f	GC5f	fTGG	N5T	N TR	
								3 V U1 S _%B5	%FWD	%RKG	1f B	N TG	
								3 V U1 S _%GD	%FWD	%RKB	1f B	N TG	
								LV U1 S _%BN	%FVW	%R10	1f R	N D	
3 V U1 S _%GD	1BICDD	0D%DfKD	kTG	E	D	DDB	DDB	3 V U1 S _%BN	0FW	DkfK	1f TW	N D	
								LV U1 S _%GD	%FVW	%R10	1f R	N D	
* POv	015IDD	NGIDD	DD	%kDfN	%GfB5	E	E	5N_06	%kDfN	%GfB5	1GkD	NGD	
3 P_~I	015IDD	0DDf10	kT	E	D	E	E	HV U1 S 3 P_	DDDD	DDDD	DD	DD	
								& 5N_0U					

* indicates a Moltage regulated bus (Moltage controlled or swing ty4e 2 achine connected to it)
indicates a bus with a load 2 is2 atch o82 ore than DD 3 V6

Project: Fm OH m EF 0
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File name: Fm2OH

ETAP
NWDCC

Study Case: NPG 16LE. 0

Page: N
Date: NND6v9DN
Sheet: mES_m000j
Revision: f6M p EF
Comments: For- al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4	
511N	jB6DD	11TIDl	Vf	L	D	L	L	3 V UGS _v% 51_NU	vN6BfW	BDB%	jNW6	vlfT		
511%	jB6DD	11TIDl	Vf	L	D	L	L	JUV%N 51_NU	v%DJjD	B66j	jBID	vlfTW		
511j.	jB6DD	11TIDl	Vf	L	D	L	L	3 V UGS _v% 51_NU	v%DJjD%	BfW6	jBf6	vlf6		
511B	jB6DD	11TIDl	Vf	L	D	L	L	3 V UGS _vBD 51_NU	vN6fBB	jNDW	jNNW	v5TW		
51_N	Nj5IDD	11TIf	DD	L	D	L	L	POR HV UGS 3 P_	ffTW	v%T%B	jjlT	v6D		
51_NU	jB6DD	11TIDl	Vf	L	D	L	L	511B 511j. 511% 511N 3 P_~j & HV UGS 3 P_	vN6fBB	jNDW	jNNW	v5TW		
HV UGS 3 P_	Nj5IDD	11TIf	DD	L	D	DD6j	DNBf	51_N 51_NU & 3 P_~j	ffTW	v%T%B	jjlT	v6D		v%6DD
JUV%N	jB6DD	NDD6D	WW	L	D	L	L	3 V UGS _vNf 3 V UGS _v% 511%	vN6alfD	jTW	%6alf	vlfT		
JUVBN	jB6DD	NDD6f6	fT	L	D	L	L	3 V UGS _vBN 3 V UGS _vB% 3 V UGS _vBj 3 V UGS _vBB	vN6fW	DB6B	jNl	vW6		
LV UGS _vDN	DWD	NDDfB6	1B	N6f6	vDBj	L	L	3 V UGS _vDN	N6f6	vDBj	NDB%	vlfB		
LV UGS _vD%	DWD	NDDf6D	1B	N6f6	vDBj	L	L	3 V UGS _vD%	N6f6	vDBj	NDB6	vlfB		
LV UGS _vDj	DWD	NDDfjW	1T	N6f6	vDBj	L	L	3 V UGS _vDj	N6f6	vDBj	NDDTW	vlfB		
LV UGS _vDB	DWD	NDD6%	1T	N6f6	vDBj	L	L	3 V UGS _vDB	N6f6	vDBj	NDD	vlfB		
LV UGS _vD6	DWD	11TfW	1T	N6f6	vDBj	L	L	3 V UGS _vD6	N6f6	vDBj	NWND	vlfB		
LV UGS _vDW	DWD	11Tf6B	1T	N6f6	vDBj	L	L	3 V UGS _vDW	N6f6	vDBj	NWDB	vlfB		
LV UGS _vDf	DWD	11Tf6	1T	N6f6	vDBj	L	L	3 V UGS _vDf	N6f6	vDBj	NWNT	vlfB		
LV UGS _vD6	DWD	11TfBB	1T	N6f6	vDBj	L	L	3 V UGS _vD6	N6f6	vDBj	NW6f	vlfB		
LV UGS _vDI	DWD	11Tf%	1T	N6f6	vDBj	L	L	3 V UGS _vDI	N6f6	vDBj	NWBT	vlfB		
LV UGS _vND	DWD	11TfWB	1T	N6f6	vDBj	L	L	3 V UGS _vND	N6f6	vDBj	NW6%	vlfB		

Project: Fm OH m EF 0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: %

0 ate: NND6v%DN

SF: m ES_m OO0 j

keAision: f6M p EF

Con8gT For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4
LV UGS_vNj	DWDD	NDDDB	1%	N5f6	vDEj j	E	E	3 V UGS_vNj	N5f6	vDEj j	NND5T	vlfB	
LV UGS_vNB	DWDD	NDDDB	1%	N5f6	vDEj j	E	E	3 V UGS_vNB	N5f6	vDEj j	NND1%	vlfB	
LV UGS_vN6	DWDD	11Tf%	1T	N5f6	vDEj j	E	E	3 V UGS_vN6	N5f6	vDEj j	NND5T	vlfB	
LV UGS_vNW	DWDD	NDDNB	1%	N5f6	vDEj j	E	E	3 V UGS_vNW	N5f6	vDEj j	NND1W	vlfB	
LV UGS_vNf	DWDD	11TWj	1D	N5f6	vDEj j	E	E	3 V UGS_vNf	N5f6	vDEj j	NNDW%	vlfB	
LV UGS_v%0	DWDD	11TB6	1D	N5f6	vDEj j	E	E	3 V UGS_v%0	N5f6	vDEj j	NND1f	vlfB	
LV UGS_v%N	DWDD	11TN5	1D	N5f6	vDEj j	E	E	3 V UGS_v%N	N5f6	vDEj j	NNDWf	vlfB	
LV UGS_v%%	DWDD	11TNf	1D	N5f6	vDEj j	E	E	3 V UGS_v%%	N5f6	vDEj j	NND5B	vlfB	
LV UGS_v%5	DWDD	11TW0	1T	N5f6	vDEj j	E	E	3 V UGS_v%5	N5f6	vDEj j	NND5T	vlfB	
LV UGS_v%B	DWDD	11TBj	5T	N5f6	vDEj j	E	E	3 V UGS_v%B	N5f6	vDEj j	NND5T	vlfB	
LV UGS_v%6	DWDD	11TBf	5T	N5f6	vDEj j	E	E	3 V UGS_v%6	N5f6	vDEj j	NND5T	vlfB	
LV UGS_v%W	DWDD	11TW	1%	N5f6	vDEj j	E	E	3 V UGS_v%W	N5f6	vDEj j	NNDW	vlfB	
LV UGS_v%4	DWDD	11T15	1%	N5f6	vDEj j	E	E	3 V UGS_v%4	N5f6	vDEj j	NND5T	vlfB	
LV UGS_v%5	DWDD	11TWW	1%	N5f6	vDEj j	E	E	3 V UGS_v%5	N5f6	vDEj j	NND5D	vlfB	
LV UGS_v%4	DWDD	11TWV	1D	N5f6	vDEj j	E	E	3 V UGS_v%4	N5f6	vDEj j	NNDW	vlfB	
LV UGS_vj N	DWDD	NDDNNf	1B	N5f6	vDEj j	E	E	3 V UGS_vj N	N5f6	vDEj j	NND1T	vlfB	
LV UGS_vj %	DWDD	11Tij N	1T	N5f6	vDEj j	E	E	3 V UGS_vj %	N5f6	vDEj j	NND1T	vlfB	
LV UGS_vj j	DWDD	11Tj f	1T	N5f6	vDEj j	E	E	3 V UGS_vj j	N5f6	vDEj j	NNDW	vlfB	
LV UGS_vj B	DWDD	11TBj	1B	N5f6	vDEj j	E	E	3 V UGS_vj B	N5f6	vDEj j	NND1f	vlfB	
LV UGS_vj W	DWDD	NDDNf	1B	N5f6	vDEj j	E	E	3 V UGS_vj W	N5f6	vDEj j	NNDW	vlfB	
LV UGS_vj f	DWDD	NDDW%	1B	N5f6	vDEj j	E	E	3 V UGS_vj f	N5f6	vDEj j	NNDW%	vlfB	
LV UGS_vj 1	DWDD	NDDNBW	1B	N5f6	vDEj j	E	E	3 V UGS_vj 1	N5f6	vDEj j	NND5T	vlfB	
LV UGS_vBD	DWDD	11Tiff	1TW	N5f6	vDEj j	E	E	3 V UGS_vBD	N5f6	vDEj j	NND1%	vlfB	
LV UGS_vBN	DWDD	NDDf1	NDD	N5f6	vDEj j	E	E	3 V UGS_vBN	N5f6	vDEj j	NND1T	vlfB	
LV UGS_vB%	DWDD	NDDj j %	NDD	N5f6	vDEj j	E	E	3 V UGS_vB%	N5f6	vDEj j	NND5T	vlfB	
LV UGS_vBj	DWDD	NDDj f5	NDD	N5f6	vDEj j	E	E	3 V UGS_vBj	N5f6	vDEj j	NND1T	vlfB	
LV UGS_vBB	DWDD	NDDW%	1T	N5f6	vDEj j	E	E	3 V UGS_vBB	N5f6	vDEj j	NNDW	vlfB	
LV UGS_vB6	DWDD	NDDW%	1T	N5f6	vDEj j	E	E	3 V UGS_vB6	N5f6	vDEj j	NND5T	vlfB	
LV UGS_vBW	DWDD	NDD1	1T	N5f6	vDEj j	E	E	3 V UGS_vBW	N5f6	vDEj j	NND1%	vlfB	
LV UGS_vB5	DWDD	NDDW1	NDD	N5f6	vDEj j	E	E	3 V UGS_vB5	N5f6	vDEj j	N615TW	vlfB	
LV UGS_vBI	DWDD	NDDW5	NDD	N5f6	vDEj j	E	E	3 V UGS_vBI	N5f6	vDEj j	N611TW	vlfB	
LV UGS_v6D	DWDD	NDDWf	NDD	N5f6	vDEj j	E	E	3 V UGS_v6D	N5f6	vDEj j	N615T	vlfB	
3 V UGS_vDN	j B5DD	NDD5j	fTN	E	D	DDB	DDB	3 V UGS_vD%	N5W%	vD5N	j %D	vW5	
3 V UGS_vD%	j B5DD	NDD5NW	fTN	E	D	DDB	DDB	LV UGS_vDN	v5WV	D5D	j %N	vW5	
								3 V UGS_vDN	v5WD	DBW	j N5	vlfD	
								3 V UGS_vDj	j T%	vD1f1	vT	vWf	
3 V UGS_vDj	j B5DD	NDDWj	fTN	E	D	DDB	DDB	LV UGS_vD%	v5WV	D5D	j %N	vW5	
								3 V UGS_vDB	6Tf1	vNB6B	16T	vW5	

Project: Fm OH m EF 0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: j

Date: NND6v%DN

SF: mES_mOO0j

Revision: f6M p EF

Configuration: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4
3 V UGS_vDB	j B6DD	NND611	f'D	E	D	DDB	DDB	LV UGS_vDj	vNFWW	D6ND	j %E%	vI W6	
								3 V UGS_vDj	v6T6fj	NBDI	16TW	vI WII	
								3 V UGS_vD6	fT6j 6	vNII %%	N64T	vI W6	
3 V UGS_vD6	j B6DD	NND6fB	f'D	E	D	DDB	DDB	LV UGS_vDB	vNFWW	D6ND	j %E%	vI W6	
								3 V UGS_vDB	vI T6fB	N6fB	N64T6	vI f'D	
								3 V UGS_vD6	1T6W	v6j 55	N61T	vI W6	
3 V UGS_vDW	j B6DD	NND6D%	VII	E	D	DDB	DDB	LV UGS_vD6	vNFWW	D6ND	j %E%	vI W6	
								3 V UGS_vDf	N6W%	vD6NB	j %E%	vI WB	
								LV UGS_vDW	vNFWW	D6ND	j %E%	vI W6	
3 V UGS_vDf	j B6DD	NND66j	VII	E	D	DDB	DDB	3 V UGS_vDW	vNFWW	D6NB	j %D	vI W6	
								3 V UGS_vNW	vN6W	D6B1	j NII	vI f'T%	
								3 V UGS_vN6	6T65%	vNBBf	1WN	vI W6	
3 V UGS_vD6	j B6DD	NND61j	VII	E	D	DDB	DDB	LV UGS_vDf	vNFWW	D6ND	j %E%	vI W6	
								3 V UGS_vD6	vI T6fW	v645	N61Tj	vI f'TN	
								3 V UGS_vDI	NNfj 5	v66N%	NIN6	vI f'D	
3 V UGS_vDI	j B6DD	NND64j	W6	E	D	DDB	DDB	LV UGS_vD6	vNFWW	D6ND	j %E%	vI W6	
								3 V UGS_vD6	vNNT6D	v6fDf	NIND	vI f'T%	
								3 V UGS_vND	N645%	vj T66N	v6j T6%	vI f'TN	
3 V UGS_vND	j B6DD	NND666	W6	E	D	DDB	DDB	LV UGS_vDI	vNFWW	D6ND	j %j	vI W6	
								3 V UGS_vDI	vN64fD	j TN6N	v664	vI f'T%	
								3 V UGS_v66	N65j %	vj T66	v66TN	vI f'TN	
3 V UGS_vNj	j B6DD	NND6W%	VII	E	D	DDB	DDB	LV UGS_vND	vNFWW	D6ND	j %j	vI W6	
								3 V UGS_vNB	N6W%	vD6Nj	j %TN	vI WB	
								LV UGS_vNj	vNFWW	D6ND	j %E%	vI W6	
3 V UGS_vNB	j B6DD	NND655	VII	E	D	DDB	DDB	3 V UGS_vNj	vNFWW	D6BN	j %D	vI W6	
								3 V UGS_vN6	j T6j	vDII 16	v6BN	vI W6W	
								LV UGS_vNB	vNFWW	D6ND	j %E%	vI W6	
3 V UGS_vN6	j B6DD	NND6%N	W6	E	D	DDB	DDB	3 V UGS_vDf	v6T6fB	Nf f f	16T6	vI f'TN	
								3 V UGS_vNB	vj TN%	DIIN	vj T6	vI f'TN	
								3 V UGS_vNf	NNNBf	v66D6	NIN6	vI f'D	
3 V UGS_vNW	j B6DD	NND6W%	VII	E	D	DDB	DDB	LV UGS_vN6	vNFWW	D6ND	j %j	vI W6	
								3 V UGS_vDf	N6W%	vD6NB	j %TN	vI WB	
								LV UGS_vNW	vNFWW	D6ND	j %E%	vI W6	
3 V UGS_vNf	j B6DD	NND66j	Wf	E	D	DDB	DDB	JUv%6N	N645B	vj TNW	v6j Tj	vI f'TN	
								3 V UGS_vN6	vNNT6%	v6W%	NIN6N	vI f'Tj	
								LV UGS_vNf	vNFWW	D6NN	j %j	vI W6	
3 V UGS_v6D	j B6DD	NND61j	Wf	E	D	DDB	DDB	3 V UGS_v6N	N6W%	vD6NB	j %E%	vI WB	
								LV UGS_v6D	vNFWW	D6ND	j %E%	vI W6	
								3 V UGS_v6D	vN661	D6j 1	j NII	vI f'Tj	

Project: Fm OH m EF0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NWDEC

Study Case: NPG 16LE_0

Page: B

Date: 10/26/2017

SF: mES_m000j

Revision: f6M p EF

Configuration: For - al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4
3 V UGS_v0%	jB6DD	NDDP%	VF	E	D	DDB	DDB	3 V UGS_v0%	jT%N	vDII6j	VBID	vIWI	
								LV UGS_v0%	vNEWW	D6ND	j%T	vIWB	
								JUV0%	fTj5	vNEWB	N0SD	vI fD	
								3 V UGS_v0%	vjTN	DII4B	VjT	vI fD	
3 V UGS_v0%	jB6DD	NDDN	WB	E	D	DDB	DDB	3 V UGS_v0%	vNE61	DB0W	jNB	vI fB	
								LV UGS_v0%	vNEWW	D6ND	j%T	vIWB	
								511j.	%DJ1B	vB6B	j6D%	vI fT	
								3 V UGS_v0%	vNE6j%	Bfjj	jNSD	vI fB	
3 V UGS_v0%	jB6DD	NDD%	WB	E	D	DDB	DDB	LV UGS_v0%	vNEWW	D6NN	j%T	vIWB	
								3 V UGS_v0%	NEW%	vD6NB	j%T	vIWB	
								LV UGS_v0%	vNEWW	D6NN	j4B	vIWB	
								511N	N6TD6	vB6%	jNT	vI fB	
3 V UGS_v0%	jB6DD	NDDND	WI	E	D	DDB	DDB	3 V UGS_vND	vNB15%	jT46	%6jT	vI fT	
								3 V UGS_v0%	vNEWN	DB%	j%N	vIWI	
								LV UGS_v0%	vNEWW	D6NN	j4B	vIWB	
								3 V UGS_v0%	NEW%	vD6NB	j%T	vIWB	
3 V UGS_v0%	jB6DD	NDDjB	WI	E	D	DDB	DDB	LV UGS_v0%	vNEWW	D6ND	j%T	vIWB	
								3 V UGS_v0%	vNEWN	DBW	j4D	vIWI	
								3 V UGS_v0%	jT%0	vDII1D	VB6%	vIWW	
								LV UGS_v0%	vNEWW	D6ND	j%T	vIWB	
3 V UGS_v0%	jB6DD	NDDP%	WI	E	D	DDB	DDB	3 V UGS_v0%	N6T6N	vB6B	jNSB	vI f%	
								3 V UGS_v0%	vjTN	DII66	VBIN	vIWI	
								3 V UGS_vj j	v04f%	%456	%00T	vI fB	
								LV UGS_v0%	vNEWW	D6ND	j%T	vIWB	
3 V UGS_v0%	jB6DD	NDDN6	VF	E	D	DDB	DDB	3 V UGS_v0%	NEW%	vD6NB	j%T	vIWB	
								LV UGS_v0%	vNEWW	D6ND	j%T	vIWB	
								3 V UGS_vj N	NEW%	vD6Nj	j%N	vIWB	
								LV UGS_vj N	vNEWW	D6ND	j%T	vIWB	
3 V UGS_vj %	jB6DD	NDBf1	fTN	E	D	DDB	DDB	3 V UGS_vj N	vNE65	DBj	jNF	vI fT	
								3 V UGS_vj j	jT%D	vDII1	VjB	vI fTN	
								LV UGS_vj %	vNEWW	D6ND	j%T	vIWB	
								3 V UGS_v0%	NjDND	vjT4N	%jT%	vI fTN	
3 V UGS_vj j	jB6DD	NDDj5W	fTD	E	D	DDB	DDB	3 V UGS_vj %	vjTNW	D61D	VjT	vI f%	
								3 V UGS_vj B	vT6%	Nf1f	N4jT	vI f%	
								LV UGS_vj j	vNEWW	D6ND	j%T	vIWB	
								3 V UGS_vj j	fTj j	vNEj f	N4TB	vI fTN	
3 V UGS_vj B	jB6DD	NDB1%	fTN	E	D	DDB	DDB	3 V UGS_vj W	vjTNj	DIIjN	VjT	vI fD	
								3 V UGS_vj 1	vNE65	Dj1j	jNW	vI fB	
								LV UGS_vj B	vNEWW	D6ND	j%T	vIWB	

Project: Fm OH m EF 0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm20H

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: 6

Date: NND6v4NF

SF: mES_m000j

Revision: f6M p EF

Configuration: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
R0	9V	M3 agT	. ngT	3 m	3 Aar	3 m	3 Aar	R0	3 m	3 Aar	. - 4	MPI	M_a4
3 V UGS _vj W	j B6DD	NNDf%W	f %	E	D	DDB	DDB	3 V UGS _vj B	j T%4	vDI 11	vBD	vI WW	
								3 V UGS _vj f	vNEW	DB5W	j %D	vI W6	
								LV UGS _vj W	vNEW	DBND	j %N	vI W6	
3 V UGS _vj f	j B6DD	NNDf%N	f %	E	D	DDB	DDB	3 V UGS _vj W	NEW%	vDBNj	j %N	vI WB	
								LV UGS _vj f	vNEW	DBND	j %N	vI W6	
3 V UGS _vj l	j B6DD	NNDWj	f %N	E	D	DDB	DDB	3 V UGS _vj B	NEW%	vDBNj	j %N	vI WB	
								LV UGS _vj l	vNEW	DBND	j %N	vI W6	
3 V UGS _vBD	j B6DD	NND6%	f j	E	D	DDB	DDB	511 B	N66%	vBT 6N	j N66	vI f B	
								3 V UGS _vBW	vNEW	j Tj 5	%BT	vI f B	
								LV UGS _vBD	vNEW	DBND	j %6	vI W6	
3 V UGS _vBN	j B6DD	NNDI%8	f T	E	D	DDB	DDB	JUvBN	NEW%	vDBNj	j %D	vI WB	
								LV UGS _vBN	vNEW	DBDI	j %N	vI W6	
3 V UGS _vB%	j B6DD	NND6ff	f T	E	D	DDB	DDB	JUvBN	f B%	vNENB	N666	vI f TN	
								3 V UGS _vBl	v66j	Nj DN	1B6	vI f B	
								LV UGS _vB%	vNEW	DBDI	j %N	vI W6	
3 V UGS _vBj	j B6DD	NNDI%4	f T	E	D	DDB	DDB	JUvBN	NEW%	vDBNj	j %D	vI WB	
								LV UGS _vBj	vNEW	DBDI	j %N	vI W6	
3 V UGS _vBB	j B6DD	NNDfB5	f W	E	D	DDB	DDB	JUvBN	vNNT6	%6W6	NIDN	vI f %	
								3 V UGS _vB6	N6DI	vj T6%	%666	vI f TN	
								LV UGS _vBB	vNEW	DBND	j %N	vI W6	
3 V UGS _vB6	j B6DD	NNDWd	f 6	E	D	DDB	DDB	3 V UGS _vBB	v6DI f W	j TdB	%6f	vI f j	
								3 V UGS _vBW	N66j 5	vj T655	%6j 6	vI f %	
								LV UGS _vB6	vNEW	DBND	j %6	vI W6	
3 V UGS _vBW	j B6DD	NND6sf	f B	E	D	DDB	DDB	3 V UGS _vBD	NW6D	vj Tj 5	%6TN	vI f j	
								3 V UGS _vB6	vN6N5	j B6B	%6j D	vI f B	
								LV UGS _vBW	vNEW	DBND	j %6	vI W6	
3 V UGS _vB5	j B6DD	NNDf4%	f Tl	E	D	DDB	DDB	3 V UGS _vBl	NEW%	vDBNj	j Nl	vI WB	
								LV UGS _vB5	vNEW	DBDI	j %D	vI W6	
3 V UGS _vBl	j B6DD	NNDN5%	f 6	E	D	DDB	DDB	3 V UGS _vB%	6T5j	vNBW	166	vI Wf	
								3 V UGS _vB5	vNEW	DBf W	j N6	vI Wl	
								3 V UGS _v6D	vNEW	DBf f	j N6	vI Wl	
								LV UGS _vBl	vNEW	DBDI	j %D	vI W6	
								3 V UGS _vBl	NEW%	vDBNj	j Nl	vI WB	
3 V UGS _v6D	j B6DD	NNDf4D	f Tl	E	D	DDB	DDB	LV UGS _v6D	vNEW	DBDI	j %D	vI W6	
								51_N	vI f TNB	%6TN	j j 1T	vI 6D	
* POR	Nj 5TD	NNDIDD	DD	vI f TNB	%6TN	E	E	HV UGS 3 P_	DDDD	DDDD	DD	DD	
3 P_~j	Nj 6DD	11TWj	Wl	E	D	E	E	& 51_NU					

* Indicates a Aoltage regulated bus (Aoltage controlled or swing ty4e - achine connected to it)

Indicates a bus with a load - is- atch o8- ore than DN3 V.

Project: Fm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I lлена- e: F m 2OH

ETAP
N1010C
Study Case: NGIP6 . 1LE0 W

Page: N
Wate: NGGI v/GN
SF : m ES_m OOWj
k eAision: f 1M p EF
Con&gD F or- al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4
5. I N0	j BDCG	.. Bf1	Tp	C	G	C	C	3 V U6 S _v4	vN5 BfT	B0Bf	j NfP%	v f B	
								5. _NU	N5 BfT	vB0Bf	j NfP%	v f B	
5. I %0	j BDCG	.. Bf1	Tp	C	G	C	C	JUv%N	v%Gpj G	B01.	j B. D	v f D	
								5. _NU	%Gpj G	vB01.	j B. D	v f D	
5. I j 0	j BDCG	.. Bf1	Tp	C	G	C	C	3 V U6 S _v%	v%GpC%	BpfB	j BSp	v f B	
								5. _NU	%GpC%	vBpfB	j BSp	v f B	
5. I B0	j BDCG	.. Bf1	Tp	C	G	C	C	3 V U6 S _vBG	vN5 BpBj	j DN1	j N%N	v 5 D	
								5. _NU	N5 BpBj	vj DN1	j N%N	v 5 D	
5. _N0	Nj 5 BDCG	NGBD. f	G0%	C	G	C	C	POR	ff DNf	v4 DpC%	j % D	v 1 B	
								HV U6 S 3 P_	vff DNf	%4 DpC%	j % D	v 1 B	
5. _NU	j BDCG	.. Bf1	Tp	C	G	C	C	5. I B0	vN5 BpBj	j DN1	j N%N	v 5 D	
								5. I j 0	v%GpC%	BpfB	j BSp	v f B	
								5. I %0	v%Gpj G	B01.	j B. D	v f D	
								5. I N0	vN5 BfT	B0Bf	j NfP%	v f B	
								3 P_~j	ff B1 G	vN1 B: T	Nj %4 B	v f D	
								& HV U6 S 3 P_					
HV U6 S 3 P_	Nj 5 BDCG	NGBD. f	G0%	C	G	G01.	G01%	5. _N0	ff DNf	v4 DpC%	j % D	v 1 B	
								5. _NU	vff D04	%4 DpG	j % D	v 1 B	%DCG
								& 3 P_~j					
JUv%N	j BDCG	.. DBT	Tp	C	G	C	C	3 V U6 S _vNf	v%4 Df G	j Bf.	%% D%	v f D	
								3 V U6 S _v0%	vf B0%N	N0. B	N%4 B	v f D%	
								5. I %0	%Gp. N	vB5fj	j 1 N0%	v f D	
JUvBN	j BDCG	NGBB%	f B	C	G	C	C	3 V U6 S _vBN	vN5 TN	G0B5B	j ND	v T B	
								3 V U6 S _vB%	vf B0%4	N5 N1	N%4 B:	v f D	
								3 V U6 S _vBj	vN5 TN	G0B51	j ND	v T B	
								3 V U6 S _vBB	NNDBf	v%4 B5j	N CD	v f B:	
LV U6 S _vGN	Gf. G	NGBB%	. B	N5f1	vGBj j	C	C	3 V U6 S _vGN	N5f1	vGBj j	NIGf B	v f B	
LV U6 S _vC%	Gf. G	NGBj T	. B	N5f1	vGBj j	C	C	3 V U6 S _vC%	N5f1	vGBj j	NIGf D	v f B	
LV U6 S _vGj	Gf. G	NGB0C%	. B	N5f1	vGBj j	C	C	3 V U6 S _vGj	N5f1	vGBj j	NIG B	v f B	
LV U6 S _vGB	Gf. G	.. DN5	. D	N5f1	vGBj j	C	C	3 V U6 S _vGB	N5f1	vGBj j	NINND	v f B	
LV U6 S _vGI	Gf. G	.. B. %	. D	N5f1	vGBj j	C	C	3 V U6 S _vGI	N5f1	vGBj j	NINj D%	v f B	
LV U6 S _vGT	Gf. G	.. B%G	. D%	N5f1	vGBj j	C	C	3 V U6 S _vGT	N5f1	vGBj j	NIN04	v f B	
LV U6 S _vGf	Gf. G	.. Bf G	. D%	N5f1	vGBj j	C	C	3 V U6 S _vGf	N5f1	vGBj j	NINj D	v f B	
LV U6 S _vG5	Gf. G	.. BNG	. D%	N5f1	vGBj j	C	C	3 V U6 S _vG5	N5f1	vGBj j	NINB0	v f B	
LV U6 S _vG	Gf. G	.. B55	. D	N5f1	vGBj j	C	C	3 V U6 S _vG	N5f1	vGBj j	NINf D	v f B	
LV U6 S _vNG	Gf. G	.. Dj G	. D	N5f1	vGBj j	C	C	3 V U6 S _vNG	N5f1	vGBj j	NINf B	v f B	

Project: Fm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I l ena- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: %
Wate: NGL vGN
SF: m ES_m OOWj
k eAision: f 1M p EF
Con8gD For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4
LV U6 S _vNj	GD. G	.. DTG	. D%	NBf1	vGDj j	C	C	3 V U6 S _vNj	NBf1	vGDj j	NINGB	v. fID	
LV U6 S _vNB	GD. G	.. DGT	. D%	NBf1	vGDj j	C	C	3 V U6 S _vNB	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vNI	GD. G	.. DTj f	. DN	NBf1	vGDj j	C	C	3 V U6 S _vNI	NBf1	vGDj j	NINI D	v. fID	
LV U6 S _vNT	GD. G	.. B5G	. D%	NBf1	vGDj j	C	C	3 V U6 S _vNT	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vNf	GD. G	.. DBT5	. D%	NBf1	vGDj j	C	C	3 V U6 S _vNf	NBf1	vGDj j	NIN5IB	v. fID	
LV U6 S _vG	GD. G	.. BNN	. D%	NBf1	vGDj j	C	C	3 V U6 S _vG	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vN	GD. G	.. D5B	. D%	NBf1	vGDj j	C	C	3 V U6 S _vN	NBf1	vGDj j	NINND	v. fID	
LV U6 S _v%	GD. G	.. D5%	. D%	NBf1	vGDj j	C	C	3 V U6 S _v%	NBf1	vGDj j	NINNT	v. fID	
LV U6 S _v%	GD. G	.. DB51	. DN	NBf1	vGDj j	C	C	3 V U6 S _v%	NBf1	vGDj j	NIN5IN	v. fID	
LV U6 S _vB	GD. G	.. Dp j 5	5B	NBf1	vGDj j	C	C	3 V U6 S _vB	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vA	GD. G	.. DpN%	5B	NBf1	vGDj j	C	C	3 V U6 S _vA	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vA	GD. G	.. DpA	. D%	NBf1	vGDj j	C	C	3 V U6 S _vA	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vA	GD. G	.. DTj	. D%	NBf1	vGDj j	C	C	3 V U6 S _vA	NBf1	vGDj j	NINI D	v. fID	
LV U6 S _vB	GD. G	.. DBN	. D%	NBf1	vGDj j	C	C	3 V U6 S _vB	NBf1	vGDj j	NINND	v. fID	
LV U6 S _v%	GD. G	.. Dp j %	. D%	NBf1	vGDj j	C	C	3 V U6 S _v%	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vj N	GD. G	.. D5%	. DB	NBf1	vGDj j	C	C	3 V U6 S _vj N	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vj %	GD. G	.. D. T	. DB	NBf1	vGDj j	C	C	3 V U6 S _vj %	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vj j	GD. G	.. DpC%	. Dp	NBf1	vGDj j	C	C	3 V U6 S _vj j	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vj B	GD. G	.. B5G	. DB	NBf1	vGDj j	C	C	3 V U6 S _vj B	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vj T	GD. G	NCGDBI	. DB	NBf1	vGDj j	C	C	3 V U6 S _vj T	NBf1	vGDj j	NIG DN	v. fID	
LV U6 S _vj f	GD. G	NCGDN	. D	NBf1	vGDj j	C	C	3 V U6 S _vj f	NBf1	vGDj j	NIGDp	v. fID	
LV U6 S _vj .	GD. G	NCGDN%	. DB	NBf1	vGDj j	C	C	3 V U6 S _vj .	NBf1	vGDj j	NIG D	v. fID	
LV U6 S _vBG	GD. G	.. B5B%	. D	NBf1	vGDj j	C	C	3 V U6 S _vBG	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vBN	GD. G	NCGDBI	NIGD	NBf1	vGDj j	C	C	3 V U6 S _vBN	NBf1	vGDj j	NIGD	v. fID	
LV U6 S _vB%	GD. G	NCGDN f	NIGD	NBf1	vGDj j	C	C	3 V U6 S _vB%	NBf1	vGDj j	NIGIT	v. fID	
LV U6 S _vBj	GD. G	NCGDBj	NIGD	NBf1	vGDj j	C	C	3 V U6 S _vBj	NBf1	vGDj j	NIGD	v. fID	
LV U6 S _vBB	GD. G	NCGDIT	. D	NBf1	vGDj j	C	C	3 V U6 S _vBB	NBf1	vGDj j	NIGD	v. fID	
LV U6 S _vBI	GD. G	.. D5.	. B	NBf1	vGDj j	C	C	3 V U6 S _vBI	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vBT	GD. G	.. DGB	. D	NBf1	vGDj j	C	C	3 V U6 S _vBT	NBf1	vGDj j	NINND	v. fID	
LV U6 S _vB5	GD. G	NCGDTI	NIGD	NBf1	vGDj j	C	C	3 V U6 S _vB5	NBf1	vGDj j	NIGD	v. fID	
LV U6 S _vB	GD. G	NCGDB	NIGD	NBf1	vGDj j	C	C	3 V U6 S _vB	NBf1	vGDj j	NIGD	v. fID	
LV U6 S _vIG	GD. G	NCGDTj	NIGD	NBf1	vGDj j	C	C	3 V U6 S _vIG	NBf1	vGDj j	NIGD	v. fID	
3 V U6 S _vGN	j BDGG	NCGDTG	fDN	C	G	GDB	GDB	3 V U6 S _vGN	NB1T%	vDNj	j %DN	v. TD	
								LV U6 S _vGN	vNB1T	GDNG	j %DN	v. TD	
3 V U6 S _vGN	j BDGG	NCGDT5%	fDN	C	G	GDB	GDB	3 V U6 S _vGN	vNB1T	GDNT	j ND	v. fID	
								3 V U6 S _vGj	j Dp%	vD5G	THD	v. TD	
								LV U6 S _vGN	vNB1T	GDNG	j %DN	v. TD	
3 V U6 S _vGj	j BDGG	NCGDT1G	fDN	C	G	GDB	GDB	3 V U6 S _vGN	vj DpN	GD BN	Tj B	v. TD	
								3 V U6 S _vGB	1Df5	vNB11	. 1D	v. TD	

Project: Fm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I l ena- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: j
Wate: NAGl v%GN
SF : m ES_m OOWj
keAision: f 1M p EF
Con&gD F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4
3 V U6 S _vGB	j BD CG	NCGBT	f DN	C	G	G0CB	G0CB	LV U6 S _vG	vN5TT	GDNG	j %B%	v TD	
								3 V U6 S _vG	vIDfj	NBNG	. 1B	v TD	
								3 V U6 S _vGI	fDBj 1	vND%B	N%TD	v TB	
3 V U6 S _vGI	j BD CG	NCGBN	f DB	C	G	G0CB	G0CB	LV U6 S _vGB	vN5TT	GDNG	j %B%	v TD	
								3 V U6 S _vGB	vIDB%B	N5fT	N%TD	v f DB	
								3 V U6 S _vG5	. DBT	v%G	NL D	v TB	
3 V U6 S _vGT	j BD CG	NCGPT	TD	C	G	G0CB	G0CB	LV U6 S _vGI	vN5TT	GDNG	j %B%	v TD	
								3 V U6 S _vGT	N5T%	vDNB	j %B%	v TB	
								LV U6 S _vGT	vN5TT	GDNG	j %B%	v TD	
3 V U6 S _vGT	j BD CG	NCGPG	TD	C	G	G0CB	G0CB	3 V U6 S _vGT	vN5TN	GBS1	j %DN	v TB	
								3 V U6 S _vNT	vN5TG	GBR	j ND	v f DB%	
								3 V U6 S _vNI	1D5%	vNBR5	. TB%	v TB	
3 V U6 S _vG5	j BD CG	NCGPTG	TD	C	G	G0CB	G0CB	LV U6 S _vGT	vN5TT	GDNG	j %B%	v TD	
								3 V U6 S _vGI	v DBT	%GCG	NL D	v f DN	
								3 V U6 S _vG	NNDj f	v%BNB	N NB	v f DB	
3 V U6 S _vG	j BD CG	NCGDJ .	TB	C	G	G0CB	G0CB	LV U6 S _vG5	vN5TT	GDNG	j %B%	v TD	
								3 V U6 S _vG5	vNNDN	%BG	N NB	v f DB%	
								3 V U6 S _vNG	N%DSN	vj DB%	%%D	v f DN	
3 V U6 S _vNG	j BD CG	NCGBN	TB	C	G	G0CB	G0CB	LV U6 S _vG	vN5TT	GDNN	j %B%	v TD	
								3 V U6 S _vG	vN%DFG	j DBB	%%DB%	v f DB%	
								3 V U6 S _v%4	NB5j %	vj DT5	%41TB	v f DN	
3 V U6 S _vNj	j BD CG	NCGDG	TD	C	G	G0CB	G0CB	LV U6 S _vNG	vN5TT	GDNN	j %B%	v TD	
								3 V U6 S _vNB	N5T%	vDNB	j %B%	v TB	
								LV U6 S _vNj	vN5TT	GDNG	j %B%	v TD	
3 V U6 S _vNB	j BD CG	NCGB11	TD	C	G	G0CB	G0CB	3 V U6 S _vNj	vN5TN	GBS%	j %DB	v TB	
								3 V U6 S _vNI	j DB%	vGD. 1	TB%	v TD	
								LV U6 S _vNB	vN5TT	GDNG	j %B%	v TD	
3 V U6 S _vNI	j BD CG	NCGD55	TB	C	G	G0CB	G0CB	3 V U6 S _vGT	vIDfB	Npf5	. 1D	v f DN	
								3 V U6 S _vNB	vj DBN	GDN5	Tj D	v f DN	
								3 V U6 S _vNT	NDBB	v%BNB	N %DB	v f DB	
3 V U6 S _vNT	j BD CG	NCGB%	TD	C	G	G0CB	G0CB	LV U6 S _vNI	vN5TT	GDNG	j %B%	v TD	
								3 V U6 S _vGT	N5T%	vDNB	j %B%	v TB	
								LV U6 S _vNT	vN5TT	GDNG	j %B%	v TD	
3 V U6 S _vNT	j BD CG	NCGPG	TB	C	G	G0CB	G0CB	JUv%N	N%DSB	vj DB.	%%DB	v f DN	
								3 V U6 S _vNI	vNND%	%DTB	N NB	v f DB%	
								LV U6 S _vNT	vN5TT	GDNN	j %DB	v TD	
3 V U6 S _v%G	j BD CG	NCGPTG	TB	C	G	G0CB	G0CB	3 V U6 S _v%N	N5T%	vDNB	j %B%	v TB	
								LV U6 S _v%G	vN5TT	GDNG	j %B%	v TD	
								3 V U6 S _v%G	vN51.	GBj .	j ND	v f DB	

Project: Fm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I lлена- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: B
Wate: NGL v%GN
SF : m ES_m OOWj
keAision: f lM p EF
Con8gD F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR		
RW	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RW	3 m	3 Aar	0 - 4	MPI	M_a4	
3 V U6 S _v%%	j BD CG	NCGDj j	TD	C	G	G0CB	G0CB	3 V U6 S _v%%	j D%N	vGD l j	THD	v TD		
								LV U6 S _v%N	vN5TT	GDNG	j %D	v TD		
								JUV%N	f D% f	vN5Tl	N%5DN	v f lD		
								3 V U6 S _v%N	vj D%N	GD%B	THD	v f lD		
3 V U6 S _v%	j BD CG	NCGDj f	TD	C	G	G0CB	G0CB	3 V U6 S _v%	vN51.	GD%T	j ND	v f D		
								LV U6 S _v%%	vN5TT	GDNN	j %D	v TD		
								5. l j 0	%GD. B	vB51%	j l GD	v f D		
								3 V U6 S _v%	vN5D j %	B D j f	j N5TB	v f TB		
3 V U6 S _v%B	j BD CG	. . B. N	TD	C	G	G0CB	G0CB	LV U6 S _v%	vN5TT	GDNN	j %B	v TD		
								3 V U6 S _v%B	N5T%	vGDNI	j %B	v TB		
								LV U6 S _v%B	vN5TT	GDNN	j %B	v TB		
								5. l ND	N5DCB	vB% f	j N5DN	v f D		
3 V U6 S _v%D	j BD CG	. . B5Tl	TD	C	G	G0CB	G0CB	3 V U6 S _vNG	vN5B5N	j D4 G	%j DT	v f TB		
								3 V U6 S _v%B	vN5TN	GD%%	j %D%	v TD		
								LV U6 S _v%D	vN5TT	GDNN	j %B	v TB		
								3 V U6 S _v%	N5T%	vGDNB	j %D%	v TB		
3 V U6 S _v%T	j BD CG	NCGD%T	TD	C	G	G0CB	G0CB	LV U6 S _v%T	vN5TT	GDNG	j %D	v TD		
								3 V U6 S _v%T	vN5TN	GD% f	j %DN	v TD		
								3 V U6 S _v%	j D%%	vGD. N	THD	v TD		
								LV U6 S _v%	vN5TT	GDNG	j %D	v TD		
3 V U6 S _v%	j BD CG	NCGD% %	TD	C	G	G0CB	G0CB	3 V U6 S _v%	N5D l G	vB515	j N lD	v f D%		
								3 V U6 S _v%	vj D%N	GD l T	THD	v TB		
								3 V U6 S _vj j	v%GD f N	%D55	%B%T	v f TB		
								LV U6 S _v%	vN5TT	GDNN	j %D	v TD		
3 V U6 S _v%	j BD CG	NCGD%N	TD	C	G	G0CB	G0CB	3 V U6 S _v%	N5T%	vGDNB	j %D%	v TB		
								LV U6 S _v%	vN5TT	GDNG	j %D	v TD		
								3 V U6 S _vj N	N5T%	vGDNB	j %D%	v TB		
								LV U6 S _vj N	vN5TT	GDNG	j %D%	v TD		
3 V U6 S _vj %	j BD CG	NCGD%T	f DN	C	G	G0CB	G0CB	3 V U6 S _vj N	vN515	GDGB	j N%T	v f TB		
								3 V U6 S _vj j	j D%G	vGDN5	Tj D	v f DN		
								LV U6 S _vj %	vN5TT	GDNG	j %D	v TD		
								3 V U6 S _v%	Nj lDGN	vj D%j	%% D	v f DN		
3 V U6 S _vj j	j BD CG	NCGD4%	f DN	C	G	G0CB	G0CB	3 V U6 S _v%	vj D%N	GD. N	Tj B	v f D%		
								3 V U6 S _vj B	v f D%%	NB. .	N%TD	v f D%		
								LV U6 S _vj j	vN5TT	GDNG	j %D	v TD		
								3 V U6 S _vj B	f D%j	vN5j .	N%TB	v f DN		
3 V U6 S _vj T	j BD CG	NCGD15	f DN	C	G	G0CB	G0CB	3 V U6 S _vj T	vj D%j	GDj N	Tj B	v f lD		
								3 V U6 S _vj .	vN515	GD. B	j N%T	v f B		
								LV U6 S _vj B	vN5TT	GDNG	j %D	v TD		

Project: F m OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I ilena- e: F m 2OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: 1
Wate: NGL vGN
SF : m ES_m OOWj
keAision: f 1M p EF
Con&gD For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
RV	9V	M 3 agD	0 ngD	3 m	3 Aar	3 m	3 Aar	RV	3 m	3 Aar	0 - 4	MPI	M_a4
3 V U6 S _vj T	j BDCG	NCGD . %	f D%	C	G	GDCB	GDCB	3 V U6 S _vj B	j D%	vNDCG	THD	v TD	
								3 V U6 S _vj f	vNBTN	GDBT	j %D%	v TB	
								LV U6 S _vj T	vNBT	GNG	j %D%	v TD	
3 V U6 S _vj f	j BDCG	NCGDj 5	f D%	C	G	GDCB	GDCB	3 V U6 S _vj T	NBT%	vDNj	j %D	v TDB	
								LV U6 S _vj f	vNBT	GNG	j %D%	v TD	
3 V U6 S _vj .	j BDCG	NCGDTG	f D%	C	G	GDCB	GDCB	3 V U6 S _vj B	NBT%	vDNB	j %D	v TDB	
								LV U6 S _vj .	vNBT	GNG	j %D%	v TD	
3 V U6 S _vBG	j BDCG	NCGD . N	f D	C	G	GDCB	GDCB	5 . 1 B0	NBD%	vBDPT	j NTD%	v f D	
								3 V U6 S _vBT	vNBTj	j BBT%	%D	v f DB	
								LV U6 S _vBG	vNBT	GNG	j %D%	v TD	
3 V U6 S _vBN	j BDCG	NCGD . N	f B	C	G	GDCB	GDCB	JUvBN	NBT%	vDNj	j %D	v TDB	
								LV U6 S _vBN	vNBT	GNG	j %D	v TD	
3 V U6 S _vB%	j BDCG	NCGDBB	f D	C	G	GDCB	GDCB	JUvBN	f D%	vBN	N%D%	v f D	
								3 V U6 S _vB	vDj	N%D%	. BD	v f DB	
								LV U6 S _vB%	vNBT	GNG	j %D	v TD	
3 V U6 S _vBj	j BDCG	NCGD . G	f B	C	G	GDCB	GDCB	JUvBN	NBT%	vDNj	j %D	v TDB	
								LV U6 S _vBj	vNBT	GNG	j %D	v TD	
3 V U6 S _vBB	j BDCG	NCGDN	f D	C	G	GDCB	GDCB	JUvBN	vND%	%DTN	N CD	v f D%	
								3 V U6 S _vBl	N%D . G	vj DB	%D	v f D	
								LV U6 S _vBB	vNBT	GNG	j %D%	v TD	
3 V U6 S _vBl	j BDCG	NCGDj f	f D	C	G	GDCB	GDCB	3 V U6 S _vBB	v%Df l	j Df	%D%	v f D	
								3 V U6 S _vBT	NBJ f	vj D . N	%D	v f D%	
								LV U6 S _vBl	vNBT	GNG	j %D%	v TD	
3 V U6 S _vBT	j BDCG	NCGDBj	f DB	C	G	GDCB	GDCB	3 V U6 S _vBG	NBT .	vj DB%	%D	v f D	
								3 V U6 S _vBl	vBN	j D%	%j DB	v f DB	
								LV U6 S _vBT	vNBT	GNG	j %D%	v TD	
3 V U6 S _vB5	j BDCG	NCGD	f D	C	G	GDCB	GDCB	3 V U6 S _vB	NBT%	vDNj	j %D%	v TDB	
								LV U6 S _vB5	vNBT	GNG	j %D%	v TD	
3 V U6 S _vB	j BDCG	NCGDB5	f D	C	G	GDCB	GDCB	3 V U6 S _vB%	1D5j	vNBT	. 1D	v TDB	
								3 V U6 S _vB5	vNBTN	GDBT	j N5	v TD	
								3 V U6 S _vLG	vNBTN	GDBT	j N5	v TD	
								LV U6 S _vB	vNBT	GNG	j %D%	v TD	
3 V U6 S _vLG	j BDCG	NCGD	f D	C	G	GDCB	GDCB	3 V U6 S _vB	NBT%	vDNj	j %D%	v TDB	
								LV U6 S _vLG	vNBT	GNG	j %D%	v TD	
* POR	N 5DCG	NGLDCG	G%	v f DNT	% DCD	C	C	5 . _ND	v f DNT	% DCD	j % D	v 1D%	
3 P _~j	N 5CG	. . D5	TD	C	G	C	C	HV U6 S 3 P _	GDCG	GDCG	G%	G%	
								& 5 . _NU					

* Bdicates a Aoltage regulated bus (Aoltage controlled or swing ty4e - achine connected to it)
Bdicates a bus with a load - is- atch o8- ore than GDN3 V0

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C
Study Case: 1 UN T PY

Page: F
Date: F0-06-20F7
SU: WESI WOODP
Revision: F00% GEU
Config.: Uormal

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
ND	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ND	MW	Mvar	Amp	%PY	%I ap	
89YFA	34.500	99.8F2	8.5	0	0	0	0	MV B1 S I -25	-24.580	0.3F8	4F2.F	F00.0		
								89I FB	24.580	-0.3F8	4F2.F	F00.0		
89Y2A	34.500	99.8F2	8.5	0	0	0	0	JB-2/F	-27.048	0.442	453.6	-F00.0		
								89I FB	27.048	-0.442	453.6	-F00.0		
89Y3A	34.500	99.8F2	8.5	0	0	0	0	MV B1 S I -23	-27.00F	0.30F	452.7	F00.0		
								89I FB	27.00F	-0.30F	452.7	F00.0		
89Y4A	34.500	99.8F2	8.5	0	0	0	0	MV B1 S I -40	-24.358	-0.485	408.5	F00.0		
								89I FB	24.358	0.485	408.5	F00.0		
89I FA	F38.000	F00.000	0.0	0	0	0	0	PON	F02.555	-F6.04F	434.3	-98.8		
								HV B1 S MPI	-F02.555	F6.04F	434.3	-98.8		
89I FB	34.500	99.8F2	8.5	0	0	0	0	89Y4A	-24.358	-0.485	408.5	F00.0		
								89Y3A	-27.00F	0.30F	452.7	F00.0		
								89Y2A	-27.048	0.442	453.6	-F00.0		
								89YFA	-24.580	0.3F8	4F2.F	F00.0		
								MPI ~3	F02.988	-0.576	F726.8	F00.0		
HV B1 S MPI	F38.000	F00.000	0.0	0	0	0.053	0.F47	& HV B1 S MPI						
								89I FA	F02.555	-F6.04F	434.3	-98.8		
								89I FB	-F02.609	F5.894	434.4	-98.8	-0.625	
JB-2/F	34.500	F00.F76	8.9	0	0	0	0	& MPI ~3						
								MV B1 S I -F7	-F7.268	0.420	288.5	-F00.0		
								MV B1 S I -22	-9.883	0.266	F65.2	-F00.0		
JB-4/F	34.500	F0F.690	F0.2	0	0	0	0	89Y2A	27.F5F	-0.685	453.7	-F00.0		
								MV B1 S I -4F	-2.480	0.098	40.8	-99.9		
								MV B1 S I -42	-9.89F	0.273	F62.8	-F00.0		
								MV B1 S I -43	-2.480	0.099	40.9	-99.9		
LV B1 S I -0F	0.690	F0F.886	F2.3	2.500	0.000	0	0	MV B1 S I -44	F4.852	-0.47F	244.5	-99.9		
								MV B1 S I -0F	2.500	0.000	2053.F	F00.0		
								MV B1 S I -02	2.500	0.000	2055.3	F00.0		
								MV B1 S I -03	2.500	0.000	2059.0	F00.0		
								MV B1 S I -04	2.500	0.000	206F.5	F00.0		
								MV B1 S I -05	2.500	0.000	2065.2	F00.0		
								MV B1 S I -06	2.500	0.000	2065.4	F00.0		
								MV B1 S I -07	2.500	0.000	2066.8	F00.0		
								MV B1 S I -08	2.500	0.000	2067.9	F00.0		
								MV B1 S I -09	2.500	0.000	207F.9	F00.0		
LV B1 S I -F0	0.690	F00.858	F2.0	2.500	0.000	0	0	MV B1 S I -F0	2.500	0.000	2074.F	F00.0		

Project: UW OH WNUD

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Filename: UW_OH

ETAP

F6.0.0C

Page: 2

Date: F0-06-20F7

SU: WESI WOODP

Revision: F00% GEU

Config.: Uormal

Study Case: 1 UN T PY

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ND	MW	Mvar	Amp	%PY	%I ap
LV B1 S I -F3	0.690	F0F.464	F2.F	2.500	0.000	0	0	MV B1 S I -F3	2.500	0.000	206F.7	F00.0	
LV B1 S I -F4	0.690	F0F.390	F2.F	2.500	0.000	0	0	MV B1 S I -F4	2.500	0.000	2063.2	F00.0	
LV B1 S I -F5	0.690	F0F.0F9	F2.0	2.500	0.000	0	0	MV B1 S I -F5	2.500	0.000	2070.8	F00.0	
LV B1 S I -F6	0.690	F0F.362	F2.F	2.500	0.000	0	0	MV B1 S I -F6	2.500	0.000	2063.7	F00.0	
LV B1 S I -F7	0.690	F00.746	FF.9	2.500	0.000	0	0	MV B1 S I -F7	2.500	0.000	2076.4	F00.0	
LV B1 S I -20	0.690	F0F.204	FF.9	2.500	0.000	0	0	MV B1 S I -20	2.500	0.000	2067.0	F00.0	
LV B1 S I -2F	0.690	F0F.029	FF.9	2.500	0.000	0	0	MV B1 S I -2F	2.500	0.000	2070.5	F00.0	
LV B1 S I -22	0.690	F00.889	FF.9	2.500	0.000	0	0	MV B1 S I -22	2.500	0.000	2073.4	F00.0	
LV B1 S I -23	0.690	F00.804	F2.0	2.500	0.000	0	0	MV B1 S I -23	2.500	0.000	2075.2	F00.0	
LV B1 S I -24	0.690	F00.479	FF.7	2.500	0.000	0	0	MV B1 S I -24	2.500	0.000	208F.9	F00.0	
LV B1 S I -25	0.690	F00.44F	FF.7	2.500	0.000	0	0	MV B1 S I -25	2.500	0.000	2082.7	F00.0	
LV B1 S I -26	0.690	F0F.F79	F2.2	2.500	0.000	0	0	MV B1 S I -26	2.500	0.000	2067.5	F00.0	
LV B1 S I -27	0.690	F0F.092	F2.F	2.500	0.000	0	0	MV B1 S I -27	2.500	0.000	2069.3	F00.0	
LV B1 S I -28	0.690	F00.924	F2.F	2.500	0.000	0	0	MV B1 S I -28	2.500	0.000	2072.7	F00.0	
LV B1 S I -29	0.690	F0F.095	FF.9	2.500	0.000	0	0	MV B1 S I -29	2.500	0.000	2069.2	F00.0	
LV B1 S I -3F	0.690	F0F.59F	F2.3	2.500	0.000	0	0	MV B1 S I -3F	2.500	0.000	2059.F	F00.0	
LV B1 S I -32	0.690	F0F.335	F2.3	2.500	0.000	0	0	MV B1 S I -32	2.500	0.000	2064.3	F00.0	
LV B1 S I -33	0.690	F0F.205	F2.3	2.500	0.000	0	0	MV B1 S I -33	2.500	0.000	2066.9	F00.0	
LV B1 S I -34	0.690	F0F.359	F2.3	2.500	0.000	0	0	MV B1 S I -34	2.500	0.000	2063.8	F00.0	
LV B1 S I -36	0.690	F0F.684	F2.4	2.500	0.000	0	0	MV B1 S I -36	2.500	0.000	2057.2	F00.0	
LV B1 S I -37	0.690	F0F.748	F2.4	2.500	0.000	0	0	MV B1 S I -37	2.500	0.000	2055.9	F00.0	
LV B1 S I -39	0.690	F0F.639	F2.4	2.500	0.000	0	0	MV B1 S I -39	2.500	0.000	2058.F	F00.0	
LV B1 S I -40	0.690	F0F.502	F2.6	2.500	0.000	0	0	MV B1 S I -40	2.500	0.000	2060.9	F00.0	
LV B1 S I -4F	0.690	F02.F94	F3.0	2.500	0.000	0	0	MV B1 S I -4F	2.500	0.000	2046.9	F00.0	
LV B1 S I -42	0.690	F02.F29	F3.0	2.500	0.000	0	0	MV B1 S I -42	2.500	0.000	2048.2	F00.0	
LV B1 S I -43	0.690	F02.F92	F3.0	2.500	0.000	0	0	MV B1 S I -43	2.500	0.000	2047.0	F00.0	
LV B1 S I -44	0.690	F0F.920	F2.9	2.500	0.000	0	0	MV B1 S I -44	2.500	0.000	2052.4	F00.0	
LV B1 S I -45	0.690	F0F.783	F2.9	2.500	0.000	0	0	MV B1 S I -45	2.500	0.000	2055.2	F00.0	
LV B1 S I -46	0.690	F0F.62F	F2.7	2.500	0.000	0	0	MV B1 S I -46	2.500	0.000	2058.5	F00.0	
LV B1 S I -48	0.690	F02.654	F3.F	2.500	0.000	0	0	MV B1 S I -48	2.500	0.000	2037.8	F00.0	
LV B1 S I -49	0.690	F02.570	F3.F	2.500	0.000	0	0	MV B1 S I -49	2.500	0.000	2039.4	F00.0	
LV B1 S I -50	0.690	F02.65F	F3.F	2.500	0.000	0	0	MV B1 S I -50	2.500	0.000	2037.8	F00.0	
MV B1 S I -0F	34.500	F0F.450	9.4	0	0	0.004	0.004	MV B1 S I -02	2.482	-0.F29	4F.0	-99.9	
								LV B1 S I -0F	-2.486	0.F25	4F.F	-99.9	
MV B1 S I -02	34.500	F0F.34F	9.4	0	0	0.004	0.004	MV B1 S I -0F	-2.479	0.082	4F.0	-99.9	
								MV B1 S I -03	4.96F	-0.2FF	82.0	-99.9	
								LV B1 S I -02	-2.486	0.F25	4F.F	-99.9	
MV B1 S I -03	34.500	F0F.F57	9.4	0	0	0.004	0.004	MV B1 S I -02	-4.952	0.F72	82.0	-99.9	
								MV B1 S I -04	7.434	-0.302	F23.F	-99.9	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UN T PY

Page: 3
Date: F0-06-20F7
SU: WESI WOODP
Revision: F00% GEU
Config.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ND	MW	Mvar	Amp	%PY	%I ap
MV B1 S I -04	34.500	F0F.034	9.3	0	0	0.004	0.004	LV B1 S I -03	-2.486	0.F26	4F.2	-99.9	
								MV B1 S I -03	-7.425	0.258	F23.F	-99.9	
								MV B1 S I -05	9.907	-0.388	F64.2	-99.9	
MV B1 S I -05	34.500	F00.852	9.3	0	0	0.004	0.004	LV B1 S I -04	-2.486	0.F26	4F.2	-99.9	
								MV B1 S I -04	-9.888	0.342	F64.2	-99.9	
								MV B1 S I -08	F2.370	-0.473	205.4	-99.9	
MV B1 S I -06	34.500	F00.842	9.2	0	0	0.004	0.004	LV B1 S I -05	-2.486	0.F27	4F.3	-99.9	
								MV B1 S I -07	2.482	-0.F30	4F.2	-99.9	
								LV B1 S I -06	-2.486	0.F27	4F.3	-99.9	
MV B1 S I -07	34.500	F00.773	9.2	0	0	0.004	0.004	MV B1 S I -06	-2.480	0.F0F	4F.2	-99.9	
								MV B1 S I -F6	-2.478	0.065	4F.2	-F00.0	
								MV B1 S I -F5	7.440	-0.297	F23.6	-99.9	
MV B1 S I -08	34.500	F00.720	9.2	0	0	0.004	0.004	LV B1 S I -07	-2.486	0.F27	4F.3	-99.9	
								MV B1 S I -05	-F2.353	0.388	205.4	-F00.0	
								MV B1 S I -09	F4.835	-0.5F8	246.6	-99.9	
MV B1 S I -09	34.500	F00.523	9.F	0	0	0.004	0.004	LV B1 S I -08	-2.486	0.F27	4F.4	-99.9	
								MV B1 S I -08	-F4.806	0.422	246.6	-F00.0	
								MV B1 S I -F0	F7.287	-0.553	287.9	-99.9	
MV B1 S I -F0	34.500	F00.420	9.F	0	0	0.004	0.004	LV B1 S I -09	-2.486	0.F27	4F.4	-99.9	
								MV B1 S I -09	-F7.269	0.48F	287.9	-F00.0	
								MV B1 S I -25	F9.75F	-0.6F3	329.3	-F00.0	
MV B1 S I -F3	34.500	F0F.027	9.2	0	0	0.004	0.004	LV B1 S I -F0	-2.486	0.F28	4F.5	-99.9	
								MV B1 S I -F4	2.482	-0.F30	4F.2	-99.9	
								LV B1 S I -F3	-2.486	0.F26	4F.2	-99.9	
MV B1 S I -F4	34.500	F00.953	9.2	0	0	0.004	0.004	MV B1 S I -F3	-2.480	0.098	4F.F	-99.9	
								MV B1 S I -F5	4.962	-0.228	82.3	-99.9	
								LV B1 S I -F4	-2.486	0.F26	4F.3	-99.9	
MV B1 S I -F5	34.500	F00.58F	9.F	0	0	0.004	0.004	MV B1 S I -07	-7.426	0.229	F23.6	-F00.0	
								MV B1 S I -F4	-4.943	0.F5F	82.3	-F00.0	
								MV B1 S I -F7	F4.85F	-0.5FF	247.2	-99.9	
MV B1 S I -F6	34.500	F00.925	9.2	0	0	0.004	0.004	LV B1 S I -F5	-2.486	0.F27	4F.4	-99.9	
								MV B1 S I -07	2.482	-0.F30	4F.2	-99.9	
								LV B1 S I -F6	-2.486	0.F26	4F.3	-99.9	
MV B1 S I -F7	34.500	F00.307	9.0	0	0	0.004	0.004	JB-2/F	F7.29F	-0.509	288.6	-F00.0	
								MV B1 S I -F5	-F4.809	0.378	247.F	-F00.0	
								LV B1 S I -F7	-2.486	0.F28	4F.5	-99.9	
MV B1 S I -20	34.500	F00.766	9.0	0	0	0.004	0.004	MV B1 S I -2F	2.482	-0.F3F	4F.3	-99.9	
								LV B1 S I -20	-2.486	0.F27	4F.3	-99.9	
								MV B1 S I -20	-2.477	0.056	4F.2	-F00.0	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C

Study Case: 1 UN T PY

Page: 4
Date: F0-06-20F7
SU: WESI WOODP
Revision: F00% GEU
Config.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ND	MW	Mvar	Amp	%PY	%I ap
MV B1 S I -22	34.500	F00.450	8.9	0	0	0.004	0.004	MV B1 S I -22	4.959	-0.F87	82.6	-99.9	
								LV B1 S I -2F	-2.486	0.F27	4F.4	-99.9	
								JB-2/F	9.9FF	-0.332	F65.2	-99.9	
								MV B1 S I -2F	-4.952	0.F58	82.5	-99.9	
								MV B1 S I -29	-2.477	0.043	4F.3	-F00.0	
MV B1 S I -23	34.500	F00.366	9.F	0	0	0.004	0.004	LV B1 S I -22	-2.486	0.F28	4F.5	-99.9	
								89Y3A	27.F56	-0.673	452.9	-F00.0	
								MV B1 S I -28	-24.674	0.54F	4FF.5	-F00.0	
MV B1 S I -24	34.500	F00.040	8.7	0	0	0.004	0.004	LV B1 S I -23	-2.486	0.F28	4F.5	-99.9	
								MV B1 S I -25	2.482	-0.F32	4F.6	-99.9	
MV B1 S I -25	34.500	F00.002	8.7	0	0	0.004	0.004	LV B1 S I -24	-2.486	0.F29	4F.6	-99.9	
								89YFA	24.628	-0.474	4F2.2	-F00.0	
								MV B1 S I -F0	-F9.666	0.25F	329.F	F00.0	
MV B1 S I -26	34.500	F00.742	9.2	0	0	0.004	0.004	MV B1 S I -24	-2.48F	0.090	4F.5	-99.9	
								LV B1 S I -25	-2.486	0.F29	4F.7	-99.9	
								MV B1 S I -27	2.482	-0.F3F	4F.3	-99.9	
								LV B1 S I -26	-2.486	0.F27	4F.3	-99.9	
MV B1 S I -27	34.500	F00.654	9.2	0	0	0.004	0.004	MV B1 S I -26	-2.480	0.093	4F.3	-99.9	
								MV B1 S I -28	4.96F	-0.224	82.6	-99.9	
								LV B1 S I -27	-2.486	0.F27	4F.4	-99.9	
MV B1 S I -28	34.500	F00.485	9.2	0	0	0.004	0.004	MV B1 S I -23	24.705	-0.642	4FF.6	-F00.0	
								MV B1 S I -27	-4.953	0.F89	82.5	-99.9	
								MV B1 S I -33	-F7.270	0.322	287.7	-F00.0	
								LV B1 S I -28	-2.486	0.F28	4F.5	-99.9	
MV B1 S I -29	34.500	F00.657	9.0	0	0	0.004	0.004	MV B1 S I -22	2.482	-0.F3F	4F.3	-99.9	
								LV B1 S I -29	-2.486	0.F27	4F.4	-99.9	
								MV B1 S I -32	2.482	-0.F30	4F.F	-99.9	
MV B1 S I -3F	34.500	F0F.F54	9.4	0	0	0.004	0.004	LV B1 S I -3F	-2.486	0.F26	4F.2	-99.9	
								MV B1 S I -32	-2.476	0.0F9	4F.F	F00.0	
								MV B1 S I -33	4.957	-0.F49	82.3	-F00.0	
MV B1 S I -32	34.500	F00.897	9.4	0	0	0.004	0.004	LV B1 S I -32	-2.486	0.F26	4F.3	-99.9	
								MV B1 S I -28	F7.320	-0.5F7	287.8	-F00.0	
								MV B1 S I -32	-4.95F	0.F23	82.2	-F00.0	
								MV B1 S I -34	-9.888	0.264	F64.3	-F00.0	
MV B1 S I -33	34.500	F00.767	9.4	0	0	0.004	0.004	LV B1 S I -33	-2.486	0.F27	4F.3	-99.9	
								MV B1 S I -33	9.903	-0.302	F64.3	-F00.0	
								MV B1 S I -36	-4.946	0.F63	82.F	-99.9	
								MV B1 S I -39	-2.475	0.009	4F.0	F00.0	
								LV B1 S I -34	-2.486	0.F26	4F.3	-99.9	

Project: UW OH WNUD
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Filename: UW_OH

ETAP
F6.0.0C
Study Case: 1 UN T PY

Page: 5
Date: F0-06-20F7
SU: WESI WOODP
Revision: F00% GEU
Config.: Uormal

Bus		Voltage		Generation		Load		Load Flow				XFMR	
ND	kV	% Mag.	Ang.	MW	Mvar	MW	Mvar	ND	MW	Mvar	Amp	%PY	%I ap
MV B1 S I -36	34.500	F0F.247	9.5	0	0	0.004	0.004	MV B1 S I -34	4.962	-0.23F	82.F	-99.9	
								MV B1 S I -37	-2.480	0.F0F	4F.0	-99.9	
								LV B1 S I -36	-2.486	0.F26	4F.F	-99.9	
MV B1 S I -37	34.500	F0F.3FF	9.5	0	0	0.004	0.004	MV B1 S I -36	2.482	-0.F29	4F.F	-99.9	
								LV B1 S I -37	-2.486	0.F25	4F.F	-99.9	
MV B1 S I -39	34.500	F0F.202	9.5	0	0	0.004	0.004	MV B1 S I -34	2.482	-0.F29	4F.F	-99.9	
								LV B1 S I -39	-2.486	0.F26	4F.2	-99.9	
MV B1 S I -40	34.500	F0F.065	9.7	0	0	0.004	0.004	89Y4A	24.665	-0.552	408.5	-F00.0	
								MV B1 S I -46	-22.F83	0.422	367.4	-F00.0	
								LV B1 S I -40	-2.486	0.F26	4F.2	-99.9	
MV B1 S I -4F	34.500	F0F.758	F0.2	0	0	0.004	0.004	JB-4/F	2.482	-0.F28	40.9	-99.9	
								LV B1 S I -4F	-2.486	0.F24	40.9	-99.9	
MV B1 S I -42	34.500	F0F.693	F0.2	0	0	0.004	0.004	JB-4/F	9.89F	-0.274	F62.8	-F00.0	
								MV B1 S I -49	-7.409	0.F46	F22.0	-F00.0	
								LV B1 S I -42	-2.486	0.F25	4F.0	-99.9	
MV B1 S I -43	34.500	F0F.756	F0.2	0	0	0.004	0.004	JB-4/F	2.482	-0.F28	40.9	-99.9	
								LV B1 S I -43	-2.486	0.F24	40.9	-99.9	
MV B1 S I -44	34.500	F0F.484	F0.F	0	0	0.004	0.004	JB-4/F	-F4.82F	0.366	244.5	-F00.0	
								MV B1 S I -45	F7.303	-0.495	285.4	-F00.0	
								LV B1 S I -44	-2.486	0.F25	4F.0	-99.9	
MV B1 S I -45	34.500	F0F.346	F0.0	0	0	0.004	0.004	MV B1 S I -44	-F7.279	0.396	285.4	-F00.0	
								MV B1 S I -46	F9.76F	-0.525	326.4	-F00.0	
								LV B1 S I -45	-2.486	0.F25	4F.F	-99.9	
MV B1 S I -46	34.500	F0F.F84	9.8	0	0	0.004	0.004	MV B1 S I -40	22.2F0	-0.508	367.4	-F00.0	
								MV B1 S I -45	-F9.728	0.378	326.3	-F00.0	
								LV B1 S I -46	-2.486	0.F26	4F.2	-99.9	
MV B1 S I -48	34.500	F02.2F9	F0.3	0	0	0.004	0.004	MV B1 S I -49	2.482	-0.F27	40.7	-99.9	
								LV B1 S I -48	-2.486	0.F23	40.8	-99.9	
MV B1 S I -49	34.500	F02.F35	F0.3	0	0	0.004	0.004	MV B1 S I -42	7.442	-0.308	F22.0	-99.9	
								MV B1 S I -48	-2.480	0.090	40.7	-99.9	
								MV B1 S I -50	-2.480	0.09F	40.7	-99.9	
								LV B1 S I -49	-2.486	0.F23	40.8	-99.9	
MV B1 S I -50	34.500	F02.2F6	F0.3	0	0	0.004	0.004	MV B1 S I -49	2.482	-0.F27	40.7	-99.9	
								LV B1 S I -50	-2.486	0.F23	40.8	-99.9	
* PON	F38.000	F00.000	0.0	-F02.552	F6.056	0	0	89I FA	-F02.552	F6.056	434.3	-98.8	
MPI ~3	F3.800	99.706	9.3	0	0	0	0	HV B1 S MPI	0.000	0.000	0.0	0.0	
& 89I FB													

* Indicates a voltage regulated bus (voltage controlled or swing type machine connected to it)
Indicates a bus with a load mismatch of more than 0.F MVA

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDCC

Study Case: NPG 16L. 0

Page: N
j ate: ND%6%DNk
SF: m ES_m OOj I
AeMsion: NDDp 0 EF
Con8gT F or2 al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4	
51- N	1B6DD	117511	1'D	E	D	E	E	3 V UGS _%6	%B6NN	%N6ff	B61 k	1D6		
								51_ NU	fB6NN	NN6ff	B61 k	1D6		
51- f.	1B6DD	117511	1'D	E	D	E	E	JU%6/N	%VUk6B	%N'61W	B15 k	1D6W		
								51_ NU	fVUk6B	N'61W	B15 k	1D6W		
51- L.	1B6DD	117511	1'D	E	D	E	E	3 V UGS _%6I	%VUIN5	%N'k6	B15 5	1DB		
								51_ NU	fVUIN5	N'k6	B15 5	1DB		
51- B	1B6DD	117511	1'D	E	D	E	E	3 V UGS _%6D	%BTFB6	%N'TLB	B66B	51T		
								51_ NU	fBTFB6	N'TLB	B66B	51T		
51_ N	N 5TDD	NDDEDI	DD	E	D	E	E	POv	ND'TN5	11 k1N	B61T	16D		
								HV UGS 3 P_	%ND'TN5	%61 k1N	B61T	16D		
51_ NU	1B6DD	117511	1'D	E	D	DDDD	%T11f	51- B	%BTFB6	%N'TLB	B66B	51T		
								51- L.	%VUIN5	%N'k6	B15 5	1DB		
								51- f.	%VUk6B	%N'61W	B15 k	1D6W		
								51- N	%B6NN	%N6ff	B61 k	1D6		
								3 P_~I	ND'TN5	61 TN 1	N1W	55 5		
								& HV UGS 3 P_						
HV UGS 3 P_	N 5TDD	NDDEDI	DD	E	D	DD6B	DN6k	51_ N	ND'TN5	11 k1N	B61T	16D		
								51_ NU	%ND'TNk6	%61 5k5	B6DI	1BII	k6DD	
								& 3 P_~I						
JU%6/N	1B6DD	ND66kW	1T	E	D	E	E	3 V UGS _%6k	%kT1f	%61k	1N6B	1DII		
								3 V UGS _%6f	%6W6	%B61	N6DI	1ND		
								51- f.	f kDlk	N'T5W	B16 k	1DII		
JU%6/N	1B6DD	ND'TN5	NDI	E	D	E	E	3 V UGS _%6N	%6k5	%NDLB	B1T	1N6		
								3 V UGS _%6f	%6kk	%B6DD	NkWN	1ND		
								3 V UGS _%6I	%6k5	%NDI1	B1T	1N6		
								3 V UGS _%6B	NB511	W6k	f'W7I	1NT		
LV UGS _%6N	DWD	ND6NDf	N'TN	f'6DD	N'fND	E	E	3 V UGS _%6N	f'6DD	N'fND	ff'NNf	1DD		
LV UGS _%6f	DWD	NBII5W	N'TN	f'6DD	N'fND	E	E	3 V UGS _%6f	f'6DD	N'fND	ff'N'W	1DD		
LV UGS _%6I	DWD	NB6k6D	N'Tf	f'6DD	N'fDD	E	E	3 V UGS _%6I	f'6DD	N'fDD	ff'N6k	1Df		
LV UGS _%6B	DWD	NB6W6k	N'Tf	f'6DD	N'fND	E	E	3 V UGS _%6B	f'6DD	N'fND	ff'fD6	1DD		
LV UGS _%66	DWD	NB6I6	N'Tf	f'6DD	N'fND	E	E	3 V UGS _%66	f'6DD	N'fND	ff'f6T	1DD		
LV UGS _%6W	DWD	NBII fD	N'TN	f'6DD	N'fND	E	E	3 V UGS _%6W	f'6DD	N'fND	ff'fk6	1DD		
LV UGS _%6k	DWD	NB6f6k	N'TN	f'6DD	N'fND	E	E	3 V UGS _%6k	f'6DD	N'fND	ff'f1T	1DD		
LV UGS _%65	DWD	NB6f6B	N'Tf	f'6DD	N'fND	E	E	3 V UGS _%65	f'6DD	N'fND	ff'f1T	1DD		
LV UGS _%6I	DWD	ND'T5W	N'TN	f'6DD	N'fND	E	E	3 V UGS _%6I	f'6DD	N'fND	ff'1BII	1DD		
LV UGS _%6D	DWD	ND'61D	N'TN	f'6DD	N'fND	E	E	3 V UGS _%6D	f'6DD	N'fND	ff'15T	1DD		

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC
Study Case: NPG 16L. 0

Page: f
j ate: ND%6%DNk
SF: m ES_m OOj I
AeMsion: NDp 0 EF
Con8gT F or2 al

Bus	Voltage			Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
LV UGS_ %M	DWDD	NDBKDD	N'D	f'6DD	NFND	£	£	3 V UGS_ %M	f'6DD	NFND	fff1I II	1DD	
LV UGS_ %B	DWDD	NDBE'D	N'D	f'6DD	NFND	£	£	3 V UGS_ %B	f'6DD	NFND	fff6TW	1DD	
LV UGS_ %6	DWDD	NDBD'f	N'TN	f'6DD	NFND	£	£	3 V UGS_ %6	f'6DD	NFND	ff1B1N	1DD	
LV UGS_ %MW	DWDD	NDBED6	N'TN	f'6DD	NFND	£	£	3 V UGS_ %MW	f'6DD	NFND	fff6II	1DD	
LV UGS_ %k	DWDD	NDITW6	N'TN	f'6DD	NFND	£	£	3 V UGS_ %k	f'6DD	NFND	ffB'F	1DD	
LV UGS_ %D	DWDD	NDBND6	NNII	f'6DD	NFND	£	£	3 V UGS_ %D	f'6DD	NFND	ff1fT	1DD	
LV UGS_ %N	DWDD	NDITf'D	N'D	f'6DD	NFND	£	£	3 V UGS_ %N	f'6DD	NFND	ff1W	1DD	
LV UGS_ %f	DWDD	NDIKkD	N'D	f'6DD	NFND	£	£	3 V UGS_ %f	f'6DD	NFND	ff11TW	1DD	
LV UGS_ %I	DWDD	NDIK1D	N'TN	f'6DD	NFND	£	£	3 V UGS_ %I	f'6DD	NFND	ff11TN	1DD	
LV UGS_ %B	DWDD	NDITk5	NNII	f'6DD	NFND	£	£	3 V UGS_ %B	f'6DD	NFND	ff6f'B	1DD	
LV UGS_ %6	DWDD	NDITN1	NNII	f'6DD	NFND	£	£	3 V UGS_ %6	f'6DD	NFND	ff61'B	1DD	
LV UGS_ %W	DWDD	NDBf5D	N'T	f'6DD	NFND	£	£	3 V UGS_ %W	f'6DD	NFND	fff5TW	1DD	
LV UGS_ %k	DWDD	NDBf6W	N'T	f'6DD	NFND	£	£	3 V UGS_ %k	f'6DD	NFND	ff1DDW	1DD	
LV UGS_ %5	DWDD	NDBEDk	N'T	f'6DD	NFND	£	£	3 V UGS_ %5	f'6DD	NFND	ff1B6	1DD	
LV UGS_ %1	DWDD	NDIT11N	N'D	f'6DD	NFND	£	£	3 V UGS_ %1	f'6DD	NFND	ff1B6	1DD	
LV UGS_ %N	DWDD	NDBf6B	N'T	f'6DD	NFND	£	£	3 V UGS_ %N	f'6DD	NFND	ffNMW	1DD	
LV UGS_ %f	DWDD	NDB6kD	N'T	f'6DD	NFND	£	£	3 V UGS_ %f	f'6DD	NFND	ffff'B	1DD	
LV UGS_ %I	DWDD	NDBE1N	N'T	f'6DD	NFND	£	£	3 V UGS_ %I	f'6DD	NFND	fff6'B	1DD	
LV UGS_ %B	DWDD	NDBWDD	N'T	f'6DD	NFND	£	£	3 V UGS_ %B	f'6DD	NFND	fffNMW	1DD	
LV UGS_ %W	DWDD	NDBII65	N'T	f'6DD	NFND	£	£	3 V UGS_ %W	f'6DD	NFND	ffNBf	1DD	
LV UGS_ %k	DWDD	NDBf'W	N'T	f'6DD	NFND	£	£	3 V UGS_ %k	f'6DD	NFND	ffN'6	1DD	
LV UGS_ %1	DWDD	NDBIID1	N'T	f'6DD	NFND	£	£	3 V UGS_ %1	f'6DD	NFND	ffN6f	1DD	
LV UGS_ %D	DWDD	NDBf'D	N'6	f'6DD	NFND	£	£	3 V UGS_ %D	f'6DD	NFND	ffN'T	1DD	
LV UGS_ %N	DWDD	NDBEB	N'K	f'6DD	NFND	£	£	3 V UGS_ %N	f'6DD	NFND	f'NIN6	1DD	
LV UGS_ %f	DWDD	NDBIk6	N'K	f'6DD	NFND	£	£	3 V UGS_ %f	f'6DD	NFND	f'NIf'II	1DD	
LV UGS_ %I	DWDD	NDBE'f	N'K	f'6DD	NFND	£	£	3 V UGS_ %I	f'6DD	NFND	f'NINW	1DD	
LV UGS_ %B	DWDD	NDBTWf	N'K	f'6DD	NFND	£	£	3 V UGS_ %B	f'6DD	NFND	f'N56	1DD	
LV UGS_ %6	DWDD	NDBf6W	N'K	f'6DD	NFND	£	£	3 V UGS_ %6	f'6DD	NFND	ffDI TN	1DD	
LV UGS_ %W	DWDD	NDBf'k	N'TW	f'6DD	NFND	£	£	3 V UGS_ %W	f'6DD	NFND	ffD66	1DD	
LV UGS_ %5	DWDD	NDB6k6	N'K	f'6DD	NFND	£	£	3 V UGS_ %5	f'6DD	NFND	f'6DDW	1DD	
LV UGS_ %1	DWDD	NDBf6W	N'K	f'6DD	NFND	£	£	3 V UGS_ %1	f'6DD	NFND	f'6f'B	1DD	
LV UGS_ %D	DWDD	NDB6kf	N'K	f'6DD	NFND	£	£	3 V UGS_ %D	f'6DD	NFND	f'6DK	1DD	
3 V UGS_ %N	1B6DD	NDfTW	16	£	D	DDDB	DDDB	3 V UGS_ %f	f'6SD	NDWN	BBIN	1NII	
3 V UGS_ %f	1B6DD	NDf'6D	16	£	D	DDDB	DDDB	LV UGS_ %N	%f6B	%NDW	BBf	1NII	
								3 V UGS_ %N	%f6k	%NDI	BB6	1NI	
								3 V UGS_ %I	BII6W	f'NkD	55TW	1NIW	
3 V UGS_ %I	1B6DD	NDNIB6	16	£	D	DDDB	DDDB	LV UGS_ %f	%f6B	%NDW	BBf	1NII	
								3 V UGS_ %B	kBf6	IT61	NITN	1NIW	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: 1
j ate: ND66%DNk
SF: m ES_m OOj 1
AeMsion: NDp 0 EF
Con8gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
3 V UGS_%B	1B6DD	NN65D	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBT	1fD	
								3 V UGS_%B	%B5B	%D6B	BBT	1fD	
								3 V UGS_%B	%B5B	%D6B	BBT	1fD	
3 V UGS_%B	1B6DD	NN656	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%W	1B6DD	NN6W	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%k	1B6DD	NN6f	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%B	1B6DD	NN6DD	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%D	1B6DD	NN66	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%D	1B6DD	NN66	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%D	1B6DD	NN66	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%B	1B6DD	NN6kD	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%B	1B6DD	NN6W	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%W	1B6DD	NN665	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%k	1B6DD	ND6k1	1B	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%D	1B6DD	NN66D	1T	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
3 V UGS_%N	1B6DD	NN66k	1T	E	D	DDB	DDB	LV UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	
								3 V UGS_%B	%B5B	%D6B	BBB	1NII	

Project: Fm OH m vF j

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File Name: Fm 70H

ETAP

NWDEC

Study Case: NPG 16L. 0

Page: B

Project: NWDEC

SF: m ES_m OOj 1

Assignment: NPG 0 EF

Configuration: For 2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p_a4
3 V UGS_%f	1B6DD	NDI1D	1T	E	D	DDB	DDB	3 V UGS_%f	B116B	fT1f	51K	1NB	
								LV UGS_%N	%B5B	%NDW	BBK	1fTD	
								JU%/N	1B15	BBfB	Nk1B	1NT	
								3 V UGS_%N	%B1B6	%TfD	51T	1NT	
3 V UGS_%I	1B6DD	NDI1f6	1B	E	D	DDB	DDB	3 V UGS_%I	%Bk1	%NBW	B6T	1DK	
								LV UGS_%f	%B5B	%NDW	BBB	1fTD	
								51-1.	fK1NB	NfBDB	B1BT	1D1	
								3 V UGS_%5	%B1W6	%N1BW	BB1W	1D5	
3 V UGS_%B	1B6DD	NDI1W	1T	E	D	DDB	DDB	LV UGS_%I	%B5B	%NDW	BBB	1fTD	
								3 V UGS_%6	fBk1	ND6W	B6TD	1fTD	
								LV UGS_%B	%B51	%D61	B6TD	1fTD	
								51- N	fB6W	N1f51	B6fTD	1DK	
3 V UGS_%6	1B6DD	NDI16N	1T	E	D	DDB	DDB	3 V UGS_%D	%B1W6	%Tf1	1WN5	1D5	
								3 V UGS_%B	%Bk5	%D15	B6T	1NB	
								LV UGS_%6	%B51	%D61	B6TN	1fTD	
								3 V UGS_%k	fBk1	ND61	BBB	1fTD	
3 V UGS_%W	1B6DD	NDI1f6	1B	E	D	DDB	DDB	LV UGS_%W	%B5B	%NDW	BBW	1N1	
								3 V UGS_%k	%Bk1	%D1k	BBK	1NB	
								3 V UGS_%5	B116W	fT66	51T	1NK	
								LV UGS_%k	%B5B	%NDW	BBW	1N1	
3 V UGS_%5	1B6DD	NDI1W	1T	E	D	DDB	DDB	3 V UGS_%I	fB1W6	N1f61	B6B5	1ND	
								3 V UGS_%k	%B1Bk	%N1D	51B	1NB	
								3 V UGS_%I	%Bk1W	%D6	1NB6	1DK	
								LV UGS_%5	%B5B	%NDW	BBK	1N1	
3 V UGS_%I	1B6DD	NDI1D	1T	E	D	DDB	DDB	3 V UGS_%f	fBk1	ND65	BBW	1fTD	
								LV UGS_%I	%B5B	%NDW	BBK	1N1	
								3 V UGS_%N	fB5D	NDWD	BBf	1N1	
								LV UGS_%N	%B5B	%NDW	BBf	1N1	
3 V UGS_%f	1B6DD	NDI1fB	1W	E	D	DDB	DDB	3 V UGS_%N	%Bk1	%Nk1	B6TD	1DB	
								3 V UGS_%I	B116f	fT1f	51B	1NT	
								LV UGS_%f	%B5B	%NDW	BBB	1N1	
								3 V UGS_%5	NkT16	kB5Nk	1NTK	1NN	
3 V UGS_%I	1B6DD	NDI1f6	1W	E	D	DDB	DDB	3 V UGS_%f	%B1BB	%T61	51B	1ND	
								3 V UGS_%B	%BkN	%B11	Nk5K	1ND	
								LV UGS_%I	%B5B	%NDW	BBB	1N1	
								3 V UGS_%I	1B51	BBW	Nk5B	1NT	
3 V UGS_%B	1B6DD	NDI1W	1W	E	D	DDB	DDB	3 V UGS_%W	%B11	%TN5	51TD	1NT	
								3 V UGS_%I	%BkN	%N51	B6TN	1DT	
								LV UGS_%B	%B5B	%NDW	BBB	1N1	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
NWDEC

Study Case: NPG 16L. 0

Page: 6
j ate: ND%6%DNk
SF: m ES_m OOj l
AeMsion: NDp 0 EF
Con8gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	. ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	. 2 4	p P-	p _a4
3 V UGS _%W	1B6DD	NDTN	1TW	E	D	DDB	DDB	3 V UGS _%B	Bll6k	fTN6D	55B	1NR	
								3 V UGS _%k	%Ek5	%ND61	BBB	1NB	
								LV UGS _%W	%ESB	%NDWB	BBT	1NI	
3 V UGS _%k	1B6DD	NDTN	1TW	E	D	DDB	DDB	3 V UGS _%W	fESD	NDWN	BBT	1NI	
								LV UGS _%k	%ESB	%NDW6	BBT	1NI	
3 V UGS _%l	1B6DD	NDTkf	1TW	E	D	DDB	DDB	3 V UGS _%B	fESD	NDWN	BBT	1NI	
								LV UGS _%l	%ESB	%NDWB	BBT	1NI	
3 V UGS _%D	1B6DD	NDT6	1Tl	E	D	DDB	DDB	51- B	fBNWk	NIW	BBBD	1D6	
								3 V UGS _%BW	%fTNk	%DIDD	111Tl	1DK	
								LV UGS _%D	%ESB	%NDW6	BBT	1NI	
3 V UGS _%N	1B6DD	NDTlB	NDT	E	D	DDB	DDB	JU%B/N	fESD	NDWB	BTk	1NI	
								LV UGS _%N	%ESB	%NDWk	BT6	1NI	
3 V UGS _%Bf	1B6DD	NDTNB	NDT	E	D	DDB	DDB	JU%B/N	lEk	BBll	NkWN	1ND	
								3 V UGS _%Bl	%Tllk	%BW	NfT	1DK	
								LV UGS _%Bf	%ESB	%NDWk	BTll	1NI	
3 V UGS _%Bl	1B6DD	NDTlf	NDT	E	D	DDB	DDB	JU%B/N	fESD	NDWB	BTk	1NI	
								LV UGS _%Bl	%ESB	%NDWk	BT6	1NI	
3 V UGS _%B	1B6DD	NDTkB	NDN	E	D	DDB	DDB	JU%B/N	%BRlW	%Wk1N	fVB6	1DI	
								3 V UGS _%B6	NkTkW	k6B	lD6k	1ND	
								LV UGS _%B	%ESB	%NDW	BBD	1NI	
3 V UGS _%B6	1B6DD	NDTW	NDN	E	D	DDB	DDB	3 V UGS _%B	%kTB6	%ll6N	lDlTW	1D6	
								3 V UGS _%BW	NTrf5	lTN	l6l6	1ND	
								LV UGS _%B6	%ESB	%NDW	BBN	1NI	
3 V UGS _%BW	1B6DD	NDT5W	ND	E	D	DDB	DDB	3 V UGS _%D	fTNW	NDN6	111D	1D6	
								3 V UGS _%B6	%NTW61	%TN6W	l6Bll	1DK	
								LV UGS _%BW	%ESB	%NDW6	BBT	1NI	
3 V UGS _%B5	1B6DD	NDTk5	NDN	E	D	DDB	DDB	3 V UGS _%Bl	fESD	NDW6	BT6	1NI	
								LV UGS _%B5	%ESB	%NDW	BTW	1NI	
3 V UGS _%Bl	1B6DD	NDT6k	NDT	E	D	DDB	DDB	3 V UGS _%Bf	kBT6	lTkD	NNN	1NB	
								3 V UGS _%B5	%Tk5	%NDl	BT6	1NB	
								3 V UGS _%D	%Tk5	%NDT	BT6	1NB	
								LV UGS _%Bl	%ESB	%NDW	BTW	1NI	
3 V UGS _%D	1B6DD	NDTk6	NDN	E	D	DDB	DDB	3 V UGS _%Bl	fESD	NDW6	BT6	1NI	
								LV UGS _%D	%ESB	%NDW	BTW	1NI	
* POv	N 5TDD	NDIDD	DD	%DTN6	%lKNB	E	E	51_N	%DTN6	%lKNB	BBTl	16D	
3 P_~l	N 6DD	ND6f1	lTl	E	D	E	E	HV UGS 3 P_	DDDD	DDDD	DD	DD	
								& 51_NU					

* indicates a Voltage regulated bus (Voltage controlled or swing ty4e 2 achine connected to it)
indicates a bus with a load 2 is2 atch o82 ore than DN3 V.

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: 0
j ate: 0D%BC%DDk
SF : m ES_m OOj l
AeMsion: 0DDp . EF
Con&gT F or2 al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4	
5N 06	1BICDD	0DDkKB	ND	E	D	E	E	3 V U1 S _%G	%BICD1	%0TBBW	BQTB	NDW		
								5N_0U	fBICD1	00TBBW	BQTB	NDW		
5N f6	1BICDD	0DDkKB	ND	E	D	E	E	JU%0	%WkKk	%fTCD	BNkT	NDK		
								5N_0U	fWkKk	0fTCD	BNkT	NDK		
5N 16	1BICDD	0DDkKB	ND	E	D	E	E	3 V U1 S _%I	%Wf0	%fTWf	BNkT	NDG		
								5N_0U	fWf0	0fTWf	BNkT	NDG		
5N B6	1BICDD	0DDkKB	ND	E	D	E	E	3 V U1 S _%BD	%BfBN	%fTfG	BCHD	5NT		
								5N_0U	fBfBN	0fTfG	BCHD	5NT		
5N_06	015TDD	NGDD	DD	E	D	E	E	POv	0DfD15	11TG0	Bk1TB	NGD		
								HV U1 S 3 P_	%DfD15	%1TG0	Bk1TB	NGD		
5N_0U	1BICDD	0DDkKB	ND	E	D	DDDD	%BDW	5N B6	%BfBN	%fTfG	BCHD	5NT		
								5N 16	%Wf0	%fTWf	BNkT	NDG		
								5N f6	%WkKk	%fTCD	BNkT	NDK		
								5N 06	%BICD1	%0TBBW	BQTB	NDW		
								3 P_~I	0DfTWD	GfT500	0NDW	55TN		
HV U1 S 3 P_	015TDD	NGDD	DD	E	D	DDDS	DDH	& HV U1 S 3 P_						
								5N_06	0DfD15	11TG0	Bk1TB	NGD		
								5N_0U	%DfD5W	%1TWWB	Bk1TB	NGD	0T5kG	
JU%0	1BICDD	0DDkKB	NT	E	D	E	E	& 3 P_~I						
								3 V U1 S _%k	%kT11	%T51G	10BG	N0D		
								3 V U1 S _%f	%NSWW	%BCB	0kN5	N0D		
JU%0	1BICDD	0DfTfD	0DD	E	D	E	E	5N f6	fkdNN	0fT5N	BNBT	N0D		
								3 V U1 S _%BD	%Tk5	%T5G	BfTB	N0TW		
								3 V U1 S _%Bf	%Tk5	%BWB	0kGW	N0D		
								3 V U1 S _%BI	%Tk5	%T5B	BfTB	N0TW		
								3 V U1 S _%BB	0B511	WW1	fWT	N0T		
LV U1 S _%BD	DMND	0DGfBG	0fD	fTCD	0TDD	E	E	3 V U1 S _%BD	fTCD	0TDD	ffDBK	NDf		
LV U1 S _%Bf	DMND	0DG0fN	0fD	fTCD	0TDD	E	E	3 V U1 S _%Bf	fTCD	0TDD	ffEkT	NDf		
LV U1 S _%BI	DMND	0DBNf	0fD	fTCD	0TDD	E	E	3 V U1 S _%BI	fTCD	0TDD	ff00T	NDf		
LV U1 S _%BB	DMND	0DBkN0	0fD	fTCD	0TDD	E	E	3 V U1 S _%BB	fTCD	0TDD	ff0BT	NDf		
LV U1 S _%BG	DMND	0DBGkN	0fD	fTCD	0TDD	E	E	3 V U1 S _%BG	fTCD	0TDD	ff05TB	NDf		
LV U1 S _%BW	DMND	0DBEWB	0fD	fTCD	0TDD	E	E	3 V U1 S _%BW	fTCD	0TDD	fff0T	NDf		
LV U1 S _%Bk	DMND	0DBfN0	0fD	fTCD	0TDD	E	E	3 V U1 S _%Bk	fTCD	0TDD	ffffTB	NDf		
LV U1 S _%BS	DMND	0DBfNN	0fD	fTCD	0TDD	E	E	3 V U1 S _%BS	fTCD	0TDD	ffffTW	NDf		
LV U1 S _%BN	DMND	0DBD10	0fD	fTCD	0TDD	E	E	3 V U1 S _%BN	fTCD	0TDD	fff5T	NDf		
LV U1 S _%BD	DMND	0DfTkW	0fD	fTCD	0TDD	E	E	3 V U1 S _%BD	fTCD	0TDD	ff10TW	NDf		

Project: Fm OH m vF j

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File Name: F m 7OH

ETAP

0WDEC

Study Case: NGP1_NGL6.

Page: f

Project Name: 0D0CP%DDk

SF: mES_mOOj 1

Assumptions: 0DDp . EF

Configuration: F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
LV U1 S_ %I	DMND 0DBNBB	0fTD	fTDD	0TDD				3 V U1 S_ %I	fTDD	0TDD	ff0kTB	NDF	
LV U1 S_ %B	DMND 0DBGBW	0fTD	fTDD	0TDD				3 V U1 S_ %B	fTDD	0TDD	ff0ND	NDF	
LV U1 S_ %G	DMND 0DBDWk	0fTD	fTDD	0TDD				3 V U1 S_ %G	fTDD	0TDD	fffkTG	NDF	
LV U1 S_ %W	DMND 0DBGG	0fTD	fTDD	0TDD				3 V U1 S_ %W	fTDD	0TDD	ff0NT	NDF	
LV U1 S_ %k	DMND 0DTRNG	0fTD	fTDD	0TDD				3 V U1 S_ %k	fTDD	0TDD	ff1GG	NDF	
LV U1 S_ %D	DMND 0DBFCB	00TN	fTDD	0TDD				3 V U1 S_ %D	fTDD	0TDD	fffGK	NDF	
LV U1 S_ %0	DMND 0DBDWW	00TN	fTDD	0TDD				3 V U1 S_ %0	fTDD	0TDD	fffNK	NDF	
LV U1 S_ %f	DMND 0DITNW	0fTD	fTDD	0TDD				3 V U1 S_ %f	fTDD	0TDD	ff1fTN	NDF	
LV U1 S_ %I	DMND 0DITNW	0fTD	fTDD	0TDD				3 V U1 S_ %I	fTDD	0TDD	ff1fTG	NDF	
LV U1 S_ %B	DMND 0DITfW	00TN	fTDD	0TDD				3 V U1 S_ %B	fTDD	0TDD	ffBGK	NDF	
LV U1 S_ %G	DMND 0DIT5f	00TN	fTDD	0TDD				3 V U1 S_ %G	fTDD	0TDD	ffBMW	NDF	
LV U1 S_ %W	DMND 0DBFB	0fTD	fTDD	0TDD				3 V U1 S_ %W	fTDD	0TDD	ffffTD	NDF	
LV U1 S_ %k	DMND 0DBIT0	0fTD	fTDD	0TDD				3 V U1 S_ %k	fTDD	0TDD	ffffBD	NDF	
LV U1 S_ %5	DMND 0DBDGD	0fTF	fTDD	0TDD				3 V U1 S_ %5	fTDD	0TDD	fffkTN	NDF	
LV U1 S_ %N	DMND 0DBD1k	00TN	fTDD	0TDD				3 V U1 S_ %N	fTDD	0TDD	fff5TF	NDF	
LV U1 S_ %0	DMND 0DBNSW	0fTF	fTDD	0TDD				3 V U1 S_ %0	fTDD	0TDD	ff0Df	NDF	
LV U1 S_ %f	DMND 0DBR0I	0fTF	fTDD	0TDD				3 V U1 S_ %f	fTDD	0TDD	ff0GN	NDF	
LV U1 S_ %I	DMND 0DBCKB	0fTF	fTDD	0TDD				3 V U1 S_ %I	fTDD	0TDD	ff05TN	NDF	
LV U1 S_ %B	DMND 0DBRGI	0fTF	fTDD	0TDD				3 V U1 S_ %B	fTDD	0TDD	ff0GD	NDF	
LV U1 S_ %W	DMND 0DGDLD	0fTF	fTDD	0TDD				3 V U1 S_ %W	fTDD	0TDD	ff1kTB	NDF	
LV U1 S_ %k	DMND 0DGDW%	0fTF	fTDD	0TDD				3 V U1 S_ %k	fTDD	0TDD	ffDM	NDF	
LV U1 S_ %N	DMND 0DGDGD	0fTF	fTDD	0TDD				3 V U1 S_ %N	fTDD	0TDD	ff1DfTB	NDF	
LV U1 S_ %D	DMND 0DGDW0	0fTG	fTDD	0TDD				3 V U1 S_ %D	fTDD	0TDD	ffDMG	NDF	
LV U1 S_ %B0	DMND 0DWD5D	0fTK	fTDD	0TDD				3 V U1 S_ %B0	fTDD	0TDD	f05GI	NDF	
LV U1 S_ %Bf	DMND 0DWD0f	0fTK	fTDD	0TDD				3 V U1 S_ %Bf	fTDD	0TDD	f05Wk	NDF	
LV U1 S_ %BI	DMND 0DWDk5	0fTK	fTDD	0TDD				3 V U1 S_ %BI	fTDD	0TDD	f05GI	NDF	
LV U1 S_ %BB	DMND 0DG5fN	0fTK	fTDD	0TDD				3 V U1 S_ %BB	fTDD	0TDD	f0NTG	NDF	
LV U1 S_ %BG	DMND 0DGTWB	0fTW	fTDD	0TDD				3 V U1 S_ %BG	fTDD	0TDD	f0NM%	NDF	
LV U1 S_ %BW	DMND 0DGTGW	0fTW	fTDD	0TDD				3 V U1 S_ %BW	fTDD	0TDD	ff1fTB	NDF	
LV U1 S_ %B5	DMND 0DWR0D	0fTK	fTDD	0TDD				3 V U1 S_ %B5	fTDD	0TDD	f0kBG	NDF	
LV U1 S_ %BN	DMND 0DWW0	0fTK	fTDD	0TDD				3 V U1 S_ %BN	fTDD	0TDD	f0kWI	NDF	
LV U1 S_ %GD	DMND 0DWR1k	0fTK	fTDD	0TDD				3 V U1 S_ %GD	fTDD	0TDD	f0kBG	NDF	
3 V U1 S_ %D0	1BICDD 0DfTfG	NG			D	DDDB	DDDB	3 V U1 S_ %Df	fTSD	0TDf	BBD	NfD	
								LV U1 S_ %D0	%fSB	%DGW	BBD	NfD	
3 V U1 S_ %Df	1BICDD 0DfT0W	NG			D	DDDB	DDDB	3 V U1 S_ %D0	%fBk	%DDD	BBf	N0B	
								3 V U1 S_ %DI	BNGW	fTDf	55TB	N0K	
								LV U1 S_ %Df	%fSB	%DGG	BBD	NfD	
3 V U1 S_ %DI	1BICDD 0DfTDG	NG			D	DDDB	DDDB	3 V U1 S_ %Df	%BNBW	%DNO	55TW	N0B	
								3 V U1 S_ %DB	kTBG	1TfBf	01fTB	N0TW	

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: I
j ate: 0D%CP%DDk
SF : m ES_m OOj I
AeMsion: 0DDp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S_%B	1BICDD 0DDTKD	NG	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%T5W	%T5W	011D	N'B	
								3 V U1 S_%B	NENB	BT1W	0kkT	N'W	
3 V U1 S_%G	1BICDD 0DDTKG	NG	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%W	1BICDD 0DDTWG	NB	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%k	1BICDD 0DDTWD	NB	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%S	1BICDD 0DDTWS	NG	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%N	1BICDD 0DDTNB	NB	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%D	1BICDD 0DDTDB	NB	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%I	1BICDD 0DDT0N	NI	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%B	1BICDD 0DDTK15	NI	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%G	1BICDD 0DDTI10	NB	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%W	1BICDD 0DDTkfW	NB	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%k	1BICDD 0DDNBN	NI	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%D	1BICDD 0DDT0N	NI	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
3 V U1 S_%0	1BICDD 0DDTfk	NI	E	D	DDDB	DDDB	3 V U1 S_%B	LV U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	
								3 V U1 S_%B	%TSB	%DGB	BBB	N'D	

Project: Fm OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1 NGL6 .

Page: B
j ate: 0D%CP%DDk
SF : m ES_m OOj I
AeMsion: 0DDp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow					XFMR
yj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	yj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S _%f	1BICDD	0DDTkI	NI	E	D	DDDB	DDDB	3 V U1 S _%f	BNGB	fDkB	5NB	N0IW	
								LV U1 S _%0	%B5B	%DGI	BBW	N'D	
								JU%/0	N5N5	BI 55	0kNI	N0'B	
								3 V U1 S _%0	%BNBW	%TDI	5NIW	N0'B	
3 V U1 S _%I	1BICDD	0DDTENB	NB	E	D	DDDB	DDDB	3 V U1 S _%N	%TkI	%DI 5	BGD	NDN	
								LV U1 S _%f	%B5B	%DGI	BBK	N'D	
								5N 16	fKDDW	OfTDk	BN'5	N0'D	
								3 V U1 S _%5	%BWk	%DTGN	B5T'	NDN	
3 V U1 S _%B	1BICDD	0DDBNW	ND	E	D	DDDB	DDDB	LV U1 S _%I	%B5B	%DGI	BBW	N'D	
								3 V U1 S _%G	fTkN	0TBk	BB5	N'D	
3 V U1 S _%G	1BICDD	0DDTB'B	ND	E	D	DDDB	DDDB	LV U1 S _%B	%B5I	%DGD	BBN	N'D	
								5N 06	fBICk0	00TDW	BCKk	ND5	
3 V U1 S _%W	1BICDD	0DDTNG	NG	E	D	DDDB	DDDB	3 V U1 S _%D	%NIW0B	%DkD	1VD5	NDIW	
								3 V U1 S _%B	%Tk5	%DSN	BGD	N0'G	
								LV U1 S _%G	%B5I	%DGD	BBN	N'D	
								3 V U1 S _%k	fT5D	0TGD	BBB	N'D	
3 V U1 S _%k	1BICDD	0DDTB'5	NG	E	D	DDDB	DDDB	LV U1 S _%W	%B5B	%DGI	BBB	N'D	
								3 V U1 S _%W	%Tk5	%DS5	BBW	N0'W	
3 V U1 S _%5	1BICDD	0DDT0B	NG	E	D	DDDB	DDDB	3 V U1 S _%5	BNGk	fD1k	5ND	N0'5	
								LV U1 S _%k	%B5B	%DGI	BBG	N'D	
								3 V U1 S _%I	fBNW	00DWG	BKkT'	N0'D	
								3 V U1 S _%k	%BNk	%Dkf	5NI'	N0'W	
3 V U1 S _%N	1BICDD	0DDTDD	NI	E	D	DDDB	DDDB	3 V U1 S _%I	%kT1k	%NBB	101TG	ND5	
								LV U1 S _%5	%B5B	%DGI	BBW	N'D	
								3 V U1 S _%f	fTkN	0DBN	BBG	N'D	
								LV U1 S _%N	%B5B	%DGI	BBW	N'D	
3 V U1 S _%0	1BICDD	0DDTkD	NW	E	D	DDDB	DDDB	3 V U1 S _%f	fT5D	0DGD	BBD	N'D	
								LV U1 S _%0	%B5B	%DGG	BBT'	N'D	
3 V U1 S _%f	1BICDD	0DDT5ND	NW	E	D	DDDB	DDDB	3 V U1 S _%0	%Tkf	%DWB	BBN	NDG	
								3 V U1 S _%I	BNG'	fT0B	5ND	N0'T	
3 V U1 S _%I	1BICDD	0DDTB'5	NW	E	D	DDDB	DDDB	LV U1 S _%f	%B5B	%DGB	BBT'	N'D	
								3 V U1 S _%5	0kTNW	kRkGB	100'5	N0'T	
								3 V U1 S _%f	%BNB	%TB0	5NI	N0'D	
								3 V U1 S _%B	%5kf	%BW	0k5T'	N0'D	
3 V U1 S _%B	1BICDD	0DDTN 0	NW	E	D	DDDB	DDDB	LV U1 S _%I	%B5B	%DGB	BBB	N'D	
								3 V U1 S _%I	N5ND	BBfG	0kkTN	N0'T	
								3 V U1 S _%W	%BN N	%TDD	55'5	N0'T	
								3 V U1 S _%N	%Tkf	%DkB	BBN	NDI	
								LV U1 S _%B	%B5B	%DGB	BBT'	N'D	

Project: F m OH m vF j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
- ilena2 e: F m 7OH

ETAP
0WDEC

Study Case: NGP1_NGL6.

Page: G
j ate: 0D%CP%Dk
SF: m ES_m OOj l
AeMsion: 0DDp . EF
Con&gT F or2 al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
vj	9V	p 3 agT	6 ngT	3 m	3 Mr	3 m	3 Mr	vj	3 m	3 Mr	6 2 4	p P-	p _a4
3 V U1 S _%W	1BICDD	0DfT5k	NW	E	D	DIDB	DIDB	3 V U1 S _%B	BNG5	fTD10	55T	N0N	
								3 V U1 S _%k	%Tk5	%D5D	BBT	N0K	
								LV U1 S _%W	%TSB	%DGG	BBT	NTD	
3 V U1 S _%k	1BICDD	0DfTGW	NW	E	D	DIDB	DIDB	3 V U1 S _%W	fT5D	0DGT	BBD	NTD	
								LV U1 S _%k	%TSB	%DGW	BBD	NTD	
3 V U1 S _%N	1BICDD	0DfT1k	NW	E	D	DIDB	DIDB	3 V U1 S _%B	fT5D	0DGD	BBD	NTD	
								LV U1 S _%N	%TSB	%DGG	BBT	NTD	
3 V U1 S _%D	1BICDD	0DfTBN	NN	E	D	DIDB	DIDB	5N B6	fBN05	00Tki	BBTK	NDN	
								3 V U1 S _%BW	%fD1N	%Dff0	1N5K	ND5	
								LV U1 S _%D	%TSB	%DGG	BBD	NTD	
3 V U1 S _%D	1BICDD	0DfTNB	DD	E	D	DIDB	DIDB	JU%B0	fT5D	0DGB	BTW	NTD	
								LV U1 S _%D	%TSB	%DGS	BTK	NTD	
3 V U1 S _%Bf	1BICDD	0DfTfi	DD	E	D	DIDB	DIDB	JU%B0	N5k5	BBW	0kGW	N0D	
								3 V U1 S _%BN	%TN5	%BDN	010N	ND5	
								LV U1 S _%Bf	%TSB	%DGS	BTK	NTD	
3 V U1 S _%Bf	1BICDD	0DfTNf	DD	E	D	DIDB	DIDB	JU%B0	fT5D	0DGB	BTW	NTD	
								LV U1 S _%Bf	%TSB	%DGS	BTK	NTD	
3 V U1 S _%BB	1BICDD	0DfTIB	DD	E	D	DIDB	DIDB	JU%B0	%BKNk	%Wk15	fVBD	N0D	
								3 V U1 S _%BG	0kTkk	kKN0	1Dk5	N0T	
								LV U1 S _%BB	%TSB	%DGk	BTN	NTD	
3 V U1 S _%BG	1BICDD	0DfTfB	DD	E	D	DIDB	DIDB	3 V U1 S _%BB	%kTBN	%f5N	1D5K	NDN	
								3 V U1 S _%BW	0NrFN	5TNBf	1GTG	N0D	
								LV U1 S _%BG	%TSB	%DGk	BTN	NTD	
3 V U1 S _%BW	1BICDD	0DfTBN	NN	E	D	DIDB	DIDB	3 V U1 S _%D	fTDkD	0DD15	1Nk5	NDN	
								3 V U1 S _%BG	%NWN	%ND5W	1GTN	ND5	
								LV U1 S _%BW	%TSB	%DGW	BBD	NTD	
3 V U1 S _%B5	1BICDD	0DfTNW	DD	E	D	DIDB	DIDB	3 V U1 S _%BN	fT5D	0DGW	BTB	NTD	
								LV U1 S _%B5	%TSB	%DWD	BTG	NTD	
3 V U1 S _%BN	1BICDD	0DfTBG	DD	E	D	DIDB	DIDB	3 V U1 S _%Bf	kBTG	1TBT	01DK	N0K	
								3 V U1 S _%B5	%Tk5	%DNB	BTW	N0G	
								3 V U1 S _%GD	%Tk5	%DN	BTW	N0G	
								LV U1 S _%BN	%TSB	%DGN	BTG	NTD	
3 V U1 S _%GD	1BICDD	0DfTN1	DD	E	D	DIDB	DIDB	3 V U1 S _%BN	fT5D	0DGW	BTB	NTD	
								LV U1 S _%GD	%TSB	%DWD	BTG	NTD	
* POv	015TDD	NGIDD	DD	%DfD1G	%lTD0	E	E	5N_06	%DfD1G	%lTD0	Bk1B	NGD	
3 P_~I	01f5DD	0DDWNS	N5	E	D	E	E	HV U1 S 3 P_	DDDD	DDDD	DD	DD	
								& 5N_0U					

* indicates a Moltage regulated bus (Moltage controlled or swing ty4e 2 achine connected to it)
indicates a bus with a load 2 is2 atch o82 ore than DD 3 V6

Project: Fm OH m Fj
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File name: Fm2OH

ETAP
NOTICE

Study Case: NGLP6 . 1L0 W

Page: N
Date: NAGIVGN
Sheet: mES_mOOj P
Revision: NGM WEF
Config: For- al

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow					XFMR	
B	8V	M 9 agD	0 ngD	9 m	9 Ar	9 m	9 Ar	B	9 m	9 Ar	0 - 3	MPI	M_a3	
4.1N0	5BDGG	. . D. 5	. DN	C	G	C	C	9 V U6 S _v4	vBDG	vND%G	BBD	. GD		
								4. _NU	vBDG	ND%G	BBD	. GD		
4.1%0	5BDGG	. . D. 5	. DN	C	G	C	C	JUV%N	v4Df%	vN44B	B . D	. GD		
								4. _NU	v4Df%	N44B	B . D	. GD		
4.150	5BDGG	. . D. 5	. DN	C	G	C	C	9 V U6 S _v5	v4DN	vN4NN	B . D	. GD		
								4. _NU	v4DN	N4NN	B . D	. GD		
4.1B0	5BDGG	. . D. 5	. DN	C	G	C	C	9 V U6 S _vBG	v4B5	vN44T	BTD	4. D%		
								4. _NU	v4B5	N44T	BTD	4. D%		
4. _N0	N54BGG	NGLBGG	GB	C	G	C	C	POR	N4B5	55D4B	B4D%	. 1B		
								HV U6 S 9 P_	vN4B5	v55D4B	B4D%	. 1B		
4. _NU	5BDGG	. . D. 5	. DN	C	G	GBGG	v5Df1	4.1B0	v4B5	vN44T	BTD	4. D%		
								4.150	v4DN	vN4NN	B . D	. GD		
								4.1%0	v4Df%	vN44B	B . D	. GD		
								4.1N0	vBDG	vND%G	BBD	. GD		
								9 P_~5	N4B5	15BTT	N 5. D	44B		
								& HV U6 S 9 P_						
HV U6 S 9 P_	N54BGG	NGLBGG	GB	C	G	GBL	GBN5	4. _N0	N4B5	55D4B	B4D%	. 1B		
								4. _NU	vN4B5	v55D4B	B4D%	. 1B		N5D4
								& 9 P_~5						
JUV%N	5BDGG	NGBfG	. B	C	G	C	C	9 V U6 S _vN	vN45N	vB. N	5NBB	. GD		
								9 V U6 S _v%	v. BTD	vB44T	N4B	. NB		
								4.1%0	v4B. T	N45fT	B. TD	. NB		
JUVBN	5BDGG	N4D1.	N4B%	C	G	C	C	9 V U6 S _vBN	vB4	vNB. B	BBD	. ND		
								9 V U6 S _vB%	v. BfT	vB. f	NfTD	. NB		
								9 V U6 S _vB5	vB4	vNB. 5	BBD	. ND		
								9 V U6 S _vBB	NB5%	TD45	vBBD	. NB%		
LV U6 S _vGN	GD. G	NGBDGI	NB%	%DGG	NBNG	C	C	9 V U6 S _vGN	%DGG	NBNG	%NB B	. GB		
LV U6 S _vC%	GD. G	NGB4.	NB%	%DGG	NBNG	C	C	9 V U6 S _vC%	%DGG	NBNG	%NB B	. GB		
LV U6 S _vC5	GD. G	NGB. %	NB%	%DGG	NBNG	C	C	9 V U6 S _vC5	%DGG	NBNG	%B4B	. GB		
LV U6 S _vCB	GD. G	NGBB. G	NB%	%DGG	NBNG	C	C	9 V U6 S _vCB	%DGG	NBNG	%B4B	. GB		
LV U6 S _vGI	GD. G	NGB5f	NB%	%DGG	NBNG	C	C	9 V U6 S _vGI	%DGG	NBNG	%B. D	. GB		
LV U6 S _vGT	GD. G	NGBB%N	NB%	%DGG	NBNG	C	C	9 V U6 S _vGT	%DGG	NBNG	%B4B	. GB		
LV U6 S _vGf	GD. G	NGBB4	NB%	%DGG	NBNG	C	C	9 V U6 S _vGf	%DGG	NBNG	%B5D	. GB		
LV U6 S _vG4	GD. G	NGBBT	NB%	%DGG	NBNG	C	C	9 V U6 S _vG4	%DGG	NBNG	%B5B	. GB		
LV U6 S _vG	GD. G	NGB4f	NB%	%DGG	NBNG	C	C	9 V U6 S _vG	%DGG	NBNG	%B. B%	. GB		
LV U6 S _vNG	GD. G	NGB5N	NB%	%DGG	NBNG	C	C	9 V U6 S _vNG	%DGG	NBNG	%B4D	. GB		

Project: Fm OH m Fj

Location: Paulding, OH

Contract:

Engineer: Josh Venden

File name: Fm2OH

ETAP

NOTICE

Study Case: NGLP6 . 1L0 W

Page: 5

Project: NGLP6

SF: mES_mOOj P

Revision: NGLM WEF

Config: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	8V	M 9 agD	0 ngD	9 m	9 Aar	9 m	9 Aar	B	9 m	9 Aar	0 - 3	MPI	M_a3
9 V U6 S_vCB	5BDGG	NGN1GN	. 17	C	G	G00CB	G00CB	LV U6 S_vG5	v0004B	vN0015	BE00	. ND	
								9 V U6 S_vG5	v0000B	v500NN	N500B	. N5	
								9 V U6 S_vG1	. 0. B	BE0f G	Nf40N	. ND	
9 V U6 S_vG1	5BDGG	NGN545	. 17	C	G	G00CB	G00CB	LV U6 S_vCB	v0004B	vN0015	BE00	. ND	
								9 V U6 S_vCB	v. 0f%	v500N1	Nf40D	. N5	
								9 V U6 S_vG4	N0051%	100f5	%0000	. ND	
9 V U6 S_vGf	5BDGG	NGN94B	. 1B	C	G	G00CB	G00CB	LV U6 S_vG1	v0004B	vN001%	BE00	. ND	
								9 V U6 S_vGf	%00f.	N0014	BE00	. %00	
								LV U6 S_vGf	v0004B	vN001%	BE00	. ND	
9 V U6 S_vGf	5BDGG	NGND4.	. 1D	C	G	G00CB	G00CB	9 V U6 S_vGf	v0000f	vN0044	BE00	. ND	
								9 V U6 S_vNf	v00001	vND04B	B100	. ND	
								9 V U6 S_vN1	f005%	500fG	N500	. ND	
9 V U6 S_vG4	5BDGG	NGNDf	. 1D	C	G	G00CB	G00CB	LV U6 S_vGf	v0004B	vN001%	BE00	. ND	
								9 V U6 S_vG1	v00055%	v1011f	%0000	. ND	
								9 V U6 S_vG	N000NN	TDN1	%0040%	. N5	
9 V U6 S_vG	5BDGG	NGCD%N	. 1D	C	G	G00CB	G00CB	LV U6 S_vG4	v0004B	vN001%	BE00	. ND	
								9 V U6 S_vG4	vN000fT	vTD04	%0. DN	. ND	
								9 V U6 S_vNG	Nf0041	f00T1	5N50	. ND	
9 V U6 S_vNG	5BDGG	NGCDTN	. 1D	C	G	G00CB	G00CB	LV U6 S_vG	v0004B	vN001N	BE00	. %00	
								9 V U6 S_vG	vNf005	v0055	5N00	. ND	
								9 V U6 S_v04	N. 00N5	40. G	51. 0%	. ND	
9 V U6 S_vN5	5BDGG	NGN0B	. 1B	C	G	G00CB	G00CB	LV U6 S_vNG	v00045	vN001N	BE00	. %00	
								9 V U6 S_vNB	%00f.	N001.	BE00	. %00	
								LV U6 S_vN5	v0004B	vN0015	BE00	. ND	
9 V U6 S_vNB	5BDGG	NGN0Tf	. 1B	C	G	G00CB	G00CB	9 V U6 S_vN5	v0000f	vN00. N	BE00	. ND	
								9 V U6 S_vN1	ED1f	%001G	4. 0%	. ND	
								LV U6 S_vNB	v0004B	vN001%	BE00	. ND	
9 V U6 S_vN1	5BDGG	NGCD14	. 1D	C	G	G00CB	G00CB	9 V U6 S_vGf	v0000N1	v50054	N500	. ND	
								9 V U6 S_vNB	vED51	v0000f	4. 0%	. ND	
								9 V U6 S_vNf	N000%	TD0%	%0. 0%	. N5	
9 V U6 S_vNf	5BDGG	NGN011	. 1B	C	G	G00CB	G00CB	LV U6 S_vN1	v0004B	vN001N	BE00	. %00	
								9 V U6 S_vGf	%00f.	N001.	BE00	. %00	
								LV U6 S_vNf	v0004B	vN001%	BE00	. ND	
9 V U6 S_v0G	5BDGG	NGCDfB	. 1B	C	G	G00CB	G00CB	JU00N	Nf004.	f00GT	5N10%	. ND	
								9 V U6 S_vN1	vN0004G	vTD0B	%000	. ND	
								LV U6 S_vNf	v00045	vN001G	BE00	. %00	
9 V U6 S_v0N	5BDGG	NGN0BT	. 1B	C	G	G00CB	G00CB	9 V U6 S_v0N	%00f.	N0014	BE00	. %00	
								LV U6 S_v0G	v0004B	vN001%	BE00	. %00	
								9 V U6 S_v0G	v0000B	vND55	B10%	. CD	

Project: F m OH m F j
Location: Paulding, OH
Contract:
Engineer: Josh Venden
I l l ena- e: F m 2OH

ETAP
N11010C
Study Case: NGLP6 . 1L0 W

Page: B
j ate: NGGIV%GN
SF : m ES_m OOj P
keAision: NGM WEF
ConpigD F or- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	8V	M 9 agD	0 ngD	9 m	9 Aar	9 m	9 Aar	B	9 m	9 Aar	0 - 3	MPI	M_a3
9 V U6 S _v%%	5BD CG	NGGT .	. B	G	G	G0CB	G0CB	9 V U6 S _v%%	BD1B	%D G	4. D	. ND	
								LV U6 S _v%N	v%DB45	vN0HTN	BE0	. %40	
								JUV%N	. B. 4	BD0%N	N4CP%	. N5	
								9 V U6 S _v%N	vEDB1	v%DN	. GN	. N9%	
9 V U6 S _v%	5BD CG	NGCB%	. D	G	G	G0CB	G0CB	9 V U6 S _v%	v%DB45	vNDB1	BI B	. CB	
								LV U6 S _v%%	v%DB45	vN0HTN	BE0	. %40	
								4. I 50	%DDB	N% B	B. 1B%	. CD	
								9 V U6 S _v%4	v%DB4B	vNDB5f	BI CB	. CB	
9 V U6 S _v%B	5BD CG	NGCB% G	. B%	G	G	G0CB	G0CB	LV U6 S _v%	v%DB45	vN0HTN	BE0	. %40	
								9 V U6 S _v%4	%DB4.	N0B. 1	BI B%	. %40	
								LV U6 S _v%B	v%DB45	vN0B.	BI DN	. %40	
								4. I N0	%BD T4	NNB4%	BI %D	. CB	
9 V U6 S _v%T	5BD CG	NGND%5	. D	G	G	G0CB	G0CB	9 V U6 S _vNG	vN DNN	v. B%	5T%4	. CD	
								9 V U6 S _v%B	v%DB44	vN0B. f	BI B	. NB	
								LV U6 S _v%4	v%DB45	vN0B.	BI B%	. %40	
								9 V U6 S _v%B	%DB4.	N0B. 4	BE0	. %40	
9 V U6 S _v%4	5BD CG	NGND%4	. D	G	G	G0CB	G0CB	LV U6 S _v%T	v%DB4B	vN0HT%	BE0	. ND	
								9 V U6 S _v%4	v%DB4f	vN0B. T	BE0	. NB	
								9 V U6 S _v%4	BD1T	%DN B	4. B	. NB	
								LV U6 S _v%4	v%DB4B	vN0HT%	BE0	. ND	
9 V U6 S _v%4	5BD CG	NGCB%	. D	G	G	G0CB	G0CB	9 V U6 S _v%	%BD TN	NNB4B	BB. B	. N0	
								9 V U6 S _v%B	vEDBT	v%DB4.	4. B	. NB	
								9 V U6 S _v55	vN%DB51	vD. 4	5NB B%	. CB	
								LV U6 S _v%4	v%DB4B	vN0HTN	BE0	. %40	
9 V U6 S _v%	5BD CG	NGCB%T	. B	G	G	G0CB	G0CB	9 V U6 S _v%%	%DB4.	N0B. f	BE0	. %40	
								LV U6 S _v%	v%DB4B	vN0HTN	BE0	. %40	
								9 V U6 S _v5%	%DB4G	N0HTG	BE0	. %40	
								LV U6 S _v5N	v%DB4B	vN0HTB	BE0	. ND	
9 V U6 S _v5%	5BD CG	NGND%N	. B	G	G	G0CB	G0CB	9 V U6 S _v5N	v%DB4%	vNDB%	BI DN	. CB	
								9 V U6 S _v55	BD1%	%DB5N	4. D	. N9%	
								LV U6 S _v5%	v%DB4B	vN0HT5	BE0	. ND	
								9 V U6 S _v%4	N%DB	fBN%	5NB B	. ND	
9 V U6 S _v5B	5BD CG	NGNDT%	. B	G	G	G0CB	G0CB	9 V U6 S _v5%	vEDBB	v%DB4f	4. B	. NB	
								9 V U6 S _v5B	v. BfN	vDB. 1	N. B%	. N0	
								LV U6 S _v55	v%DB4B	vN0HT%	BE0	. ND	
								9 V U6 S _v55	. B4.	BD14	N%4B	. N9%	
9 V U6 S _v5T								9 V U6 S _v5T	vED54	v%DBN	4. B%	. N9%	
								9 V U6 S _v5.	v%DB4N	vNDB4%	BI DN	. CB%	
								LV U6 S _v5B	v%DB4B	vN0HT5	BE0	. ND	

Project: Fm OH m Ffj
Location: Paulding, OH
Contract:
Engineer: Josh Venden
File name: Fm2OH

ETAP
NOTICE

Study Case: NGLP6 . 1L0 W

Page: 1
Date: NAGIV/GN
Sheet: mES_mOOj P
Revision: NGM WEF
Config: For- al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
B	8V	M 9 agD	0 ngD	9 m	9 Aar	9 m	9 Aar	B	9 m	9 Aar	0 - 3	MPI	M_a3
9 V U6 S_v5T	5BDGG	NGNDN	. D	C	G	G0CB	G0CB	9 V U6 S_v5B	BD1f	%DB	44B	. N9	
								9 V U6 S_v5f	v%DB4	vN0H4	BBB	. ND	
								LV U6 S_v5T	v%DB4B	vN0H1B	BBB	. ND	
9 V U6 S_v5f	5BDGG	NGND4.	. D	C	G	G0CB	G0CB	9 V U6 S_v5T	%DB4G	N0H1G	BBB%	. ND	
								LV U6 S_v5f	v%DB4B	vN0H1B	BBB	. ND	
9 V U6 S_v5.	5BDGG	NGNDT.	. D	C	G	G0CB	G0CB	9 V U6 S_v5B	%DB4G	N0H1G	BBB	. %40	
								LV U6 S_v5.	v%DB4B	vN0H1B	BBB	. ND	
9 V U6 S_vBG	5BDGG	NGND4%	NCB	C	G	G0CB	G0CB	4.1B0	%BD1N	NB31N	BBB9	. CB	
								9 V U6 S_vBT	v%DB5T	vN0H%N	BCCF	. CB	
								LV U6 S_vBG	v%DB4B	vN0H1B	BBB	. ND	
9 V U6 S_vBN	5BDGG	NCBDB5	NCB%	C	G	G0CB	G0CB	JUvBN	%DB4G	N0H15	B5B	. ND	
								LV U6 S_vBN	v%DB4B	vN0H1f	B5D	. ND	
9 V U6 S_vB%	5BDGG	NCBDBT5	NCB%	C	G	G0CB	G0CB	JUvBN	. Bff	BDB T	NfTB	. N0	
								9 V U6 S_vB	vfB. f	v5DB55	N5%D	. CB	
								LV U6 S_vB%	v%DB4B	vN0H1f	B5D	. ND	
9 V U6 S_vB5	5BDGG	NCBDB5N	NCB%	C	G	G0CB	G0CB	JUvBN	%DB4G	N0H15	B5B	. ND	
								LV U6 S_vB5	v%DB4B	vN0H1f	B5D	. ND	
9 V U6 S_vBB	5BDGG	NCBDBT%	NCB%	C	G	G0CB	G0CB	JUvBN	vNB0. T	vTB4T	%TB1B	. CB	
								9 V U6 S_vBI	NfDB4T	fBB	5GB	. N0	
								LV U6 S_vBB	v%DB4B	vN0H1T	BBB	. ND	
9 V U6 S_vBI	5BDGG	NCBDBTG	NCB%	C	G	G0CB	G0CB	9 V U6 S_vBB	vNfDB4f	vfDB1	5NCB	. CB	
								9 V U6 S_vBT	NfB%	. BCB	51B0%	. N0	
								LV U6 S_vBI	v%DB4B	vN0H11	BBB	. ND	
9 V U6 S_vBT	5BDGG	NCBDB4B	NCB%	C	G	G0CB	G0CB	9 V U6 S_vBG	%DB4G	N0H1G	5. . B	. CB	
								9 V U6 S_vBI	vNfDB44	v. DB	511D	. CB	
								LV U6 S_vBT	v%DB4B	vN0H11	BBB	. ND	
9 V U6 S_vB4	5BDGG	NCBDBf4	NCB%	C	G	G0CB	G0CB	9 V U6 S_vB	%DB4G	N0H1B	B5B	. ND	
								LV U6 S_vB4	v%DB4B	vN0H14	B5B	. ND	
9 V U6 S_vB	5BDGG	NCBDB4f	NCB%	C	G	G0CB	G0CB	9 V U6 S_vB%	fDB51	5B44	N5NB	. ND	
								9 V U6 S_vB4	v%DB4	vN0H5	B5D	. NB	
								9 V U6 S_v1G	v%DB4	vN0CN	B5B	. NB	
								LV U6 S_vB	v%DB4B	vN0H14	B5B	. ND	
9 V U6 S_v1G	5BDGG	NCBDBf1	NCB%	C	G	G0CB	G0CB	9 V U6 S_vB	%DB4G	N0H1B	B5B	. ND	
								LV U6 S_v1G	v%DB4B	vN0H14	B5B	. ND	
* POR	N54BGG	NG1BGG	CB	vN0B0CN	v55DfN	C	C	4. _ND	vN0B0CN	v55DfN	B/4B%	. 1B%	
9 P_~5	N5BGG	NCB%B	. D	C	G	C	C	HV U6 S 9 P_	G0CG	G0CG	CB	CB	
								& 4. _NU					

* B indicates a Aoltage regulated bus (Aoltage controlled or swing ty3e - achine connected to it)
B indicates a bus with a load - is- atch op- ore than CB9 V0

Project: Farm OH m 7F0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project Name: Farm - OH

ETAP

NEW

Study Case: NPG 16LE_0

Page: N

Date: 12/27/2023

Sheet: m ES_m 000 P

Revision: NDA MEF

Configuration: For all

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	8V	A 9 agT	. ngT	9 m	9 kar	9 m	9 kar	70	9 m	9 kar	. I 3	APj	A_a3
41j N	5B6DD	11T1W	4F	E	D	E	E	9 V UGS_R6	R/B6W	B64N	B64%	R4B	
								41_NU	vB6W	B64N	B64%	R4B	
41j v.	5B6DD	11T1W	4F	E	D	E	E	JUR/N	R/%D5	B11D	B61T	R4B	
								41_NU	v/%D5	B11D	B61T	R4B	
41j 5.	5B6DD	11T1W	4F	E	D	E	E	9 V UGS_R5	R/V146	B64W	B64T%	R4B	
								41_NU	v/V146	B64W	B64T%	R4B	
41j B	5B6DD	11T1W	4F	E	D	E	E	9 V UGS_RB	R/B65%	5TW	BNNH	R4T	
								41_NU	vB65%	5TW	BNNH	R4T	
41_N	N64DD	11T1W	DD	E	D	E	E	PO7	N/VB4	B56N6	B6NN	R6D	
								HV UGS 9 P_	R/VB4	556N6	B6NN	R6D	
41_NU	5B6DD	11T1W	4F	E	D	E	E	41j B	R/B65%	5TW	BNNH	R4T	
								41j 5.	R/V146	B64W	B64T%	R4B	
								41j v.	R/%D5	B11D	B61T	R4B	
								41j N	R/B6W	B64N	B64%	R4B	
								9 P_~5	N/V1vD	R64W	N64T	R4TW	
								& HV UGS 9 P_					
HV UGS 9 P_	N64DD	11T1W	DD	E	D	DD65	DNB%	41_N	N/VB4	B56N6	B6NN	R6D	
								41_NU	R/V65v	556W%	B6NN	R6N	B6N6
								& 9 P_~5					
JUR/N	5B6DD	NDWv6	4T%	E	D	E	E	9 V UGS_R%	R/%WD	5TW	v156	R4B	
								9 V UGS_Rv	R/T4	N64%	NW4I	R4B	
								41j v.	v/%61	B6NB	BNNH	R4B	
JUR/N	5B6DD	NN6W	NDW	E	D	E	E	9 V UGS_RN	R/B4D	D6D6	BNNH	R4D	
								9 V UGS_RBv	R/T4%	N11D	NW4W	R4B	
								9 V UGS_RB5	R/B4D	D6D6	BNNH	R4D	
								9 V UGS_RBB	NBHW	R/TND	vB1T	R4TN	
LV UGS_RN	DWD	ND1W	N6F	v6DD	R6DD	E	E	9 V UGS_RN	v6DD	R6DD	vD146	R4T%	
LV UGS_RDv	DWD	NDH6W	N6F	v6DD	R6DD	E	E	9 V UGS_RDv	v6DD	R6DD	vND6	R4T%	
LV UGS_RD5	DWD	NDW4W	N6F	v6DD	R6DD	E	E	9 V UGS_RD5	v6DD	R6DD	vNB6v	R4T%	
LV UGS_RBB	DWD	ND6W	N6F	v6DD	R6DD	E	E	9 V UGS_RBB	v6DD	R6DD	vNDW	R4T%	
LV UGS_RD6	DWD	ND61N	N6F	v6DD	R6DD	E	E	9 V UGS_RD6	v6DD	R6DD	vNDW	R4T%	
LV UGS_RDW	DWD	NDEN	N6T	v6DD	R6DD	E	E	9 V UGS_RDW	v6DD	R6DD	vND1W	R4T%	
LV UGS_RD%	DWD	ND66v	N6D	v6DD	R6DD	E	E	9 V UGS_RD%	v6DD	R6DD	vNND	R4T%	
LV UGS_RD4	DWD	NDW4W	N6T	v6DD	R6DD	E	E	9 V UGS_RD4	v6DD	R6DD	vNN4W	R4T%	
LV UGS_RDI	DWD	NDND%	N6D	v6DD	R6DD	E	E	9 V UGS_RDI	v6DD	R6DD	vNNW	R4T%	
LV UGS_RND	DWD	NDDv	NNI	v6DD	R6DD	E	E	9 V UGS_RND	v6DD	R6DD	vNN4D	R4T%	

Project: F m OH m 7F 0

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project Name: F m - OH

ETAP

Model

Study Case: NPG 16LE. 0

Page: v

Date: 10/24/2023

Sheet: m ES_m 000 P

Description: NDA MEF

Configuration: For all

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	8V	A 9 agT	. ngT	9 m	9 kar	9 m	9 kar	70	9 m	9 kar	. I 3	APj	A_a3
LV UGS_R5	DWDD	NDDW6	N/TN	v6DD	ROBDD	L	L	9 V UGS_R5	v6DD	ROBDD	vND6T%	R4T%	
LV UGS_RB	DWDD	NDD655	N/TN	v6DD	ROBDD	L	L	9 V UGS_RB	v6DD	ROBDD	vND6W%	R4T%	
LV UGS_R6	DWDD	NDDN6	N/D	v6DD	ROBDD	L	L	9 V UGS_R6	v6DD	ROBDD	vNNDH	R4T%	
LV UGS_RW	DWDD	NDD611	N/TN	v6DD	ROBDD	L	L	9 V UGS_RW	v6DD	ROBDD	vND6H	R4T%	
LV UGS_R%	DWDD	11T56	NNH	v6DD	ROBDD	L	L	9 V UGS_R%	v6DD	ROBDD	vNN1T	R4T%	
LV UGS_RD	DWDD	NDD61v	NNH	v6DD	ROBDD	L	L	9 V UGS_RD	v6DD	ROBDD	vND6W	R4T%	
LV UGS_RN	DWDD	NDD6vv	NNH	v6DD	ROBDD	L	L	9 V UGS_RN	v6DD	ROBDD	vN65T	R4T%	
LV UGS_Rv	DWDD	NDD646	NNH	v6DD	ROBDD	L	L	9 V UGS_Rv	v6DD	ROBDD	vNNDW	R4T%	
LV UGS_R5	DWDD	11T1W	NNH	v6DD	ROBDD	L	L	9 V UGS_R5	v6DD	ROBDD	vNN1T	R4T%	
LV UGS_RB	DWDD	11T4N	NNW	v6DD	ROBDD	L	L	9 V UGS_RB	v6DD	ROBDD	vN6BD	R4T%	
LV UGS_R6	DWDD	11T46	NN6	v6DD	ROBDD	L	L	9 V UGS_R6	v6DD	ROBDD	vN6BT%	R4T%	
LV UGS_RW	DWDD	NDD61%	N/TN	v6DD	ROBDD	L	L	9 V UGS_RW	v6DD	ROBDD	vN6T	R4T%	
LV UGS_R%	DWDD	NDD6Nv	N/TN	v6DD	ROBDD	L	L	9 V UGS_R%	v6DD	ROBDD	vN6BD	R4T%	
LV UGS_R4	DWDD	NDD6B4	N/TN	v6DD	ROBDD	L	L	9 V UGS_R4	v6DD	ROBDD	vNND6B	R4T%	
LV UGS_R1	DWDD	NDD64W	NNH	v6DD	ROBDD	L	L	9 V UGS_R1	v6DD	ROBDD	vNND6B	R4T%	
LV UGS_RN	DWDD	NDD66B	N/6	v6DD	ROBDD	L	L	9 V UGS_RN	v6DD	ROBDD	vN6BT%	R4T%	
LV UGS_Rv	DWDD	NDD66B	N/6	v6DD	ROBDD	L	L	9 V UGS_Rv	v6DD	ROBDD	vND1T	R4T%	
LV UGS_R5	DWDD	NDD6%4	N/6	v6DD	ROBDD	L	L	9 V UGS_R5	v6DD	ROBDD	vNND6W	R4T%	
LV UGS_RB	DWDD	NDD6v	N/6	v6DD	ROBDD	L	L	9 V UGS_RB	v6DD	ROBDD	vND1T	R4T%	
LV UGS_RW	DWDD	NDD6%1	N/6	v6DD	ROBDD	L	L	9 V UGS_RW	v6DD	ROBDD	vND1T	R4T%	
LV UGS_R%	DWDD	NDD6HN	N/6	v6DD	ROBDD	L	L	9 V UGS_R%	v6DD	ROBDD	vNND6W	R4T%	
LV UGS_R1	DWDD	NDD66	N/6	v6DD	ROBDD	L	L	9 V UGS_R1	v6DD	ROBDD	vND6T	R4T%	
LV UGS_RD	DWDD	NDD6W	N/6W	v6DD	ROBDD	L	L	9 V UGS_RD	v6DD	ROBDD	vND6W	R4T%	
LV UGS_RN	DWDD	NND661	N6TN	v6DD	ROBDD	L	L	9 V UGS_RN	v6DD	ROBDD	vD1W%	R4T%	
LV UGS_Rv	DWDD	NDD1%W	N6TN	v6DD	ROBDD	L	L	9 V UGS_Rv	v6DD	ROBDD	vD14T	R4T%	
LV UGS_R5	DWDD	NND66%	N6TN	v6DD	ROBDD	L	L	9 V UGS_R5	v6DD	ROBDD	vD1W%	R4T%	
LV UGS_RB	DWDD	NDD64B	N6TD	v6DD	ROBDD	L	L	9 V UGS_RB	v6DD	ROBDD	vNNDH	R4T%	
LV UGS_R6	DWDD	NDD6Wv	N/6	v6DD	ROBDD	L	L	9 V UGS_R6	v6DD	ROBDD	vN6BN	R4T%	
LV UGS_RW	DWDD	NDD664	N/6	v6DD	ROBDD	L	L	9 V UGS_RW	v6DD	ROBDD	vND6W%	R4T%	
LV UGS_R4	DWDD	NND66%	N66	v6DD	ROBDD	L	L	9 V UGS_R4	v6DD	ROBDD	vD14T%	R4T%	
LV UGS_R1	DWDD	NND661N	N6T	v6DD	ROBDD	L	L	9 V UGS_R1	v6DD	ROBDD	vD11B	R4T%	
LV UGS_RD	DWDD	NND664D	N66	v6DD	ROBDD	L	L	9 V UGS_RD	v6DD	ROBDD	vD14T%	R4T%	
9 V UGS_RN	5B6DD	NND66D	1B	L	D	DDB	DDB	9 V UGS_RDv	vB4N	DB5B	BNH	R4T%	
								LV UGS_RN	R/B4W	DB5N	BvTD	R4T%	
9 V UGS_RDv	5B6DD	NND66B	16	L	D	DDB	DDB	9 V UGS_RN	R/B4	DB4%	BNH	R4TN	
								9 V UGS_R6	B11W	RNDv	45T%	R4H	
								LV UGS_RDv	R/B46	DB5N	BvTD	R4T%	
9 V UGS_R6	5B6DD	NND6W%	16	L	D	DDB	DDB	9 V UGS_RDv	RB16D	D145	45TW	R4TN	
								9 V UGS_RB	%65v	R66N	Nv6TW	R4TD	

Project: Fm OH m 70

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project Name: Fm - OH

ETAP

Model

Study Case: NPG 16LE. 0

Page: 5

Location: NDRW/DN%

SF: m ES_m 000 P

File Name: NDA MEF

Configuration: Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	8V	A 9 agT	. ngT	9 m	9 kar	9 m	9 kar	70	9 m	9 kar	. I 3	APj	A_a3
9 V UGS _RB	5B6DD	NDDI65	1T	E	D	DDB	DDB	LV UGS _R5	R/B46	D65N	Bv/N	R%4	
								9 V UGS _R5	R/B4v	NB%6	Nv6B	R4TN	
								9 V UGS _R6	1TD5	R/DN	NW%6	R4TD	
9 V UGS _R6	5B6DD	NDDI45	1T	E	D	DDB	DDB	LV UGS _RB	R/B46	D65v	Bv/N	R%4	
								9 V UGS _RB	R/B4B	NIIW	NW%6	R4TN	
								9 V UGS _RD	NvFW	R/DN	vDI T	R4TD	
9 V UGS _RDW	5B6DD	NDDHNN	1TN	E	D	DDB	DDB	LV UGS _R6	R/B46	D65v	Bv/T	R%4	
								9 V UGS _R%	vB4N	RD65W	Bv/N	R%4%	
								LV UGS _RDW	R/B46	D65v	Bv/T	R%4	
9 V UGS _R%	5B6DD	NDDI46	1TD	E	D	DDB	DDB	9 V UGS _RDW	R/B4	D6D%	Bv/D	R4TD	
								9 V UGS _RW	R/B4%	DB%N	BNII	R4TV	
								9 V UGS _R6	%B54	RN6N	NvWN	R4TD	
9 V UGS _RD	5B6DD	NDDIWD	1TN	E	D	DDB	DDB	LV UGS _R%	R/B46	D65v	Bv/T	R%4	
								9 V UGS _R6	RvTB4	vBN%	vDI T	R4TN	
								9 V UGS _RD	NB4v1	R/II65	v6NB	R4TN	
9 V UGS _RD	5B6DD	NDD6DN	1TD	E	D	DDB	DDB	LV UGS _RD	R/B46	D65v	Bv/T	R%4	
								9 V UGS _RD	RNB41	vH64	v6ND	R4TV	
								9 V UGS _RD	Nv4D	BT16	v15T	R4TN	
9 V UGS _RD	5B6DD	NDDEN4	4TI	E	D	DDB	DDB	LV UGS _RD	R/B46	D655	Bv/T	R%4	
								9 V UGS _RD	Rv4WN	5TvB	v1vTI	R4TV	
								9 V UGS _R6	NIT4v	BT4WD	556T	R4TN	
9 V UGS _R5	5B6DD	NDDI1W	1TN	E	D	DDB	DDB	LV UGS _RD	R/B46	D655	Bv/T	R%4	
								9 V UGS _RB	vB4N	RD656	Bv/N	R%4	
								LV UGS _R5	R/B46	D65v	Bv/N	R%4	
9 V UGS _RB	5B6DD	NDDIvB	1TN	E	D	DDB	DDB	9 V UGS _R5	R/B4	D6D5	BNII	R4TD	
								9 V UGS _R6	BIIWN	RND61	4BD	R%4I	
								LV UGS _RB	R/B46	D65v	Bv/N	R%4	
9 V UGS _R6	5B6DD	NDD6WW	1TD	E	D	DDB	DDB	9 V UGS _R%	R/B4v5	NBB6	Nv6H	R4TV	
								9 V UGS _RB	RBII BN	DIIW	45H	R4TV	
								9 V UGS _R%	NBHB6	R/II BB	v6NH	R4TN	
9 V UGS _RW	5B6DD	NDDH1N	1TN	E	D	DDB	DDB	LV UGS _R6	R/B46	D655	Bv/T	R%4	
								9 V UGS _R%	vB4N	RD65W	Bv/N	R%4%	
								LV UGS _RW	R/B46	D65v	Bv/T	R%4	
9 V UGS _R%	5B6DD	NDD65N	4H	E	D	DDB	DDB	JURvN	Nv4B	BT5BI	v15TW	R4TV	
								9 V UGS _R6	RNBID5	vHNv	v6N5	R4TV	
								LV UGS _R%	R/B46	D655	Bv/T	R%4	
9 V UGS _RD	5B6DD	NDDI46	4TI	E	D	DDB	DDB	9 V UGS _RN	vB4N	RD65W	Bv/N	R%4%	
								LV UGS _RD	R/B46	D65v	Bv/T	R%4	
								9 V UGS _RD	R/B4%	DBWN	BNII	R4TV	

Project: F m OH m 70

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project Name: F m - OH

ETAP

NWDEC

Study Case: NPG 16LE. 0

Page: B

Date: 12/20/2023

Sheet: m ES_m 000 P

File Name: NDA MEF

Configuration: For Final

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	8V	A 9 agT	. ngT	9 m	9 kar	9 m	9 kar	70	9 m	9 kar	. I 3	APj	A_a3
9 V UGS _Rv	5B6DD	NDD64D	4T	E	D	DDB	DDB	9 V UGS _Rv	B1164	R111%	4BN	R4D	
								LV UGS _RN	R1B46	D655	BvT	R%4	
								JURvN	11D4	R116B	NW1v	R4TN	
								9 V UGS _RN	R116N	D11W	4BD	R4TN	
9 V UGS _R5	5B6DD	NDD61	4T	E	D	DDB	DDB	9 V UGS _R1	R1B4W	D6B4	BN1	R4B	
								LV UGS _Rv	R1B46	D655	BvT	R%4	
								41j 5.	v1B1B	R1NBD	BW1%	R4B	
								9 V UGS _R4	R1B4W	BW1	BN1B	R4B	
9 V UGS _RB	5B6DD	NDD64	4T	E	D	DDB	DDB	LV UGS _R5	R1B46	D655	BvT	R%4	
								9 V UGS _R6	v1B4N	R1654	BvT	R%4%	
								LV UGS _RB	R1B46	D65B	BvT	R%4	
								41j N	v1B4W	R1656	BN1B	R4B	
9 V UGS _R6	5B6DD	NDD65	4T	E	D	DDB	DDB	9 V UGS _RD	R11W6B	5T1D	555T%	R4B	
								9 V UGS _RB	R1B4D	DB16	BvT	R4TN	
								LV UGS _R6	R1B46	D65B	BvT	R%4	
								9 V UGS _R%	v1B4N	R165W	BvT	R%4%	
9 V UGS _RW	5B6DD	NDDW1D	1TN	E	D	DDB	DDB	LV UGS _RW	R1B46	D65v	BvT	R%4	
								9 V UGS _RW	R1B4	DB11	BvT	R4D	
								9 V UGS _R4	B11WD	R1D6	4B5	R%4	
								LV UGS _R%	R1B46	D655	BvT	R%4	
9 V UGS _R4	5B6DD	NDD65	1TN	E	D	DDB	DDB	9 V UGS _R5	v1B4W	R1B4v	BN1T	R4T	
								9 V UGS _R%	R116N	NDDN	4B1v	R4D	
								9 V UGS _R5	R1B4W	5TN6	v1vB	R4B	
								LV UGS _R4	R1B46	D655	BvT	R%4	
9 V UGS _R1	5B6DD	NDDW1	4T	E	D	DDB	DDB	9 V UGS _Rv	v1B4N	R165W	BvT	R%4%	
								LV UGS _R1	R1B46	D65v	BvT	R%4	
								9 V UGS _R5	v1B4N	R1656	BvT	R%4	
								LV UGS _RN	R1B46	D65N	BvT	R%4	
9 V UGS _R5v	5B6DD	NDD64%	1T	E	D	DDB	DDB	9 V UGS _RN	R1B46	DBv6	BN1%	R4TW	
								9 V UGS _R5	B116W	R11WN	45T	R4T	
								LV UGS _Rv	R1B46	D65v	BvT	R%4	
								9 V UGS _R4	N1B1B	R1T64	v15T	R4T	
9 V UGS _R5	5B6DD	NDDW1N	1T	E	D	DDB	DDB	9 V UGS _Rv	R11B1	D115B	45T%	R4B	
								9 V UGS _RB	R114B	N14%	NW1	R4T	
								LV UGS _R5	R1B46	D65v	BvT	R%4	
								9 V UGS _R5	1T11	R11v6	NW1B	R4T	
9 V UGS _RB	5B6DD	NDD1N6	1T	E	D	DDB	DDB	9 V UGS _R5W	R111B	D11%	45TW	R4TN	
								9 V UGS _R1	R1B4B	DE16	BN1W	R4TW	
								LV UGS _RB	R1B46	D65v	BvT	R%4	

Bus		Voltage		Generation		Load		Load Flow				XFMR	
70	8V	A 9 agT	. ngT	9 m	9 kar	9 m	9 kar	70	9 m	9 kar	. I 3	APj	A_a3
9 V UGS _R5W	5B6DD	NNN41	1B	E	D	DDB	DDB	9 V UGS _R5B	B11W	RDBv	45II	R4II	
								9 V UGS _R5%	R/B4D	D6D%	BNII	R4ID	
								LV UGS _R5W	R/B46	D65N	BvTN	R4%I	
9 V UGS _R5%	5B6DD	NNNIN	1B	E	D	DDB	DDB	9 V UGS _R5W	vB4N	R656	BvTD	R4%I	
								LV UGS _R5%	R/B46	D65N	BvTD	R4%I	
9 V UGS _R5I	5B6DD	NNND46	1B	E	D	DDB	DDB	9 V UGS _R5B	vB4N	R656	BvTD	R4%I	
								LV UGS _R5I	R/B46	D65N	BvTN	R4%I	
9 V UGS _R5D	5B6DD	NDH4WD	1T%	E	D	DDB	DDB	41j B	vB16v	R31W5	BNW	R4T5	
								9 V UGS _R5W	RvT0N	BD44	5%BN	R4T5	
								LV UGS _R5D	R/B46	D65v	BvTV	R4%I	
9 V UGS _R5N	5B6DD	NDN6%	NDW	E	D	DDB	DDB	JURBN	vB4N	R65B	BNII	R4%I	
								LV UGS _R5N	R/B4W	D65D	BNII	R4%I	
9 V UGS _R5v	5B6DD	NDN5WB	NDW	E	D	DDB	DDB	JURBN	1H4%	R11DN	NWW	R4Tv	
								9 V UGS _R5I	R/B4W	N5WW	NvB5	R4T5	
								LV UGS _R5v	R/B4W	D65N	BvTD	R4%I	
9 V UGS _R55	5B6DD	NDN6vW	NDW	E	D	DDB	DDB	JURBN	vB4N	R65B	BNII	R4%I	
								LV UGS _R55	R/B4W	D65D	BNII	R4%I	
9 V UGS _R5B	5B6DD	NDN4B	NDID	E	D	DDB	DDB	JURBN	RBNB	vHD%	vBI TB	R4T5	
								9 V UGS _R56	N6416	R5TBv	v1N5	R4Tv	
								LV UGS _R5B	R/B46	D65N	BvTD	R4%I	
9 V UGS _R56	5B6DD	NNND%	1II	E	D	DDB	DDB	9 V UGS _R5B	R64%D	5TB6	v1ND	R4T5	
								9 V UGS _R5W	N1T6N	R5T4D	555ID	R4Tv	
								LV UGS _R56	R/B46	D65N	BvTN	R4%I	
9 V UGS _R5W	5B6DD	NDII6D	1H	E	D	DDB	DDB	9 V UGS _R5D	vvNI1	RBN%	5%BB	R4T5	
								9 V UGS _R56	RNTN%	5TW	55vTB	R4T5	
								LV UGS _R5W	R/B46	D65v	BvTN	R4%I	
9 V UGS _R54	5B6DD	NDN464	ND5	E	D	DDB	DDB	9 V UGS _R5I	vB4N	R655	BNP%	R4%I	
								LV UGS _R54	R/B4W	D6v1	BNH	R4%I	
9 V UGS _R5I	5B6DD	NDN68%	ND5	E	D	DDB	DDB	9 V UGS _R5v	%BB	RN5v%	NvBII	R4ID	
								9 V UGS _R54	R/B4	DBI W	BNIV	R4TN	
								9 V UGS _R5D	R/B4	DBI%	BNIV	R4ID	
								LV UGS _R5I	R/B4W	D65D	BNH	R4%I	
								9 V UGS _R5I	vB4N	R655	BNP%	R4%I	
9 V UGS _R5D	5B6DD	NDN46W	ND5	E	D	DDB	DDB	LV UGS _R5D	R/B4W	D6v1	BNH	R4%I	
* PO7	N54IDD	NDIDD	DD	RNDVB%	55T5N	E	E	41_N	RNDVB%	55T5N	B6NN	R6ID	
9 P_~5	N5HID	11TW4	1TN	E	D	E	E	HV UGS 9 P_	DDDD	DDDD	DD	DD	
								& 41_NU					

* 7ndicates a koltage regulated bus (koltage controlled or swing ty3e I achine connected to it)

7ndicates a bus with a load I isI atch opI ore than DN9 V.

Project: Farm 7.
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Project Name: Farm-OH

ETAP
09/01/2020
Study Case: N1 NLE6.

Page: 0
Date: 09/01/2020
Sheet: 001 of 001
Revision: 001
Configuration: For all

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7.	8V	A 9 agT	6 ngT	9 m	9 kar	9 m	9 kar	7.	9 m	9 kar	6 I 3	APj	A_a3
4N 06	5BICD	NNEvW	4B	L	D	L	L	9 V U1 S _RG	R/BIGW	BFW	B0NN	R4TG	
								4N_0U	vBIGW	BFW	B0NN	R4TG	
4N v6	5BICD	NNEvW	4B	L	D	L	L	JUR/0	R%IXN	BH4B	BWFS	R4TB	
								4N_0U	v%IXN	BH4B	BWFS	R4TB	
4N 56	5BICD	NNEvW	4B	L	D	L	L	9 V U1 S _R5	R/VN4D	BPGW	BWTD	R4TG	
								4N_0U	vVN4D	BPGW	BWTD	R4TG	
4N B6	5BICD	NNEvW	4B	L	D	L	L	9 V U1 S _RD	R/BF50	5TN4	B0BD	R4TN	
								4N_0U	vBF50	5TN4	B0BD	R4TN	
4N_06	054IDD	NBNW	DD	L	D	L	L	PO7	0DVBW	R5TNB	B/BIN	RGD	
								HV U1 S 9 P_	R0DVBW	55TNB	B/BIN	RGD	
4N_0U	5BICD	NNEvW	4B	L	D	L	L	4N B6	R/BF50	5TN4	B0BD	R4TN	
								4N 56	R/VN4D	BPGW	BWTD	R4TG	
								4N v6	R%IXN	BH4B	BWFS	R4TB	
								4N 06	R/BIGW	BFW	B0NN	R4TG	
								9 P_~5	0DVTN5	R0ICNN	0%IBD	R4TW	
								& HV U1 S 9 P_					
HV U1 S 9 P_	054IDD	NBNW	DD	L	D	DD4	DD55	4N_06	0DVBW	R5TNB	B/BIN	RGD	
								4N_0U	R0DVTDD	55BW	B/BIN	RGD	R4DD
								& 9 P_~5					
JUR/0	5BICD	NNWB	4B	L	D	L	L	9 V U1 S _R0%	R%IXG4	5TB0	vNH	R4TB	
								9 V U1 S _Rv	RNH4	0H4W	0V4H	R4TB	
								4N v6	v%IX5W	RGD0%	BWSTW	R4TB	
JUR/0	5BICD	0DDHvN	0DB	L	D	L	L	9 V U1 S _RD	R/TB/N	DD	B/ID	R4TD	
								9 V U1 S _RBv	RNH4W	0H44	0V4D	R4TB	
								9 V U1 S _RB5	R/TB4D	DDv	B/ID	R4TD	
								9 V U1 S _RBB	0BHBG	R/HN0	vGDID	R4TB	
LV U1 S _RD	DDND	0DDBSG	0vTG	vTDD	RDENG	L	L	9 V U1 S _RD	vTDD	RDENG	v0D4TW	R4TB	
LV U1 S _RDv	DDND	0DDBSvN	0vTB	vTDD	RDENG	L	L	9 V U1 S _RDv	vTDD	RDENG	v00DN	R4TB	
LV U1 S _RD5	DDND	0DDDB4	0vTB	vTDD	RDENG	L	L	9 V U1 S _RD5	vTDD	RDENG	v00B%	R4TB	
LV U1 S _RBB	DDND	0DDDB5	0vTB	vTDD	RDENG	L	L	9 V U1 S _RBB	vTDD	RDENG	v00%DD	R4TB	
LV U1 S _RDG	DDND	NNH4W	0vTB	vTDD	RDENG	L	L	9 V U1 S _RDG	vTDD	RDENG	v0vD%	R4TB	
LV U1 S _RDW	DDND	NNH4N	0vTB	vTDD	RDENG	L	L	9 V U1 S _RDW	vTDD	RDENG	v0vDv	R4TB	
LV U1 S _RD%	DDND	NNHvv	0vTB	vTDD	RDENG	L	L	9 V U1 S _RD%	vTDD	RDENG	v0v0TW	R4TB	
LV U1 S _RD4	DDND	NNP4W	0vTB	vTDD	RDENG	L	L	9 V U1 S _RD4	vTDD	RDENG	v0v5TB	R4TB	
LV U1 S _RDN	DDND	NNP4G	0vTD	vTDD	RDENG	L	L	9 V U1 S _RDN	vTDD	RDENG	v0v4H	R4TB	
LV U1 S _RD	DDND	NNEND	0vTD	vTDD	RDENG	L	L	9 V U1 S _RD	vTDD	RDENG	v0v4%	R4TB	

Project: Fm OH m 7.

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project: Fm - OH

ETAP

000000

Study Case: NCP1 NGLE6.

Page: v

Rate: 0000000%

SF: mES_mOO. P

Efficiency: 0000 MEF

Configuration: For all

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7.	8V	A 9 agT	6 ngT	9 m	9 kar	9 m	9 kar	7.	9 m	9 kar	6 I 3	APj	A_a3
LV U1 S_R05	DIWD	000000V	0vT	VTED	RDENG	L	L	9 V U1 S_R05	VTED	RDENG	v00W	R4T	
LV U1 S_R0B	DIWD	000000B	0vT	VTED	RDENG	L	L	9 V U1 S_R0B	VTED	RDENG	v00%T	R4T	
LV U1 S_R0G	DIWD	NN000	0vD	VTED	RDENG	L	L	9 V U1 S_R0G	VTED	RDENG	v0vGB	R4T	
LV U1 S_R0W	DIWD	NN000	0vT	VTED	RDENG	L	L	9 V U1 S_R0W	VTED	RDENG	v004TB	R4T	
LV U1 S_R0%	DIWD	NN000	0vD	VTED	RDENG	L	L	9 V U1 S_R0%	VTED	RDENG	v05D0G	R4T	
LV U1 S_R0D	DIWD	NN000	0vD	VTED	RDENG	L	L	9 V U1 S_R0D	VTED	RDENG	v0vD0%	R4T	
LV U1 S_R00	DIWD	NN000	0vD	VTED	RDENG	L	L	9 V U1 S_R00	VTED	RDENG	v0vBB	R4T	
LV U1 S_R0v	DIWD	NN000	00TN	VTED	RDENG	L	L	9 V U1 S_R0v	VTED	RDENG	v0v%0	R4T	
LV U1 S_R05	DIWD	NN000	0vD	VTED	RDENG	L	L	9 V U1 S_R05	VTED	RDENG	v0vNN	R4T	
LV U1 S_R0B	DIWD	NN000	00T%	VTED	RDENG	L	L	9 V U1 S_R0B	VTED	RDENG	v05B0%	R4T	
LV U1 S_R0G	DIWD	NN000	00T%	VTED	RDENG	L	L	9 V U1 S_R0G	VTED	RDENG	v05G0G	R4T	
LV U1 S_R0W	DIWD	NN000	0vT	VTED	RDENG	L	L	9 V U1 S_R0W	VTED	RDENG	v0vvT	R4T	
LV U1 S_R0%	DIWD	NN000	0vT	VTED	RDENG	L	L	9 V U1 S_R0%	VTED	RDENG	v0vBT	R4T	
LV U1 S_R04	DIWD	NN000	0vT	VTED	RDENG	L	L	9 V U1 S_R04	VTED	RDENG	v0v4D	R4T	
LV U1 S_R0N	DIWD	NN000	0vD	VTED	RDENG	L	L	9 V U1 S_R0N	VTED	RDENG	v0v5TD	R4T	
LV U1 S_R00	DIWD	00000vG	0vG	VTED	RDENG	L	L	9 V U1 S_R00	VTED	RDENG	v00GD	R4T	
LV U1 S_R0v	DIWD	NN000	0vB	VTED	RDENG	L	L	9 V U1 S_R0v	VTED	RDENG	v0vDG	R4T	
LV U1 S_R05	DIWD	NN000	0vB	VTED	RDENG	L	L	9 V U1 S_R05	VTED	RDENG	v0v5T	R4T	
LV U1 S_R0B	DIWD	NN000	0vG	VTED	RDENG	L	L	9 V U1 S_R0B	VTED	RDENG	v0vDD	R4T	
LV U1 S_R0W	DIWD	0000000	0vG	VTED	RDENG	L	L	9 V U1 S_R0W	VTED	RDENG	v005T	R4T	
LV U1 S_R0%	DIWD	000000B	0vG	VTED	RDENG	L	L	9 V U1 S_R0%	VTED	RDENG	v00vTD	R4T	
LV U1 S_R0N	DIWD	000000W	0vG	VTED	RDENG	L	L	9 V U1 S_R0N	VTED	RDENG	v00B5	R4T	
LV U1 S_R0D	DIWD	NN000	0vT	VTED	RDENG	L	L	9 V U1 S_R0D	VTED	RDENG	v00ND	R4T	
LV U1 S_R00	DIWD	0000005	05T	VTED	RDENG	L	L	9 V U1 S_R00	VTED	RDENG	v0D0D	R4T	
LV U1 S_R0v	DIWD	000000D	05T	VTED	RDENG	L	L	9 V U1 S_R0v	VTED	RDENG	v0D4T	R4T	
LV U1 S_R05	DIWD	000000v	05T	VTED	RDENG	L	L	9 V U1 S_R05	VTED	RDENG	v0D0D	R4T	
LV U1 S_R0B	DIWD	000000W	05D	VTED	RDENG	L	L	9 V U1 S_R0B	VTED	RDENG	v00vT	R4T	
LV U1 S_R0G	DIWD	000000B	05D	VTED	RDENG	L	L	9 V U1 S_R0G	VTED	RDENG	v00BT	R4T	
LV U1 S_R0W	DIWD	000000N	0vTN	VTED	RDENG	L	L	9 V U1 S_R0W	VTED	RDENG	v00%0	R4T	
LV U1 S_R04	DIWD	000000N	05B	VTED	RDENG	L	L	9 V U1 S_R04	VTED	RDENG	vDN0TN	R4T	
LV U1 S_R0N	DIWD	000000W	05B	VTED	RDENG	L	L	9 V U1 S_R0N	VTED	RDENG	vDNNW	R4T	
LV U1 S_R0D	DIWD	000000%	05B	VTED	RDENG	L	L	9 V U1 S_R0D	VTED	RDENG	vD00TN	R4T	
9 V U1 S_RD0	5BTED	000000%	NG	L	D	DDDB	DDDB	9 V U1 S_RDv	vB40	RD00	BvD	R004	
								LV U1 S_RD0	R/B4G	DC0%	BvT	R004	
9 V U1 S_RDv	5BTED	0000000	NB	L	D	DDDB	DDDB	9 V U1 S_RD0	R/B04	DB4B	BvD	R4TD	
								9 V U1 S_RD5	BNWD	RD0G	4BD	R4TD	
								LV U1 S_RDv	R/B4G	DC0%	BvT	R004	
9 V U1 S_RD5	5BTED	000000v	NB	L	D	DDDB	DDDB	9 V U1 S_RDv	RBNGD	DN0%	4BD	R4TD	
								9 V U1 S_RDB	%050	RD04	0vW	R4TD	

Project: Fm OH m T.
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: Fm - OH

ETAP
0WDEC
Study Case: NQ1 NLE6.

Page: 5
. ate: 0DROWD0%
SF: mES_mOO. P
f ekision: 0DDA MEF
ConpigT Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7.	8V	A 9 agT	6 ngT	9 m	9 kar	9 m	9 kar	7.	9 m	9 kar	6 I 3	APj	A_a3
9 V U1 S _RB	5BICD	0DDW04	NB	E	D	DIDB	DIDB	LV U1 S _R5	R/B4G	DCv4	Bv/B	R0/4	
								9 V U1 S _R5	R0Bv	0BWG	0vWD	R4TD	
								9 V U1 S _RG	NN5	R0NN%	0WB	R4TD	
9 V U1 S _RG	5BICD	0DDWB%	N5	E	D	DIDB	DIDB	LV U1 S _RB	R/B4G	DCv4	Bv/B	R0/4	
								9 V U1 S _RB	RN4B	0NG5	0WB	R4TD	
								9 V U1 S _R4	0vFWG	R/B4G	v0DG	R4TD	
9 V U1 S _RW	5BICD	0DDW%G	N5	E	D	DIDB	DIDB	LV U1 S _RG	R/B4G	DCvN	Bv/B	R0/4	
								9 V U1 S _R0%	vB40	RDC5v	Bv/B	R0/4	
								LV U1 S _RW	R/B4G	DCv4	Bv/B	R0/4	
9 V U1 S _R0%	5BICD	0DDWD4	ND	E	D	DIDB	DIDB	9 V U1 S _RW	R/B0N	DC5	Bv/B	R4TD	
								9 V U1 S _RW	R/B0%	DEBM	Bv/D	R4T5	
								9 V U1 S _RG	%B54	R0C5	0vW%	R4TD	
9 V U1 S _R4	5BICD	0DD05v	N5	E	D	DIDB	DIDB	LV U1 S _R0%	R/B4G	DCvN	Bv/B	R0/4	
								9 V U1 S _RG	R0v5B%	vBDv	v0DW	R4T5	
								9 V U1 S _RN	0BHv4	R/T5B	vGv/Tv	R4TD	
9 V U1 S _RN	5BICD	NNN%	ND	E	D	DIDB	DIDB	LV U1 S _R4	R/B4G	DCvN	Bv/B	R0/4	
								9 V U1 S _R4	R0B0%	vHBD	vGv/B	R4T5	
								9 V U1 S _RD	0%v%4	B5T5	vNB%	R4TD	
9 V U1 S _RD	5BICD	NN4%	ND	E	D	DIDB	DIDB	LV U1 S _RN	R/B4G	DCvN	Bv/B	R0/4	
								9 V U1 S _RN	R0vGN	5T5B	vNB5	R4T5	
								9 V U1 S _RG	0NP4D	B5H5%	55WN	R4T5	
9 V U1 S _R5	5BICD	0DDW0	N5	E	D	DIDB	DIDB	LV U1 S _RD	R/B4G	DCvN	Bv/B	R0/4	
								9 V U1 S _RB	vB40	RDC5v	Bv/B	R0/4	
								LV U1 S _R5	R/B4G	DCv4	Bv/B	R0/4	
9 V U1 S _RB	5BICD	0DD544	N5	E	D	DIDB	DIDB	9 V U1 S _R5	R/B0N	DCD	Bv/B	R4TD	
								9 V U1 S _RG	BNWD	R0T5v	4BG	R0/4N	
								LV U1 S _RB	R/B4G	DCv4	Bv/B	R0/4	
9 V U1 S _RG	5BICD	0DDDv4	ND	E	D	DIDB	DIDB	9 V U1 S _R0%	R0Bv	0B5W	0vWG	R4T5	
								9 V U1 S _RB	BBNB0	DNGW	4B5	R4T5	
								9 V U1 S _R0%	0BHHB	R/TvG	vG5D	R4TD	
9 V U1 S _RW	5BICD	0DD5CG	N5	E	D	DIDB	DIDB	LV U1 S _RG	R/B4G	DCvN	Bv/B	R0/4	
								9 V U1 S _R0%	vB40	RDC5v	Bv/B	R0/4	
								LV U1 S _RW	R/B4G	DCv4	Bv/B	R0/4	
9 V U1 S _R0%	5BICD	NN0	4N	E	D	DIDB	DIDB	JUR/0	0%v4v	B5TvN	vNGD	R4T5	
								9 V U1 S _RG	R0BHD0	vPvG	vGv/Tv	R4T5	
								LV U1 S _R0%	R/B4G	DC5D	Bv/B	R0/4	
9 V U1 S _RD	5BICD	0DDWB%	ND	E	D	DIDB	DIDB	9 V U1 S _R0	vB40	RDC5v	Bv/B	R0/4	
								LV U1 S _RD	R/B4G	DCv4	Bv/B	R0/4	
								9 V U1 S _RD	R/B0%	DEB4	Bv/D	R4T5	

Project: Fm OH m F.
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: Fm - OH

ETAP
0WDEC
Study Case: NP1 NLE6.

Page: B
. ate: 0DROWD0%
SF: mES_mOO. P
f ekision: 0DDA MEF
ConpigT Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7.	8V	A 9 agT	6 ngT	9 m	9 kar	9 m	9 kar	7.	9 m	9 kar	6 I 3	APj	A_a3
9 V U1 S _Rv	5BICD	NNNB	4TN	E	D	DDB	DDB	9 V U1 S _Rv	BNG#	RNN0	4BIG	R#D	
								LV U1 S _R0	R/B4G	DCvN	BvTG	R0#	
								JUR/0	NND%	R/NB0	0VND	R#D	
								9 V U1 S _R0	RNGD	DNW	4BB	R#V	
9 V U1 S _R5	5BICD	NN#0N	ND	E	D	DDB	DDB	9 V U1 S _RN	R/B#W	DEBW	BvD	R#B	
								LV U1 S _Rv	R/B4G	DCvN	BvTG	R0#	
								4N 56	v%D0	RGD0D	B#D	R#F	
								9 V U1 S _R4	R/BW0D	BCD%	BvDG	R#F	
9 V U1 S _RB	5BICD	NNGW	4TW	E	D	DDB	DDB	LV U1 S _R5	R/B4G	DCSD	BvTW	R0#	
								9 V U1 S _RG	vB40	RDCSB	BvTW	R0#	
								LV U1 S _RB	R/B4G	DCSD	BvT%	R0#	
								4N 06	vB#0v	RBCD0	BvDW	R#B	
9 V U1 S _RW	5BICD	0DDDC	N#	E	D	DDB	DDB	9 V U1 S _RD	RNN#D	5B4G	55GG	R#TG	
								9 V U1 S _RB	R/B4D	DE#v	BvTG	R#D	
								LV U1 S _RG	R/B4G	DCSD	BvT%	R0#	
								9 V U1 S _R%	vB40	RDCSv	BvB	R0#	
9 V U1 S _R%	5BICD	0DDDM	N#	E	D	DDB	DDB	LV U1 S _RW	R/B4G	DCvN	BvTG	R0#	
								9 V U1 S _RW	R/B#N	DENG	BvF	R#D	
								9 V U1 S _R4	BND	R/D#4	4B#%	R0#N	
								LV U1 S _R%	R/B4G	DCvN	BvTG	R0#	
9 V U1 S _R4	5BICD	NNNB	N#	E	D	DDB	DDB	9 V U1 S _R5	vB#W5	R#WB	BvD	R#F	
								9 V U1 S _R%	RNGD	DNNB	4B#W	R#D	
								9 V U1 S _R5	R0#W0D	5DB%	vN5TN	R#B	
								LV U1 S _R4	R/B4G	DCvN	BvTW	R0#	
9 V U1 S _RN	5BICD	0DDDB	4TN	E	D	DDB	DDB	9 V U1 S _Rv	vB40	RDCSv	BvB	R0#	
								LV U1 S _RN	R/B4G	DCvN	BvTG	R0#	
								9 V U1 S _R5v	vB40	RDCSv	BvT%	R0#	
								LV U1 S _R0	R/B4G	DCv4	BvF	R0#	
9 V U1 S _R5v	5BICD	0DDW0D	NB	E	D	DDB	DDB	9 V U1 S _R0	R/B#B	DBv	B0TN	R#TW	
								9 V U1 S _R5	BNGW	RNGG	4B#	R#V	
								LV U1 S _R5v	R/B4G	DCv4	BvB	R0#	
								9 V U1 S _R4	0%#05	R5F5W	vNB#%	R#V	
9 V U1 S _R5	5BICD	0DD05B	NB	E	D	DDB	DDB	9 V U1 S _R5v	R#N#N	DN#4	4BD	R#F	
								9 V U1 S _R5B	R#445	0H%G	0WTD	R#V	
								LV U1 S _R5	R/B4G	DCvN	BvTG	R0#	
								9 V U1 S _R5	N#NN	R0TN5	0WTV	R#V	
9 V U1 S _R5B	5BICD	0DDW%N	NB	E	D	DDB	DDB	9 V U1 S _R5W	R#NB	DN#	4BD	R#D	
								9 V U1 S _RN	R/B#B	DB0v	B0TN	R#TW	
								LV U1 S _R5B	R/B4G	DCv4	BvB	R0#	

Project: F m OH m F.
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: F m -OH

ETAP
0WDEC
Study Case: NCP1 NLE6.

Page: G
. ate: 0DROWD0%
SF: mES_mOO. P
f ekision: 0DDA MEF
ConpigT Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7.	8V	A 9 agT	6 ngT	9 m	9 kar	9 m	9 kar	7.	9 m	9 kar	6 I 3	APj	A_a3
9 V U1 S _R5W	5BICDD	0DDKNG	NG	E	D	DICB	DICB	9 V U1 S _R5B	BFW0	RDC6	4B5	R04N	
								9 V U1 S _R5%	R/B4D	DICB	BvD	R04D	
								LV U1 S _R5W	R/B4G	DICv4	BvB	R04#	
9 V U1 S _R5%	5BICDD	0DDW0%	NG	E	D	DICB	DICB	9 V U1 S _R5W	vB40	RDC50	BvB	R04#	
								LV U1 S _R5%	R/B4G	DICv%	BvB	R04#	
9 V U1 S _R5N	5BICDD	0DDKCD	NG	E	D	DICB	DICB	9 V U1 S _R5B	vB40	RDC50	BvB	R04#	
								LV U1 S _R5N	R/B4G	DICv4	BvB	R04#	
9 V U1 S _R5D	5BICDD	0DD5vB	N#	E	D	DICB	DICB	4N B6	vBFWN	RDCN%	B04B	R04B	
								9 V U1 S _R5W	RvDW	BDCG	5%GN	R04B	
								LV U1 S _R5D	R/B4G	DICv4	BvB	R04#	
9 V U1 S _R50	5BICDD	0DDHNG	0D5	E	D	DICB	DICB	JURB0	vB40	RDC50	BvD	R04#	
								LV U1 S _R50	R/B4G	DICv%	BvD	R04#	
9 V U1 S _R5v	5BICDD	0DDH50	0D5	E	D	DICB	DICB	JURB0	NH4%	RTH44	0W4D	R04B	
								9 V U1 S _R5N	R/BDCG	0B5G4	0vGD	R04B	
								LV U1 S _R5v	R/B4G	DICv%	BvB	R04#	
9 V U1 S _R55	5BICDD	0DDHNS	0D5	E	D	DICB	DICB	JURB0	vB40	RDC50	BvD	R04#	
								LV U1 S _R55	R/B4G	DICv%	BvD	R04#	
9 V U1 S _R5B	5BICDD	0DDWGD	0DD	E	D	DICB	DICB	JURB0	R0B405	vB4N	vGDW	R04B	
								9 V U1 S _R5G	0%vNB	R5Bv0	vNvB	R04B	
								LV U1 S _R5B	R/B4G	DICv%	BvB	R04#	
9 V U1 S _R5G	5BICDD	0DDK54	0DD	E	D	DICB	DICB	9 V U1 S _R5B	R0vWN	5BvW	vNvB	R04B	
								9 V U1 S _R5W	0NvGD	R5Bv%	55BFW	R04B	
								LV U1 S _R5G	R/B4G	DICv4	BvB	R04#	
9 V U1 S _R5W	5BICDD	0DD50B	NN	E	D	DICB	DICB	9 V U1 S _R5D	vvDNW	R0DB%	5%vB	R04B	
								9 V U1 S _R5G	R0N00G	5BvW	55BD	R04B	
								LV U1 S _R5W	R/B4G	DICv4	BvB	R04#	
9 V U1 S _R54	5BICDD	0DD5v4	0DB	E	D	DICB	DICB	9 V U1 S _R5N	vB40	RDCvN	B0N	R04#	
								LV U1 S _R54	R/B4W	DICvW	BvD	R04#	
9 V U1 S _R5N	5BICDD	0DDWB%	0DB	E	D	DICB	DICB	9 V U1 S _R5v	%BBD	R0DvW	0vGG	R04D	
								9 V U1 S _R54	R/BvN	DEN5	B0B	R04D	
								9 V U1 S _R5D	R/BvN	DENB	B0B	R04D	
								LV U1 S _R5N	R/B4W	DICvW	BvD	R04#	
9 V U1 S _R5D	5BICDD	0DD5vG	0DB	E	D	DICB	DICB	9 V U1 S _R5N	vB40	RDCvN	B0N	R04#	
								LV U1 S _R5D	R/B4W	DICvW	BvD	R04#	
* PO7	054IDD	NGIDD	DD	R0DvBGN	55Bv05	E	E	4N_06	R0DvBGN	55Bv05	BvBvN	RNGD	
9 P_~5	05THDD	NND4G	Nv	E	D	E	E	HV U1 S 9 P_	DICD	DICD	DD	DD	
								& 4N_0U					

* 7ndicates a koltage regulated bus (koltage controlled or swing ty3e I achine connected to it)
7ndicates a bus with a load I isl atch opl ore than DD 9 V6

Project: Farm OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
Project Name: Farm - OH

ETAP
NOTICE
Study Case: NGIP6 - 1LE0 W

Page: N
Date: 11/11/2024
Sheet: 1 of 1
Revision: 1
Project: NGIP6 - 1LE0 W

LOAD FLOW REPORT

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
4. j N0	5BD CG	.. D% B	4B	C	G	C	C	9 V U6 S _R1	RBD TB	B3. N	BN4D	R 4B	
								4. _NU	vBD TB	BB3. N	BN4D	R 4B	
4. j v0	5BD CG	.. D% B	4B	C	G	C	C	JUR/N	R%4B5v	BDN	BTCD%	R 4B	
								4. _NU	v%4B5v	BDN	BTCD%	R 4B	
4. j 50	5BD CG	.. D% B	4B	C	G	C	C	9 V U6 S _R5	R/TD45	BD44	Bl. D	R 4D	
								4. _NU	vTD45	BD44	Bl. D	R 4D	
4. j B0	5BD CG	.. D% B	4B	C	G	C	C	9 V U6 S _RBG	R/B351	SDN%	BNvD	R 4D	
								4. _NU	vB351	SDN%	BNvD	R 4D	
4. _N0	N54B CG	NCBD. T	G0B	C	G	C	C	PO7	NGvBDT1	BS5D5v	Bv. D%	R 1B0	
								HV U6 S 9 P_	NGvBDT1	BS5D5v	Bv. D%	R 1B0	
4. _NU	5BD CG	.. D% B	4B	C	G	C	C	4. j B0	R/B351	SDN%	BNvD	R 4D	
								4. j 50	R/TD45	BD44	Bl. D	R 4D	
								4. j v0	R%4B5v	BDN	BTCD%	R 4B	
								4. j N0	RBD TB	B3. N	BN4D	R 4B	
								9 P_~5	NGvDNB	R%4BN	N%4ND	R 4D	
								& HV U6 S 9 P_					
HV U6 S 9 P_	N54B CG	NCBD. T	G0B	C	G	G0B.	G0B.	4. _N0	NGvBDT1	BS5D5v	Bv. D%	R 1B0	
								4. _NU	NGvDvB	BS5D5v	Bv. D%	R 1B0	N3%
								& 9 P_~5					
JUR/N	5BD CG	NCBD. T	4B%	C	G	C	C	9 V U6 S _R%	R%4B1.	SDTT	v. 5B	R 4B	
								9 V U6 S _Rv	R B%	NB. G	NT4D	R 4D	
								4. j v0	v%4B54	R DNT	BTvB0	R 4D	
JUR/N	5BD CG	NCBD. T	4B%	C	G	C	C	9 V U6 S _REN	R/B4G	GDG	BN4	R 4B0	
								9 V U6 S _RBv	R B4%	NDG	NTTD	R 4D	
								9 V U6 S _RB5	R/B4G	GDG	BN4	R 4B0	
								9 V U6 S _RB3	NEBBT	R/DNB	v1CD	R 4D	
LV U6 S _RGN	GD. G	NCBD44	NvB	vDCG	RBD CG	C	C	9 V U6 S _RGN	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _RGv	GD. G	NCBD4v	NvB	vDCG	RBD CG	C	C	9 V U6 S _RGv	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _RG5	GD. G	NCBD5	NvB	vDCG	RBD CG	C	C	9 V U6 S _RG5	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _R3B	GD. G	NCBD44	NvB	vDCG	RBD CG	C	C	9 V U6 S _R3B	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _R3I	GD. G	NCBDN%	NvB	vDCG	RBD CG	C	C	9 V U6 S _R3I	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _R3T	GD. G	NCBDN1	NvB	vDCG	RBD CG	C	C	9 V U6 S _R3T	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _R3%	GD. G	NCBDN4	NvB	vDCG	RBD CG	C	C	9 V U6 S _R3%	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _R34	GD. G	NCBDNv	NvB	vDCG	RBD CG	C	C	9 V U6 S _R34	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _RG	GD. G	.. D5v	NvB	vDCG	RBD CG	C	C	9 V U6 S _RG	vDCG	RBD CG	vNGD	R 4B%	
LV U6 S _RNG	GD. G	.. D44	NvB	vDCG	RBD CG	C	C	9 V U6 S _RNG	vDCG	RBD CG	vNGD	R 4B%	

Project: F m OH m F W

Location: Paulding, OH

Contract:

Engineer: Josh Venden

Project: F m - OH

ETAP

NOTICE

Study Case: NGIP6 . 1LE0 W

Page: v

Date: 11/11/2024

Sheet: m ES_m OOWP

Revision: NGGA MEF

Config: For all

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
LV U6 S _R5	CT. G NGCB5v	NvD	vDCG	RDCG	C	C	9 V U6 S _R5	vDCG	RDCG	vNG D	R 4D		
LV U6 S _RB	CT. G NGCB1.	NvD	vDCG	RDCG	C	C	9 V U6 S _RB	vDCG	RDCG	vNGD	R 4D		
LV U6 S _RI	CT. G . . D. %	NvD	vDCG	RDCG	C	C	9 V U6 S _RI	vDCG	RDCG	vNND	R 4D		
LV U6 S _RT	CT. G NGCBv1	NvD	vDCG	RDCG	C	C	9 V U6 S _RT	vDCG	RDCG	vNND	R 4D		
LV U6 S _R%	CT. G . . D4G	NND	vDCG	RDCG	C	C	9 V U6 S _R%	vDCG	RDCG	vNvD	R 4D		
LV U6 S _RG	CT. G NGCB4	NND	vDCG	RDCG	C	C	9 V U6 S _RG	vDCG	RDCG	vNvD	R 4D		
LV U6 S _RN	CT. G NGCB%	NND	vDCG	RDCG	C	C	9 V U6 S _RN	vDCG	RDCG	vNvD	R 4D		
LV U6 S _Rv	CT. G . . DNN	NND	vDCG	RDCG	C	C	9 V U6 S _Rv	vDCG	RDCG	vNvD	R 4D		
LV U6 S _R5	CT. G . . D4.	NvD	vDCG	RDCG	C	C	9 V U6 S _R5	vDCG	RDCG	vNvD	R 4D		
LV U6 S _RB	CT. G . . DTT	NND	vDCG	RDCG	C	C	9 V U6 S _RB	vDCG	RDCG	vNvD	R 4D		
LV U6 S _R1	CT. G . . D5G	NND	vDCG	RDCG	C	C	9 V U6 S _R1	vDCG	RDCG	vNvD	R 4D		
LV U6 S _RT	CT. G NGCBv5	NvD	vDCG	RDCG	C	C	9 V U6 S _RT	vDCG	RDCG	vNND	R 4D		
LV U6 S _R%	CT. G NGCB%	NvD	vDCG	RDCG	C	C	9 V U6 S _R%	vDCG	RDCG	vNvD	R 4D		
LV U6 S _R4	CT. G . . D%	NvD	vDCG	RDCG	C	C	9 V U6 S _R4	vDCG	RDCG	vNND	R 4D		
LV U6 S _R.	CT. G NGCBv	NND	vDCG	RDCG	C	C	9 V U6 S _R.	vDCG	RDCG	vNND	R 4D		
LV U6 S _RN	CT. G NGCB4G	NvD	vDCG	RDCG	C	C	9 V U6 S _RN	vDCG	RDCG	vNGD	R 4D		
LV U6 S _Rv	CT. G NGCB5G	NvD	vDCG	RDCG	C	C	9 V U6 S _Rv	vDCG	RDCG	vNND	R 4D		
LV U6 S _R5	CT. G NGCB%	NvD	vDCG	RDCG	C	C	9 V U6 S _R5	vDCG	RDCG	vNND	R 4D		
LV U6 S _RB	CT. G NGCB4	NvD	vDCG	RDCG	C	C	9 V U6 S _RB	vDCG	RDCG	vNND	R 4D		
LV U6 S _RT	CT. G NGCBT1	NvD	vDCG	RDCG	C	C	9 V U6 S _RT	vDCG	RDCG	vNGD	R 4D		
LV U6 S _R%	CT. G NGCBv%	NvD	vDCG	RDCG	C	C	9 V U6 S _R%	vDCG	RDCG	vNGD	R 4D		
LV U6 S _R.	CT. G NGCBvN	NvD	vDCG	RDCG	C	C	9 V U6 S _R.	vDCG	RDCG	vNND	R 4D		
LV U6 S _RBG	CT. G NGCB. 5	NvD	vDCG	RDCG	C	C	9 V U6 S _RBG	vDCG	RDCG	vNND	R 4D		
LV U6 S _RN	CT. G NGCBT1	NvD	vDCG	RDCG	C	C	9 V U6 S _RN	vDCG	RDCG	vNGD	R 4D		
LV U6 S _Rv	CT. G NGCBv	NvD	vDCG	RDCG	C	C	9 V U6 S _Rv	vDCG	RDCG	vNGD	R 4D		
LV U6 S _R5	CT. G NGCBT5	NvD	vDCG	RDCG	C	C	9 V U6 S _R5	vDCG	RDCG	vNGD	R 4D		
LV U6 S _RB	CT. G NGCBvG	NvD	vDCG	RDCG	C	C	9 V U6 S _RB	vDCG	RDCG	vNGD	R 4D		
LV U6 S _RT	CT. G NGCB4	NvD	vDCG	RDCG	C	C	9 V U6 S _RT	vDCG	RDCG	vNND	R 4D		
LV U6 S _RB	CT. G NGCB4B	NvD	vDCG	RDCG	C	C	9 V U6 S _RB	vDCG	RDCG	vNND	R 4D		
LV U6 S _RB	CT. G NGCB. .	NvD	vDCG	RDCG	C	C	9 V U6 S _RB	vDCG	RDCG	vG ND	R 4D		
LV U6 S _RB	CT. G NGCB4	NvD	vDCG	RDCG	C	C	9 V U6 S _RB	vDCG	RDCG	vG ND	R 4D		
LV U6 S _RG	CT. G NGCB. %	NvD	vDCG	RDCG	C	C	9 V U6 S _RG	vDCG	RDCG	vG ND	R 4D		
9 V U6 S _RN	5BDG NGND%	. D	C	G	GDCB	GDCB	9 V U6 S _RGv	vD4N	GD51	BvD	R %D		
							LV U6 S _RN	R/D41	GD5N	BvD	R %D		
9 V U6 S _RGv	5BDG NGND%	. D	C	G	GDCB	GDCB	9 V U6 S _RN	R/D44	GD44	BN	R 4D		
							9 V U6 S _R5	BDTG	RNDv5	45D	R %D		
							LV U6 S _RGv	R/D41	GD5N	BvD	R %D		
9 V U6 S _R5	5BDG NGCB. 1	. D	C	G	GDCB	GDCB	9 V U6 S _RGv	BDTG	GD41	45D	R 4D		
							9 V U6 S _RB	%D5N	RNDvG	NvD	R 4D		

Project: Fm OH m FW
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: Fm - OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: 5
Wate: NRGTR/GN%
SF : mES_m OOWP
fekision: NGA MEF
ConpigD Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
9 V U6 S _R5	5BDGG	NCGD4N	. 15	C	G	G00CB	G00CB	LV U6 S _R5	R/DB41	GD5v	Bv/D	R %43	
								9 V U6 S _R5	R/DB4v	NB8%	Nv1D%	R 41D	
								9 V U6 S _RG1	. DG5	R/DB5	NT%43	R 41D	
9 V U6 S _RG1	5BDGG	NCGDNG	. 1D	C	G	G00CB	G00CB	LV U6 S _R5	R/DB41	GD5v	Bv/D	R %43	
								9 V U6 S _R5	R/DB4B	NDT4	NT%4T	R 41D	
								9 V U6 S _RG4	Nv/DT1	R/DCB	vG D	R 41D	
9 V U6 S _RG1	5BDGG	NCGD54	. 1D	C	G	G00CB	G00CB	LV U6 S _RG1	R/DB41	GD55	Bv/D	R %43	
								9 V U6 S _R5%	v/DB4N	RCD5T	Bv/D	R %4%	
								9 V U6 S _RG1	R/DB41	GD55	Bv/D	R %43	
9 V U6 S _R5%	5BDGG	NCGD%v	. 1D	C	G	G00CB	G00CB	9 V U6 S _RG1	R/DB%	GD0%	Bv/D	R 41D	
								9 V U6 S _RNT	R/DB%	GD8%N	Bv/D	R 41D	
								9 V U6 S _RNI	%4D54	RNDNI	Nv/D	R 41D	
9 V U6 S _RG4	5BDGG	NCGD8 %	. 1D	C	G	G00CB	G00CB	LV U6 S _R5%	R/DB41	GD55	Bv/D	R %43	
								9 V U6 S _RG1	Rv/DDB4	v/DBvG	vG D	R 41D	
								9 V U6 S _RG	NB8v.	R/D1%	v1N8	R 41D	
9 V U6 S _RG	5BDGG	NCGDv4	. 1D	C	G	G00CB	G00CB	LV U6 S _RG4	R/DB41	GD55	Bv/D	R %43	
								9 V U6 S _RG4	RND%4	v/DTv	v1ND	R 41D	
								9 V U6 S _RG	N%4D%	BD.	v. 5D%	R 41D	
9 V U6 S _RG	5BDGG	NCGDDB	4D	C	G	G00CB	G00CB	LV U6 S _RG	R/DB41	GD55	Bv/D	R %43	
								9 V U6 S _RG	RNDTG	5Dv.	v. 5D	R 41D	
								9 V U6 S _R1	N D4N	BDTT	551D	R 41D	
9 V U6 S _R5	5BDGG	NCGDvB	. 1D	C	G	G00CB	G00CB	LV U6 S _RG	R/DB41	GD5B	Bv/D	R %43	
								9 V U6 S _RB	v/DB4N	RCD5T	Bv/D	R %4%	
								LV U6 S _R5	R/DB41	GD5v	Bv/D	R %43	
9 V U6 S _RB	5BDGG	NCGD4v	. 1D	C	G	G00CB	G00CB	9 V U6 S _R5	R/DB%	GD0B	Bv/D	R 41D	
								9 V U6 S _RNI	BDTG	RND8G	4D	R %4D	
								LV U6 S _RB	R/DB41	GD5v	Bv/D	R %43	
9 V U6 S _RNI	5BDGG	NCGD. 5	. 1D	C	G	G00CB	G00CB	9 V U6 S _R5%	R/DBv5	NDB8%	Nv/D	R 41D	
								9 V U6 S _RB	RDBN	GDTB	45D	R 41D	
								9 V U6 S _R5%	NB8B1	R/DB4	v1vD	R 41D	
9 V U6 S _RNT	5BDGG	NCGD.N	. 1D	C	G	G00CB	G00CB	LV U6 S _RNI	R/DB41	GD55	Bv/D	R %43	
								9 V U6 S _R5%	v/DB4N	RCD5T	Bv/D	R %4%	
								LV U6 S _RNT	R/DB41	GD5v	Bv/D	R %43	
9 V U6 S _R5%	5BDGG	NCGDNI%	4D	C	G	G00CB	G00CB	JUR/N	N%445	BD1B	v. D	R 41D	
								9 V U6 S _RNI	RNBGv	vBN%	v1N8	R 41D	
								LV U6 S _R5%	R/DB41	GD5B	Bv/D	R %43	
9 V U6 S _RG	5BDGG	NCGDv	4D	C	G	G00CB	G00CB	9 V U6 S _RN	v/DB4N	RCD5T	Bv/D	R %4%	
								LV U6 S _RG	R/DB41	GD55	Bv/D	R %43	
								9 V U6 S _RG	R/DB%	GD8Tv	Bv/D	R 41D	

Project: F m OH m 7F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: F m - OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W

Page: B
Wate: NRGTR/GN%
SF : m ES_m OOWP
f ekision: NGA MEF
ConpigD Forl al

Bus		Voltage		Generation		Load		Load Flow					XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3	
9 V U6 S _Rv	5BD CG	NCGBC%	4D	C	G	G0CB	G0CB	9 V U6 S _Rv	BD14	RD .	4B5	R 4I0		
								LV U6 S _RN	R/DB41	GD55	BvB	R %4		
								JUR/N	. DG%	RND1T	NT4D	R 4ID		
								9 V U6 S _RN	RED1G	GD%G	4B0	R 4ID		
								9 V U6 S _R.	R/DB4T	GBR	BvB	R 4IB		
9 V U6 S _R5	5BD CG	NCGD41	4D	C	G	G0CB	G0CB	LV U6 S _Rv	R/DB41	GD55	BvB	R %4		
								4. j 50	v%DB5	R/DB	BTND	R 4ID		
								9 V U6 S _R4	R/BDTv	BDNN	BN DN	R 4IB		
9 V U6 S _RB	5BD CG	. . DTB	4D	C	G	G0CB	G0CB	LV U6 S _R5	R/DB41	GD5B	BvD	R %4		
								9 V U6 S _R1	v/DB4N	RD54	BvD	R %4%		
9 V U6 S _R1	5BD CG	. . Dv.	4D	C	G	G0CB	G0CB	LV U6 S _RB	R/DB41	GD5B	BvD	R %4		
								4. j N0	v/BDNB	REDDB	BN D	R 4IB		
								9 V U6 S _RG	RN D15	5DNG	55B5	R 4IB		
9 V U6 S _RT	5BD CG	NCGDN%	. DN	C	G	G0CB	G0CB	9 V U6 S _RB	R/DB4G	GB T	BvB	R 4ID		
								LV U6 S _R1	R/DB41	GD5B	BvD	R %4		
								9 V U6 S _R%	v/DB4N	RD5%	BvB	R %4%		
								LV U6 S _RT	R/DB41	GD55	BvB	R %4		
9 V U6 S _R%	5BD CG	NCGD5v	. DN	C	G	G0CB	G0CB	9 V U6 S _RT	R/DB%	GB .	BvDN	R 4I0		
								9 V U6 S _R4	BDTG	RND5T	4BDB	R %4		
								LV U6 S _R%	R/DB41	GD55	BvB	R %4		
9 V U6 S _R4	5BD CG	NCGDT.	. DN	C	G	G0CB	G0CB	9 V U6 S _R5	v/BD. B	REDNG	BN D	R 4ID		
								9 V U6 S _R%	RED1N	N0Gv	4B5	R 4I0		
								9 V U6 S _R5	R%4D/Tv	5D0N	v. vD	R 4IB		
								LV U6 S _R4	R/DB41	GD5B	BvB	R %4		
9 V U6 S _R.	5BD CG	NCGDT	4D	C	G	G0CB	G0CB	9 V U6 S _Rv	v/DB4N	RD5%	BvB	R %4%		
								LV U6 S _R.	R/DB41	GD55	BvB	R %4		
								9 V U6 S _R5v	v/DB4N	RD5T	BvDN	R %4%		
9 V U6 S _R5v	5BD CG	NCGTvB	. B	C	G	G0CB	G0CB	LV U6 S _RN	R/DB41	GD5v	BvD	R %4		
								9 V U6 S _RN	R/DB4	GBvT	BN	R 4IT		
								9 V U6 S _R5	BD1T	RD/Tv	4B0	R 4ID		
9 V U6 S _R5	5BD CG	NCGD. 4	. B	C	G	G0CB	G0CB	LV U6 S _Rv	R/DB41	GD55	BvB	R %4		
								9 V U6 S _R4	N4B5	RB/Tv	v. 5D%	R 4ID		
								9 V U6 S _R5v	REDB	GD5T	45D	R 4IB		
								9 V U6 S _R5B	R/DB45	NB. G	NT%IT	R 4ID		
9 V U6 S _R5B	5BD CG	NCGDv	. DB	C	G	G0CB	G0CB	LV U6 S _R5	R/DB41	GD55	BvB	R %4		
								9 V U6 S _R5	. B. .	RNDv4	NT%0%	R 4ID		
								9 V U6 S _RT	REDBB	GD%T	45B	R 4ID		
								9 V U6 S _R.	R/DB4B	GBNT	BN%	R 4IT		
								LV U6 S _R5B	R/DB41	GD55	BvB	R %4		

Project: F m OH m F W
Location: Paulding, OH
Contract:
Engineer: Josh Venden
j ilenal e: F m - OH

ETAP
N1010C
Study Case: NGLP6 . 1LE0 W


Page: 1
Wate: NRGTR/CN%
SF : m ES_m OOWP
fekision: NGA MEF
ConpigD Forl al

Bus		Voltage		Generation		Load		Load Flow				XFMR	
7W	8V	A 9 agD	0 ngD	9 m	9 kar	9 m	9 kar	7W	9 m	9 kar	0 I 3	APj	A_a3
9 V U6 S _RST	5BDGG	NCGD1%	. DB	C	G	G0CB	G0CB	9 V U6 S _RSB	BDTN	RN0B5	4B0	R %D	
								9 V U6 S _R5%	R/DB4G	GDG4	BvDB	R 4B0	
								LV U6 S _RST	R/DB41	GD5v	BvDB	R %4	
9 V U6 S _R5%	5BDGG	NGND4	. D	C	G	G0CB	G0CB	9 V U6 S _RST	vDB4N	RCD51	BvDB	R %4	
								LV U6 S _R5%	R/DB41	GD5v	BvDB	R %4	
9 V U6 S _R5.	5BDGG	NCGDN5	. DB	C	G	G0CB	G0CB	9 V U6 S _RSB	vDB4N	RCD5T	BvDB	R %D%	
								LV U6 S _R5.	R/DB41	GD5v	BvDB	R %4	
9 V U6 S _RBG	5BDGG	NCGD4%	. D%	C	G	G0CB	G0CB	4. j B0	vBD1N	RBD5N	BNTD	R 4B	
								9 V U6 S _RBT	RvDB4G	B0: 1	5%BD%	R 4B	
								LV U6 S _RBG	R/DB41	GD5v	BvDB	R %4	
9 V U6 S _RBN	5BDGG	NGND11	NCD	C	G	G0CB	G0CB	JURBN	vDB4N	RCD51	BvDB	R %4	
								LV U6 S _RBN	R/DB4T	GD5N	BvDB	R %4	
9 V U6 S _RBv	5BDGG	NGNDv	NCD	C	G	G0CB	G0CB	JURBN	. B4%	RNDG5	NITD	R 4D	
								9 V U6 S _RB	R/DBGT	N5T4	NvBD	R 4B	
								LV U6 S _RBv	R/DB41	GD5N	BvDB	R %4	
9 V U6 S _RB5	5BDGG	NGND15	NCD	C	G	G0CB	G0CB	JURBN	vDB4N	RCD51	BvDB	R %4	
								LV U6 S _RB5	R/DB41	GD5N	BvDB	R %4	
9 V U6 S _RBB	5BDGG	NGNDNN	NCDN	C	G	G0CB	G0CB	JURBN	RBB4NB	vBNN	vB B	R 4D	
								9 V U6 S _RBI	N%4. 1	RB5B%	v. NB	R 4D	
								LV U6 S _RBB	R/DB41	GD5v	BvDB	R %4	
9 V U6 S _RBI	5BDGG	NCG4.	NCD5	C	G	G0CB	G0CB	9 V U6 S _RBB	R%4%G	5B1N	v. ND	R 4B	
								9 V U6 S _RBT	N DB4N	RBDB4T	555D	R 4D	
								LV U6 S _RBI	R/DB41	GD5v	BvDB	R %4	
9 V U6 S _RBT	5BDGG	NCGD84T	. DB	C	G	G0CB	G0CB	9 V U6 S _RBG	vvDB4	RBDB%	5%4DN	R 4B	
								9 V U6 S _RBI	RN DB4%	5DB5	555B0	R 4B	
								LV U6 S _RBT	R/DB41	GD5v	BvDB	R %4	
9 V U6 S _RB4	5BDGG	NGND4T	NCD	C	G	G0CB	G0CB	9 V U6 S _RB	vDB4N	RCD5B	BN4	R %4	
								LV U6 S _RB4	R/DB4T	GD5G	BN4	R %4	
9 V U6 S _RB	5BDGG	NGNDGI	NCD5	C	G	G0CB	G0CB	9 V U6 S _RBv	%4BEG	RNDv4	Nv1DN	R 4B0	
								9 V U6 S _RB4	R/DB%	GB %	BN4	R 4DN	
								9 V U6 S _RIG	R/DB%	GB 4	BN4%	R 4B0	
								LV U6 S _RB	R/DB4T	GD5G	BN4	R %4	
9 V U6 S _RIG	5BDGG	NGND45	NCD	C	G	G0CB	G0CB	9 V U6 S _RB	vDB4N	RCD5B	BN4	R %4	
								LV U6 S _RIG	R/DB4T	GD5G	BN4	R %4	
* PO7	N54BGG	NGLDBCG	G05	RNGvDBT5	55DBT	C	C	4. _ND	RNGvDBT5	55DBT	Bv. D%	R 1B0	
9 P_~5	N5BGG	. . DB15	. DN	C	G	C	C	HV U6 S 9 P_	G0CG	G0CG	G05	G05	
								& 4. _NU					

* 7ndicates a koltage regulated bus (koltage controlled or swing ty3e I achine connected to it)
7ndicates a bus with a load I isI atch op1 ore than 4DN9 V0

APPENDIX B: ETAP SINGLE LINE DIAGRAM

One-Line Diagram - NW_OH (Load Flow Analysis)



Westwood

APPENDIX C: ETAP MODEL INPUTS

Power Grid Editor - Haviland

Info Rating Short Circuit Time Domain Harmonic Reliability Energy Price Remarks Comment

138 kV Swing

Grounding

SC Rating

	MVA _{sc}	MVA _{sc}	X/R	kA _{sc}
3-Phase	1723.7		4.375	7.211
1-Phase	1612.8	537.6	5.068	6.747

sqrt(3)V_L I_f V_n I_f

SC Impedance (100 MVA_b)

	% R	% X
Pos.	1.29271	5.65562
Neg.	1.29271	5.65562
Zero	1.35513	6.86778

Power Grid Editor - Future System (2022)

Info Rating Short Circuit Time Domain Harmonic Reliability Energy Price Remarks Comment

138 kV Swing

Grounding

SC Rating

	MVA _{sc}	MVA _{sc}	X/R	kA _{sc}
3-Phase	2145		4.375	8.974
1-Phase	1875	625	5.068	7.844

sqrt(3)V_L I_f V_n I_f

SC Impedance (100 MVA_b)

	% R	% X
Pos.	1.03881	4.5448
Neg.	1.03881	4.5448
Zero	1.2927	6.55141

Figure 1: Utility Equivalent Data

Westwood

3-Winding Transformer Editor - MPT

Reliability		Remarks		Comment	
Info	Rating	Impedance	Tap	Grounding	Protection
70.2	70.2	70.2 MVA			138 34.5 13.8 kV

Impedance

	Positive		Zero		MVA Base
	% Z	X/R	% Z	X/R	
PS	10.103	40.4	9.903	39.6	70.2
PT	16.204	36.38	14.561	32.69	70.2
ST	4.192	12.2	3.765	10.95	70.2

Z Variation

@ - 5 % Tap
0 %

@ + 5 % Tap
0 %

No Load Losses (Unbalanced Load Flow only)

	% FLA	kW	% G	% B
Positive	0	0	0	0
Zero	0	0	0	0

☐ Buried Delta Winding

Zero Seq. Impedance

Z Tolerance
± 0 %

Figure 2: Main Power Transformer Impedance

Westwood

2-Winding Transformer Editor - GSU T-01

Reliability		Remarks			Comment																				
Info	Rating	Impedance	Tap	Grounding	Sizing	Protection	Harmonic																		
2.75 MVA ANSI Liquid-Fill Other 65 C						34.5	0.69 kV																		
Impedance <table border="1"> <thead> <tr> <th></th> <th>%Z</th> <th>X/R</th> <th>R/X</th> <th>%X</th> <th>%R</th> </tr> </thead> <tbody> <tr> <td>Positive</td> <td>5.75</td> <td>9.03</td> <td>0.111</td> <td>5.715</td> <td>0.633</td> </tr> <tr> <td>Zero</td> <td>5.75</td> <td>9.03</td> <td>0.111</td> <td>5.715</td> <td>0.633</td> </tr> </tbody> </table> Typical Z & X/R Typical X/R							%Z	X/R	R/X	%X	%R	Positive	5.75	9.03	0.111	5.715	0.633	Zero	5.75	9.03	0.111	5.715	0.633	Z Base MVA 2.75 Other 65	
	%Z	X/R	R/X	%X	%R																				
Positive	5.75	9.03	0.111	5.715	0.633																				
Zero	5.75	9.03	0.111	5.715	0.633																				
Z Variation <table border="1"> <thead> <tr> <th></th> <th>%Z</th> <th>% Z Variation</th> </tr> </thead> <tbody> <tr> <td>@ -5 % Tap</td> <td>5.75</td> <td>0</td> </tr> <tr> <td>@ 5 % Tap</td> <td>5.75</td> <td>0</td> </tr> </tbody> </table>							%Z	% Z Variation	@ -5 % Tap	5.75	0	@ 5 % Tap	5.75	0	Z Tolerance + 0 % - 0 %										
	%Z	% Z Variation																							
@ -5 % Tap	5.75	0																							
@ 5 % Tap	5.75	0																							
No Load Test Data (Used for Unbalanced Load Flow only) <table border="1"> <thead> <tr> <th></th> <th>% FLA</th> <th>kW</th> <th>% G</th> <th>% B</th> </tr> </thead> <tbody> <tr> <td>Positive</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> <tr> <td>Zero</td> <td>0</td> <td>0</td> <td>0</td> <td>0</td> </tr> </tbody> </table> ☐ Buried Delta Winding Zero Seq. Impedance Typical Value									% FLA	kW	% G	% B	Positive	0	0	0	0	Zero	0	0	0	0			
	% FLA	kW	% G	% B																					
Positive	0	0	0	0																					
Zero	0	0	0	0																					

GSU T-01 OK Cancel

Figure 3: Step-Up Transformer Impedance Data

Westwood

Wind Turbine Generator - WTG T-01

Info Rating Imp/Model Turbine Wind Controls Pitch Control Inertia Time Domain Reliability Rv

Generic 0.69 kV 2.5 MW Voltage Control

Locked Rotor

LRC 600 %

PF 11.15 %

ANSI Short-Circuit Z

Xsc

Std MF 20 1/2 cy

Xsc 20 1.5-4 cy

Parameters

Xo 20 X2 20

X/R 45.093 Td' 0.2

Grounding

Connection  Type Solid

Earthing Type NEC

Model

Model Type

WT3G

Sample Data

X" 0.2 T1 0 T2 0 T3 0 Lvplsw 0

Lvpl1 1.11 Lvpl2 0 zerox 0.5 brkpt 0.9 mpwr 0

☐ None ☒ Current Injection

WTG T-01

OK Cancel

Figure 4: Turbine Impedance/Short Circuit Data

NW_OH 1/C AL XLPE 35 kV 100 % Non-Mag. 60 Hz Ohms/1000ft RHO 200°C.cm/W														
Ampacity	Impedance	Physical	Cable Pulling											
	Phase			Ground/Neutral		R	X	L	Y	Ro	Xo	Lo	Yo	Rdc
	Avail.	Code	Size	#	Size	90°C	60 Hz	60 Hz	60 Hz	90°C	60 Hz	60 Hz	60 Hz	25°C
1	Yes	1/0 - 2/3 CN	1/0	18	16	0.24087	0.05182	0.00014	1.77E-05	0.35886	0.05482	0.00015	1.77E-05	0.18596
2	Yes	4/0 - 1/2 CN	4/0	17	14	0.11303	0.04679	0.00012	2.2E-05	0.28416	0.07373	0.0002	2.2E-05	0.08673
3	Yes	500 - 1/3 CN	500	16	12	0.4939	0.04115	0.00011	3.05E-05	0.16756	0.04488	0.00012	3.05E-05	0.0361
4	Yes	750 - 1/6 CN	750	19	14	0.0343	0.03865	0.0001	3.56E-05	0.18978	0.05914	0.00016	3.56E-05	0.0248
5	Yes	1000 - 1/6 CN	1000	25	14	0.02568	0.03703	0.0001	3.98E-05	0.20941	0.07373	0.0002	3.98E-05	0.01814
6	Yes	1250 - 1/6 CN	1250	20	12	0.02048	0.03537	9E-05	4.36E-05	0.23977	0.09952	0.00026	4.36E-05	0.01422

Figure 5: Cable Impedance Data

for

TriState Wind Ohio, LLC
c/o Starwood Energy Group, LLC
5 Greenwich Office Park, 2nd Floor
Greenwich, CT 06831

TriLake Wind Ohio, LLC
c/o Starwood Energy Group,
5 Greenwich Office Park, 2nd
Greenwich, CT 06831

(NOT TO SCALE)

Cover Sheet

Not For Construction
Array Date: 09/14/2017

Date: 09/27/17
Sheet: E100

0007186..E100 COVER.dwg

Sheet List Table	
Sheet Number	Sheet Title
E.100	Cover Sheet
E.101	Index Sheet
E.105	General Symbolology & Abbreviations
E.200	MVAC Oneline Diagram Circuits 1 and 2
E.201	MVAC Oneline Diagram Circuits 3 and 4
E.210	Fiber Optic Oneline Diagram
E.211	Fiber Optic Oneline Diagram (2)
E.300	Overall Electrical Site Plan
E.310	Electrical Site Plan
E.311	Electrical Site Plan
E.312	Electrical Site Plan
E.313	Electrical Site Plan
E.314	Electrical Site Plan
E.315	Electrical Site Plan
E.316	Electrical Site Plan
E.317	Electrical Site Plan
E.318	Electrical Site Plan
E.319	Electrical Site Plan
E.320	Electrical Site Plan
E.321	Electrical Site Plan
E.322	Electrical Site Plan
E.323	Electrical Site Plan
E.324	Electrical Site Plan
E.325	Electrical Site Plan
E.326	Electrical Site Plan
E.327	Electrical Site Plan
E.328	Electrical Site Plan
E.329	Electrical Site Plan
E.330	Electrical Site Plan
E.331	Electrical Site Plan
E.400	Medium Voltage Trench Details
E.410	Below Grade Work GE 2.5-116 Turbines
E.411	Turbine Grounding - Spread Foundation GE 2.5-116
E.420	Padmount Transformer Feedthrough
E.421	Padmount Transformer Terminal
E.422	Sectionalizing Cabinet
E.800	MVAC Wiring Schedule

Drawn by: JBT

Checked: AAB

Described: JAC

As-Built Drawings

Project: PAULDING

1. 09/27/17 - 50% Plans

WHITE

an IEEE COMPANY

800 E. White Ave

Channahon, IL 61018

Tridelta Wind Ohio, LLC

c/o Starwood Energy Group, LLC

5 Connecticut Office Park, 2nd Floor

Greenwich, CT 06830

Northwest

Ohio Wind

Project

Paulding County, Ohio

Index Sheet

Not For Construction

Array Date: 09/14/2017

Date: 09/27/17



Sheet: E.101

0007165_1100_COVER.dwg

GENERAL NOTES

- SEE SUBSTATION DRAWING WPD-01-001 FOR SUBSTATION SINGLE LINE DRAWING.
- ALL SURGE ARRESTERS 24.4KV MON.
- SEE E3807 FOR MVAC WIRE SCHEDULE

34.5KV COLLECTION SYSTEM



35 kV CABLE AND CONCENTRIC NEUTRAL SIZES				
PHASE CONDUCTOR		CONCENTRIC NEUTRAL		
SIZE	MAT'L	DESIGNATION	MAT'L	WIRE SIZE
1/0 AWG	Al	2/3	Cu	16 AWG
4/0 AWG	Al	1/2	Cu	14 AWG
500 KCMIL	Al	1/3	Cu	12 AWG
750 KCMIL	Al	1/6	Cu	14 AWG
1000 KCMIL	Al	1/6	Cu	14 AWG
1250 KCMIL	Al	1/6	Cu	12 AWG

Northwest Ohio Wind Project
Paulding County, Ohio

MVAC Online Diagram
Circuits 1 and 2

Not For Construction
Array Date: 09/14/2007

Date: 09/27/07
Sheet: E200

0007166_E200_0165_LINES.dwg

WHITE
an IEEE COMPANY
800 E. White Ave
Channahon, IL 61608


Tridale Wind Ohio, LLC
c/o Starwood Energy Group, LLC
5 Greenfield Office Park, 2nd Floor
Greenwich, CT 06830

Prepared by:

Designed by:	JRT
Checked by:	AWB
Drawn by:	JMC
As-Built Drawings:	
Project No:	09/27/07
Revision:	50% Final

GENERAL NOTES

1. SEE SUBSTATION DRAWING FOR FIBER TERMINATION DIAGRAMS.
2. FIBER NETWORK IS ARRANGED AS A "COLLAPSED RING". EACH LINE IN DIAGRAM REPRESENTS A PAIR OF FIBER STRANDS (TRANSMIT/RECEIVE).
3. NON TERMINATED FIBERS SPLICED THROUGH IN EACH LOCATION, SYMBOLIZED BY "X" IN DIAGRAM.



Northwest Ohio Wind Project

Fiber Optic Online Diagram

Not For Construction
Array Date: 09/14/2017

Date:	09/27/17
Sheet:	E210


0007186_F200_ONELINES.dwg



WHITE
an IEA company

3900 E. White Ave
Clinton, IN 47342

TriState Wind Ohio, LLC
c/o Starwood Energy Group, LLC
5 Greenwich Office Park, 2nd Floor
Greenwich, CT 06831



Westwood

Westwood Professional Services, Inc.
1000 E. 10th Ave.
Suite 200
Greenwich, CT 06830
Tel: (860) 397-7500
Fax: (860) 397-7501
www.westwoodps.com

Client:	WTG
Check:	AWB
Drawn:	JAC
As-Built:	Drawn:
Project:	Northwest Ohio Wind
Date:	09/27/17
Scale:	1:1
Sheet:	001

WHITE
an OSHA company

800 E. White Ave.
Channahon, IL 61615

Tridale Wind Ohio, LLC
c/o Starwood Energy Group, LLC
5 Connecticut Office Park
Greenwich, CT 06830

**Northwest
Ohio Wind
Project**

Paulding County, Ohio

Fiber Optic Oneline
Diagram (2)

Not For Construction
Array Date: 09/14/2017
Date: 09/27/17
Sheet: E211

000186_E200_ONLINE.dwg

Client:	TRW
Check:	AKB
Drawn:	AKB
As-built:	AKB
Project No.:	10000
Project Name:	Northwest Ohio Wind Project
Project Location:	Paulding County, Ohio
Project Date:	09/27/17
Project Status:	50% Done

WHITE
 an ARCADIS company
 8000 E. White Ave.
 Chicago, IL 60642

Trickle Wind Ohio, LLC
 c/o Starwood Energy Group, LLC
 5 Connecticut Office Building Floor
 Greenwich, CT 06830



Northwest Ohio Wind Project Paulding County, Ohio

Overall Electrical Site Plan


Not For Construction
 Array Date: 09/14/2017
 Date: 09/27/17
 Sheet: E.300
 000195_E.300_Overall Electrical Site Plan.dwg



Drawn by	JST
Checked by	AWB
Designed by	JST
As-built drawings	
Project No.	2007000001
Date	09/27/17
Scale	1" = 300'

WHITE
 an ARCA company
 8800 E. White Ave
 Chicago, IL 60617


Tridale Wind Ohio, LLC
 c/o Starwood Energy Group, LLC
 5 Connecticut Office Park, 4th Floor
 Greenwich, CT 06830



Northwest Ohio Wind Project Paulding County, Ohio


Electrical Site Plan

Not For Construction
 Array Date: 09/14/2017
 Date: 09/27/17
 Sheet: E-310
 0001166_001000_Site Plan.dwg



LEGEND

TURBINE LOCATION
T-XX
 TURBINE NUMBER
 PROPOSED CIRCUIT 1
 PROPOSED CIRCUIT 2
 PROPOSED CIRCUIT 3
 PROPOSED CIRCUIT 4
 DELINEATED WETLAND
 NON-PARTICIPATING PROPERTY



KEY MAP

SEE SHEET E-312

Prepared for:




Northwest Ohio Wind Project

Not For Construction
Array Date: 09/14/2017


Date: 09/27/17
Sheet: R311

0007186_Electrical Site Plans.dwg



KEY MAP

SEE SHEET E.310



LEGEND



TURBINE LOCATION

TURBINE NUMBER

PROPOSED CIRCUIT 1

PROPOSED CIRCUIT 2

PROPOSED CIRCUIT 3

DELINEATED WETLAND

NON-PARTICIPATING PROPERTY

GENERAL NOTES

1. LV POWER FOR MET-1 FED FROM WTC T-04. LV POWER CABLE INSTALLED IN COMMON MV TRENCH FROM T-04.
2. FIBER OPTIC CABLE BETWEEN T-03 AND T-04 RUNS THROUGH MET-1 PATCH PANEL (SEE E.210).

DATE	DESCRIPTION	DEBIT	CREDIT	BALANCE
01/01/17	OPENING BALANCE			100.00
01/15/17	PAYROLL	50.00		50.00
01/20/17	RECEIVED		25.00	75.00
02/01/17	CLOSING BALANCE			75.00

Prepared for:



3900 E. White Ave
Clinton, IN 47342

TriState Wind Ohio, LLC
c/o Starwood Energy Group, LLC
5 Greenwich Office Park, 2nd Floor
Greenwich, CT 06831



Northwest Ohio Wind Project

Electrical Site Plan


Not For Construction

Army Date: 09/14/2017

Date: 08/23/1977

7/6/01

KEY MAP



Client:	TRT
Check:	AKB
Drawn:	JAC
As-Built:	Drawn:
Project:	Northwest Ohio Wind Project
Drawn:	09/27/17
Scale:	1" = 300'

WHITE
 an AECOM company
 8800 E. White Ave
 Chicago, IL 60617

Tridale Wind Ohio, LLC
 c/o Starwood Energy Group, LLC
 5 Connecticut Office Park, 4th Floor
 Greenwich, CT 06830




Northwest Ohio Wind Project

Paulding County, Ohio


Electrical Site Plan

Not For Construction
 Array Date: 09/14/2017
 Date: 09/27/17
 Sheet: E-313
 0001166_Detailed Site Plan.dwg



LEGEND

TURBINE LOCATION
T-XX
 TURBINE NUMBER
 PROPOSED CIRCUIT 1
 PROPOSED CIRCUIT 2
 PROPOSED CIRCUIT 3
 PROPOSED CIRCUIT 4
 DELINEATED WETLAND
 NON-PARTICIPATING PROPERTY



KEY MAP

Drawn by	JST
Checked by	AWB
Designed by	JST
As-Built Drawings	
Project No.	16-0000000000
Revision	1. 09/27/17 - 50% Plans

WHITE
 an AECOM company
 800 E. White Ave
 Columbus, IN 47202

Tridale Wind Ohio, LLC
 c/o Starwood Energy Group, LLC
 5 Connecticut Office Park East Floor
 Greenwich, CT 06830



Northwest Ohio Wind Project Paulding County, Ohio

Electrical Site Plan


Not For Construction
 Array Date: 09/14/2017
 Date: 09/27/17
 Sheet: E-316
 0001166_Detailed Site Plan.dwg

LEGEND

- TURBINE LOCATION
- T-XX
- P-PUG-1
- P-PUG-2
- P-PUG-3
- P-PUG-4
- DELINEATED WETLAND
- NON-PARTICIPATING PROPERTY


GENERAL NOTES

1. EXACT POSITION OF JB4-1 IS TO BE DETERMINED.



SEE SHEET E-311

SEE SHEET E-324



KEY MAP

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/25/2017 3:37:16 PM

in

Case No(s). 13-0197-EL-BGN, 16-1687-EL-BGA, 17-1099-EL-BGA

Summary: Notice of Update to September 1, 2017 Filing Regarding Compliance with Condition 6 – Drawings for Final Design Plan (Part 3 of 5) electronically filed by Mr. William V Vorys on behalf of Trishe Wind Ohio, LLC

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/26/2017 8:32:06 AM

in

Case No(s). 13-0197-EL-BGN, 16-1687-EL-BGA, 17-1099-EL-BGA

Summary: Notice (Corrected rotated pages)of Update to September 1, 2017 Filing Regarding Compliance with Condition 6 – Drawings for Final Design Plan (Part 3 of 5) electronically filed by Mr. William V Vorys on behalf of Trishe Wind Ohio, LLC electronically filed by Docketing Staff on behalf of Docketing