



COLUMBUS | CLEVELAND
CINCINNATI | DAYTON
MARIETTA

BRICKER & ECKLER LLP
100 South Third Street
Columbus, OH 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

January 31, 2018

Via Electronic Filing

Ms. Barcy McNeal
Administration/Docketing
Ohio Power Siting Board
180 East Broad Street, 11th Floor
Columbus, Ohio 43215-3793

**Re: Dominion Energy Ohio,
Case No. 17-2337-GA-BNR**

Dear Ms. McNeal:

Attached is a copy of Dominion Energy Ohio's responses to the Ohio Power Siting Board Staff's data requests.

If you have any questions please call at the number listed above.

Sincerely,

Sally W. Bloomfield

Attachment

cc: Ashton Holderbaum (w/Attachment)

**Dominion Energy Ohio Construction Notice for PIR 2364 Pipeline
Replacement Project, Cuyahoga Falls, Summit County, Ohio
OPSB Case No. 17-2337-GA-BNR**

Responses to Staff Data Requests

1. What is the current MAOP of the system?

RESPONSE: *174 psi*

2. Is the current section of pipe an MAOP restriction?

RESPONSE: *No*

3. If so, will the system be uprated with the current 8" pipe replaced?

RESPONSE: *N/A*

4. Can the existing pipe not be uprated to keep pace with demand?

RESPONSE: *No, the existing pipe cannot be uprated because the pipe is old, but it will be upsized to 12-inch diameter due to the importance of the line supplying critical regulator stations and with most of the system being 12-inch it is good for consistency.*

5. Is there leakage history, or inoperable or degrading facilities on the existing section of pipe?

RESPONSE: *No.*

6. At what percent capacity is the current pipe operating on peak day?

RESPONSE: *The 8-inch pipe is about 75% capacity.*

7. At what percent capacity will the proposed pipe operate on peak day?

RESPONSE: *It is expected to be about 40% capacity.*

8. How much and what kind of growth has been added downstream?

RESPONSE: *There has not been significant growth.*

9. Is future growth expected?

RESPONSE: *No significant growth is expected in the future. The primary purpose of the replacement is to meet current demand and to permit a complete integrity evaluation along high pressure pipeline #5876 as well as to maintain pipeline safety and integrity.*

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

1/31/2018 3:23:42 PM

in

Case No(s). 17-2337-GA-BNR

Summary: Text Dominion Energy Ohio's Response to OPSB Staff Data Requests
electronically filed by Teresa Orahoud on behalf of Sally W. Bloomfield