

FILE

April 13, 2018

Ms. Barcy F. McNeal  
Docketing Division  
The Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**PRE-APPLICATION NOTIFICATION LETTER**  
**Amendment to the**  
**East Springfield-Tangy 138kV Loop to Broadview Substation Project**  
**Case No. 18-0594-EL-BTA**

Dear Ms. McNeal:

In accordance with Ohio Administrative Code ("OAC") Rule 4906-6-03(A) and OAC Chapter 4906-6 generally, this letter will serve as the pre-application notice letter of applicant American Transmission Systems, Incorporated ("ATSI"), a FirstEnergy company, for the above referenced Project. ATSI expects to file an Amendment Application with the Ohio Power Siting Board ("OPSB") for the Project shortly.

In this Project, ATSI proposes four minor route adjustments to the transmission line approved by the Ohio Power Siting Board in Case No. 16-1982-EL-BTX. These adjustments are proposed at the request of property owners and are not expected to have greater than the approved route. In addition, ATSI is proposing an engineering clarification proposed in this Application to change the conductor size from 336 ACSR to 795 ACSR. This change is also not expected to have any additional impact. The Project will be located in Moorefield Township, Clark County, Ohio.

The construction for this Project is expected to begin as early as October 1, 2018 and be completed by April 30, 2019.

Sincerely,



Nataliya Bryksenkova  
Engineer  
Energy Delivery  
Transmission and Substation Design  
FirstEnergy Service Company

RECEIVED - DOCKETING DIV  
2018 APR 16 PM 1:38  
PUCO

This is to certify that the enclosed copy is an accurate and complete representation of the original document delivered in the regular course of business.  
Technician Am Date Processed 4/16/18