
From: noreply@salesforce.com [mailto:noreply@salesforce.com] **On Behalf Of** Applications Team
Sent: Wednesday, June 27, 2018 1:41 PM
To: mary.mackenty@srectrade.com; Bellamy, Mark <mark.bellamy@puco.ohio.gov>
Subject: RE: PUCO 18-0929-EL-REN Kuehn, Jeff Residence – J Kuehn [ref: _00D80MOIZ_500801CcFji:ref]

Hi Mark,

I apologize for the delay in our response. The nameplate capacity is 28.32kW.
I have been trying to upload the amendment but the website seems not to be loading. I will keep trying but in the meantime, I have attached the amendment.

Sorry again for the delay and thanks for the reminder.
Best,
Mary

Case No. 18-0929-EL-REN

Kuehn, Jeff Residence - J Kuehn Staff Interrogatories - Initial Set

Section I.a : Nameplate capacity

In Section I.a of the application, the nameplate capacity is listed as 21.17 kW. However, in section G.1 you state that the system has 96 295 watt panels which would give you a nameplate capacity of 28.32 kW. Is the nameplate capacity 28.32 kW? If not, please explain how the nameplate capacity was determined.

Answer 1: The nameplate capacity is 28.32kW.

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/27/2018 1:49:15 PM

in

Case No(s). 18-0929-EL-REN

Summary: Reply electronically filed by Mark C Bellamy on behalf of SRECTrade