



**Case No. 18-1503-EL-REN  
Beachwood System 1  
Staff Interrogatories – Initial Set**

Question 1: In Section G.1, the nameplate capacity is 269.8 kW and the number of modules is 792 340W which would give you a nameplate capacity of 269.28 kW. However, in section G.4 you state that the system has 1,584 340W panels which would give you a nameplate capacity of 538.56 kW and in section I.a the nameplate capacity is 269.00 kW. What is the correct nameplate capacity, number of modules and module wattage?

Answer 1: The System is 269.28 kW-DC (199.80 kW-AC), comprised of 792 modules that are 340W.

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**10/19/2018 4:45:35 PM**

**in**

**Case No(s). 18-1503-EL-REN**

Summary: Reply electronically filed by Mr. Tom Rollason on behalf of Rollason, Tom Mr.