

Case No. 18-1674-EL-REN
North Vernon - North Vernon Pumping Station
Staff Interrogatories – Initial Set

Question 1: In section I.1 the nameplate capacity is listed as 316.23 kW. But in section G.1 you state the facility has 1002 315W panels. Since $1002 \times 315\text{W} = 315,630\text{W}$ or 315.63 kW, is the nameplate capacity 315.63 kW?

Answer 1:

There are 1002 x Neo Solar Power - D6P315E4A panels at 315W each, for a total facility size of 315.63 kW

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

12/11/2018 1:28:36 PM

in

Case No(s). 18-1674-EL-REN

Summary: Response Response to Staff Interrogatories – Initial Set
North Vernon - North Vernon Pumping Station

electronically filed by Mr. Steven Eisenberg on behalf of Mike Ochs